NRC FORM 591M PAR (06-2010)	Г1			U.S NUCLEAR RI	EGULATORY COMMISSION	
10 CFR 2.201						
SAFETY INSPECTION REPORT AND COMPLIANCE INSPECTION						
1. LICENSEE/LOCATIO	N INSPECTED:		2. NRC/REGIONAL OFFIC	F .		
Ashland, INC.			NRC REGION III. 2443 WARRENUTTIE Rol			
11083 Highwas D 63353			Lisle, IL 60532			
REPORT NUMBERIES 2010-00/						
3. DOCKET NUMBER(S	Parties of the Partie of the Partie of the Parties of the Partie of the Parties o	4. LICENSEE NUMBER(S)	5. DATE(S) OF INS		
030-0	5086	24-0306	0-01	10/18/	10	
LICENSEE:						
The inspection was an examination of the activities conducted under your license as they relate to radiation safety and to compliance with the Nuclear Regulatory Commission (NRC) rules and regulations and the conditions of your license. The inspection consisted of selective examinations of procedures and						
representative records, interviews with personnel, and observations by the inspector. The inspection findings are as follows:						
1. Based on the inspection findings, no violations were identified.						
2. Previous vi	2. Previous violation(s) closed.					
3. The violation(s), specifically described to you by the inspector as non-cited violations, are not being cited because they were						
self-identified, non-repetitive, and corrective action was or is being taken, and the remaining criteria in the NRC Enforcement Policy, NUREG-1600, to exercise discretion, were satisfied						
Non-cited violation(s) were discussed involving the following requirement(s):						
4. During this inspection certain of your activities, as described below and/or attached, were in violation of NRC						
requirements and are being cited. This form is a NOTICE OF VIOLATION, which may be subject to posting in accordance with 10 CFR 19.11						
Statement of Corrective Actions						
I hereby state that, within 30 days, the actions described by me to the inspector will be taken to correct the violations identified. This statement of						
corrective actions is made in accordance with the requirements of 10 CFR 2.201 (corrective steps already taken, corrective steps which will be taken, date when full compliance will be achieved). I understand that no further written response to NRC will be required, unless specifically requested.						
Title		Printed Name		Signature	Date	
LICENSEE'S						
REPRESENTATIVE						
NRC INSPECTOR	N II		0 (1 0	1	
	E.L. KUL	-2PR	CLK	ulzu	10/18/10	
Branch Chief	E.L. KUL		4 - 10	0	j j	
	I, E. DI	TOHER	22/5	Dow	10/27/10	

NRC FORM 591 M PART 3 U.S. NUCLEAR REGULATORY COMMISSION (06-2010)10 CFR 2.201 Docket File Information SAFETY INSPECTION REPORT AND COMPLIANCE INSPECTION 1. LICENSEE 2. NRC/REGIONAL OFFICE Ashland Inc **US Nuclear Regulatory Commission** 11083 Highway D Region III 2443 Warrenville Rd Lousiana, MO 63353 Lisle, I. 160532 REPORT NUMBER(S) 2010/001 5. LICENSE NUMBER(S) 3. DOCKET NUMBER(S) 5. DATE(S) OF INSPECTION 24-03060-01 030-05086 10/18/2010 6. INSPECTION PROCEDURES 7. INSPECTION FOCUS AREAS 87124 03.01-03.07 SUPPLEMENTAL INSPECTION INFORMATION 1.PROGRAM 2. PRIORITY 4. TELEPHONE NUMBER 3. LICENSEE CONTACT 03120 573-754-6211 Minh Hoac, RSO Main Office Inspection Next Inspection Date: 10/2015 ☐ Field Office Inspection

PROGRAM SCOPE

The licensee is an organic chemical manufacturer authorized to use cesium-137 as sealed sources with no single source to exceed the maximum activity specified in the certificate of registration issued by NRC or an Agreement State for use in devices manufactured by Ohmart. And Amersham (Kay Ray) which have been evaluated and approved for licensing purposes and authorized for distribution under a license issued by the US Nuclear Regulatory Commission or an Agreement State. The gauges are located at the one authorized location of use as specified on the license. The licensee possess a total of thirteen gauges, 12 Ohmart with activities ranging from 10 mCl to 300 mCl and one 100 mCl Kay-Ray gauges in storage. The RSO performs shutter checks, surveys, cleaning, and inventory of the gauges as required. Survey meters are available and are calibrated annually. Any other maintenance or service is conducted by the manufacturer. The devices have a three year leak test requirement according to the SSDR.

Performance Observations

During the inspection, the licensee's RSO demonstrated: (1) survey meter use and calibration; (2) tagout procedures; (3) signage; (4) security of licensed material; (5) gauge maintenance; (6) staff training; (7) leak test procedures. This was a fixed gauge licensee and required no dosimetry.