



**Pacific Gas and  
Electric Company®**

**James R. Becker**  
Site Vice President

Diablo Canyon Power Plant  
Mail Code 104/5/601  
P. O. Box 56  
Avila Beach, CA 93424

805.545.3462  
Internal: 691.3462  
Fax: 805.545.6445

October 27, 2010

PG&E Letter DCL-10-135

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20852

Docket No. 50-275, OL-DPR-80  
Docket No. 50-323, OL-DPR-82  
Diablo Canyon Units 1 and 2  
Response to NRC Letter dated September 30, 2010, Request for Additional  
Information (Set 28) for the Diablo Canyon License Renewal Application

Dear Commissioners and Staff:

By letter dated November 23, 2009, Pacific Gas and Electric Company (PG&E) submitted an application to the U.S. Nuclear Regulatory Commission (NRC) for the renewal of Facility Operating Licenses DPR-80 and DPR-82, for Diablo Canyon Power Plant (DCPP) Units 1 and 2, respectively. The application included the license renewal application (LRA), and Applicant's Environmental Report (ER) – Operating License Renewal Stage.

By letter dated September 30, 2010, the NRC staff requested additional information needed to continue their review of the DCPP LRA.

PG&E's response to the request for additional information is provided in Enclosure 1.


PG&E makes no regulatory commitments (as defined in NEI 99-04) in this letter.

If you have any questions regarding this response, please contact Mr. Terence L. Grebel, License Renewal Project Manager, at (805) 545-4160.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on October 27, 2010.

Sincerely,



James R. Becker



TLG/50346359

Enclosure

cc: Diablo Distribution

cc/enc: Elmo E. Collins, NRC Region IV Regional Administrator

Nathanial Ferrer, NRC Project Manager, License Renewal

Kimberly J. Green, NRC Project Manager, License Renewal

Fred Lyon, NRC Project Manager, Office of Nuclear Reactor Regulation

Michael S. Peck, NRC Senior Resident Inspector

Alan B. Wang, NRC Project Manager, License Renewal

**PG&E Response to NRC Letter dated September 30, 2010  
Request for Additional Information (Set 28) for the  
Diablo Canyon License Renewal Application**

RAI 2.3.3.12-4 (follow-up)

*By letter dated July 28, 2010, the applicant responded to request for additional information (RAI) 2.3.3.12-4 and clarified a discrepancy between license renewal boundary drawing LRDCPP-18-1 06718-12 and Final Safety Analysis Report Section 9.5.1.2.6.1, regarding areas and locations of low pressure CO<sub>2</sub> fire hose reel coverage. However, the RAI response did not provide the CO<sub>2</sub> fire hose reel location for "25kV Potential Transformer Area," listed in RAI 2.3.3.12-4. The staff requests that the applicant identify the location of the CO<sub>2</sub> fire hose reel for the "25kV Potential Transformer Area."*

PG&E Response to RAI 2.3.3.12-4 (follow-up)

The 25 kV Potential Transformers (PT) and the Isophase Bus Motor Operated Disconnect are located in the same room. There are two Isophase Bus rooms (one for each unit). Manually initiated low-pressure CO<sub>2</sub> hose reels are provided for the 25 kV potential transformers at the location noted below.

<b>CO<sub>2</sub> Hose Reel Location</b>	<b>FSAR Referenced Area Covered by a CO<sub>2</sub> Hose Reel</b>
Isophase Bus Room / PT Area Elevation 107'	25 kV potential transformer area