

From: Bamford, Peter
Sent: Monday, November 01, 2010 8:44 AM
To: 'Wendi.Croft@exeloncorp.com'; 'david.distel@exeloncorp.com'
Cc: 'david.helker@exeloncorp.com'
Subject: Acceptance Review of TMI-1 LAR Regarding Maximum Allowable Power Level with Inoperable MSSVs, TAC No ME4808

By letter dated September 24, 2010 (ADAMS Accession No. ML102780570), Exelon Generation Company, LLC submitted a license amendment request (LAR) for Three Mile Island Nuclear Station, Unit 1 (TMI-1), proposing changes to the Technical Specifications relating to the Main Steam Safety Valves (MSSVs). The proposed changes would allow up to two MSSVs per steam generator to be inoperable with no required reduction in power level, and revise the required maximum overpower trip setpoints for any additional inoperable MSSVs.

The purpose of this email is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed license amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.



Peter Bamford
NRR/DORL/LPL 1-2
Limerick & TMI-1 Project Manager
301-415-2833

E-mail Properties

Mail Envelope Properties ()

Subject: Acceptance Review of TMI-1 LAR Regarding Maximum Allowable Power Level with Inoperable MSSVs, TAC No ME4808
Sent Date: 11/1/2010 8:31:54 AM
Received Date: 11/1/2010 8:44:00 AM
From: Bamford, Peter

Created By: Peter.Bamford@nrc.gov

Recipients:

Wendi.Croft@exeloncorp.com ('Wendi.Croft@exeloncorp.com')

Tracking Status: None

david.distel@exeloncorp.com ('david.distel@exeloncorp.com')

Tracking Status: None

david.helker@exeloncorp.com ('david.helker@exeloncorp.com')

Tracking Status: None

Siva.Lingam@nrc.gov (Lingam, Siva)

Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	20684	11/1/2010
image001.gif	4069	

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: