ES-301

Facility: North Anna Power Station

Date of Examination: 6/21/2010

Examination Level: Combined (See Below)

Operating Test Number: 1 (FINAL)

Administrative Topic (see Note)	Type Code*	Describe activity to be performed (KA)			
1a) Conduct of Operations	Determine the Quadrant Power Tilt Ratio by hand calculation (1-PT-23) and determine maximum allowable power level b on the calculation. (ALL) (G2.1.7, RO 4.4 / SRO 4.7)				
1b) Conduct of Operations	D, R G2.1.25	Determine time to boil (1-GOP-13.1, Att. 1). (ALL) (2.1.25, RO 3.9 / SRO 4.2)			
2) Equipment Control M, R G2.2.37 Evaluate and apply Tech Specs and procedure requirement based on UNSAT condition of a plant component. (SRO) (2.2.37, RO 3.6 / SRO 4.6)		Evaluate and apply Tech Specs and procedure requirements based on UNSAT condition of a plant component. (SRO) (2.2.37, RO 3.6 / SRO 4.6)			
3) Radiation Control M, R G2.3.7		Given an attached survey, determine entry requirements and stay times associated with a given work activity. (AII) (2.3.7, RO 3.5 / SRO 3.6)			
4) (SRO) Emergency Plan G2.4.41 M, R G2.4.41 Classify an emergency event (EPIP-1.0 (SRO ONLY) (2.4.41, RO 2.9 / SRO 4.6		Classify an emergency event (EPIP-1.01) (SRO ONLY) (2.4.41, RO 2.9 / SRO 4.6)			
4) (RO) Emergency Plan M, S, P G2.4.43 M, S, P G2.4.43 Transmit report of emergency to State and local governments. (RO only) (2.4.43, RO 3.2 / SRO 3.8)					
NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.					
 * Type Codes & Criteria: (C)ontrol room, (S)imulator, or Class(R)oom (D)irect from bank (≤ 3 for ROs; ≤ 4 for SROs & RO retakes) (N)ew or (M)odified from bank (≥ 1) (P)revious 2 exams (≤ 1; randomly selected) 					

Dominion North Anna Power Station ADMINISTRATIVE JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

INITIAL CONDITIONS

Unit was at 100% power when a control rod dropped into the core

The Unit has been stabilized at 99% power with Tavg and Tref matched.

Unit 1 PCS is unavailable.

All ex-core power-range channels are operable.

The Instrument Shop has obtained power range detector current readings.

A copy of 1-PT-22.4, Attachment 4, Unit 1 Power Range Calibration Data is available.

INITIATING CUE

You are requested to perform a Quadrant Power Tilt Ratio determination by hand calculation in accordance with 1-PT-23, Quadrant Power Tilt Ratio Determination.

KET is in back of JPM

Dominion North Anna Power Station ADMINISTRATIVE JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

R709(M)

<u>TASK</u>

Determine the Quadrant Power Tilt Ratio by hand calculation (1-PT-23) and determine maximum allowed power level based on the calculation.

TASK STANDARDS

Maximum QPTR correctly calculated and maximum power level allowed by TS 3.2.4 correctly determined.

K/A REFERENCE:

G2.1.7 (4.4/4.7)

ALTERNATE PATH:

N/A

TASK COMPLETION TIMES

Validation Time = 24 minutes Actual Time = minutes Start Time = _____ Stop Time = _____

PERFORMANCE EVALUATION

Rating	[] SATISFACTORY	[] UNSATISFACTORY
Candidate (Print)		
Evaluator (Print)		
Evaluator's Signature / Date		
EVALUATOR'S COMMENTS		

Dominion North Anna Power Station

ADMINISTRATIVE JOB PERFORMANCE MEASURE (Evaluation)

OPERATOR PROGRAM

R709

INITIAL CONDITIONS

Unit was at 100% power when a control rod dropped into the core

The Unit has been stabilized at 99% power with Tavg and Tref matched.

Unit 1 PCS is unavailable.

All ex-core power-range channels are operable.

The Instrument Shop has obtained power range detector current readings.

A copy of 1-PT-22.4, Attachment 4, Unit 1 Power Range Calibration Data is available.

INITIATING CUE

You are requested to perform a Quadrant Power Tilt Ratio determination by hand calculation in accordance with 1-PT-23, Quadrant Power Tilt Ratio Determination.

EVALUATION METHOD

Demonstration if conducted in the simulator or in a laboratory (use DEMONSTRATION cues)

Verbal-visual if conducted in the station or on a dead simulator (use VERBAL-VISUAL cues)

TOOLS AND EQUIPMENT

Calculator

Copy of 1-PT-22.4, Attachment 4, Unit 1 Power Range Calibration Data.

Evaluator will need a copy of Technical Specifications and Bases for performance of elements 5 and 6 of this evaluation.

PERFORMANCE STEPS

1

_

Record the expected 100% power current readings in attachment 2. Procedure Step

SAT[] UNSAT[]

Standards Data correctly transcribed from the copy of 1-PT-22.4 provided.

Notes/Comments

2 Calculate the normalized detector currents and averages. Procedure Step

SAT[] UNSAT[]

Standards Normalized detector currents and averages are calculated.

Notes/Comments

3	Calculate the quadrant power tilt ratios.	•••••	Procedure Step		
	Critical Step		SAT[] UNSAT[]		

<u></u>	
Standards	Upper and lower quadrant power tilt ratios are calculated.
	\rightarrow Individual QPTRs determined per the acceptance criteria of the
	attached answer key
	AND
	→ Maximum QPTR determined to be 1.0396
	acceptance criteria: 1.0386 to 1.0406 (+/- 0.001)

Notes/Comments	 	

4	Record the value and location of the largest quadrant power tilt ratio.	Procedure Step
		SAT[] UNSAT[]

Standards	Value transcribed from previous step.
	Location recorded is N41L.

Notes/Comments	The following elements take place one-on-one with the evaluator, after the candidate has completed the QPTR calculation in the classroom.

EVALUATOR'S NOTE

<u>IF</u> QPTR calculations are correct, <u>THEN</u> continue the JPM, otherwise JPM should be terminated at this point.

	Identifies QPTR ex	Procedure Step		
			SAT[] UNSAT[]	
	Evaluator's Note	ns and Bases for use in		
	Demonstration			
	Cues	are met.		
Standards Technical Specification 3.2.4 is identified and QPTR determined exceed the LCO 3.2.4 based on given conditions (thermal power >50% RTP provided in the IC, so TS 3.2.4 Applicability is met).			QPTR determined to ons (thermal power of plicability is met).	

Notes/Comments

Critical Step		SAT[] UNSAT[]			
Evaluator's Note	$ $ <u>IF</u> the candidate calculated a QPTR of \leq 1.02 and determined that the LCO was met in element 5, <u>THEN</u> end the evaluation at this point.				
	IF the candidate calculated a QPTR of \geq 1.02 and determined that the LCO was NOT met in element 5, <u>THEN</u> provide the following cue.				
Demonstration					
<u>Cues</u>	Technical Specification 3.2.4, based on the	e QPTR.			
<u>Standards</u>	Maximum power level determined to be 88 (from TS 3.2.4 power must be reduced \geq 3 QPTR > 1.00. Therefore 3.96% X 3 = 11.8	8.12% % from RTP for each 1% o 38).			
	For conservatism power may be rounded of	down to 88% ± 1%			

>>>> END OF EVALUATION <<<<<

STOP TIME

KE

1-PT-23 **Revision 29** Page 15 of 15

(Page 3 of 3) Attachment 2 **QPTR Hand Calculation**

NOTE: Current Readings may be obtained from the face meters of the Power Range "B" Drawer OR from the test jacks OR from the Unit 1 PCS, if operable.

Description	N-41 Upper	N-42 Upper	N-43 Upper	N-44 Upper	Avg. of Upper Normalized Currents
Current Reading (record to nearest μa)	154	144	167	200	
Expected Current (record as shown in Reactor Data Book or 1-PT-22.4)	154.2	162.8	170.4	700.3	
Normalized Current (Current Reading / Expected Current) (4 decimal places)	.9987	, 8845	.9800	,9985	. 9654
QPTR (Normalized Current / Avg. of Norm. Currents) (4 decimal places)	1.0345	.9162	1.0151	1.0343	

Description	N-41 Lower	N-42 Lower	N-43 Lower	N-44 Lower	Avg. of Lower Normalized Currents
Current Reading (record to nearest µa)	183	147	204	218	
Expected Current (record as shown in Reactor Data Book or 1-PT-22.4)	איררו.	162.8	204	212.1	
Normalized Current (Current Reading / Expected Current) (4 decimal places)	1.0292	.9079	1.0000	1.0278	. 989975
QPTR (Normalized Current / Avg. of Norm. Currents) (4 decimal places)	1.0396	.9170	1.0101	1.0382	

 KEY
 Date:

Maximum QPTR: 1.0396

(Record Maximum Upper or

Quadrant of Max QPTR: N-41 LOWER

Completed by: _____

Verified by:_____

Date/Time Verification Completed:

Lower QPTR Value from above)

(N41 Upper, N41 Lower N42 Upper, N42 Lower, etc.)

(Use this Time for recording when surveillance is completed)

Dominion North Anna Power Station ADMINISTRATIVE JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

INITIAL CONDITIONS

The unit entered Mode 3 on 4/01/2010 at 0600 for a scheduled refueling outage.

The core has been reloaded and the cavity drain-down is complete.

Current conditions are as follows:

- The Date and time is 4/20/2010, 2000
- RCS level is 74 inches above Mid Loop
- RHR pump discharge temperature is 97°F
- 55 fuel assemblies were exchanged during on-load

INITIATING CUE

The Shift Manager has directed you to determine the estimated time to boil in accordance with 1-GOP-13.1, using the current conditions. (Record your results in the space provided)

Corrected Time to Boil estimate:

Dominion North Anna Power Station ADMINISTRATIVE JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

<u>TASK</u>

Determine estimated time to boil.

TASK STANDARDS

Given a copy of 1-GOP-13.1, determine the estimated time to boil

K/A REFERENCE:

G2.1.25 (3.9/4.2)

ALTERNATE PATH:

N/A

TASK COMPLETION TIMES

Validation Time = 10 minutes Actual Time = ____ minutes Start Time = _____ Stop Time = _____

PERFORMANCE EVALUATION

Rating	[] SATISFACTORY	[] UNSATISFACTORY
Candidate (Print)		
Evaluator (Print)		
Evaluator's Signature / Date		
EVALUATOR'S COMMENTS		

Dominion North Anna Power Station

ADMINISTRATIVE JOB PERFORMANCE MEASURE (Evaluation)

OPERATOR PROGRAM

READ THE APPLICABLE INSTRUCTIONS TO THE CANDIDATE

Instructions for Simulator JPMs

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

Instructions for In-Plant JPMs

I will explain the initial conditions, and state the task to be performed. All steps, including any required communications, shall be simulated for this JPM. Under no circumstances are you to operate any plant equipment. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS

The unit entered Mode 3 on 4/01/2010 at 0600 for a scheduled refueling outage.

The core has been reloaded and the cavity drain-down is complete.

Current conditions are as follows:

- The Date and time is 4/20/2010, 2000
- RCS level is 74 inches above Mid Loop
- RHR pump discharge temperature is 97°F
- 55 fuel assemblies were exchanged during on-load

INITIATING CUE

The Shift Manager has directed you to determine the estimated time to boil in accordance with 1-GOP-13.1, using the current conditions.

EVALUATION METHOD

<u>Demonstration</u> if conducted in the simulator or in a laboratory (use DEMONSTRATION cues)

Verbal-visual if conducted in the station or on a dead simulator (use VERBAL-VISUAL cues)

TOOLS AND EQUIPMENT

Calculator

Copy of 1-GOP-13.1.

PERFORMANCE STEPS

START TIME

1	Determine time after shutdown for use on attachment 1 or 2.	Procedure Step N/A

SAT[] UNSAT[]

Standards	Operator determines time after shutdown for use on attachment 1
	or 2 is 19 days and 14 hours (470 hours).

Notes/Comments:	

2	Enter Time to Boil from midloop and 100°F from attachment 1 or 2.	Procedure Step: 5.6.1
	Critical Step	SAT[] UNSAT[]

Standards	Operator determines 19.25 minutes (based on time of 470 hours from entry into Mode 3).
	Acceptance criteria of 19.0 – 19.5 (based on half-increment readability).

Notes/Comments:		

3	Enter correction factor for RCS water level from attachment 3.	Procedure Step: 5.6.2	
	Critical Step	SAT[] UNSAT[]	

<u>Standards</u>	Operator determines 1.61 (based on initial condition of 74 inches above midloop).
	Acceptance criteria of 1.60 – 1.62 (based on half-increment readability).

Notes/Comments:	
	,

4	Enter correction factor for initial RCS temperature from attachment 4.	Procedure Step: 5.6.3
	Critical Step	SAT[] UNSAT[]

<u>Standards</u>	Operator determines 1.025 (based on initial condition of 97°F RHR pump discharge temperature).
	Acceptance criteria of 1.00 – 1.05 (based on half-increment readability).

Notes/Comments:		***	

5 Enter correction factor for number of fuel assemblies exchanged Procedure Step: this fuel cycle on-load attachment 5. 5.6.4	
--	--

Critical Step	SAT[]	UNSAT []

<u>Standards</u>	Operator determines 1.1175 (based on initial condition of 55 fuel assemblies were exchanged during on-load).	
	Acceptance criteria of 1.1150 – 1.1200 (based on half-increment readability).	

Notes/Comments:	 	

6 Determine corrected time to boil estimate.		Procedure Step: 5.6.5	
	Critical Step	SAT[] UNSAT[]	

<u>Standards</u>	Operator determines corrected Time to Boil 35.5 minutes based on above elements. (19.25 x 1.61 x 1.025 x 1.1175)
	Acceptance criteria:
	Low calc - 33.9 minutes** (19.0 x 1.60 x 1.00 x 1.1150) High calc - 37.1 minutes (19.5 x 1.62 x 1.05 x 1.1200)
	** for conservatism a lower limit of acceptance criteria of 33 minutes is acceptable based on rounding down times.

Notes/Comments:	

>>>> END OF EVALUATION <<<<<

STOP TIME

KEY

NOTE: An individual correction factor that does not apply should be entered as 1.0.

- 5.6 <u>IF</u> in Mode 5 (with RCS vented or soon to be vented) <u>OR</u> in Mode 6 (with Cavity level less than 23 ft above the Reactor pressure vessel flange), <u>THEN</u> calculate estimated time to boiling in the RCS for loss of cooling by doing the following: (**Reference 2.4.1**)
 - 5.6.1 Enter Time to Boil from midloop and 100°F, for desired time after Shutdown, Attachment 1 or Attachment 2: 19.25 (470 hours) (19.0-19.5)

NOTE: For water levels above 78", a factor of 1.64 should be used.

- 5.6.2 Enter desired correction factor for RCS water level, K_w , from Attachment 3: $\frac{1.61}{(1.60-1.67)}$
- NOTE: RHR pump discharge is the preferred location to obtain RCS temperature when RHR is in service.
 - 5.6.3 Enter desired correction factor for initial RCS temperature, K_t , from Attachment 4: 1.025(97°F) (1.00-1.05)
 - 5.6.4 Enter desired correction factor for number of fuel assemblies exchanged this fuel cycle on-load (assemblies <u>NOT</u> used in the just-completed cycle), K_f, from Attachment 5: $\frac{1.1175}{(1.1150 1.1200)}$

NOTE: Times should be rounded down for conservatism.

- 5.6.5 Multiply values of Steps 5.6.1 * 5.6.2 * 5.6.3 * 5.6.4 to obtain corrected Time to Boil estimation:
- 5.6.6 Enter the corrected Time to Boil estimate on 1-GOP-13.0.

Ideal 19.25 × 1.61 × 1.025 × 1.1175 = 35.5 10 w 19.00 × 1.60 × 1.00 × 1.1150 = 33.9 high 19.50 × 1.62 × 1.05 × 1.1200 = 37.15

KEY_

1-GOP-13.1 **Revision 18** Page 14 of 18

(Page 1 of 1) Attachment 1



KEY_

1-GOP-13.1 Revision 18 Page 15 of 18

(Page 1 of 1) Attachment 2 Time to Boil Based on Days After Shutdown

Time to Boil, Midloop and 100°F





1-GOP-13.1 Revision 18 Page 16 of 18



.



1-GOP-13.1 Revision 18 Page 17 of 18

(Page 1 of 1) Attachment 4 Correction Factor For Initial RCS Temperature





1-GOP-13.1 Revision 18 Page 18 of 18

Attachment 5





Dominion North Anna Power Station JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

INITIAL CONDITIONS

Unit 1 is operating at 100% when Nuclear Oversight reports that an inspection has identified calculation errors during the previous main steam safety valve (MSSV) testing.

The data was recalculated, and the following lists for the actual setpoints for the affected SG MSSVs:

1-MS-SV-101A – 1125 psig	1-MS-SV-103B – 1070 psig	1-MS-SV-103C – 1150 psig
1-MS-SV-102A – 1090 psig	1-MS-SV-104B – 1103 psig	
1-MS-SV-104A - 1158 psig		

INITIATING CUE

Based on the revised setpoint data provided, you are requested to perform the following:

- 1. Identify inoperable MSSVs, if any.
- 2. Evaluate compliance with Technical Specification requirements and determine actions required, if any.

Dominion North Anna Power Station JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

S35

<u>TASK</u>

Evaluate compliance with technical requirements (Technical Requirements) for Main Steam Safety Valves.

TASK STANDARDS

LCO 3.7.1 was entered

K/A REFERENCE:

GEN-2.2.37 (3.6/4.6)

ALTERNATE PATH:

N/A

TASK COMPLETION TIMES

Validation Time = 20 minutes Actual Time = _____ minutes Start Time = _____ Stop Time = _____

PERFORMANCE EVALUATION

Rating	[] SATISFACTORY	[] UNSATISFACTORY
Candidate (Print)		
Evaluator (Print)		
Evaluator's Signature / Date		
EVALUATOR'S COMMENTS		

Dominion North Anna Power Station

JOB PERFORMANCE MEASURE (Evaluation)

OPERATOR PROGRAM

S35

READ THE APPLICABLE INSTRUCTIONS TO THE CANDIDATE

Instructions for Simulator JPMs

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

Instructions for In-Plant JPMs

I will explain the initial conditions, and state the task to be performed. All steps, including any required communications, shall be simulated for this JPM. Under no circumstances are you to operate any plant equipment. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

PREREQUISITES

The trainee has completed the applicable course knowledge training at the senior reactor operator level.

INITIAL CONDITIONS

Unit 1 is operating at 100% when Nuclear Oversight reports that an inspection has identified calculation errors during the previous main steam safety valve setpoint.

The data was recalculated, and the following lists for the actual setpoints for the affected SG MSSVs:

 1-MS-SV-101A – 1125 psig
 1-MS-SV-103B – 1070 psig
 1-MS-SV-103C – 1150 psig

 1-MS-SV-102A – 1090 psig
 1-MS-SV-104B – 1103 psig

1-MS-SV-104A - 1158 psig

INITIATING CUE

Based on the revised setpoint data provided, you are requested to perform the following:

- 1. Identify inoperable MSSVs, if any.
- 2. Evaluate compliance with Technical Specification requirements and determine actions required, if any.

EVALUATION METHOD

<u>Perform</u> if conducted in the simulator or in a laboratory (use Performance Cue(s))

<u>Simulate</u> if conducted in the station or on a dead simulator (use Simulation Cue(s))

TOOLS AND EQUIPMENT

Technical Specifications, Technical Requirements Manual, and Bases Documents.

Calculator

PERFORMANCE STEPS

START TIME

1 Identify the applicable technical specification LCO requirement. Procedure Step

Critical Step	SAT[] UNSAT[]

Standards Tech Spec 3.7.1 is identified as the applicable LCO

Notes/Comments

2 Determine operability of affected components using Table 3.7.1-2. Procedure Step

Critical Step

SAT[] UNSAT[]

Standards Candidate identifies only 101A, 104A, 103B, and 103C, are inoperable (see table below, valves outside acceptance criteria shown in **bold** type).

Valve Number	Lift setpoint provided by JPM	Tech Spec lift setting (Table 3.7.1-2)	Tech Spec acceptable range (+/- 3%)
1-MS-SV-101A	1125 psig	1085 psig	1053 - 1117 psig
1-MS-SV-102A	1090 psig	1095 psig	1063 - 1127 psig
1-MS-SV-104A	1158 psig	1120 psig	1087 – 1153 psig
1-MS-SV-103B	1070 psig	1110 psig	1077 – 1143 psig
1-MS-SV-104B	1103 psig	1120 psig	1087 – 1153 psig
1-MS-SV-103C	1150 psig	1110 psig	1077 – 1143 psig

Notes/Comments

This results in two (2) MSSVs on "A" SG inoperable, one (1) MSSV on "B" SG inoperable, and one (1) MSSV on "C" SG inoperable.

3	Determine the REQUIRED ACTION and COMPLETION TIME for	Procedure Step
	the applicable limiting condition for operation (LCO).	

Critical Step

SAT[] UNSAT[]

<u>Standards</u> Using Table 3.7.1-1 and the data from element 2 candidate the following actions and completion times apply (required shown in bold type):		2 candidate determines y (required power level
	Action	Completion time
	B.1, Reduce THERMAL POWER to less than or equal to the Maximum Allowable % RTP (37%) specified in Table 3.7.1-1 for the number of OPERABLE MSSVs.	4 hours
	 B.2, Reduce the Power Range Neutron Flux- High reactor trip setpoint to less than or equal to the Maximum Allowable % RTP (37%) specified in Table 3.7.1-1 for the number of OPERABLE MSSVs. 	36 hours

Notes/Comments

Based on "A" SG having only 3 operable MSSVs. If candidate misreads table 3.7.1-1 they may erroneously select 21% power (table is based on <u>operable</u> number per SG, NOT <u>inoperable</u> number per SG.

END OF EVALUATION

STOP TIME

Dominion North Anna Power Station ADMINISTRATIVE JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

INITIAL CONDITIONS

Both Units are operating at 100% power with no abnormal conditions. A drain valve on the west side at the bottom of the fluid waste treating tank (1-DC-TK-2) needs to be cycled several times.

All radiation workers involved in the task have worked at the North Anna site and no other locations.

INITIATING CUE

.

You are directed to perform the following:

- Select the appropriate RWP for operations personnel
- Determine the required protective clothing for the job.
- Determine the required dosimetry for the job.
- Determine the dose alarm setpoint <u>AND</u> the dose rate alarm setpoint in effect under the RWP.
- Determine the maximum stay time based on reaching the dosimeter alarm setpoint (assume that NO dose is accumulated in transit to or from the work location).
- State the action(s) required if a dosimeter alarm setpoint is reached.

Dominion North Anna Power Station ADMINISTRATIVE JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

<u>TASK</u>

Determine Correct RWP, Stay Time, Dosimetry, and Dressout Requirements For A Given Task.

TASK STANDARDS

Correct RWP is selected, protective clothing and dosimetry are selected for the given RWP, dose alarm and dose rate setpoints identified from the RWP, and the maximum stay time calculated based on the alarm setpoints.

K/A REFERENCE:

ALTERNATE PATH:

N/A

TASK COMPLETION TIMES			
Validation Time = 20 n Actual Time = r	ninutes minutes	Start Time = _ Stop Time = _	
PERFORMANCE EVALUATIO	N		
Rating	[] SATISFACT	ORY	[] UNSATISFACTORY
Candidate (Print)	· · · · · · · · · · · · · · · · · · ·		
Evaluator (Print)			
Evaluator's Signature / Date			
EVALUATOR'S COMMENTS			

Dominion North Anna Power Station

ADMINISTRATIVE JOB PERFORMANCE MEASURE (Evaluation)

OPERATOR PROGRAM

READ THE APPLICABLE INSTRUCTIONS TO THE CANDIDATE

Instructions for Simulator JPMs

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

Instructions for In-Plant JPMs

I will explain the initial conditions, and state the task to be performed. All steps, including any required communications, shall be simulated for this JPM. Under no circumstances are you to operate any plant equipment. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

INITIAL CONDITIONS

Both Units are operating at 100% power with no abnormal conditions. A drain valve on the west side at the bottom of the fluid waste treating tank (1-DC-TK-2) needs to be cycled several times.

All radiation workers involved in the task have worked at the North Anna site and no other locations.

INITIATING CUE

You are directed to perform the following:

- Select the appropriate RWP for operations personnel
- Determine the required protective clothing for the job.
- Determine the required dosimetry for the job.
- Determine the dose alarm setpoint AND the dose rate alarm setpoint in effect under the RWP.
- Determine the maximum stay time based on reaching the dosimeter alarm setpoint (assume that NO dose is accumulated in transit to or from the work location).
- State the action(s) required if a dosimeter alarm setpoint is reached.

EVALUATION METHOD

<u>Demonstration</u> if conducted in the simulator or in a laboratory (use DEMONSTRATION cues) <u>Verbal-visual</u> if conducted in the station or on a dead simulator (use VERBAL-VISUAL cues)

TOOLS AND EQUIPMENT

RWPs, Survey Map, Calculator

**** Ensure survey map is color copy ****

PERFORMANCE STEPS

START TIME

1	From the RWPs provided determine which RWP is applicable for	Procedure Step
	the job.	RWP 10-2229

Critical Step SA	. Τ[]	UNSAT []

Standards RWP 10-2229 is selected from the four RWPs provided.

Notes/Comments:

RWP 10-0001 is not correct since no HRA entries are allowed under this RWP. RWP 10-1007 is not correct since it is for maintenance activities. RWP 10-1203 is not correct since it is for emergency situations **RWP 10-2229 is the correct RWP.**

2	From the RWPs provided, determine the protective clothing requirements.	Procedure Step: RWP 10-2229
		· · · · · · · · · · · · · · · · · · ·

Critical Step	SAT[] UNSAT[]

<u>Standards</u>	Operator determines that the area is in a contaminated area (CA) and the protective clothing requirements are those listed on the
	RWP (page 4) for contaminated areas.
	Protective Clothing Requirements:
	1.0) Required Protective Clothing
	One Hood
	One Pair Coveralls
	Rubber Boots
	High Top Shoe Covers
	Cotton Inserts
	One Pair Rubber Gloves

Notes/Comments:	Operator is required to identify from the survey map that the area is a contaminated area (CA).

3	From the RWPs provided, determine the dosimetry required.	Procedure Step: RWP 10-2229
	Critical Step	SAT[] UNSAT[]

Standards	Operator identifies that DAD/SRD & TLD are required (page 4 of
	RWP).

Notes/Comments: Operator is required to identify from the survey map that the area is a high rad area.

Critical Step		SAT[] UNSAT[]
Standards	Operator correctly identifies that the dose a the dose rate alarm is 500 mRem/hr (RWF	alarm is 50 mRem and 9 page 1 or page 4).
Notes/Comments:	Operator is required to identify from the survey must be used based on work location.	map that task 2 setpoint
	<u>Standards</u> Notes/Comments:	Standards Operator correctly identifies that the dose a the dose rate alarm is 500 mRem/hr (RWP Notes/Comments: Operator is required to identify from the survey must be used based on work location.

5	Determine the maximum stay time in minutes based on reaching the RWP dose alarm setpoint.		Procedure Step: RWP 10-2229	
	Critical Step		SAT[] UNSAT[]	
	Standards	Operator uses RWP to determine dose ala	arm is set at 50 mRem.	
		Operator uses survey map to determine g 125 mr/hr.	eneral area dose rate is	
		Operator then divides 50 by 125 to obtain after converting to minutes (.4 hrs x 60 minutes)	a stay time of 24 minutes nutes).	

Notes/Comments:

;	State the action(s) required if a dosimeter alarm setpoint is reached.	Procedure Step: RWP 10-2229
	Critical Step	SAT[] UNSAT[]

<u>Standards</u>	Operator correctly identifies leave area immediately and report to (notify) the health physics office (RWP page 5, worker instructions 1.1 and 1.2.

Notes/Comments:

END OF EVALUATION

STOP TIME

Dominion North Anna Power Station JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

INITIAL CONDITIONS

Unit 1 is shutdown with RCS temperature at 420°F.

Unit 2 is at 100% power.

1-VG-RM-179 has had a valid reading of 4.22 E + 7 $^{\mu}$ Ci/sec. for 18 minutes.

Dose assessment is available and indicates that doses at or beyond the site boundary are 40 mR TEDE and 120 mR CDE thyroid.

INITIATING CUE

You are requested to classify an emergency event in accordance with EPIP-1.01.

This is a time critical JPM.

Dominion North Anna Power Station JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

<u>TASK</u>

Classify an emergency event.

TASK STANDARDS

Event was identified as RA1.2 within 15 minutes.

K/A REFERENCE:

GEN-2.4.41 (2.9/4.6)

ALTERNATE PATH:

N/A

TASK COMPLETION TIMES

Validation Time =	10 minutes
Actual Time =	minutes

Start	Time =	
Stop	Time =	

PERFORMANCE EVALUATION

Rating	[] SATISFACTORY	[] UNSATISFACTORY
Candidate (Print)		
Evaluator (Print)		
Evaluator's Signature / Date		
EVALUATOR'S COMMENTS		

Dominion North Anna Power Station

JOB PERFORMANCE MEASURE (Evaluation)

OPERATOR PROGRAM

READ THE APPLICABLE INSTRUCTIONS TO THE CANDIDATE

Instructions for Simulator JPMs

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

Instructions for In-Plant JPMs

I will explain the initial conditions, and state the task to be performed. All steps, including any required communications, shall be simulated for this JPM. Under no circumstances are you to operate any plant equipment. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

PREREQUISITES

The trainee has completed the applicable course knowledge training at the Senior Reactor Operator level.

INITIAL CONDITIONS

Unit 1 is shutdown with RCS temperature at 420°F.

Unit 2 is at 100% power.

VG-RM-179 has had a valid reading of 4.22 E + 7 $^{\mu}$ Ci/sec. for 18 minutes.

Dose assessment is available and indicates that doses at or beyond the site boundary are 40 mR TEDE and 120 mR CDE thyroid.

INITIATING CUE

You are requested to classify an emergency event in accordance with EPIP-1.01. This is a time critical JPM.

EVALUATION METHOD

Perform if conducted in the simulator or in a laboratory (use Performance Cue(s))

<u>Simulate</u> if conducted in the station or on a dead simulator (use Simulation Cue(s))

TOOLS AND EQUIPMENT

Copy of EAL tables and EAL technical basis document

PERFORMANCE STEPS

1

START TIME _____ (15 minute clock begins once candidate acknowledges that they understand their task)

Note: Candidate should use HOT CONDITIONS (RCS > 200°F) based on initial conditions provided by JPM.

Determine the EAL identifier using the emergency action level matrix.	Procedure Step

Critical Step		SAT []	UNSAT []
entiour otop	 		

Standards	Event is evaluated and identified as Abnormal Rad Release / Rad
	Effluent (RA1.2).

Notes/Comments

Since dose assessment <u>IS</u> available, candidate must apply Note 1 of the EAL matrix to make the correct classification (if rad monitor reading are used it will result in an inappropriate classification level, RS1.1)

2	Event declaration	n made within 15 minutes.	Procedure Step
	Critical Step		SAT[] UNSAT[]
	Standards	Event is declared as RA1.2 within 15 minutes.	
	Notes/Comments	i	······
	start time Acceptance c	- stop time = minutes riteria: (time is less than or equal to 15 minutes)	
	L	>>>> END OF EVALUATION <<<<<	
6-		(15 minute clock and a near condidate)	makaa alaasifiastisu

 $(\)$

Dominion North Anna Power Station JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

INITIAL CONDITIONS

You are the Emergency Communicator.

Unit 2 has experienced a loss of offsite power and the Station Emergency Manager (SEM), the evaluator, has declared an NOUE, EAL identifier SU1.1.

NO release of radioactive material is presently occurring.

There are NO known impediments to site access.

INITIATING CUE

You are requested to make the initial state and local notification in accordance with EPIP 2.01, Notification of State and Local Governments.

This is the initial emergency declaration and the Station Emergency Manager has directed items 5 through 9 of the form be excluded from the message.

The time of the declaration is now.

This JPM is time critical.

Dominion North Anna Power Station JOB PERFORMANCE MEASURE EVALUATION

OPERATOR PROGRAM

<u>TASK</u>

Make state and local notifications in accordance with EPIP-2.01.

TASK STANDARDS

Make notification of event (SU1.1).

K/A REFERENCE:

GEN-2.4.43 (3.2/3.8)

ALTERNATE PATH:

N/A

TASK COMPLETION TIMES

Validation Time =	10 minutes
Actual Time =	minutes

Start Time = _____ Stop Time = _____

PERFORMANCE EVALUATION

Rating	[] SATISFACTORY	[] UNSATISFACTORY	
Candidate (Print)			
Evaluator (Print)			
Evaluator's Signature / Date			
EVALUATOR'S COMMENTS			

Dominion North Anna Power Station

JOB PERFORMANCE MEASURE (Evaluation)

OPERATOR PROGRAM

READ THE APPLICABLE INSTRUCTIONS TO THE CANDIDATE

Instructions for Simulator JPMs

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

Instructions for In-Plant JPMs

I will explain the initial conditions, and state the task to be performed. All steps, including any required communications, shall be simulated for this JPM. Under no circumstances are you to operate any plant equipment. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

PREREQUISITES

The trainee has completed the applicable course knowledge training at the senior reactor operator level.

INITIAL CONDITIONS

You are the Emergency Communicator.

Unit 2 has experienced a loss of offsite power and the Station Emergency Manager (SEM), the evaluator, has declared an NOUE, EAL identifier SU1.1.

NO release of radioactive material is presently occurring.

There are NO known impediments to site access.

INITIATING CUE

You are requested to make the initial state and local notification in accordance with EPIP 2.01, Notification of State and Local Governments.

This is the initial emergency declaration and the Station Emergency Manager has directed items 5 through 9 of the form be excluded from the message.

The time of the declaration is now.

This JPM is time critical.

EVALUATION METHOD

<u>Perform</u> if conducted in the simulator or in a laboratory (use Performance Cue(s))

Simulate if conducted in the station or on a dead simulator (use Simulation Cue(s))

TOOLS AND EQUIPMENT

Emergency Communicator Notebook (Located in Simulator).

PERFORMANCE STEPS

START TIME _____ (15 minute clock begins once candidate acknowledges that they understand their task)

 1
 Obtain Notification form
 Procedure Step

 EPIP-2.01
 SAT [] UNSAT []

Standards Operator obtains form from Emergency Communicator Notebook.

Notes/Comments

Note: Average wind speed and direction will vary slightly with simulator run time and IC, evaluator should observe that candidate uses the correct indicator (as discussed below in the Notes section) when completing the form.

2	Record information on Report of Emergency to State and Local	Procedure Step
	Governments.	EPIP-2.01

Critical Step	SAT []	UNSAT[]

Standards	Information on Report of Emergency to State and Local Governments is filled in as shown on attached key.
	 Candidate enters Emergency Classification as NOUE, SU1.1 (provided by initial conditions of JPM)
	 Candidate obtains Wind Speed from Main Tower lower Level
	 Candidate obtains Wind Direction from Main Tower lower Level
	 Candidate uses EPIP-2.01, Attachment 1, page 5 of 9, and determines the Compass Point to, wind direction to, and Compass Point from, based on "wind direction from" which they obtained from PCS or recorders.

Notes/Comments

Main Tower lower Level is required to be used for obtaining wind direction and Wind Speed as this is the FIRST priority given by EPIP-2.01 (see Attachment 1, page 4 of 9).

Have SEM/RM approve report.		Procedure Step EPIP-2.01
Critical Step		SAT[] UNSAT[]
Standards	SEM/RM approves and signs the appro	oval block.
Performance Cue(s)	Inform operator "I am the SEM and I wi approval line on top right hand corner o	II approve the report." (sign of form)
Notes/Comments	5	•••

4	Establish communications.	Procedure Step EPIP-2.01

SAT[] UNSAT[]

Standards Operator uses VEOC ARD to establish contact.

Notes/Comments

Booth operator will respond as Virginia EOC and local governments during ring down.

NOTE: Time critical portion of JPM stops when operator makes contact.

Operator make Centers (EOCs	Procedure Step EPIP-2.01		
Critical Step	SAT[] UNSAT[]		
<u>Standards</u>	Time contact made: Start Time Time contact made Acceptance Criteria: Operator establishes contact in less than or equ	= mins. al to 15 minutes.	
Notes/Comments Booth operator will respond as Virginia EOC			

6

Perform initial roll call.	Procedure Step 6.c of EPIP-2.01
Critical Step	SAT[] UNSAT[]

Standards Operator checks boxes as EOCs answer.

Notes/Comments

Booth operator will respond to roll call as follows: "Louisa County is on the line, Spotsylvania County is on the line, Hanover County is on the line, Orange County is on the line, Caroline County is on the line."

7

Record time initial notification was made on form.

Procedure Step EPIP-2.01

SAT[] UNSAT[]

Standards	Operator enters time.
Derf	
Performance	Inform operator JPM is complete.

Notes/Comments

END OF EVALUATION

STOP TIME

SIMULATOR, LABORATORY, IN--PLANT SETUP (If Required)

Reset to IC #2, 100% power.

DO simspray and check recorders.

→ Change PCS screens if required such that MET data screen is NOT displayed.

Do phone check from on simulator floor (VEOC ARD line) (only for first JPM of day)

 → Booth operator respond as Virginia EOC when rung and for roll call as follows:
 → Louisa County is on the line, Spotsylvania County is on the line, Hanover County is on

the line, Orange County is on the line, Caroline County is on the line."

KEY	See addition	mal vemarke MERGENCY TO STA	S TE AND LOCAL GOV	ERNMENTS KEY
MESS	SAGE # 1	APPROV	AL (EVALVATOR	FOR JPM DURDISES
MEO			(Station Emergency Mana	ger or Recovery Manager)
This is messa	North Anna Power Station 🗹 Gage. Use a Report of Emergency	Control Room	OF [] CEOF. Standby for roll- nduct a roll-call and check b	call and following emergency
🔲 Vir	ginia EOC 🔄 Louisa County	🗌 Spotsylvania County 🛛	Hanover County 🔲 Orang	e County 🔲 Caroline County
The tir	ne is: The em (24-hr time) K	ergency message is as follow ME CONTACT	ws: (READ SLOWLY) M LD E	
Item 1	STATUS: PActual Event		ited	
			at on(24-hr time) (d	ate)
Item 2.	EMERGENCY CLASSIFICATI		Site Area Emergency	
	Category Classification R MS U S H F A G E C	<u>1</u> . <u>1</u> Declared at <u>(</u>	(TIME AND DATE C on 24-hr time) (date) ected: □ N/A □ Fuel Clad □	Reactor Coolant Containment
Item 3.	RELEASE OF RADIOACTIVE	MATERIAL: Routine releas	es ongoing due to plant operat	ions.
	Additional radiological releases A. No radiological release B. Radiological release in C. Radiological release no D. Radiological release pr	s associated with the event: Will NOT transmit Report o progress. Will transmit Report w terminated. Will transmit I ojected to occur. Will transm	f Radiological Conditions to Vi ort of Radiological Conditions to Report of Radiological Condition it Report of Radiological Cond	rginia EOC. o Virginia EOC. ons to Virginia EOC. itions to Virginia EOC.
Item 4.	METEOROLOGICAL DATA:	Based on: I On-site Mea	surements 🔲 Off-site Meas	surements 🔲 Not Available
TIN DA O	Time: AVE V にモーブ(24-hr time) TA IBTAINED AVE W	Vind Direction from 107 to <u>28</u> /ind Speed <u>25</u> m	$\mathbf{I}_{\underline{\mathbf{I}}_{\underline{\mathbf{I}}}}$ degrees (0 [°] to 360 [°]), Com $\mathbf{I}_{\underline{\mathbf{I}}_{\underline{\mathbf{I}}}}$ degrees (0 [°] to 360 [°]), Com	pass Point <u>ESE</u> pass Point <u>WNW</u>
NOTE:	Items 5 - 9 optional for message from message" may be checked	ge reporting initial Emergenc d. "Items 5 - 9 are exclude	y Plan entry or emergency clased from message" may be rea	ssification change and "Excluded ad in lieu of reading each item.
ltem 5.	ASSISTANCE REQUESTED O	R BEING PROVIDED:		Excluded from message
	(#) Fire Units from		(#) Police Units from	l
		I	(#) Other	
ltem 6.		TIONS UNDERWAY:		Excluded from message
	None Station monitoring teams di	anatabad off site	Station emergency person	nel called in
Item 7.	No Evacuation to Primary Rem	note Assembly Area:	Planned 🗌 In progress 🗌 Co	pmpleted Released from RAA
	Evacuation to Secondary F	Remote Assembly Area: 🔲 I	Planned 🔲 In progress 🗌 Co	ompleted Released from RAA
	Company Dismissal:	E F	Planned 📋 In progress 🔲 Co	ompleted
Ham 0				Evoluded from massage
		SINGE LASI REPURI:		© ⊏xciuueu irom message
	☐ Improving ☐ Othe	r		
Item 9		(Do not use abbreviations	mark numbers or acronyms). PExcluded from message
This is	(name)			/Emergency Communicator
Please	acknowledge receipt of this me	essage. (Conduct roll-call a	and check boxes as each par	ty answers.)
└ Virg This is	jinia EOC	☐ Spotsylvania County ☐ Control Room ☐ TSC ☐ LEC]Hanover County	e County 🔲 Caroline County on
	_		(24-hr tim	ne) (date)

CONTINUED ON REVERSE FOR STATE



Admin JPM 4 (RO only), Additional remarks

Items show in GREEN highlight are completed PRIOR to obtaining approval

Items shown in ORANGE highlight are completed when Emergency Communicator has completed form and obtains approval from SEM to transmit AND

Makes contact

For item 1: typically "Drill" is checked for anything other than a bona fide ACTUAL emergency. The candidate may check Actual Event since this is an NRC evaluated JPM. Either is acceptable for the JPM, evaluator may discuss with candidate after completion of jpm if desired.

For item 4: data shown is for illustration purposes only, actual values may vary slightly with simulator IC and run time. See JPM for explanation of where data should be obtained from and how compass points are determined.