Attachment 2

"The Evaluation of Indications in Peach Bottom Unit 2 Vessel Closure Head For Continued Operation," Report Number GE-NE-0000-0007-9747, September 2002

GE Nuclear Energy



ENGINEERING & TECHNOLOGY GE Nuclear Energy 175 Curtner Avenue, San Jose, CA 95125 GE-NE-0000-0007-9747 Rev. 1 DRF #0000-0007-9747 Class II September 2002

THE EVALUATION OF INDICATIONS IN PEACH BOTTOM UNIT 2 VESSEL CLOSURE HEAD FOR CONTINUED OPERATION

September 2002

Prepared for

Exelon Corp. Peach Bottom Atomic Power Station, Unit 2

ST	ATION Peach Bottom	UNIT 2 _			
DO	CUMENT		SHT	RE	/
G-0	80-VC-301	i	C		
D A T E	DESCRIPTI	ON	I	E v I r	R v w r
1/14/ 103	Initial Issue ECR PB 22- Rev. 0	- 4 C	> <r >627</r 	He.	- sur

1

THE EVALUATION OF INDICATIONS IN PEACH BOTTOM UNIT 2 VESSEL CLOSURE HEAD FOR CONTINUED OPERATION

September 2002

ling smith Prepared by:_ S. Kleinsmith, Engineer

Structural Mechanics & Materials

Verified by:

H.S. Mehta, Engineering Fellow Structural Mechanics & Materials

(h Approved by:

R.M. Horn, Manager Structural Mechanics & Materials

Matthew O'Connor

i

DISCLAIMER OF RESPONSIBILITY Important Notice Regarding the Contents of this Report Please Read Carefully

The only undertakings of the General Electric Company (GE) respecting information in this document are contained in the contract between Exelon Corporation and GE, Purchase Order 01026357 Revision 5, effective 8/28/02, as amended to the date of transmittal of this document, and nothing contained in this document shall be construed as changing the contract. The use of this information by anyone other than Exelon Corporation, or for any purpose other than that for which it is furnished by GE, is not authorized; and with respect to any unauthorized use, GE makes no representation or warranty, express or implied, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document, or that its use may not infringe privately owned rights.

Copyright, General Electric Company, 2002.

Table of Contents

<u>Subject</u>

7

,

Page No.

1		1
1.	EXECUTIVE SUMMARY	1
1.1.	REFERENCE	1
2.	INTRODUCTION AND REPORT OUTLINE	2
2.1.	REFERENCE	2
3.	UT INSPECTION RESULTS & FLAW GEOMETRY FOR EVALUATION	4
3.1.	UT INSPECTION RESULTS	4
3.2.	FLAW GEOMETRIES CONSIDERED IN EVALUATION	4
3.3.	FABRICATION REVIEW	5
3.4.	REFERENCES	5
4.	FRACTURE MECHANICS EVALUATION	12
4.1.	ASSUMPTIONS	12
4.2.	APPLIED AND WELD RESIDUAL STRESSES	12
4.3.	K CALCULATION METHODOLOGY	13
4.4.	FATIGUE CRACK GROWTH	14
4.5.	ALLOWABLE K VALUES	14
4.6.	DISPOSITION OF INDICATIONS	15
4.7.	REFERENCES	16
5.	SUMMARY AND CONCLUSIONS	20
APPE	NDIX A	A
APPF	NDIX B	В
	۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬۰٬	

1. EXECUTIVE SUMMARY

The reactor pressure vessel closure head at Peach Bottom Atomic Power Station, Unit 2 (PBAPS-2) was ultrasonically examined during refueling outage fourteen (2R-14). Each of the six meridional welds was examined. Several indications were noted at these welds. Other than the CH-MB weld, the detected indications at the other meridional welds were acceptable as-is by the acceptance standards IWB-3510 of ASME Section XI (1989 Edition without Addenda). At the CH-MB weld numerous recordable indications were noted out of which eighteen (18) indications/flaws displayed tip signals and possessed a through-wall dimension. Sixteen (16) of these flaws did not meet the acceptance standards. The Section XI Code allows for the acceptance of such flaws for continued service if they meet the requirements of Paragraph IWB-3600, Analytical Evaluation of Flaws. The analysis involves the use of fracture mechanics procedures in accordance with Appendix A of Section XI. The objective of this report is to document the results of such evaluation.

The use of surface proximity rules of Section XI indicated that all sixteen (16) indications need to be characterized as surface flaws for the purposes of fracture mechanics evaluation. Two conditions were determined to be governing: bolt-up and system pressure test. The bounding membrane and bending stress values for the fracture mechanics evaluation for the two conditions were obtained through a review of previous stress analyses of the closure heads. The bolt-up temperature was assumed as 70°F [1-1 & 1-2] at a pressure of 0 psi and the pressure test temperature was assumed as 169°F [1-1] with a pressure of 1050 psi [1-1]. The stress intensity factors for the characterized surface flaws were calculated for various flaw depth (a) to flaw length (l) ratios (or, aspect ratios). It was determined that the pressure-test condition was governing. The limiting flaw was found to be acceptable per ASME Section XI Code even after accounting for projected crack growth for the life of the plant including license renewal (60 total years).

Based on this evaluation it is concluded that all of the indications found in PBAPS-2 vessel closure head during Refueling Outage (2R-14) are acceptable by the flaw acceptance criteria of the ASME Section XI Code.

1.1. REFERENCE

- [1-1] Exelon Nuclear, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-680-2, Rev. 6: Reactor Pressure Vessel (Class 1) Hydrostatic Pressure Test.
- [1-2] PECO Energy Company, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-500-2, Rev. 7: Recording and Monitoring Reactor Vessel Temperature and Pressure.

2. INTRODUCTION AND REPORT OUTLINE

The reactor pressure vessel closure head at Peach Bottom, Unit 2 (PBAPS-2) was ultrasonically examined during the 2R14 refueling outage. Figure 2-1 shows the geometry of the vessel head. The inside radius of the head is 125.69 inches and the minimum specified thickness is 4.00 inches [2-1]. However, the measured thickness reported during the UT examination is 4.25 inches, the value used in the evaluations conducted for this report [2-2]. The inside surface of the closure head is unclad. Meridional welds were examined. Several flaws were noted in the meridional weld CH-MB. All of the flaws are not ID connected (i.e. sub surface) as confirmed by surface examination conducted at the ID surface. However, portions of the flaws are less than 0.4d from the ID surface, thus they were classified as surface flaws for fracture mechanics analysis. The observed flaws were first characterized and compared with the acceptance standards provided in Table IWB-3500-1 of Section XI, ASME Code [2-3]. Some of the flaws did not meet the acceptance standards. Section XI, subparagraph IWB-3132.4 allows for the acceptance of such flaws for continued service if they meet the requirements of Paragraph IWB-3600, Analytical Evaluation of Flaws. The analysis involves the use of fracture mechanics procedures in accordance with Appendix A of Reference 2-3. The objective of this report is to document the results of such evaluation.

Section 3 of this report summarizes UT inspection results and describes the flaw geometries considered in the evaluation. The results of the fracture mechanics evaluation are presented in Section 4. A comparison with the allowable flaw values is presented. Finally, summary and conclusions are presented in Section 5.

2.1. REFERENCE

- [2-1] Babcock & Wilcox CO. Pressure Boundary Drawing, "Closure Head Assembly" for Peach Bottom Unit 2, Drawing # 129392 E R7, GE VPF# 1896-67-8.
- [2-2] GE Nuclear Energy, Peach Bottom Unit 2 2R14 UT Examination Report # 008900 for Weld ID – CH-MB Meridional Weld @ 60 Degrees. September 27, 2002.
- [2-3] ASME Boiler and Pressure Vessel Code, Section XI, Rules for In-Service Inspection of Nuclear Power Plant Components, ASME, 1989 Edition without Addenda.



Figure 2-1 PBAPS 2 Vessel Closure Head Geometry

3. UT INSPECTION RESULTS & FLAW GEOMETRY FOR EVALUATION

This section discusses the UT results and the flaw geometries considered in the subsequent fracture mechanics evaluation. Appendix B shows the evaluation sheets for the limiting/bounding case flaws that were found to exceed acceptance standards and required fracture mechanics evaluation. A brief discussion on the origin of the indications is also provided.

3.1. UT INSPECTION RESULTS

Automated 0°L, 2.25 MHz, 45°S, 1.0 MHz, 60°L, 2.0 MHz, 70°L, 2.0 MHz scans were performed on the closure head meridional weld CH-MB. The scans and calibrations were performed in accordance with procedure GE-UT-704 Version 4 DRR# P3-001, that is qualified to the Performance Demolition Initiative (PDI). All of the detected flaws were sub-surface but in close proximity to the surface, thus they were classified as surface flaws for the analysis [Appendix A & B].

There were sixty-five (65) recordable indications detected in the CH-MB weld. Eighteen (18) indications displayed tip signals and possessed a through wall dimension. Forty-seven (47) indications without through wall dimension have been evaluated as being acceptable to the requirements of Table IWB-3510-1 [2-3]. Of the eighteen (18) remaining separate flaws, two (2) of the recorded flaws have been evaluated as being acceptable to the requirements of Table IWB-3510-1 [2-3]. Sixteen (16) of flaws have been evaluated as being rejectable to the requirements of Table IWB-3510-1. These Sixteen (16) flaws are characterized in Table 3-2. The GERIS 2000 Indication Data Sheets for each indication can be found in the Appendix A. The GERIS 2000 Indication Evaluation Data Sheets for each flaw can be found in the Appendix B.

Figures 3-1-1 thru 3-1-3 shows the approximate locations of the indications relative to the CH-MB weld centerline.

3.2. FLAW GEOMETRIES CONSIDERED IN EVALUATION

Table 3-2 shows the criteria used to determine if the indications that are to be evaluated need to be characterized as surface or sub-surface type flaws for the purpose of fracture mechanics analysis. The guidance for this characterization is provided in Article IWA-3000 [2-3]. Figure 3-2 shows the parameters used for surface proximity evaluation. It is seen in Table 3-2 that all of the indications are to be characterized as surface. In view of the varying aspect ratio (a/l), the stress intensity factors in the next section were calculated for different a/l values: 0.0, 0.1, 0.2, 0.3, .0.4, and 0.5.

3.3, FABRICATION REVIEW

All the indications in question are sub surface, in close proximity to the surface and are not service induced, but were considered as surface flaws for the fracture mechanics evaluation. A fabrication review (Reference 3-1) concluded the following:

- The flaws detected during 2R14 have existed since the closure head was fabricated.
- These flaws do not indicate "abnormal degradation of the pressure boundary" as defined by the USNRC.
- These flaws should be considered newly discovered flaws, rather than newly developed flaws.

Indications at vessel welds of the type seen in the Peach Bottom Unit 2 top head welds are not uncommon and have been found in other reactor pressure vessel welds in other plants. In most cases, the new finding is attributed to the ability of current UT techniques to detect flaws that would have been undetectable using inspection techniques available during the time of fabrication of the Peach Bottom vessel. Thus, as long as the required fracture margins are demonstrated, the indications are judged to be benign and have no impact on structural integrity.

3.4. REFERENCES

[3-1] Miller, W.F., "Investigation into the Origin of Ultrasonic Indications in RPV Closure Head Welds for the Peach Bottom 2R14 Outage," GE Report No. GENE-955-004-0902 Rev. 1, September 2002.

Weld ID	Location	Number of Recordable Indications	Number of Indications / flaws with through wall dimension	Acceptable per Table IWB-3510-1
СН-МВ	60° Azimuth	65	18 (See description below)	2 (#10 & #39)

Table 3-1 Listing of Ultrasonic Indications in RPV Closure Head Weld CH-
MB at Peach Bottom Unit 2

CH-MB

IND # 5	Flaw length = 0.75 " Flaw depth (a) = 0.17 " S = 0"	
IND # 6	Flaw length = 1.00 " Flaw depth (a) = 0.20 " S = 0"	
IND # 10	Flaw length = 0.75 " Flaw depth (a) = 0.10 " S = 0"	
IND # 14	Flaw length = 1.75 " Flaw depth (a) = 0.16 " S = 0"	
IND # 16	Flaw length = 3.75 " Flaw depth (a) = 0.25 " S = 0"	
IND # 20	Flaw length = 1.25 " Flaw depth (a) = 0.17 " S = 0"	
IND # 24	Flaw length = 1.00 " Flaw depth (a) = 0.17 " S = 0"	
IND # 34	Flaw length = 0.75 " Flaw depth (a) = 0.16 " S = 0"	
IND # 38	Flaw length = 0.75 " Flaw depth (a) = 0.19 " S = 0"	
IND # 39	Flaw length = 0.40 " Flaw depth (a) = 0.16 " S = 0"	
IND # 42	Flaw length = 1.75 " Flaw depth (a) = 0.19 " S = 0"	
IND # 44	Flaw length = 0.75 " Flaw depth (a) = 0.17 " S = 0"	
IND # 50	Flaw length = 1.00" Flaw depth (a) = 0.12 " S = 0"	
IND # 53	Flaw length = 0.75 " Flaw depth (a) = 0.14 " S = 0"	
IND # 56	Flaw length = 1.00" Flaw depth (a) = 0.17 " S = 0"	
IND # 57	Flaw length = 1.00 " Flaw depth (a) = 0.17 " S = 0"	
IND # 61	Flaw length = 1.00 " Flaw depth (a) = 0.12 " S = 0"	
IND # 63	Flaw length = 1.50 " Flaw depth (a) = 0.17 " S = 0"	

Note: Values reported are taken directly from Appendix A & B.

Weld ID	IND #	<i>l</i> (in.)	a (in.)	S (in.)	S<0.4a*	a/l
CH-MB	5	0.75	0.17	0.0	Yes	0.2267
CH-MB	6	1.00	0.20	0.0	Yes	0.2
CH-MB	10	0.75	0.10	0.0	Yes	0.1334
CH-MB	14	1.75	0.16	0.0	Yes	0.0914
CH-MB	16	3.75	0.25	0.0	Yes	0.0667
CH-MB	20	1.25	0.17	0.0	Yes	0.136
CH-MB	24	1.00	0.17	0.0	Yes	0.17
CH-MB	34	0.75	0.16	0.0	Yes	0.2133
CH-MB	38	0.75	0.19	0.0	Yes	0.2534
CH-MB	39	0.40	0.16	0.0	Yes	0.4
CH-MB	42	1.75	0.19	0.0	Yes	0.1086
CH-MB	44	0.75	0.17	0.0	Yes	0.2267
CH-MB	50	1.00	0.12	0.0	Yes	0.12
CH-MB	53	0.75	0.14	0.0	Yes	0.1867
CH-MB	56 -	1.00	0.17	0.0	Yes	0.17
CH-MB	57	1.00	0.17	0.0	Yes	0.17
CH-MB	61	1.00	0.12	0.0	Yes	0.12
CH-MB	63	1.50	0.17	0.0	Yes	0.1134

Table 3-2 Characterization of Flaws

* Flaw characterized as surface flaw if S < 0.4a.

.



Figure 3-1-1 Plot displaying Approx. Location of Indications with No Throughwall Dimension



Figure 3-1-2 Plot displaying Approx. Location of Acceptable Indications with Throughwall Dimension



Figure 3-1-3 Plot displaying Approx. Location of Unacceptable UT Indications with Throughwall Dimension



Figure 3-2 Parameters for Surface Proximity Evaluation

4. FRACTURE MECHANICS EVALUATION

The fracture mechanics evaluation was conducted for several surface flaw shape geometries using the procedures outlined in Appendix A of Section XI [4-1]. Two conditions were found to be limiting for the determination of allowable flaw sizes: (1) bolt-up, and (2) system pressure test.

4.1. ASSUMPTIONS

The following values were used for the pressure and temperature conditions during the bolt-up and system pressure test conditions. These values remain unchanged for power uprate conditions, but can change when new PT curves are licensed.

- The bolt-up temperature is 70°F [4-2 & 4-3].
- The pressure test pressure and temperature are 1050 psi and 169°F [4-4].
- The limiting RT_{NDT} value for the closure head side plate (torus) region is 10°F. [4-3]

The number of bolt-up, pressure test and start up-shut down events assumed in the fatigue crack growth calculation was based on [Reference 4-5], and is discussed in Subsection 4.4.

4.2. APPLIED AND WELD RESIDUAL STRESSES

The applied stresses in the vessel closure head to flange region are primarily from the following sources: bolt preload, internal pressure and weld residual stress. The internal pressure is zero during the bolt-up. Since all of the flaws are in the meridional direction welds, the circumferential or hoop stress is of interest for the purpose of this evaluation. Due to the complex geometry of the flange region, only a detailed finite element analysis of PBAPS Unit 2 closure head geometry can provide a complete picture of the stress distribution due to bolt-up and internal pressure. Since such an analysis was unavailable, the results from finite element analyses conducted for other BWR vessels of similar size on file with GENE were reviewed to conservatively determine a set of membrane and bending stresses. The determination took into account the differences in the R/t ratios between the available finite element model geometry and the PBAPS, Unit 2 closure head geometry.

During bolt-up large hoop bending stresses are introduced in the head near the flange junction but they attenuate rapidly as one moves away from the flange meridionally. These bending stresses are compressive at the ID surface near the flange junction. The hoop membrane stress is tensile but attenuates less rapidly. The longest flaw extends 3.75 inches in the meridional direction beginning approximately 41 inches above the top surface of the flange. Therefore, the hoop membrane and bending stress distributions corresponding to the meridional length of this indication were reviewed to determine the following conservative values for hoop membrane and bending stresses:

$$\sigma_m = 14.0 \text{ ksi}$$

 $\sigma_b = -8.0 \text{ ksi}$

During the pressure test, the internal pressure stresses are superimposed over those induced by the bolt-up condition. Since some of the discontinuity related internal pressure stresses cancel those due to bolt-up, the overall stress level is lower than the simple addition of the bolt-up and the nominal pressure stresses in the vessel head. The same approach as that used for bolt-up case was also used to determine the following set of conservative membrane and bending stress values for the pressure test case:

$$\sigma_m = 25.0 \text{ ksi}$$

 $\sigma_b = 0 \text{ ksi}$

It should be noted that the nominal value of hoop or meridional stress from an internal pressure of 1050 psi is 15.5 ksi. Thus, the difference between this value and the 25.0 ksi reported above represents the discontinuity effects from bolt-up and pressurization.

After the torus section plates are welded together, residual stresses remain due to thermal expansion and contraction. The post-weld heat treatment effectively reduces these residual stresses. A bending stress of 8.0 ksi was assumed in this analysis to model the remaining residual stresses. This bending stress closely approximates the measured cosine stress distribution for welds with PWHT reported in [Reference 4-6]. The 8 ksi magnitude was added algebraically to the calculated bending stresses due to bolt-up and pressure. Figures 4-1 and 4-2 graphically show the stress distributions used for the bolt-up and pressure test cases, respectively.

4.3. K CALCULATION METHODOLOGY

Since all of the analyzed indications have been characterized as surface flaws (Table 3-2), the stress intensity factor (K) calculation procedures specified for surface flaws in Appendix A of Section XI [4-1] were used. Table 4-1 shows the calculated values of K as a function of 'a' values for the pressure test cases for an assumed aspect ratio of 0.0. Similar calculations were also conducted for aspect ratios of 0.1, 0.2, 0.3, 0.4 and 0.5.

4.4. FATIGUE CRACK GROWTH

Since all the flaws are characterized as surface flaws, they are assumed as being exposed to the reactor water environment. Thus, the crack growth analysis was performed using the Section XI fatigue crack growth rates for water environment.

The current analyzed reactor pressure vessel cycles for the 40-year design life are listed in [Reference 4-5]. Only the bolt-up (66), hydrostatic test (130) and heatup-cooldown (161) events are significant from the perspective of fatigue crack growth in the vessel closure head. The stress range for the heatup-cooldown cycle is bounded by that for the pressure test, and therefore, the cycles for the two events were lumped together for the fatigue crack growth calculation purposes. The number of cycles for these events were increased by 50% to account for operation during the license renewal period. Thus, the number of events assumed for the bolt-up were 66x1.5 or 100. The number of events assumed for the pressure test were {(130+161)x1.5} or ~ 440. This approach is conservative since it does not take any credit for the number of cycles already used so far. The highest applied K values listed in Tables 4-2 and 4-3 were used for the fatigue crack growth calculations. The predicted crack growth was calculated as 56.2 micro inches per cycle. Which results in a crack growth of 0.025" for 440 cycles.

4.5. ALLOWABLE K VALUES

The first step in the allowable flaw calculation is to determine the K_{Ia} value at the temperature appropriate for the operating condition being analyzed. The 1989 version of Section XI [4-1] does not provide an explicit mathematical equation for the calculation of K_{Ia} at a given temperature and RT_{NDT} . However, Reference 4-7 gives the following equation that was used to calculate the K_{Ia} curve given in Figure A-4200-1[4-1]:

 $K_{Ia} = 26.78 + 1.233 * Exp(0.0145 * (T - RT_{NDT} + 160))$

where, T and RT_{NDT} are in °F and K_{Ia} is in ksi \sqrt{Ia} .

Paragraph IWB-3613 of Section XI [4-1] also indicates that for flange region a safety factor of $\sqrt{2}$ can be used for bolt-up condition. Thus, a safety factor of $\sqrt{2}$ was used for the bolt-up condition to obtain K_{Ia} allowable. For the pressure test condition, a safety factor of $\sqrt{10}$ was used as specified in IWB-3613[4-1]. The following summarizes the numerical values:

Bolt-up

Applied K =	14.3	(ksi √in) at 0 (psi) and 70 (°F)
Allowable K =	40.1	(ksi √in)

Pressure test

Applied K =	34.8	(ksi \sqrt{in}) at 1050 (psi) and 169 (°F)
Allowable K =	48.3	(ksi \sqrt{in}) at 1050 (psi) and 169 (°F)

4.6. DISPOSITION OF INDICATIONS

Tables 4-2 and 4-3 show comparisons of the K values for the limiting flaw being evaluated and the allowable values for bolt-up and pressure test conditions, respectively. It is seen that the calculated K values for all of the indications are less than the allowable values.

The calculated primary stresses after subtracting the area lost to indications, satisfied the primary stress limits specified in the original Code of construction for the reactor vessel.

Based on the preceding, it is concluded that the subject flaws are acceptable for continued operation in as-is condition.

4.7. REFERENCES

- [4-1] ASME Boiler and Pressure Vessel Code, Section XI, Rules for In-Service Inspection of Nuclear Power Plant Components, ASME, 1989 Edition without Addenda.
- [4-2] PECO Energy Company, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-500-2, Rev. 7: Recording and Monitoring Reactor Vessel Temperature and Pressure.
- [4-3] L. Tilly, "Pressure-Temperature Curves for Exelon Peach Bottom Unit 2" GE Nuclear Energy, San Jose, CA, GE-NE-B13-02118-00-01 Rev. 0, September 2002.
- [4-4] Exelon Nuclear, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-680-2, Rev. 6: Reactor Pressure Vessel (Class 1) Hydrostatic Pressure Test.
- [4-5] PECO Energy Company, Peach Bottom Unit 2, Surveillance Test Specification ST-O-080-940-2, Rev. 6: Reactor Pressure Vessel Transients Cycles Record.
- [4-6] D.A. Ferrill, et al, "Measurement of Residual Stresses in Heavy Weldment," Welding Journal Research Supplement, Vol 45, Nov. 1966.
- [4-7] EPRI Report No. NP-719-SR, "Flaw Evaluation Procedures: ASME Section XI," August 1978.

Table 4-1 Calculated K values for Pressure test Cases

Calculation of Stress Intensities (ksi-sqrt[in])

a =	0.25	(in)	t =	4.25	(in)
<i>l</i> =	3.75	(in)	$\sigma_{YS} =$	45.0	(ksi)
σ _m =	25.0	(ksi)	σ _b =	8.0	(ksi)

Ap	a/l	Q	M _m	M _b	Km	Kb	K _{TOTAL}	ΔK
(psi)					(ksi)	(ksi)	(ksi)	(ksi)
1050	0.0	0.879	1.147	1.057	27.100	7.991	35.091	27.100
1050	0.1	0.989	1.117	1.016	24.889	7.242	32.131	24.889
1050	0.2	1.212	1.105	0.985	22.236	6.340	28.577	22.236
1050	0.3	1.521	1.10	0.963	19.740	5.538	25.277	19.740
1050	0.4	1.904	1.10	0.953	17.660	4.896	22.556	17.660
1050	0.5	2.356	1.10	0.937	15.880	4.329	20.209	15.880

Weld IND #	ID: CH-M : 16	B						
	a (initial) =		0.25	(in)	t =		4.25	(in)
	<i>l</i> =	3.75	(in)		$\sigma_{YS} =$	45.0	(ksi)	
	$\sigma_{m} =$	14.0	(ksi)		$\sigma_{b} =$	0.0	(ksi)	
	TEMP = a / l =	70 0.067	(°F)		A _P =	0	(psi)	
	Applied K =		13.6	(ksi √in)	Assumes no c	rack gr	owth	
				()		0 -		
	Applied K =		14.3	(ksi √in)	Includes an in to account for	crease of fatigue	of 5% crack g	growth
	Allowable K =	=	40.1	(ksi √in)				

Table 4-2 Comparison of Calculated and Allowable K values for bolt-up

Table 4-3 Comparison of Calculated and Allowable K values for pressure tests

Weld I IND #	D: :	CH-M 16	В						
	A (initi	al) =		0.25	(in)	t =		4.25	(in)
	<i>l</i> =		3.75	(in)		$\sigma_{YS} =$	45.0	(ksi)	
	σ_{m} =		25.0	(ksi)		$\sigma_{b} =$	8.0	(ksi)	
	TEMP	=	169	(°F)		$A_P =$	1050	(psi)	
	a / l =		0.067						
	Applied	1 K =		33.2	(ksi √in)	Assumes no ci	rack gro	owth	
	Applie	d K =		34.8	(ksi √in)	Includes an in- to account for	crease o fatigue	of 5% crack g	growth
	Allowa	ble K =	=	48 <u>.</u> 3	(ksi √in)				





Figure 4-1 Through-Wall Stress Distribution Assumed for Bolt-up Condition

PRESSURE TEST LOAD CONDITION



Figure 4-2 Through-Wall Stress Distribution Assumed for Pressure Test Condition

5. SUMMARY AND CONCLUSIONS

The reactor pressure vessel closure head at Peach Bottom Atomic Power Station, Unit 2 (PBAPS-2) was ultrasonically examined during refueling outage fourteen (2R-14). Each of the six meridional welds was examined. Several indications were noted at these welds. Other than the CH-MB weld, the detected indications at the other meridional welds were acceptable as-is by the acceptance standards IWB-3510 of ASME Section XI (1989 Edition without Addenda). At the CH-MB weld numerous recordable indications were noted out of which eighteen (18) indications/flaws displayed tip signals and possessed a through-wall dimension. Sixteen (16) of these flaws did not meet the acceptance standards. The Section XI Code allows for the acceptance of such flaws for continued service if they meet the requirements of Paragraph IWB-3600, Analytical Evaluation of Flaws. The analysis involves the use of fracture mechanics procedures in accordance with Appendix A of Section XI. The objective of this report is to document the results of such evaluation.

The use of surface proximity rules of Section XI indicated that all sixteen (16) indications need to be characterized as surface flaws for the purposes of fracture mechanics evaluation. Two conditions were determined to be governing: bolt-up and system pressure test. The bounding membrane and bending stress values for the fracture mechanics evaluation for the two conditions were obtained through a review of previous stress analyses of the closure heads. The bolt-up temperature was assumed as 70°F at a pressure of 0 psi and the pressure test temperature was assumed as 169°F with a pressure of 1050 psi. The stress intensity factors for the characterized surface flaws were calculated for various flaw depth (a) to flaw length (l) ratios (or, aspect ratios). It was determined that the pressure-test condition was governing. The limiting flaw was found to be acceptable per ASME Section XI Code even after accounting for projected crack growth for the life of the plant including license renewal (60 total years).

Based on this evaluation it is concluded that all of the indications found in PBAPS-2 vessel closure head during Refueling Outage (2R-14) are acceptable by the flaw acceptance criteria of the ASME Section XI Code.

APPENDIX A

GERIS 2000 Indication Data Sheets

Rev 1 September 2002 (Includes 2 Appended Pages September 27, 2002)

Ser

88	GE NUCLE UT EXAMI	EAR ENERGY NATION SUMMARY S	HEET Rep	ort No:008900
PROJECT	Peach Bo	ttom Unit 2 - 2R14		
WELD ID:	CH-MB M	eridional Weld @ 60 Degre	ê\$	
SYSTEM:	<u> </u>	osure Head		
INITIAL CA	LIBRATION:	VES.IN.1		
FINAL CAL	BRATION:	VES.OUT.1		L - A
GERIS DAT	A: 0.	CE Emkos Lu	mpilo, mpil4, mpr.1, m uli Shano Gauthiar Iv	IDF.2 Hit Mode Lillhom 1., it
CAMINER MANUAL D]; Λτα·		V. Onane Gauther Ly	n, wark hildom Ly II
FYAMINER	S:	C. Minor I v. I	11.	
MAGNETIC	PARTICLE:	MT-016		
EXAMINER	S:	Steve Woodw	vard Lv II	
Ultrasonic exa Addenda, Cal	amination result tegory B-A Weld	s were unacceptable to the req is.	uirements of ASME B&P	VC Section XI, 1989 Edition No
704 Version 4	L, 43 3, 60 KL, .		ons were performed in at	condance with procedure GE-U1-
Automated sc	anning was per	formed from the OD surface, ex	camining the top and bott	om sides of weld H9 for a
There were si aligned with th	xty five (65) reco ne fusion line.	ordable indications. The indica	tions are located intermit	tently along the weld length and are
Eighteen (18) indications ha recorded indic	indications disp ve been evaluat ations have bee	layed tip signals and possesse ted as being unacceptable to th en evaluated as being acceptat	d a through wall dimension requirements of Table sole to the requirements of	on. Sixteen (16) of the recorded IWB-3510-1. Two (2) of the Table IWB-3510-1.
The remaining the requireme	forty seven (47 Ints of Table IW	') indications without through w B-3510-1.	all dimension have been	evaluated as being acceptable to
Baseline exan	nination results	were reviewed, the number and	l lengths of indications cl	nanged but the location did not .
Magnetic part Revision V3.	icle examination No recordable ir	is were performed on the weld (indications were found.	CH-MB inside surface in	accordance with GE-MT-100
A visual VT-3 recordable inc	examination wa lications were fo	s performed on the weld CH-Mi bund.	B inside surface in accor	dance with MAG-CG-407 Rev. 7. No
Supplemental accordance w sizing. No nea	manual ultrasor ith PDI-UT-7 Re Ir surface indica	nic examination of selected are w. E Addenda-01. PDI-UT-7 us tions were found.	as of the internal surface sed for information only, r	of weld CH-MB was performed in not qualified for ID detection or
Due to scan li	mitations it not p	ossible to examine 100% of the	ASME code required a	rea.
Auto UT comp	osite coverage	= 93.1%		
•	-			
				· · · ·
HabIu	rh II	Huss Ollet hale I		
PREPARED BY	,	REVIEWED BY	UTILITY REVIEW	ANIL REVIEW

•

PEACH BOTTOM 2 R 14 PAGE _____ OF ____ 24

· · · · ·

.

<u>_</u>		G G	E Nuclea	ar Energ	<u>v</u>		GERIS 2000 Indication Data Sheet					
		<u></u>	Project : Weld ID :	Peach Bo CH-MB	<u>ttom 2 - 2</u>	<u>R14</u>			Exam Data Sheet : mbl.3 Patch ID : mbl.3			
		(Channel :	2	Angle ;	<u>45</u>			Diraction : 270			
	ĺ		-	Searc	h Unit		•	-	•			
	, j	Ind #	Amp.	<u> </u>	<u> </u>	Thruwan	Length	ت م	<u>Comments</u>			
			4.284	475 70	9.04	++		0.00	·			
		<u>⊢-'</u>	12%	135.20	9.03		0.50	0.00	·			
I		i†	/ /	╂┦	10.14	++	·	┟				
I		 		<u></u> ∕	11 64	 †	·•	├ †	·····			
1			15%	135.53	12 14	N/A	1 00	0.00				
1	1 1	i		133.00	12.64							
1		rt		├ ───┦		++		t				
		t			12.39			(
	·	3	13%	137.28	12.39	N/A	0.25	0.00				
1		<u> </u>			12.64	<u> </u>						
ľ			. 1	 	í							
·				r	12.64							
	Ì	4	13%	137.03	12.64	N/A	0.25	0.00				
1	Ì			T	12.89	[<u> </u>					
	Ī				· · · · · · · · · · · · · · · · · · ·							
ł	[18.89							
1		5	64%	136.78	19.14	0.17	0.75	0.00				
	• [19.64							
	[
I	[20.39							
· .]	Ī	35	20%	137.03	20.89	N/A	0.75	0.00				
1	Γ		<u> </u>		21.14							
	[
I	[
ľ	· [
199 B.	' [
I												
1	Į											
1	[
1	-			·				······································				
H				·								
f	Com	ments .										
F												
Ţ				······································								
Ļ												
		A nahuat	Dr.	A	4.1.			Deviewer	in Mab Tak			
	,	Analyse g	2 nong	<u>a ~</u>	<u>vou</u>	-	1	Keviewou	By fluxer IV Lore			
				-	• -	_	1	177	01500			

P82-CH-MB-Data 2R14.xis

p.3

	96) e	E Nucle	ar Energ	<u>v</u>		GERIS 2000 Indication Data Sheet						
		Project : Weld ID :	Peach Bo CH-MB	<u> 2 - 21 - 21 - 21 - 21 - 21 - 21 - 21 -</u>	<u>R14</u>			Exam Data Sheet: <u>mbl.1</u> Patch ID: <u>mbl.1</u>				
		Channel :	<u>2</u>	Angle :	<u>45</u>			Direction : 270				
	ind #	Amp.	Searc X	h Unit Y	ThruWall	Length	S	Comments				
				20.39								
	6	84%	137.28	20.89	0.20	1.00	0.00					
		-	<u> </u>	21.39			·	l				
		<u> </u>		22.39								
	7	13%	137.53	22.90	N/A	0.75	0.00					
				23.14								
		0.01/	407.00	24.14		0.75						
•	8	26%	137.28	24.14	N/A	0.75	0.00					
				28.14								
	9	18%	136.28	28.29	N/A	0.75	0.00					
				28.89				·				
				20.14								
•	10	12%	137.53	29.64	0.10	0.75	0.00					
i				29.89								
		40%	400.00	30.14								
		12%	139.29	30.14	N/A	_0.50	0.00					
				30.04								
				32.14								
	12	11%	138.29	32.14	N/A	0.50	0.00					
				32.64								
								· · · · · · · · · · · · · · · · · · ·				
,om	ments :											
							•					
Com	ments :											

PB2-CH-MB-Data 2R14.xls

2

-	E	GE Nucle	ar Energ	<u>v</u>		G	ERIS D	2000 Indication ata Sheet
		Project : Weld ID :	<u>Peach Bo</u> <u>CH-MB</u>	ottom 2 - 2F	<u>R14</u>			Exam Data Sheet : <u>mbi.1</u> Patch ID : <u>mbi.1</u>
		Channel :	<u>2</u>	Angle :	<u>45</u>			Direction : 270
	Ind #	Amp.	Searc X	h Unit	<u>ThruWa</u>	ll Length	<u>s</u>	Comments
	13	17%	136.03	34.89 35.14 35.64	N/A	0.75	0.00	
en an	14	24%	136.53	36.64 37.64	0.16	1.75	0.00	
	15	14%	137 78	<u>38.39</u> <u>40.14</u> 40.64	N/A	0.75	0.00	
				40.89		0.79		
	16	76%	137.28	44.14 45.39	0.25	3.75	0.00	
	17	13%	133.03	45.14 45.39 45.89	N/A	0.75	0.00	
	18	34%	137.53	48.14 48.39 48.89	N/A	0.75	0.00	
	19	187%	137.78	50.64 52.14 53.14	N/A	2.50	0.00	
	Comments :		······································					
	Analyst Level:	Ok:e	Date: _	 9-22-0	- e z _		Reviewed	IBY: Hal Traf II Date: <u>912502</u>

PB2-CH-MB-Data 2R14.xis

.

Â.	eg O	g G	E Nucle	ar Energ	<u>v</u>		GERIS 2000 Indication Data Sheet					
• •			Project : Weld ID :	Peach Bo CH-MB	ttom 2 - 2F	<u>₹14</u>			Exam Data Sheet : <u>mbl.1</u> Patch ID : <u>mbl.1</u>			
		Ċ	Channel :	2	Angle :	<u>45</u>			Direction : 270			
				Searc	h Unit							
l	Г	<u>Ind #</u>	Атр.	×	Y	ThruWall	Length	S T	Comments			
	-		22%	135 78	52.39	0.17	1 25	0.00				
	- F	-20	2270	130.70	53.64		1.20	0.00				
					00.01							
	F				55.14							
1	F	21	131%	137.28	56.14	N/A	1.50	0.00				
		1			56.64							
	Ε											
ľ	Ē				55.14							
. J	Ļ	22	17%	135.78	55.30	N/A	0.50	0.00				
					55.64	L						
	-	+	249/	425 52	57.89	NI/A	100					
<u> </u>	-	-23-+	3170	130.03	59.99	N/A						
	- H				30.08							
					58 39							
	F	24	41%	137.07	58.89	0.17	1.00	0.00				
	. ⊢				59.39							
- i i												
					58.89							
	Ē	25	18%	137.28	60.14	N/A	1.75	0.00				
					60.64				· · · · · · · · · · · · · · · · · · ·			
	Ĺ						ł					
	F			ł								
. 1	\vdash											
·	\vdash					+		~~ }~				
1	-											
	L.,											
Ĺ												
2	Comm	ents :										
4												
F												
E												
. Г		1	54.0	Al				Deviewed Du	No la Trano			
	A	naiyst: L	<n td="" x;<=""><td>anne</td><td>markin .</td><td>-</td><td>Ì</td><td>Reviewed By:</td><td>- ITIME (Vary</td></n>	anne	markin .	-	Ì	Reviewed By:	- ITIME (Vary			
j	Le	evel: 7	TT_	Date: 9	7- 22-0	2	{	Level:	- Date: <u>9125107</u>			
1												

PB2-CH-MB-Data 2R14.x/s

·· · ·· ·

-	98) G	E Nucle	ar Energ	y		G	ERIS 200 Data	0 Indication Sheet			
ŀ		Project : Weld ID :	Peach Bo CH-MB	ittom 2 - 2	R14			Exam Data Sheet : mbl. Patch ID : mbl.			
		Channel :	2	Angle :	<u>45</u>			Direction : 270			
	الله المراجع		Searc	h Unit	The second states (1	t an ath	c	0			
L		Amp.	<u> </u>	63.64	Inruwali	Lengin		Comments			
	26	20%	137.78	63.89	N/A	0.25	0.00				
				63.89							
				67.89							
	27	12%	139.04	68.39	N/A	0.75	0.00				
			<u> </u>	68,64							
				72 14	┝────┦						
	28	15%	138.04	73.39	N/A	0.75	0.00				
				73.89	<u> </u>						
				74.89							
	29	76%	138.04	75.14	N/A	0.75	0.00				
				75.64							
				76.90							
	30	143%	138.04	77.39	N/A	1.25	0.00	······································			
ł	<u>*</u>		100.01	78.14							
				82.64							
	31	<u>91%</u>	138.54	83.14	N/A	2.25	0.00				
	┝───┤			84.89	┝╍───┼	 					
	├			87.14		+					
	32	156%	138.79	87.89	N/A	1.00	0.00				
	<u>├</u> †			88.14							
•											
Con	nments :							······································			
•		FDr.	$n \Lambda$	(Deviews + Devi	10.0 -0			
	Analyst:		pon	enoti	2		Reviewed By:	rank wak			
	~			C	_	11 Al75/07					

PB2-CH-MB-Data 2R14.xis

Project: Peach Bottom 2 - 2R14 Exam Data Sheet: mbl Weld ID: CH-MB Direction: 270 Channel: 2 Angle: 45 Direction: 270 Search Unit Ind # Amp. X Y ThruWall Length S Comments 33 64% 130.29 90.14 N/A 2.05 0.00	G G	E Nuclei	ar Energy	/		GERIS 2000 Indication Data Sheet						
Channel: 2 Angle: 45 Direction: 270 Search Unit Ind # Amp. X Y ThruWall Length S Comments 33 64% 139.29 90.14 N/A 2.05 0.00		Project : Weld ID :	Peach Bo CH-M B	itom 2 - 2	R14			Exam Data Sheet: <u>mbl.2</u> Patch ID: <u>mbl.2</u>				
Search Unit Ind # Amp. X Y ThruWall Length S Comments 33 64% 139.29 90.14 N/A 2.05 0.00 33 64% 139.29 90.14 N/A 2.05 0.00 34 91.94		Channel :	<u>2</u>	Angle :	<u>45</u>	,		<i>Direction : 270</i>				
33 64% 139.29 90.14 N/A 2.05 0.00 91.94 91.94 91.94 91.94 91.94 91.94 91.89 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 91.94 92.64 92.64 92.64 92.64 92.94 92.64 92.64 92.64 92.64 92.94 92.64 92.64 92.64 92.64 92.94 92.64 92.64 92.64 92.64 92.94 92.64 92.64 92.64 92.94	Ind #	Amp.	Searc: X	h Unit	ThruWall	Length	<u></u>	Comments				
91.94 91.89 34 53% 139.04 92.14 0.16 0.75 0.00 91.89 92.64 92.14 0.16 0.75 0.00 91.89 92.64 92.64 92.64 92.64 92.64 91.89 92.64 92	33	64%	139.29	<u>89.89</u> 90.14	N/A	2.05	0.00					
91.89 0.15 0.00 34 53% 139.04 92.64 0.15 0.00 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 92.64 <td>·</td> <td></td> <td></td> <td>91.94</td> <td></td> <td></td> <td></td> <td></td>	·			91.94								
34 53% 139.04 92.14 0.16 0.75 0.00 92.64		<u> </u>		91.89								
	34	53%	139.04	92.14	0.16	0.75	0.00					
				32.04								
					├ ───┤							
				<i></i>								
								·				
								· · · · · · · · · · · · · · · · · · ·				
					<u>├</u>		_					
			ł									
	Analyst:	Phil	p An	and	<u> </u>	Reviewed By: Mark Tirch						

- -

PB2-CH-MB-Data 2R14.xis

	86) G	E Nuclea	ar Energ	<u>v</u>		GERIS 2000 Indication Data Sheet					
	L	Project : Weld ID :	Peach Bo CH-MB	ttom 2 - 21	<u>R14</u>	<u></u>	<u>, , , , , , , , , , , , , , , , , , , </u>	Exam Data Sheet : <u>mbl.4</u> Patch ID : <u>mbl.4</u>			
		Channel :	2	Angle :	<u>45</u>			Direction : 270			
		Amp.	Searc X	h Unit Y	<u>ThruWall</u>	Length	<u> </u>	Comments			
	36	18%	137.03	5.64 5.89	N/A	0.50	0.00				
~											
Con	nments :		4		L						
<u> </u>	Analyst:	Ohin	Ip A	hand	<u>.</u>	Reviewed By: 1-42 Torack					

PB2-CH-MB-Data 2R14.xis

GERIS 2000 Indication Зe **GE Nuclear Energy** Data Sheet Project : Peach Bottom 2 - 2R14 Exam Data Sheet : mbr.2 Weld ID : CH-MB Patch ID : mbr.2 Channel: 2 Angle ; 45 Direction : 270 Search Unit Y ThruWall Length S Comments Ind # Атр. X 11.11 N/A 0.50 0.00 125.96 11.38 37 15% 11.61 18.36 0.19 0.75 0.00 38 45% 127.96 18.61 19.11 21.86 127.46 31% 22.11 0.16 0.40 0.00 39 22.26 25.36 0.00 0.50 25.61 N/A 40 31% 125.71 25.86 31.61 N/A 1.50 0.00 41 31% 126.21 32.61 33.11 34.61 1.75 0.00 0.19 29% 125.96 35.11 42 36.36 39.11 0.00 127.21 N/A 0.25 43 20% 39.11 $(1,1) \in \mathbb{R}^{n}$ 39.36 Comments : Reviewed By: Mark Troch Analyst: Date: 9/2/02 Date: 9125/02 Level: III Level:

PB2-CH-MR-Data 2R14.xis

p.12

· . -=

-	36) G	E Nucle	ar Energ	<u>y</u>		GERIS 2000 Indication Data Sheet					
		Project : Weld ID :	Peach Bo CH-MB	ottom 2 - 2	<u>R14</u>			Exam Data Sheet : <u>mbr.2</u> Patch ID : <u>mbr.2</u>			
	I	Channel :	2	Angle :	<u>45</u>			Direction : 270			
		_	Searc	h Unit			_				
	Ind #	Amp.	<u> </u>	Y	ThruWall	Length	<u> </u>	Comments			
		45%	128.22	40.30	0.17	0.75	0.00				
·				41.11							
			<u> </u>		†						
				41.36							
	45	41%	128.22	41.86	N/A	1.00	0.00				
				42.36	┟╍╌╺╸╽		┝╍╼╼╸┢╸				
1				42.96	<u>├</u>						
	46	20%	128 47	42.00	N/A	0.50	0.00				
				43.36		0.00					
					 						
				45.86							
	47	34%	28.22	46.11	N/A	0.75	0.00				
	J			46.81	┦╼╾╌┥						
					├ ─ ─── ─ ├						
	├				┝╌╌╼┥						
1											
	<u>├</u>		ł		┝╾╾╼╾┠	ł					
	┝───┤										
1	┠╂										
1											
· ·]											
1											
1	┝										
	L										
1											
Сол	nments :										
· }	<u></u>										
1	Analyet	1 A	6				Reviewed D	N. L. T. O			
.	,		r	11	-			- the course			
1	Level: -7	17	Date: 3	121/07		1		L Data: 9170107			

PB2-CH-MB-Date 2R14.xls

. .

• • • • • • •

--- ---

,

-			SE Nucle	ar Energ	у <u> </u>		G	ERIS 20 Data	00 Indication a Sheet
			Project : Weld ID ;	Peach Bo	ottom 2 - 2	<u>R14</u>		<u> </u>	Exam Data Sheet : <u>mbr.1</u> Patch ID : <u>mbr.1</u>
			Channel :	2	Angle :	<u>45</u>			Direction : 270
		ind #	Amp.	Searc X	h Unit Y	ThruWall	Length	s	Comments
		48	131%	128.97	48.11 48.61 48.86	N/A	<u>0.75</u>	0.00	
					49.36				
•			143%	128.72	49.61 50.36		1.00	0.00	
		50	37%	126.96	49.86 50.61	0.12	1.00	0.00	
-					53.61				
		51	143%	128.47	53.88 54.36	N/A	0.75	0.00	
1		52	45%	127.21	56.11 56.61	N/A	0.75	0.00	
					56.86 56.36				
		53	37%	1 28.97	58.61 57.11	0.14	0.75	0.00	
		54	18%	127.46	60.11 60.86	N/A	1.00	0.00	
'≃•	ŕ				61.11				
I	Com	ments :					· · · · · · · · · · · · · · · · · · ·		
<u></u>	-	Analyst:	DO R	£				Reviewed By:	Meile Trad
		Level:	14 <u>-</u>	Date: <u></u>	3/21/02			Level: 114	Date: <u>1125</u> 02_

PB2-CH-M8-Data 2R14.xis

- . .. ----

.....

	G G	E Nuclea	ar Energy	Y		GERIS 2000 Indication Data Sheet						
		Project : Weld ID :	Peach Bo CH-MB	ttom 2 - 21	<u>R14</u>			Exam Data Sheet: mbr. Patch ID: mbr.				
	I	Channel :	2	Angle :	<u>45</u>			Direction : 270				
	Ind #	Amp.	Searc X	h Unit Y	ThruWall	Length	<u>s</u>	Comments				
	55	22%	129.47	<u>61.10</u> <u>61.36</u>	N/A	0.51	0.00					
				61.61								
	56	100%	129.71	72.61 73.10	0.17	1.00	0.00					
				73.61								
	· · · · ·			74.61								
	57	109%	129.47	75.11 75.61	0.17	1.00	0.00					
				80 11								
	58	70%	129.22	80.61	N/A	1.25	0.00					
				81.36								
	59	45%	129.72	81.61 82.11	N/A	0.75	0.00					
				82.36								
				84.11				······································				
	60	45%	129.47	<u>84.11</u> 84.61	N/A	0.50	0.00					
				84.61								
	61	171%	128.97	85.11	0.12	1.00	0.00					
				00.01								
Con	nments :	None						· · · · · · · · · · · · · · · · · · ·				
	·						<u> </u>					
		OA I	UT -				Reviewed Ru	M. K Tor				
	Level:	TI-	_# Date: <u>1</u>	ke for	_			Date: <u>9126</u> 07				

Ì

	36) g	E Nuclei	ar Energ	<u>y</u>		GERIS 2000 Indication Data Sheet					
		Project : Weld ID :	<u>Peach Bo</u> CH-MB	<u>ttom 2 - 21</u>	<u>R14</u>			Exam Data Sheet: <u>mbr.</u> Patch ID: <u>mbr.</u>			
		Channel :	<u>2</u>	Angle :	<u>45</u>			Direction : 270			
	Ind #	Amp.	Searc X	h Unit Y 87.61	ThruWall	Length	S	Comments			
	62	84%	129.22	87.86 88.11	N/A	0.50	0.00				
	63	26%	128.72	88.61 89.36	0.17	1.50	0.00				
				90.11							
	64	24%	127.46	92.86 93.36 93.61	N/A	0.75	0.00				
							· .				
·											
: .											
Cor	aments -			· · · · · · · · ·							
						······································					
	Analyst:	DA	Date: 4	hilo:			Reviewed By:	Muk Troch Date: 5/25/07			
L	Level			<u> </u>				Date C			
P82-0	H-M8-Data 2	R14.xis									

	98	GE Nucle	ar Energ	<u>v</u>		<i>GERIS 2000 Indication Data Sheet</i>					
		Project : Weld ID :	Peach Bo CH-MB	ttom 2 - 21	<u>R14</u>		Exam Data Sheet: mbr.1 Petch ID: mbr.1				
		Channel :	4	Angle :	<u>45</u>			Direction : 270			
· · · •	lad H	4.000	Searc	h Unit	Theulde	Longth	•				
	<i></i>		127.51			Lengui		Comments			
·	65	26%	128.02	92.25	N/A	1.00	0.00				
· · ·]			128.52								
				·····	<u></u>						
				<u></u>							
											
		5									
								· · · · · · · · · · · · · · · · · · ·			
		┢╌╼╌╼┤									
		┟───┤									
• • • •	,	∤			ł	<u> </u>		······································			
		╞╾╍╌╸╃									
		┝──┤									
	L	<u>. </u>					l.				
L			 	<u></u>							
<u>c</u>	omments :						<u> </u>				
E											
F											
. -		000	x		· · · · · ·						
	Analyst:	J P	Ø				Reviewed	By: Marken Turak			
				h. ha			ĩ	11 - 5125100			

PB2-CH-MB-Data 2R14.xls

! .____

η

APPENDIX B

GERIS 2000 Indication Evaluation Data Sheets

Rev 1 September 2002 (Includes 2 New Pages September 27, 2002)



EXAM-054 V.7 7/500

ndcallion Sult

p.15



EXAMIDSA V.7 7/500

p.16

es 6.xie

Richard Keck



EXAMOS4 V.7 7/5/00

p.17



EXAM-054 V.7 75400

indication 10.sts

<u>GE Nuclear Energy</u>

EXAMOSA V.7 7/5/00



Comments : None.	
Data Review By: <i>Philip Sharoli</i>	Reviewed By: <u>Male Trache</u>
Level: <u>TIT</u> Date: <u>9-22-01</u>	Level: <u>III</u> Date: <u>9125</u> 02.

Evaluation Data Sheet

GERIS 2000 Indication

p.19

<u> </u>	GE Nuclear Energy		GEI Eva	RIS 20 luatio	00 Indi n Data	ication Sheet
	Project : Peach Bolton Weld ID : CH-MB	m, Unit-2		Exam Sizing	Data Sheet : Data Sheet : Indication :	mbl.1 n/a 20
	Flaw Throughwall Dimension = Flaw Length "I" = Surface Separation "S" =	0.170 1.25 0.00		 "T" "Clad	T" nominal = ' measured = T" nominal =	4.25 4.30 N/A
		ASME Sectio TABLE	n XI, 1989 Edi IWB-3510-1 f	ition, No Ad or 4" to 12"	denda	
	a/1 0.00 0.05 0.10 0.15 0.20 0.25 0.30 0.35 0.40 0.46 0.50	Surface % 1.9 2.0 2.2 2.5 2.8 3.3 3.8 4.4 5.0 5.1 5.2 a = a/l value = Y =	Subsurface % 2.0 2.2 2.5 2.9 3.3 3.8 4.4 5.1 5.8 6.7 7.6 0.170 0.136 0.000	Surface % ~ - 2.42 ~ - - - - Allowed 2.42	Subsurface % ~ 2.79 Y ~ ~ ~ ~ ~ ~ Aliowed 0.00	
	Fi	Allowed a/t = a/t = law is unaccep	2.42% 3.95% Dtable by Table	9 IWB-3510-	1.	
· _	Data Review By: Dreep B Level: <u>III</u> Date: <u>F</u>	h-102	R	Reviewed By evel: 111	: <u>Male</u>	 Date: <u>51/25/02</u>

.

EXAM-054 V 7 7/5/00

a 20 sta



EXALOS4 V.7 7/500

indextion 24aia

717 456 4151

EXAM DS4 V.7 7/500

____

. . .

p.23

EXAM-054 V.7 7/500



indication 38 via

Project : Peach Bottom, Unit-2

Flaw Throughwall Dimension = 0.160 Flaw Length "I" = 0.40 Surface Separation "S" = 0.00

Weld ID : CH-MA

GE Nuclear Energy

"T" nominal = 4.25 "T" measured = 4.30 Ciad "T" nominal = N/A

Exam Data Sheet : mbr.2

Sizing Data Sheet : n/a Indication: 39

ASME Section XI, 1989 Edition, No Addenda TABLE IWB-3510-1 for 4" to 12"

a/î	Surface %	Subsurface %	Surface %	Subsurface %
0.00	1.9	2.0	-	-
0.05	2.0	2.2	-	~
0.10	2.2	2.5		~
0.15	2.5	2. 9	-	-
0.20	2.8	3.3	-	~
0.25	3.3	3.8	~	-
0.30	3.8	4.4	~	~
0.35	4.4	5.1	-	~
0.40	5.0	5.8	5.00	5.80 Y
0.45	5.1	6.7		-
0.50	5.2	7.6	~	~
			Alfowed	Allowed
			5.00	0.00

0.160 a = a/l value = 0.400 0.000 Y =

Flaw is Surface

Allowed a/t = 5.00% a/t = 3.72%

Flaw is acceptable by Table IWB-3510-1.

Comments : None.

Data Review By: Date: 9/2, /oz Level;

Reviewed By: Male Truk Date: 7125/02 Level:

EXAM-084 9.7 7/500

. . . .

1.0

Evaluations, ph

	<u> 3E Nuclear Energy</u>	2	GEI Eva	RIS 20 Iuatio	00 Ind n Data	ication Sheet
	<i>Project :</i> Peach Bo <i>Weld ID</i> : CH-MB	ottom, Unit-2		Exam Sizing	Data Sheet : Data Sheet : Indication :	mbr.2 n/a 42
Flaw	Throughwall Dimension Flaw Length "l Surface Separation "S	n = 0.190 " = 1.75 " = 0.00		" "T" Clad "	T" nominal = ' measured = T" nominal =	4.25 4.30 N/A
		ASME Sectio TABLE	m XI, 1989 Edi : iWB-3510-1 f	tion, No Ad or 4" to 12"	ldenda	
	a/1	Surface %	Subsurface %	Surface %	Subsurface %]
	0.00	1.9	2.0	~	~	
•	0.05	2.0	2.2	2 25	257 9	
	0.15	2.5	2.9	~	~	
	0.20	2.8	3.3	~	~	
	0.25	3.3	3.8	-	~	
	0.30	3.8	4.4	~	~	
	0.35	4.4	5.1	~	~	
	0.40	5.0	5.8	· 🛥	~	
	0.45	5.1	6.7	~	~	
	0.50	5.2	7.6	••	~	
				Allowed 2.25	Allowed 0.00	
ł		a = a/1 value = Y =	0.190 0.109 0.000			
		F	law is Surface			
		Ailowed a/t = a/t =	2.25% 4.42%			
		Flaw is unaccep	ptable by Table	IWB-3510-	1.	
Comments	: None.					
	()A no				. 0	
Data Revi	iew By		R	eviewed By	: Mel	e 1 vol
			_			

EXAM-054 V.7 7/500

induction 42 cm

. -

-



EXAM-034 V.7 7/500

(GE Nuclear Energy		GEI Eva	RIS 20 Iuatio	00 Indi n Data	ication Sheet
	Project : Peach Botton Weld ID : CH-MB	n, Unit-2		Exam Sizing	Data Sheet : Data Sheet : Indication :	mbr.1 n/a 50
	Flaw Throughwall Dimension = (Flaw Length "I" = ` Surface Separation "S" = (0.120 1.00 0.00		 יידי Clad *	T" nominal ≃ ' measured ≃ T" nominal =	4.25 4.30 N/A
	A	SME Sectio TABLE	n XI, 1989 Edi IWB-3510-1 fe	tion, No Ad or 4" to 12"	idenda	
· .	a/l 0.00	Surface %	Subsurface % 2.0	Surface %	Subsurface % ~	
	0.05 0.10	2.0 2.2	2.2 2.5	~ 2.32	~ 2.66 Y	
	0.15 0.20 0.25	2.5 2.8 3.3	2.9 3.3 3.6	~ ~	~ ~	
	0.30 0.35 0.40	3.8 4.4 5.0	4.4 5.1 5.8		~ -	
	0.45 0.50	5.1 5.2	6.7 7.6 _	~ ~ Allowed	~ ~ Allowed	
	· ·		0.400	2.32	0.00	
		a = a/i value = Y =	0.120 0.120 0.000			
		न	law is Surface			
	A	liowed a/t = a/t =	2.32% 2.79%			
4 73 + 1	Fla	w is unaccep	otable by Table	IWB-3510-	1.	
	Comments : None.					
ŀ			R	eviewed By	+ fair	Trak
	Level: <u>11</u> Date: <u>9/2</u>	, loc	L	evel: <u>11</u>	<u> </u>	Date: 9/25/02

EXAM-034 V.7 7/500

indication \$0 xts

<u>_</u> .	GE Nuclear Energy		GEI Eva	RIS 20 Iuatio	00 Ind on Data	ication Sheet
	<i>Project :</i> Peach Botto <i>Weld ID :</i> CH-MB	om, Unit-2		Exam Sizing	Data Sheet : Data Sheet : Indication :	mbr.1 n/a 53
	Flaw Throughwall Dimension = Flaw Length "I" = Surface Separation "S" =	= 0.140 = 0.75 = 0.00		"" "T" Clad "	T" nominal = ' measured = T" nominal =	4.25 4.30 N/A
		ASME Sectio TABLE	n XI, 1989 Edi JWB-3510-1 fe	tion, No Ad or 4" to 12"	ldenda	
	a/l 0.00 0.05 0.10 0.15 0.20 0.25 0.30 0.35 0.40 0.45 0.50	Surface % 1.9 2.0 2.2 2.5 2.8 3.3 3.8 4.4 5.0 5.1 5.2 a = a/l value = Y =	Subsurface % 2.0 2.2 2.5 2.9 3.3 3.8 4.4 5.1 5.8 6.7 7.6 	Surface %	Subsurface % 	
		F Allowed a/t ≈ a/t =	iaw is Surface 2.72% 3.26%			
	F	Flaw is unaccep	table by Table	IW B- 3510-	1.	
~	Data Review By: OP M Level: <u></u> Date: _9	k loz	R	eviewed By	<u>Ma</u>	li_Truck Date: <u>9/25/02</u>

EXAM-034 V.7 7/500

.....

indication 53.4M

· ---

_

	GE Nuclear Energy		GEI Eva	RIS 20 luatio	00 Ind n Data	ication Sheet	
	<i>Project</i> : Peach Botte <i>Weld ID</i> : CH-MB	om, Unit-2		Exam Sizing	Data Sheet : Data Sheet : Indication ;	mbr.1 n/a 56	
	Flaw Throughwall Dimension = Flaw Length "I" = Surface Separation "S" =	= 0.170 = 1.00 = 0.00		"T" Clad "	T" nominal = ' measured = T" nominal =	4.25 4.30 N/A	
		ASME Sectio TABLE	n XI, 1989 Edi IWB-3510-1 f	ition, No Ad or 4" to 12"	idenda		
	2/1 0.00 0.05	Surface % 1.9 2.0 2.2	Subsurface % 2.0 2.2 2.5	Surface %	Subsurface % ~ -		
	0.15 0.20 0.25	2.5 2.8 3.3	2.9 3.3 3.8	2.62 - -	3.06 Y ~ ~		/
	0.30 0.35 0.40 0.45 0.50	3.8 4.4 5.0 5.1 5.2	4.4 5.1 5.8 6.7 7.6				
				Allowed 2.62	Allowed 0.00		
	•	a = a/i value = Y =	0.170 0.170 0.000				
		F	law is Surface				
		Allowed a/t = a/t =	2.62% 3.9 5%				
² ma	í	Flaw is unaccep	ptable by Table	iW8-3510-	1.		
	Comments : None.						
· E						· · · · · · · · · · · · · · · · · · ·	
		h. la	я	leviewed By	: Hal	tinal	

	PEACH BOTTOM
Z .	RIL
	PAGE 41 OF 84

EXAM-034 V 7 7/500

GE Nuclear	Energy		GEI Eva	RIS 20 Iuatio	on Data	cation Sheet
Project : Weld ID :	Peach Bott CH-MB	om, Unit-2		Exam Sizing	Data Sheet : Data Sheet : Indication :	mbr.1 n/a 57
Flaw Throughwall I Flaw I Surface Sens	Dimension	= 0.170 = 1.00 = 0.00		"T Clad "	'T" nominai = " measured = 'T" nominal s	4.25 4.30 N/A
		ASME Sectio	m XI, 1989 Edi IWB-3510-1 f	ition, No Ac or 4" to 12"	idenda	
	a/i	Surface %	Subsurface %	Surface %	Subsurface %	
	0.00	2.0	2.0	-	~	
	0.10	2.2	2.5	~	-	
	0.15	2.5	2.9	2.62	3.06 Y	
	0.20	2.8	3.3	-	~	
	0.25	3.3	3.8	~	-	
	0.30	3.8	4.4	~	~	
	0.35	4.4	5.1	-	~	
	0.40	5.0	5.8	~	-	
	0.45	5.1	0.7 7 8		-	
	0.50	5,2	7.0	Allowed	Allowing	
	·			2.62	0.00	
·		a =	0.170		.'	
. *		a/1 value = Y =	0.170 0.000			
		F	law is Surface			
		Allowed $a/t =$	2.82%			
		a/t =	3.95%			
		Flaw is unacce	ptable by Table	e IWB-3510-	-1.	
Comments : None.						
Data Review By:	pf		F	Reviewed By	" Mal	tinch
Level Tre	Date: 5	h. los	- I - 1	aval 11	1	0-1- 0-1-21/10

PEACH BOTTOM

EXAM-054 V.7 7/5/00

10000

p.5 .

GERIS 2000 Indication Evaluation Data Sheet GE Nuclear Energy Project : Peach Bottom, Unit-2 Exam Data Sheet : mbr.1 Weld ID : CH-MB Sizing Data Sheet : n/a Indication : 61 Flaw Throughwall Dimension = 0.120 "T" nominal = 4.25 Flaw Length "I" = 1.00 "T" measured = 4.30 Surface Separation "S" = 0.00 Clad "T" nominal = N/A ASME Section XI, 1989 Edition, No Addenda TABLE IWB-3510-1 for 4" to 12" a/l Surface % Subsurface % Subsurface % 0.00 1.9 2.0 ~ ~ 0.05 2.0 2.2 ~ 0.10 2.2 2.5 2.32 2.66 Y 0.15 2.5 2.9 ~ -0.20 2.8 3.3 ~ ~ 0.25 3.3 3.8 ~ ~ 0.30 3.8 4.4 -0.35 4.4 5.1 -~ 0.40 5.0 5.8 ~ ~ 0.45 5.1 6.7 ~ ~ 0.50 5.2 7.6 -Allowed Allowed 2.32 0.00 a = 0.120 0.120 a/l value = Y = 0.000 Flaw is Surface Allowed a/t = 2.32% 2.79% a/t = Flaw is unacceptable by Table IWB-3510-1. Comments : None.

Data Review By: Level: TI

Date: <u>9/2.102</u>

Hall Toule Reviewed By: _ Date: 9/25/02 Level:_LL



EXAM-054V.7 7/500

p.30