

From: Ennis, Rick
Sent: Thursday, November 04, 2010 12:13 PM
To: Jeff Keenan
Cc: Paul Duke; Lingam, Siva; Boyle, Patrick
Subject: Acceptance Review for TACs ME4796 and ME4797- Salem 1 and 2 License Amendment Request - Snubber Surveillance Requirements

Jeff,

By letter dated October 4, 2010 (ADAMS Accession No. ML102780066), PSEG Nuclear LLC (the licensee) submitted a license amendment request for Salem Nuclear Generating Station, Unit Nos. 1 and 2 (Salem). The proposed amendment would revise the Technical Specification (TS) requirements for snubbers to conform to planned revisions to the inservice inspection program.

The purpose of this e-mail is to provide the results of the NRC staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the TSs) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment request in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. You will be advised of any further information needed to support the NRC staff's detailed technical review by separate correspondence.

If you have any questions, please contact me at (301) 415-1420.

Richard B. Ennis, Senior Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

E-mail Properties

Mail Envelope Properties (9E28710E0B702149AEC66397286364403B15677859)

Subject: Acceptance Review for TACs ME4796 and ME4797- Salem 1 and 2 License
Amendment Request - Snubber Surveillance Requirements

Sent Date: 11/04/2010 12:13:22 PM

Received Date: 11/04/2010 12:13:22 PM

From: Ennis, Rick

Created By: Rick.Ennis@nrc.gov

Recipients:

Jeff.Keenan@pseg.com (Jeff Keenan)

Tracking Status: None

Paul.Duke@pseg.com (Paul Duke)

Tracking Status: None

Siva.Lingam@nrc.gov (Lingam, Siva)

Tracking Status: None

Patrick.Boyle@nrc.gov (Boyle, Patrick)

Tracking Status: None

Post Office:

HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	14178	11/04/2010

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: