

From: Burke, John
Sent: Monday, March 22, 2010 3:43 PM
To: Lin, Bruce
Subject: FW: comments Reg guide 1.54 rev 2

Some public comments on RG 1.54

John Burke, PE
Senior Engineer
(301) 251-7628
john.burke@nrc.gov

From: Dolderer, Garth [<mailto:Garth.Dolderer@fpl.com>]
Sent: Monday, March 22, 2010 1:25 PM
To: Burke, John
Cc: garthdolderer@gmail.com
Subject: comments Reg guide 1.54 rev 2

I have reviewed the Reg Guide 1.54 rev 2 and have the following comments:

The ERPI guideline rev 2 for nuclear coatings which is now a public document should be incorporated as the guidance document for meeting the intent of this reg guide.

Containment coating inspections should be completed by an ASNI level III or equal inspector and or the NCS. Since the inspections are visual until a defect is detected the level of experience should be elevated to ensure compliance.

Garth Dolderer
954 240-6752

E-mail Properties

Mail Envelope Properties (44CD2E65B0FF0E499CB32BC30CF781F00AA9225331)

Subject: FW: comments Reg guide 1.54 rev 2
Sent Date: 3/22/2010 3:42:34 PM
Received Date: 3/22/2010 3:42:34 PM
From: Burke, John

Created By: John.Burke@nrc.gov

Recipients:
Bruce.Lin@nrc.gov (Lin, Bruce)
Tracking Status: None

Post Office:
HQCLSTR01.nrc.gov

Files Size Date & Time

MESSAGE 10717 3/22/2010

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: