

ESBWR DCD Tier 2 Sections 3.9-3.11
26A6642AK Revision 7 to Revision 8 Change List

Item	Location	Description of Change
1.	Entire Chapter	Header changed from Rev 7 to Rev 8.
2.	S3.9.2.3, next-to-last paragraph, next-to-last sentence	Corrected typographical error.
3.	S3.9.10, Reference 3.9-7	Reference for NEDE-33313P and NEDO-33313 was updated to indicate accepted versions.
4.	T3.9-8, System B32 – Isolation Condenser System Valves, Valves F009 and F010	Changed Safety Position from “C” to “O/C,” Fail Safe Position from “C” to “O,” and Containment Isolation Valve from “Y” to “N” in response to RAI 6.2-202 S01.
5.	T3.9-8, System T15-Passive Containment Cooling System Valves, Valve F001	Changed valve description from check to isolation and modified parameters in response to RAI 6.2-202 S01.
6.	S3.11.8, Reference 3.11-6	Reference for NEDE-33516P was updated to indicate accepted versions.
7.	T3.11-1, System T15-Passive Containment Cooling System	Changed “Vent Fan Check Valves” to “Vent Fan Isolation Valves” in response to RAI 6.2-202 S01.
8.	T3.11-1, System T15-Passive Containment Cooling System	Added component “Vent Line Catalyst Module” in response to RAI 6.2-202 S01.