

ESBWR DCD Tier 2 Chapter 15
26A6642BP Revision 7 to Revision 8 Change List

| Item | Location | Description of Change |
|-------------|--|--|
| 1. | Entire Chapter | Header changed from Rev 7 to Rev 8. |
| 2. | S15.0.7, Reference 15.0-6 | Reference for NEDC-33239P and NEDO-33239 was updated to indicate accepted versions. |
| 3. | S15.0.7, Reference 15.0-7 | Reference for NEDC-33326P and NEDO-33326 was updated to indicate accepted versions. |
| 4. | S15.2.8, Reference 15.2-1 | Reference for NEDE-33083P Supplement 3, and NEDO-333083 Supplement 3 was updated to indicate accepted versions. |
| 5. | S15.2.8, Reference 15.2-2 | Reference for NEDC-33239P and NEDO-33239 was updated to indicate accepted versions. |
| 6. | S15.2.8, Reference 15.2-3 | Reference for NEDC-33326P and NEDO-33326 was updated to indicate accepted versions. |
| 7. | T15.2-23 | Added new row for Process Variable “ICS DPV-Opened” per response to RAI 6.2-202 S01. |
| 8. | S15.3.18, Reference 15.3-2 | Reference for NEDE-33083P Supplement 3 and NEDO-33083 Supplement 3 was updated to indicated accepted versions. |
| 9. | S15.3.18, Reference 15.3-4 | Reference for NEDC-33239P and NEDO-33239 was updated to indicate accepted versions. |
| 10. | S15.3.18, Reference 15.3-5 | Reference for NEDC-33326P and NEDO-33326 was updated to indicate accepted versions. |
| 11. | S15.5.5.3, 1 st paragraph, 7 th sentence | Revised sentence to indicate that wide range level is above Level 1 with ICS venting after 6 hours, per response to RAI 6.2-202 S01. |
| 12. | S15.5-9, Reference 15.5-2 | Reference for NEDE-33083P Supplement 2 was updated to indicate accepted versions. |
| 13. | S15.5.9, Reference 15.5-3 | Reference for NEDC-33326P and NEDO-33326 was updated to indicate accepted versions. |
| 14. | S15.5.9, Reference 15.5-6 | Reference for NEDC-33239P and NEDO-33239 was updated to indicate accepted versions |

| Item | Location | Description of Change |
|-------------|---------------------------|---|
| 15. | S15.5.9, Reference 15.5-7 | Reference for NEDE-33083P Supplement 3 was updated to indicate accepted versions. |
| 16. | T15.5-10a | Added new row to indicate that at time 6 hours, the ICS lower header vent valves open per response to RAI 6.2-202 S01. |
| 17. | T15.5-10b | Revised table to reflect RPV conditions at 72 hours after blackout considering design changes implemented in response to RAI 6.2-202 S01. |
| 18. | S15A.5, Reference 15A-2 | Updated to reflect current revision of NEDO-33201. |