

ESBWR DCD Chapter 16
26A6642BR Revision 7 to Revision 8 Change List

Item	Location	Description of Change
1	16.00 TOC	Where applicable, updated TOC information consistent with changes to the associated LCOs.
2	16.03.03.05.03	Revised in accordance with RAI 6.2-202 Supp 1 (MFN 10-044 Supplement 3).
3	16.03.03.05.04	Revised in accordance with RAI 6.2-202 Supp 1 (MFN 10-044 Supplement 3).
4	16.03.03.06.03	Revised in accordance with RAI 6.2-202 Supp 1 (MFN 10-044 Supplement 3).
5	16.03.03.08.01, SR 3.3.8.1.3,	Added reference to Setpoint Control Program (MFN 10-279).
6	16.03.03.08.01, Table 3.3.8.1-1	Added manual actuation of GDCS Equalizing lines as Function 3 in Table 3.3.8.1-1 (MFN 10-279).
7	16.03.05.02, SR 3.5.2.4 and SR 3.5.2.5	Changed Frequency for flow path surveillances to STAGGERED TEST BASIS (MFN 10-270).
8	16.03.05.03, SR 3.5.3.6	Added flow path surveillances to GDCS – Shutdown LCO (MFN 10-270).
9	16.03.05.05, SR 3.5.5.6	Added flow path surveillance to ICS – Shutdown LCO (MFN 10-270).
10	16.03.06.01.07, SR 3.6.1.7.4 and SR 3.6.1.7.5	Added SR 3.6.1.7.4 and SR 3.6.1.7.5 in accordance with RAI 6.2-202 Supp 1 (MFN 10-044 Supplement 3).
11	16.03.07.01, SR 3.7.1.13	Changed Frequency for flow path surveillance to STAGGERED TEST BASIS (MFN 10-270).
12	16.03.07.05, LCO, Applicability, Actions, and SRs	Revised in accordance with the Response to Audit Open Items from the June 3 and 15, 2010 NRC Regulatory Audits of the ESBWR Spent Fuel Pool Required Water Inventory (MFN 10-189 Revision 2).
13	16.05.06.03, b.7	Updated LTR reference to reflect the accepted (-A) version, NEDE-33083 Supplement 3P-A Revision 1, September 2010 (MFN 10-294)