

Core Operating Limits Report for Reload 16, Cycle 17, Revision 4
Non - Proprietary Version

ENCLOSURE 2

LRW-PSG-KT1-10-122

Core Operating Limits Report for Hope Creek Generating Station Unit 1
Reload 16, Cycle 17

Non-Proprietary Information

INFORMATION NOTICE

This is a non-proprietary version of LRW-PSG-KT1-10-122 Enclosure 1, which has the proprietary information removed. Portions of the document that have been removed are indicated by white space inside open and closed bracket as shown here [[]].

CORE OPERATING LIMITS REPORT

FOR

Hope Creek Generating Station Unit 1

RELOAD 16, CYCLE 17

Effective Date: 11/4/2010

Prepared By: Kelly A. Wichman Date: Nov. 4, 2010
Kelly A. Wichman
Preparer

Reviewed By: [Signature] Date: 11/4/2010
James P. Collins
Reviewer

Approved By: Francis J. Safin
For DONALD V. NOTIGAN Date: 11/4/2010
Donald V. Notigan
Manager – BWR Design & Analysis

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

Table of Contents

1.0	Terms and Definitions	4
2.0	References	5
3.0	General Information	6
4.0	Technical Specifications that Reference the COLR	8
4.1	Average Planar Linear Heat Generation Rate	9
4.2	Minimum Critical Power Ratio	10
4.3	Linear Heat Generation Rate	13
4.4	OPRM Setpoints	15
Appendix A	Method of Core Average Scram Speed Calculation	16
Appendix B	Exposure Dependent Linear Heat Generation Rate Limits	18
Appendix C	Backup Stability Protection	23

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

List of Tables

TABLE 4.1-1	APLHGR Data for GE14 and GE14i ITAs	9
TABLE 4.2-1	MCPR Operating Limits Cycle Exposure ≤ 9450 MWd/MTU (≤ 8573 MWd/STU)	11
TABLE 4.2-2	MCPR Operating Limits Cycle Exposure > 9450 MWd/MTU (> 8573 MWd/STU)	11
TABLE 4.2-3	Power Dependent MCPR Multiplier (K_p) Data	12
TABLE 4.2-4	Flow Dependent MCPR Limit ($MCPR_f$) for GE14	12
TABLE 4.2-5	Flow Dependent MCPR Limit ($MCPR_f$) for GE14i ITAs	12
TABLE 4.3-1	Power Dependent Linear Heat Generation Rate Multiplier ($LHGRFAC_p$)	14
TABLE 4.3-2	Flow Dependent Linear Heat Generation Rate Multiplier ($LHGRFAC_f$)	14
TABLE B-1	GE14 LHGR Limits – UO ₂ Fuel Rods	20
TABLE B-2	GE14 LHGR Limits – Gadolinia Bearing Rods	20
TABLE B-3	GE14 LHGR Limits – UO ₂ Fuel Rods	21
TABLE B-4	GE14 LHGR Limits – Gadolinia Bearing Rods	21
TABLE B-5	GE14i ITA LHGR Limits – UO ₂ Fuel Rods	22
TABLE B-6	GE14i ITA LHGR Limits – Gadolinia Bearing Rods	22
TABLE C-1	BSP Region Intercepts for Cycle 16	24
TABLE C-2	BSP Region Intercepts for Cycle 17	24

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

1.0 Terms and Definitions

APLHGR	Average Planar Linear Heat Generation Rate
ARTS	APRM and RBM Technical Specification Analysis
BSP	Backup Stability Protection
COLR	Core Operating Limits Report
ECCS	Emergency Core Cooling Systems
EOC	End-of-Cycle
EOC-RPT	End-of-Cycle Recirculation Pump Trip
GNF-A	Global Nuclear Fuel – Americas, LLC
ITA	Isotope Test Assembly
LCO	Limiting Condition for Operation
LHGR	Linear Heat Generation Rate
LHGRFAC _f	ARTS LHGR thermal limit flow dependent adjustments and multipliers
LHGRFAC _p	ARTS LHGR thermal limit power dependent adjustments and multipliers
MCPR	Minimum Critical Power Ratio
MCPR _p	ARTS MCPR thermal limit power dependent adjustments and multipliers
MCPR _f	ARTS MCPR thermal limit flow dependent adjustments and multipliers
OPRM	Oscillation Power Range Monitor
SLMCPR	Safety Limit Minimum Critical Power Ratio
SLO	Single Loop Operation
TLO	Two Loop Operation

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

2.0 References

1. "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-16, and the Supplement NEDE-24011-P-A-16-US, October 2007.
2. "Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications," Global Nuclear Fuel Document NEDO-32465-A, August 1996.
3. Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Amendment 174 to Facility Operating License No. NPF-57, PSEG Nuclear LLC, Hope Creek Generating Station, Docket No. 50-354, May 14, 2008.
4. Final Safety Evaluation by the Office of Nuclear Reactor Regulation, "Applicability of GE Methods to Expanded Operating Domains," NEDC-33173P, July 2009.
5. GE14 Compliance with Amendment 22 of NEDE-24011-P-A (GESTAR II), NEDC-32868P, Revision 3, April 2009.
6. "Supplemental Reload Licensing Report for Hope Creek Unit 1 Reload 16 Cycle 17," Global Nuclear Fuel Document No. 0000-0105-6621-SRLR, Revision 0, July 2010.
7. "Fuel Bundle Information Report for Hope Creek Unit 1 Reload 16 Cycle 17," Global Nuclear Fuel Document No. 0000-0105-6621-FBIR, Revision 0, July 2010.
8. "Option B Licensing Basis & Cycle-Independent Transient Evaluation for Implementation of the Technical Specification Improvement Program (TSIP) Scram Speed," Global Nuclear Fuel Document No. 0000-0119-7785, Revision 0, October 2010.
9. Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Amendment 184 to Facility Operating License No. NPF-57, PSEG Nuclear LLC, Hope Creek Generating Station, Docket No. 50-354, October 7, 2010.
10. Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Amendment 183 to Facility Operating License No. NPF-57, PSEG Nuclear LLC, Hope Creek Generating Station, Docket No. 50-354, September 27, 2010.
11. "Core Operating Limits Report for Hope Creek Generating Station Unit 1 Reload 15, Cycle 16," COLR Hope Creek 1 Revision 3.
12. Facility Operating License No. NPF-57, PSEG Nuclear LLC, Hope Creek Generating Station, Docket No. 50-354.

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

3.0 General Information

The purpose of this revision is to provide the Core Operating Limits for Hope Creek Generating Station Unit 1 Cycle 17 / Reload 16 operation. This report provides information relative to OPRM setpoints and backup stability regions, single recirculation loop operation, and core average scram speed. The power distribution limits presented here correspond to the core thermal limits for Average Planar Linear Heat Generation Rate (APLHGR), Minimum Critical Power Ratio (MCPR), and Linear Heat Generation Rate (LHGR). Finally, this report provides references to the most recent revision of the implemented approved methodology.

These operating limit values have been determined using NRC approved methods contained in GESTAR-II (Reference 1) and NEDO-32465-A Reactor Stability Detect and Suppress Solutions Licensing Basis Methodology for Reload Applications (Reference 2). These operating limit values also include limitations where required by the NRC Safety Evaluation Report for Hope Creek License Amendment Number 174, Extended Power Uprate (Reference 3) for the use of GE Licensing Topical Report NEDC-33173P, Applicability of GE Methods to Expanded Operating Domains (Reference 4). In addition, the LHGR limits contained within are based upon the GE Report, GE14 Compliance with Amendment 22 of NEDE-24011-P-A (GESTAR II), NEDC-32868P, Revision 3, April 2009 (Reference 5). Revision 3 of the GE14 Compliance report updates the report to include a specific LHGR limit curve to be used by plants referencing NEDC-33173P.

The following sections contain operating limit values for both the GE14 fuel design and the GE14i Isotope Test Assemblies (GE14i ITAs). The limits for the GE14i ITAs were determined using the methods and limitations described in the NRC Safety Evaluation Report for Hope Creek License Amendment Number 184 (Reference 9). The operating limit values apply to both GE14 and GE14i ITAs, unless specific values are provided for the GE14i ITAs. The limitations and penalties for the GE14 fuel design discussed in the previous paragraph also apply to the GE14i ITAs.

The method of calculating core average scram speed, τ , is provided in Option B Licensing Basis & Cycle-Independent Transient Evaluation for Implementation of the Technical Specification Improvement Program (TSIP) Scram Speed (Reference 8).

These operating limits are established such that all applicable fuel thermal-mechanical, core thermal-hydraulic, ECCS, and nuclear limits such as shutdown margin, and transient and accident analysis limits are met.

Various sections of the Hope Creek Technical Specifications reference this COLR. Those sections are listed in Section 4 of this document. Hope Creek Technical Specification 6.9.1.9 also requires that this report, including any mid-cycle revisions, shall be provided upon issuance to the NRC.

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

This document is specific to Hope Creek Generating Station Unit 1 Cycle 17 Reload 16 and shall not be applicable to any other core or cycle design. This report is applicable for Cycle 17 operating from the date of issuance through the end of cycle including consideration of a power coastdown to a core thermal power that shall not go below 40% rated core thermal power. End of full power capability is reached when 100% rated power can no longer be maintained by increasing core flow (up to 105% of rated core flow), at allowable rated feedwater temperatures, in the all-rods-out configuration. Operation beyond the end of full power capability is defined as power coastdown operation which includes an operating assumption that vessel dome pressure will decrease during the power coastdown period as steam flow decreases (maintaining constant vessel dome pressure during the power coastdown period was not generically considered by GESTAR-II for determining the operating limit LCO values described above).

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

4.0 Technical Specifications that Reference the COLR

The following Hope Creek Technical Specifications reference this COLR:

<u>Technical Specification</u>	<u>Title</u>
2.1	Safety Limits
3/4.2.1	Average Planar Linear Heat Generation Rate
3/4.2.3	Minimum Critical Power Ratio
3/4.2.4	Linear Heat Generation Rate
3/4.3.11	Oscillation Power Range Monitor
3/4.4.1	Recirculation System Recirculation Loops
6.9.1.9	Administrative Controls, Core Operating Limits Report

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

4.1 Average Planar Linear Heat Generation Rate

LIMITING CONDITION FOR OPERATION

All AVERAGE PLANAR LINEAR HEAT GENERATION RATES (APLHGRs) shall be less than or equal to the limits specified in Table 4.1-1 for Two recirculation Loop Operation (TLO).

When the Technical Specification 3.4.1.1 Action statement a.1.d is entered from that section's Limiting Condition for Operation, reduce the APLHGR limits to the values specified in Table 4.1-1 for Single recirculation Loop Operation (SLO).

Linear interpolation shall be used to determine APLHGR limits as a function of exposure for intermediate values in Table 4.1-1.

TABLE 4.1-1 APLHGR Data for GE14 and GE14i ITAs

Average Planar Exposure		APLHGR Limit (kW/ft)	
MWd/MTU	MWd/STU	TLO	SLO
0.00	0.000	12.82	10.26
16000	14510	12.82	10.26
21090	19130	12.82	10.26
63500	57610	8.00	6.40
70000	63500	5.00	4.00

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

4.2 Minimum Critical Power Ratio

LIMITING CONDITION FOR OPERATION

The MINIMUM CRITICAL POWER RATIO (MCPR) shall be equal to or greater than the MCPR limit computed from the following steps:

1. Determine τ as defined in Appendix A.

NOTE

The SLO operating condition MCPR values in Tables 4.2-1, 4.2-2, 4.2-4, and 4.2-5 implement the increase in the MCPR Safety Limit to meet the requirements of Technical Specification 3.4.1.1 ACTION statement a.1.c.

2. Linearly interpolate a MCPR value as a function of τ from the MCPR value at $\tau=0$ and MCPR value at $\tau=1$ as specified in Table 4.2-1 and Table 4.2-2 for the appropriate condition. Repeat for each fuel type.
3. For the power dependent MCPR adjustment, when thermal power is $\geq 24\%$ rated core thermal power, determine a K_p value by linearly interpolating a K_p value as a function of core rated thermal power from Table 4.2-3. Multiply the MCPR value obtained from Step 2 by the K_p value to determine the power dependent MCPR limit for each fuel type.

When core thermal power is $< 24\%$ rated thermal power, no thermal limits are required.

4. For the flow dependent MCPR adjustment, determine the appropriate flow dependent MCPR limit by linearly interpolating between the MCPR limits as a function of rated core flow using the information in Table 4.2-4 (GE14) and Table 4.2-5 (GE14i ITAs).
5. Choose the most limiting (highest value) of the power and flow dependent MCPR limits determined in Steps 3 and 4 as the value for the MCPR limit for the Limiting Condition for Operation for each fuel type.

Note that the MCPR limit is a function of core average scram speed (τ), cycle exposure, core thermal power, total core flow, EOC-RPT operability, the number of reactor coolant recirculation loops in operation, and main turbine bypass operability.

EOC-RPT system operability is defined by Hope Creek Technical Specification 3.3.4.2.

Reactor coolant recirculation loop operation is defined by Hope Creek Technical Specification 3.4.1.1.

Main Turbine Bypass operability is defined by Hope Creek Technical Specification 3.7.7.

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

TABLE 4.2-1 MCPR Operating Limits Cycle Exposure ≤ 9450 MWd/MTU (≤ 8573 MWd/STU)

Main Turbine Bypass Operable			
Operating Condition	Scram Speed Option	GE14	GE14i ITAs
TLO-EOC-RPT Operable	A	1.49	1.56
	B	1.38	1.45
TLO-EOC-RPT Inoperable	A	1.51	1.58
	B	1.40	1.47
SLO-EOC-RPT Operable	A	1.51	1.58
	B	1.40	1.47
SLO-EOC-RPT Inoperable	A	1.53	1.60
	B	1.42	1.49

Scram Speed Option A $\tau=1$, Scram Speed Option B $\tau=0$
 TLO = Two Recirculation Loop Operation
 SLO = Single Recirculation Loop Operation

TABLE 4.2-2 MCPR Operating Limits Cycle Exposure > 9450 MWd/MTU (>8573 MWd/STU)

Main Turbine Bypass Operable			
Operating Condition	Scram Speed Option	GE14	GE14i ITAs
TLO-EOC-RPT Operable	A	1.60	1.67
	B	1.43	1.50
TLO-EOC-RPT Inoperable	A	1.62	1.69
	B	1.45	1.52
SLO-EOC-RPT Operable	A	1.62	1.69
	B	1.45	1.52
SLO-EOC-RPT Inoperable	A	1.64	1.71
	B	1.47	1.54

Scram Speed Option A $\tau=1$, Scram Speed Option B $\tau=0$
 TLO = Two Recirculation Loop Operation
 SLO = Single Recirculation Loop Operation

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

TABLE 4.2-3 Power Dependent MCPR Multiplier (K_p) Data

Operating Condition	Core Thermal Power (% of Rated)			
	24	45	60	≥100
	MCPR Multiplier K_p			
TLO	1.561	1.280	1.150	1.000
SLO	1.561	1.280	1.150	1.000

K_p is linearly interpolated between core thermal power entries.
 The K_p multiplier is the same for both GE14 and GE14i ITAs.
 TLO = Two Recirculation Loop Operation
 SLO = Single Recirculation Loop Operation

TABLE 4.2-4 Flow Dependent MCPR Limit ($MCPR_f$) for GE14

Operating Condition	Core Flow (% of Rated)			
	30	60	89.2	105
	MCPR Limit			
TLO	1.55		1.20	1.20
SLO	1.57	1.39		

$MCPR_f$ is linearly interpolated between core flow entries.
 TLO = Two Recirculation Loop Operation
 SLO = Single Recirculation Loop Operation

TABLE 4.2-5 Flow Dependent MCPR Limit ($MCPR_f$) for GE14i ITAs

Operating Condition	Core Flow (% of Rated)			
	30	60	89.2	105
	MCPR Limit			
TLO	1.62		1.27	1.27
SLO	1.64	1.46		

$MCPR_f$ is linearly interpolated between core flow entries.
 TLO = Two Recirculation Loop Operation
 SLO = Single Recirculation Loop Operation

4.3 Linear Heat Generation Rate

LIMITING CONDITION FOR OPERATION

The LINEAR HEAT GENERATION RATE (LHGR) shall not exceed the limit computed from the following steps:

NOTE

The steps performed in 1 through 6 below should be repeated for both UO₂ and gadolinia bearing fuel rods in each bundle type.

1. Determine the exposure dependent LHGR limit using linear interpolation between the table values in Appendix B.

NOTE

For Two recirculation Loop Operation (TLO) utilize steps 1, 2, 3, and 6 to determine the LCO LHGR limits.

When the Technical Specification 3.4.1.1 ACTION statement a.1.e is entered from that section's Limiting Condition for Operation (LCO), utilize steps 1, 4, 5, and 6 to determine the LCO LHGR limits for Single recirculation Loop Operation (SLO).

2. For the power dependent LHGR adjustment for TLO, determine a LHGRFAC_p value by linearly interpolating a LHGRFAC_p value as a function of rated core thermal power from the TLO entries in Table 4.3-1. Multiply the LHGR values obtained from Step 1 by the LHGRFAC_p value to determine the power dependent LHGR limit.
3. For the flow dependent LHGR adjustment for TLO, determine a LHGRFAC_f value by linearly interpolating a LHGRFAC_f value as a function of rated core flow from the TLO entries in Table 4.3-2. Multiply the LHGR values obtained from Step 1 by the LHGRFAC_f value to determine the flow dependent LHGR limit.
4. For the power dependent LHGR adjustment for SLO, determine a LHGRFAC_p value by linearly interpolating a LHGRFAC_p value as a function of rated core thermal power from the SLO entries in Table 4.3-1. Multiply the LHGR values obtained from Step 1 by the LHGRFAC_p value to determine the power dependent LHGR limit.
5. For the flow dependent LHGR adjustment for SLO, determine a LHGRFAC_f value by linearly interpolating a LHGRFAC_f value as a function of rated core flow from

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

the SLO entries in Table 4.3-2. Multiply the LHGR values obtained from Step 1 by the $LHGRFAC_f$ value to determine the flow dependent LHGR limit.

- Choose the most limiting (lowest value) of the power and flow dependent LHGR limits determined in Steps 2 and 3 (TLO) or 4 and 5 (SLO) as the value for the LHGR limit for the Limiting Condition for Operation.

TABLE 4.3-1 Power Dependent Linear Heat Generation Rate Multiplier ($LHGRFAC_p$)

Operating Condition	Core Thermal Power (% of Rated)		
	24	60.86	≥ 100
	LHGRFAC _p Multiplier		
TLO	0.603		1.000
SLO	0.603	0.796	

$LHGRFAC_p$ is linearly interpolated between core thermal power entries.

The $LHGRFAC_p$ multiplier is the same for both GE14 and GE14i ITAs.

TLO = Two Recirculation Loop Operation

SLO = Single Recirculation Loop Operation

TABLE 4.3-2 Flow Dependent Linear Heat Generation Rate Multiplier ($LHGRFAC_f$)

Operating Condition	Core Flow (% of Rated)					
	30	50	52.7	60	82.2	105
	LHGRFAC _f Multiplier					
TLO	0.500	0.782			1.000	1.000
SLO	0.500	0.782	0.800	0.800		

$LHGRFAC_f$ is linearly interpolated between core flow entries.

The $LHGRFAC_f$ multiplier is the same for both GE14 and GE14i ITAs.

TLO = Two Recirculation Loop Operation

SLO = Single Recirculation Loop Operation

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

4.4 OPRM Setpoints

4.4.1 1.0 Hz Corner Frequency Setpoints

LIMITING CONDITION FOR OPERATION

Four channels of the OPRM instrumentation shall be OPERABLE. Each OPRM channel period based algorithm amplitude trip setpoint (Sp) shall be less than or equal to the Allowable Value of 1.11.

Additional Information

The NRC Safety Evaluation Report, dated 12/22/04, which was issued for Technical Specification Amendment Number 159 required that the period based algorithm amplitude trip setpoint and confirmation counts be documented in the COLR. Confirmation count information applicable to Cycle 17 is documented below.

For $Sp = 1.11$, the required minimum number of successive confirmation counts for OPRM setpoint ($N2$) = 14.

Appendix A: Method of Core Average Scram Speed Calculation

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

Method of Core Average Scram Speed, τ , Calculation

τ is defined as
$$\tau = \frac{(\tau_{ave} - \tau_B)}{\tau_A - \tau_B}$$

where:
$$\tau_B = 0.672 + 1.65 \left[\frac{N_1}{\sum_{i=1}^n N_i} \right]^{1/2} \quad (0.016)$$

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i}$$

$\tau_A = 0.86$ seconds, control rod average scram insertion time limit to notch 39 per Specification 3.1.3.3

n = number of surveillance tests performed to date in cycle,

N_i = number of active control rods measured in the i th surveillance test,

τ_i = average scram time to notch 39 of all rods measured in the i th surveillance test, and

N_1 = total number of active rods measured in Specification 4.1.3.2.a.

If $\tau_{ave} \leq \tau_B$, set $\tau = 0$ to apply Option B OLM CPR.

τ shall be 1.0 ($\tau = 1.0$) prior to performance of the initial scram time measurements for the cycle in accordance with Specification 4.1.3.2.

NOTE

After implementation of Amendment Number 183 (Reference 10) to Facility Operating License Number NPF-57 for Hope Creek Generating Station, the equations for determining τ_{ave} , τ_b , and τ remain the same. However, the following changes for the terms in determination of τ should be made:

$\tau_A = 0.86$ seconds, control rod scram insertion time limit to notch 39 per Specification 3.1.3.3

N_1 = total number of active rods measured in Specification 4.1.3.3.a or 4.1.3.3.d.

τ shall be 1.0 ($\tau = 1.0$) prior to performance of the initial scram time measurements for the cycle in accordance with Specification 4.1.3.3.

Appendix B: Exposure-Dependent Linear Heat Generation Rate Limits

Exposure-Dependent Linear Heat Generation Rate Limits

The LHGR limits for all fuel and rod types are considered proprietary information of the vendor. Tables B-1 through B-6 contain exposure-dependent LHGR limits. The tables are presented in pairs since the LHGR limits are presented at separate peak pellet exposures for UO₂ and gadolinia bearing fuel rods. Several of the bundle types have the same exposure-dependent LHGR limits, and the applicable bundle types are noted before each set of tables. The gadolinia fuel rod limits provided for each bundle type reflect the bounding gadolinia LHGR limit for all gadolinium concentrations occurring in that bundle type.

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

Tables B-1 and B-2 contain limits applicable to the GE14 bundle types that follow.

- GE14-P10CNAB400-9G6.0/6G4.0-100T-150-T6-3176
- GE14-P10CNAB400-14GZ-100T-150-T6-3006
- GE14-P10CNAB402-12G6.0/2G4.0-100T-150-T6-3312
- GE14-P10CNAB405-6G6.0/11G4.0-100T-150-T6-3313
- GE14-P10CNAB402-5G6.0/14G4.0-100T-150-T6-2758
- GE14-P10CNAB396-17GZ-100T-150-T6-3007
- GE14-P10CNAB405-15GZ-100T-150-T6-3009
- GE14-P10CNAB398-17GZ-100T-150-T6-3008

TABLE B-1: GE14 LHGR Limits – UO₂ Fuel Rods

Peak Pellet Exposure		UO ₂ LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

TABLE B-2: GE14 LHGR Limits – Gadolinia Bearing Rods

Peak Pellet Exposure		Most Limiting Gadolinia LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

Tables B-3 and B-4 contain limits applicable to the GE14 bundle types that follow.

- GE14-P10CNAB393-18G4.0-100T-150-T6-2885
- GE14-P10CNAB393-18GZ-100T-150-T6-2884

TABLE B-3: GE14 LHGR Limits – UO₂ Fuel Rods

Peak Pellet Exposure		UO ₂ LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

TABLE B-4: GE14 LHGR Limits – Gadolinia Bearing Rods

Peak Pellet Exposure		Most Limiting Gadolinia LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

Tables B-5 and B-6 contain limits applicable to the GE14i ITA bundle type that follows.

- GE14I-P10CCOB379-13GZ-100T-150-T6-3309

TABLE B-5: GE14i ITA LHGR Limits – UO₂ Fuel Rods

Peak Pellet Exposure		UO ₂ LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

TABLE B-6: GE14i ITA LHGR Limits – Gadolinia Bearing Rods

Peak Pellet Exposure		Most Limiting Gadolinia LHGR Limit
MWd/MTU	MWd/STU	kW/ft
[[
]]

Appendix C: Backup Stability Protection

COLR HOPE CREEK 1 Rev 4 (Cycle 17)

Backup Stability Protection Region Intercepts

The region boundaries for Tables C-1 and C-2 are defined using the Generic Shape Function. The endpoints given in Table C-1 below were provided in Revision 3 to the Core Operating Limits Report for Cycle 16 as the bounding values for that cycle (Reference 11). Table C-2 values reflect the cycle-specific BSP region intercepts determined for Cycle 17 (Reference 6).

The BSP Region 1 and Region 2 endpoints for Cycle 17 given in Table C-2 are bounded by the region endpoints provided in Table C-1.

TABLE C-1: BSP Region Intercepts for Cycle 16

Region Boundary Intercept	% Power	% Flow
Region 1 High Flow Control Line	62.8	45.5
Region 1 Natural Circulation Line	44.7	35.0
Region 2 High Flow Control Line	67.2	51.1
Region 2 Natural Circulation Line	32.2	36.3

TABLE C-2: BSP Region Intercepts for Cycle 17

Region Boundary Intercept	% Power	% Flow
Region 1 High Flow Control Line	58.2	40.0
Region 1 Natural Circulation Line	44.7	35.0
Region 2 High Flow Control Line	66.4	50.0
Region 2 Natural Circulation Line	32.2	36.3

Region 1 = BSP Scram Region
Region 2 = BSP Controlled Entry Region