DiabloCanyonNPEm Resource

From: Tan, Miranda [M1TF@pge.com]
Sent: Tuesday, November 09, 2010 8:05 PM
To: Pick, Greg
Cc: Grebel, Terence
Subject: SAPN 50341879 (Regulator Material)

Importance: High

Greg,

I've updated the notification indicating that we will perform the walkdown and update the LRA to reflect the correct material as part of the annual update. SAP must be down. I am not able to download the notification to email to you this afternoon. However, I will email you the updated notification tomorrow morning.

Thanks,
Miranda
805 781 9415

****

09/20/2010 14:34:18 Jana M. Orlando (JMSO) Phone 805/545-3126
09/16/2010 14:46:12 Philippe R. Soenen (PNS3) Phone 805/781-9782
During a license renewal regional inspection walkdown the material type for the Unit 2 AIR-I-I-1231A regulator was questions when compared to what SAP identifies the material to be. SAP identifies this component to be made of aluminum whereas the walkdown identified this component to be some type of copper alloy.

The component material needs to be verified int he field and SAP should be revised as necessary to reflect the actual material type. The license renewal application and the basis documents need to be revised as appropriate to reflect the correct material type.

There is no operability or functinal concern with this component it is only a documentation clarification.
09/20/2010 14:34:13 Jana M. Orlando (JMSO) Phone 805/545-3126
The issue/event documented on this notification was reviewed by the Notification Review Team (NRT) and determined to be the indicated significance level per OM7.ID1, Attachment 1, Category 18.1. If additional information is discovered that would affect the significance level determination, contact a member of the NRT or e-mail DCPP NRT Members.

.
DN closed to DA.
.
11/09/2010 16:44:51 Miranda Tan (M1TF)
Walkdown will be performed to verify component material for both Unit 1 and Unit 2. The license renewal application will be updated to reflect the correct material type as part of the annual update.

Hearing Identifier: DiabloCanyon_LicenseRenewal_NonPublic
Email Number: 2154

Mail Envelope Properties (D065043718A59C4B99DDA1862BB067DE01BA244D)

Subject: SAPN 50341879 (Regulator Material)
Sent Date: 11/9/2010 8:05:03 PM
Received Date: 11/9/2010 8:05:15 PM
From: Tan, Miranda

Created By: M1TF@pge.com

Recipients:
"Grebel, Terence" <TLG1@pge.com>
Tracking Status: None
"Pick, Greg" <Greg.Pick@nrc.gov>
Tracking Status: None

Post Office: exchange12.Utility.pge.com

Files	**Size**	**Date & Time**
MESSAGE	1906	11/9/2010 8:05:15 PM

Options
Priority: High
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: