

Parks, Jazel

From: Lin, Bruce
Sent: Wednesday, April 28, 2010 10:55 AM
To: Lorette, Phillip
Cc: Burke, John
Subject: FW: Revision to Rg 1.54

Phil,

Can you set this up for tomorrow. John and I are available any time.

Bruce

-----Original Message-----

From: Case, Michael
Sent: Tuesday, April 27, 2010 7:06 AM
To: Burke, John
Cc: Lin, Bruce; Richards, Stuart
Subject: RE: Revision to Rg 1.54

Let's see if Bruce, Stu, you and I can get together on Thursday...

-----Original Message-----

From: Burke, John
Sent: Monday, April 26, 2010 1:39 PM
To: Case, Michael
Subject: RE: Revision to Rg 1.54

I'll be back on Thursday, or you can tell Bruce.

John

From: Case, Michael
Sent: Monday, April 26, 2010 7:45 AM
To: Burke, John
Subject: RE: Revision to Rg 1.54

Hi John. Brian has some comments that I need to share with you.

From: Burke, John
Sent: Thursday, April 22, 2010 1:04 PM
To: Case, Michael
Subject: FW: Revision to Rg 1.54

We're going to add the two lines in Red to the RG 1.54 Section 4

4. Maintenance of Coatings

ASTM D 5163-08, "Standard Guide for Establishing a Program for Condition Assessment of Coating Service Level I Coating Systems in Nuclear Power Plants" (Ref. 17), provides guidelines that the NRC staff finds acceptable for establishing an in-service coating monitoring program for Service Level I coating systems in operating NPPs and for Service Level II and other areas outside containment (as applicable).

An acceptable condition assessment program would be performed with qualified personnel and at a periodicity that would be able to detect potential coating degradation, and then implement repairs, before such degradation would adversely impact post-accident safety systems.

Degraded coatings identified during these condition assessments should be evaluated for impact on post-accident safety systems in accordance with draft RG 1.82 Revision 4 (DG 1234), and applicable licensing bases documents as discussed in Section 4.3.

John Burke, PE
Senior Engineer
(301) 251-7628
john.burke@nrc.gov

From: Yoder, Matthew
Sent: Tuesday, March 30, 2010 12:18 PM
To: Burke, John
Subject: RE: Revision to Rg 1.54

looks good to me

From: Burke, John
Sent: Tuesday, March 30, 2010 11:28 AM
To: Yoder, Matthew
Subject: Revision to Rg 1.54

Based on last weeks meeting I agreed to take a stab at cross referencing the two RGs. In RG 1.54 under the section D5163 I propose adding the sentence in Red.

4. Maintenance of Coatings

ASTM D 5163-08, "Standard Guide for Establishing a Program for Condition Assessment of Coating Service Level I Coating Systems in Nuclear Power Plants" (Ref. 17), provides guidelines that the NRC staff finds acceptable for establishing an in-service coating monitoring program for Service Level I coating systems in operating NPPs and for Service Level II and other areas outside containment (as applicable).

Degraded coatings identified during these condition assessments should be evaluated for impact on ECCS suction strainers in accordance with draft RG 1.82 Revision 4 (DG 1234) and applicable licensing bases documents and as discussed in Section 4.3.

John Burke, PE
Senior Engineer
(301) 251-7628
john.burke@nrc.gov