

RS-10-204

10 CFR 50.55a

November 24, 2010

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Clinton Power Station, Unit 1  
Facility Operating License No. NPF-62  
NRC Docket No. 50-461

Subject: Withdrawal of Request for NRC Approval to Use ASME Code Case N-513-2

- References:
- (1) Letter from J. L. Hansen (Exelon Generation Company, LLC) to U. S. NRC, "Third Inservice Inspection Interval Relief Request No. I3R-06 Related to Use of Code Case N-513-2," dated July 13, 2010
  - (2) NRC Regulatory Guide 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1," Revision 16, dated October 2010

In Reference 1, Exelon Generation Company, LLC (EGC) requested NRC approval to use American Society of Mechanical Engineers (ASME) Section XI Code Case N-513-2, "Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 and 3 Piping," in accordance with 10 CFR 50.55a(a)(3)(i) during the Third 10-Year Inservice Inspection (ISI) program interval at Clinton Power Station, Unit 1.

In October 2010, the NRC conditionally accepted the use of ASME Section XI, Division 1, Code Case N-513-3, "Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping, Section XI, Division 1," as documented in Reference 2. Consequently, EGC hereby withdraws the Reference 1 request.

There are no regulatory commitments contained in this letter. Should you have any questions concerning this letter, please contact Mr. Mitchel A. Mathews at (630) 657-2819.

Respectfully,



Jeffrey L. Hansen  
Manager – Licensing and Regulatory Affairs