

Parks, Jazel

From: Burke, John
Sent: Thursday, May 06, 2010 2:15 PM
To: Lin, Bruce
Subject: RE: comments Reg guide 1.54 rev 2

ANSI N45.2.6 is the typical QC inspector. I think I have a copy

John Burke, PE
Senior Engineer
(301) 251-7628
john.burke@nrc.gov

From: Lin, Bruce
Sent: Thursday, May 06, 2010 2:13 PM
To: Burke, John
Subject: RE: comments Reg guide 1.54 rev 2

I am familiar with NACE Level III. What is ASNI?

From: Burke, John
Sent: Monday, March 22, 2010 3:43 PM
To: Lin, Bruce
Subject: FW: comments Reg guide 1.54 rev 2

Some public comments on RG 1.54

John Burke, PE
Senior Engineer
(301) 251-7628
john.burke@nrc.gov

From: Dolderer, Garth [<mailto:Garth.Dolderer@fpl.com>]
Sent: Monday, March 22, 2010 1:25 PM
To: Burke, John
Cc: (b)(7)(C) *Ex. 6*
Subject: comments Reg guide 1.54 rev 2

I have reviewed the Reg Guide 1.54 rev 2 and have the following comments:

The ERPI guideline rev 2 for nuclear coatings which is now a public document should be incorporated as the guidance document for meeting the intent of this reg guide.

Containment coating inspections should be completed by an ASNI level III or equal inspector and or the NCS. Since the inspections are visual until a defect is detected the level of experience should be elevated to ensure compliance.

Garth Dolderer
(b)(6)

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions
FOIA *[Signature]*