



PLAN AT EL. 120'-0"
SCALE: 1/4" = 1'-0"

PLAN AT EL. 67'-6"
SCALE: 1/4" = 1'-0"

SECTION "B-B"
SCALE: 1" = 1'-0"

SECTION "G-G"
SCALE: 1 1/2" = 1'-0"

SECTION "D-D"
SCALE: 3" = 1'-0"

SECTION "C-C"
SCALE: 1/2" = 1'-0"

SECTION "A-A"
SCALE: 1/4" = 1'-0"

SECTION "J-J"
N.T.S.

SECTION "E-E"
SCALE: 3" = 1'-0"

PLAN AT EL. 54'-9"
N.T.S.

- NOTES:**
1. ALL TUBING IS 5/8" O.D. X .035" WALL, 304 STN. STEEL, EXCEPT AS NOTED.
 2. ALL HORIZONTAL RUNS ARE SLOPED 1"/FT. MIN. EXCEPT AS NOTED.
 3. ALL BENDS ARE 12" RADIUS MIN.
 4. INTERMEDIATE TUBE FITTINGS ARE SWAGelok #1010-6-316.

REFERENCE DRAWING:
9321-F-60030 TUBING SUPPORT ALLOWABLE SPANS (CHARTS A & 2)

ISI LEGEND
C.I.V. - CONTAINMENT ISOLATION VALVE

INFORMATION ONLY

DWN	CHK'D	INDIAN POINT NO.3 NUCLEAR POWER PLANT	
DES SUPV			
DISCIPLINE ENG			
DISCIPLINE MGR			
PROJ APPROVAL			
DATE			
		SCALE: AS NOTED	REV
		DWG NO	0
		ISI-70453	
		SHEET	0

REV NO	DATE	DESCRIPTION	BY	CHK	DES	APP	PROJ MGR
0	11/23	UPDATED TO 9321-F-70453, REV. 19.					

Sheet # 50-286
Approved: 9/11/70 210
Date: 11/23/73
Regulatory Docket File

SCALE: 1/4" = 1'-0"
 DRAWING NO: 9321-F-70453
 SHEET NO: 0
 DATE: 11/23/73
 PROJECT: INDIAN POINT NO. 3 NUCLEAR POWER PLANT
 DISCIPLINE: RADIATION MONITORING
 DRAWN BY: [Name]
 CHECKED BY: [Name]
 DESIGNED BY: [Name]
 APPROVED BY: [Name]