



- NOTES:**
1. (X) - PENETRATION NUMBER (REF. F.S.A.R.)
 2. THIS DWG. SHALL BE USED ONLY FOR DETERMINING THE EXTENT OF THE INSERVICE INSPECTION BOUNDARIES.
 3. BOUNDARIES SHOWN TO INCLUDE BOUNDARY VALVES WHERE APPROPRIATE, THE ACTUAL PRESSURE RETAINING I.S.I. BOUNDARIES FOR LEAKAGE AND HYDROSTATIC TESTING EXTEND ONLY TO VALVE INTERNALS THAT COMPRISE THE EFFECTIVE OBSTACLES ASSEMBLY.

INFORMATION ONLY

ISI LEGEND
 --1-- ISI CLASS I
 --2-- ISI CLASS II
 --3-- ISI CLASS III
 C.I.V. - CONTAINMENT ISOLATION VALVE

SI APERTURE CARD

Docket # 50-286
 Accession # 931110210
 Date 11/9/93 of Ltr
 Regulatory Docket File

REV NO	DATE	DESCRIPTION	BY	CHKD	APP'D
4	11/9/93	UPDATED TO 9321-F-27193, SH. 2, REV. 3 THRU 6.	PH	MH	JMI
3	11/9/93	UPDATED TO 9321-F-27193, SH. 2, REV. 2.	PH	DS	DS

DESIGNER	INDIAN POINT NO. 3 NUCLEAR POWER PLANT
DISCIPLINE ENG	
DISCIPLINE DIR	
PROJ APPROVAL	
DATE	
FLOW DIAGRAM WASTE DISPOSAL SYSTEM SHEET NO. 2-PAB	
New York Power Authority	
SCALE NONE	REV 4
DWG NO ISI-27193	SHEET 2