



South Texas Project Electric Generating Station 4000 Avenue F – Suite A Bay City, Texas 77414

November 22, 2010  
U7-C-STP-NRC-100252

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
One White Flint North  
11555 Rockville Pike  
Rockville MD 20852-2738

South Texas Project  
Units 3 and 4  
Docket Nos. 52-012 and 52-013  
Response to Request for Additional Information

Reference: Letter, Scott Head to Document Control Desk, "Response to Request for Additional Information," dated May 4, 2010, U7-C-STP-NRC-100103.

This letter supplements the previous response to Request for Additional Information (RAI) 19-31 provided in the Reference. Attachment 1 to this letter addresses the following RAI:

19-31, Supplemental Response

When a change to the COLA is indicated, it will be incorporated into the next routine revision of the COLA following NRC acceptance of the RAI response.

With this Supplemental Response, COM 19.9-4, Action 2, to establish HCLPF values for site-specific SSCs whose failure may affect the plant response to seismic events and which are not included in the analyses described in Appendix 19H, is complete. A summary of remaining commitments is attached.

If you have any questions regarding this submittal, please contact me at (361) 972-7136, or Bill Mookhoek at (361) 972-7274.

STI 32789023

D 091  
NRD

I declare under penalty of perjury that the foregoing is true and correct.

Executed on 11/22/10



Scott Head  
Manager, Regulatory Affairs  
South Texas Project Units 3 & 4

dws

Attachments:

1. RAI 19-31, Supplemental Response
2. Summary of Commitment 19.9-4

cc: w/o attachment except\*

(paper copy)

Director, Office of New Reactors  
U. S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852-2738

Regional Administrator, Region IV  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Kathy C. Perkins, RN, MBA  
Assistant Commissioner  
Division for Regulatory Services  
Texas Department of State Health Services  
P. O. Box 149347  
Austin, Texas 78714-9347

Alice Hamilton Rogers, P.E.  
Inspection Unit Manager  
Texas Department of State Health Services  
P. O. Box 149347  
Austin, Texas 78714-9347

\*Steven P. Frantz, Esquire  
A. H. Gutterman, Esquire  
Morgan, Lewis & Bockius LLP  
1111 Pennsylvania Ave. NW  
Washington D.C. 20004

\*Rocky Foster  
Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852

(electronic copy)

\*George F. Wunder

\* Rocky Foster

U. S. Nuclear Regulatory Commission

Steve Winn

Joseph Kiwak

Eli Smith

Nuclear Innovation North America

Peter G. Nemeth

Crain, Caton & James, P.C.

Richard Peña

Kevin Pollo

L. D. Blaylock

CPS Energy

**RAI 19-31, Supplement 1****QUESTION:**

In accordance with the ABWR DCD COL License Information Item 19.9.4, the applicant is required to evaluate the HCLPF capacities of standard plant and site-specific SSCs for updating the PRA. The staff requests that the applicant confirm that this COL License Information Item includes an update of the system model (seismic accident sequences) developed in DCD to incorporate capacity reductions due to site-specific effects (soil liquefaction, slope failure, etc.) and site-specific SSC (Ultimate Heat Sink (UHS), Service Water System (RSW) including Pumphouse, Cooling Tower and Water Reservoir), and determines whether site-specific soil failures control the seismic HCLPF capacities of SSCs associated with the seismic accident sequences. Based on the result of the update, the applicant is requested to demonstrate the sequence- and plant-level seismic HCLPF capacity. The staff needs this information to ensure that the STP's PRA-Based Seismic Margin Analysis complies with pertinent requirements of 10 CFR 52.79(a)(46) and 10 CFR 52.79(d)(1).

**SUPPLEMENTAL RESPONSE:**

The original response to this RAI, which was sent with Letter U7-C-STP-NRC-100103 dated May 4, 2010, committed that the High-Confidence Low Probability of Failure (HCLPF) values for site-specific SSCs (UHS/Pump House/Cooling Tower structure, RSW Piping Tunnel, Diesel Generator Oil Storage Vault and Cooling Tower fans) whose failure may affect the plant response to seismic events and which are not included in the analyses described in Appendix 19H will be established. This supplemental response provides that information.

In accordance with the DC/COL-ISG-20 (Interim Staff Guidance on Implementation of a Probabilistic Risk Assessment-Based Seismic Margin Analysis for New Reactors), HCLPF values were determined using the Conservative Deterministic Failure Margin (CDFM) approach used for seismic margin studies.

The CDFM approach is summarized in the EPRI NP-6041-SL report (A methodology for Assessment of Nuclear Power Plant Seismic Margin, Revision 1, August 1991). The approach taken for deriving the HCLPF values is consistent with the methods described in EPRI NP-6041-SL. The HCLPF values for the above listed SSCs are summarized in the Table below.

Site-specific SSC	Governing Failure Mode	Governing HCLPF	Ratio to GMRS PGA
UHS/Pump House/Cooling Tower Structure	Structural failure	0.20 g	2.0
RSW Piping Tunnel	Stability (Overturning)	0.22 g	2.2
Diesel Generator Fuel Oil Storage Vault	Stability (Sliding)	0.26g	2.65
Service Water Cooling Fans	Functional Failure During the Earthquake	0.20 g	2.0

As can be seen from the above table, the requirement specified in ISG-20 that the HCLPF value be equal to or greater than 1.67 times the site-specific Ground Motion Response Spectrum (GMRS) Peak Ground Acceleration (PGA=.098g, see COLA Part 2, Tier 2, Table 2.5S.2-21) is met.

COLA will be revised as shown below as a result of this response.

#### 19.9.4 Confirmation of Seismic Capacities Beyond the Plant Design Basis

The following standard supplement addresses COL License Information Item 19.4.

The High-Confidence Low Probability of Failure (HCLPF) values for site-specific SSCs (UHS/Pump House/Cooling Tower structure, RSW Piping Tunnel, Diesel Generator Oil Storage Vault and Cooling Tower fans) whose failure may affect the plant response to seismic events and which are not included in the analyses described in Appendix 19H have been established, see Table 19H-1a.

In accordance with the DC/COL-ISG-20 (Interim Staff Guidance on Implementation of a Probabilistic Risk Assessment-Based Seismic Margin Analysis for New Reactors), HCLPF values were determined using the Conservative Deterministic Failure Margin (CDFM) approach used for seismic margin studies.

The CDFM approach is summarized in the EPRI NP-6041-SL report (A methodology for Assessment of Nuclear Power Plant Seismic Margin, Revision 1, August 1991). The approach taken for deriving the HCLPF values is consistent with the methods described in EPRI NP-6041-SL.

The requirement specified in ISG-20 that the HCLPF value be equal to or greater than 1.67 times the site-specific Ground Motion Response Spectrum (GMRS) Peak Ground Acceleration (PGA=.098g, see Table 2.5S.2-21) is met for all the listed site-specific SSCs.

The following additional actions will be taken (COM 19.9-4) and the FSAR updated in accordance with 10 CFR 50.71(e) based upon the results of these analyses:

1. The High-Confidence Low Probability of Failure (HCLPF) values for the important plant-specific/as-built components corresponding to the generic components defined in Subsection 19H.4.3 shall be determined. The values will be compared to the assumed HCLPF values given in Tables 19H-1 or 19I-1. This will be completed prior to fuel load.

~~2. HCLPF values for site-specific SSCs (UHS/Pump House structure, Cooling Tower, RSW Piping Tunnel, and Diesel Generator Oil Storage Vault) whose failure may affect the plant response to seismic events and which are not included in the analyses described in Appendix 19H will be established. This will be completed by September 2010 and included in the COLA at the next scheduled update in accordance with 10 CFR 50.71(e) to incorporate these HCLPF values into Appendix 19H.~~

~~3.2.~~ The investigation for the potential for seismic induced soil failure at 1.67 times the **PGA** of the ~~GMRS site-specific SSE~~ will be completed prior to fuel load.

~~4.3.~~ The system model (seismic accident sequences) developed in the DCD will be updated to incorporate capacity reductions due to site-specific effects (soil liquefaction) and site-specific SSCs (Ultimate Heat Sink (UHS), including Reactor Service Water (RSW) Pumphouse, Cooling Tower, RSW Piping Tunnel, and Diesel Generator Oil Storage Vault). Then, it will be determined whether site-specific soil failures control the seismic HCLPF capacities of SSCs associated with the seismic accident sequences. Based on the result of the update, the sequence- and plant-level seismic HCLPF capacity will be determined. This activity will be completed prior to the fuel load.

~~5.4.~~ The remainder of the actions specified in Appendix 19H.5 will be completed prior to fuel load.

Add new Tables 19H-1a and 19I-1a as shown below.

**Table 19H-1a: HCLPF Values for Site-Specific SSCs**

Site-specific SSC	Governing Failure Mode	Governing HCLPF	Ratio to GMRS PGA
UHS/Pump House/Cooling Tower Structure	Structural failure	0.20 g	2.0
RSW Piping Tunnel	Stability (Overturning)	0.22 g	2.2
Diesel Generator Fuel Oil Storage Vault	Stability (Sliding)	0.26 g	2.65
Service Water Cooling Fans	Functional Failure During the Earthquake	0.20 g	2.0

**Table 19I-1a: HCLPF Values for Site-Specific Systems and Components**

<b>Site-specific SSC</b>	<b>Governing Failure Mode</b>	<b>Governing HCLPF</b>	<b>Ratio to GMRS PGA</b>
UHS/Pump House/Cooling Tower Structure	Structural failure	<b>0.20 g</b>	<b>2.0</b>
RSW Piping Tunnel	Stability (Overturning)	<b>0.22 g</b>	<b>2.2</b>
Diesel Generator Fuel Oil Storage Vault	Stability (Sliding)	<b>0.26 g</b>	<b>2.65</b>
Service Water Cooling Fans	Functional Failure During the Earthquake	<b>0.20 g</b>	<b>2.0</b>

**SUMMARY OF COMMITMENT COM 19.9-4**

The description of Action 2 and Action 3 is updated, and the status of Action 2 is taken to “Complete” in the following Summary of Commitment 19.9-4 table.

Commitment	Description	Completion Date
COM 19.9-4 CR 07-14004 Action 1	The High-Confidence Low Probability of Failure (HCLPF) values for the important plant-specific/as-built components corresponding to the generic components defined in Subsection 19H.4.3 shall be determined. The values will be compared to the assumed HCLPF values given in Tables 19H-1 or 19I-1	Prior to fuel load
COM 19.9-4 CR 07-14004 Action 2	HCLPF values for site-specific SSCs (UHS/Pump House structure, Cooling Tower structure, RSW Piping Tunnel, Diesel Generator Oil Storage Vault, and Cooling Tower Fans) whose failure may affect the plant response to seismic events and which are not included in the analyses described in Appendix 19H will be established	Complete
COM 19.9-4 CR 07-14004 Action 3	The investigation for the potential for seismic induced soil failure at 1.67 times the PGA of the GMRS.	Prior to fuel load
COM 19.9-4 CR 07-14004 Action 5	The system model (seismic accident sequences) developed in the DCD will be updated to incorporate capacity reductions due to site-specific effects (soil liquefaction) and site-specific SSCs (Ultimate Heat Sink (UHS), including Reactor Service Water (RSW) Pumphouse, Cooling Tower, RSW Piping Tunnel, and Diesel Generator Oil Storage Vault). Then, it will be determined whether site-specific soil failures control the seismic HCLPF capacities of SSCs associated with the seismic accident sequences. Based on the result of the update, the sequence- and plant-level seismic HCLPF capacity will be determined.	Prior to fuel load
COM 19.9-4 CR 07-14004 Action 4	The remainder of the actions specified in Appendix 19H.5.	Prior to fuel load