



- REFERENCE DWG'S
1. ON DWG. 737J224 SMT. 1 (4801-91801-WA)
 2. FOR PIPING & INSTRUMENT SYMBOLS SEE DWG. 0F0001 AND 0F0002.
 3. CT. 23973 MARCH, 1977 WESTINGHOUSE RECOMMENDATIONS TO MINIMIZE WATER DAMAGE TO STEAM TURBINES: (4803(17)-01409-WT)

- NOTES:
1. DELETED.
 2. THERMOCOUPLES TO BE OF THE CLAMP TYPE LOCATED 1 TO 2 FEET DOWN STREAM OF ASSOCIATED DRAIN VALVE. COMPUTER INPUTS TO BE RECORDED.
 3. ALL DRAIN PIPING SHOULD BE HORIZONTAL OR SLOPED DOWNWARD TO THE CONDENSER EXCEPT AS OTHERWISE AGREED TO DURING A CASE BY CASE REVIEW BETWEEN THE AFFECTED DISCIPLINES.
 4. ALL INSTRUMENTS ON THIS DIAGRAM HAVE SYSTEM DESIGNATOR MT UNLESS OTHERWISE NOTED.
 5. DRAIN MANIFOLDS TO HAVE MAXIMUM LENGTH OF 8 FEET.
 6. ALL INSTRUMENTS ON THIS DIAGRAM HAVE SEPARATION GROUP N UNLESS OTHERWISE NOTED.
 7. DELETED.
 8. DELETED.
 9. DELETED.

LR BOUNDARY DRAWING NO.	REV.
LR-STP-MD-6T169F00072#2	0A

SOUTH TEXAS PROJECT
NUCLEAR OPERATING COMPANY

PIPING & INSTRUMENTATION DIAGRAM
MAIN STEAM VENTS & DRAINS

NO.	ISSUE DATE	REVISION	ORIG	CKR	RE	DV	SE	NO.	ISSUE DATE	REVISION	ORIG	CKR	RE	DV	SE
15		INCORP. DCN 0200392													
14	11-9-92	ISSUED FOR CONSTRUCTION.	JCL												
			SIGNATURES ON FILE												

PRIORITY	CADD FILE NO.	FSUB. NO.	STI. NO.	SCALE	DWG. NO.	SHT.	REV.
1	FJA569.151	D070928		NONE	6T169F00072#2		15

ELECTRICAL