


- NOTE:**
- UNLESS OTHERWISE NOTED, THE UNIT 1 IS SHOWN ON THIS P & ID FOR APPLICATION OF THIS P & ID TO UNIT 2. USE UNIT 2 IDENTIFICATION NUMBERS FOR PIPING, VALVES, INSTRUMENTS, EQUIPMENT, ETC. REFER TO DRAWINGS 9A310F0001 AND 9A310F0002 FOR IDENTIFICATION NUMBER DETAILS.
 - DELETED.
 - ALL INSTRUMENTS ON THIS P & ID HAVE SYSTEM DESIGNATOR "DR".
 - ALL INSTRUMENTS ON THIS P & ID HAVE SEPARATION GROUP "N".
 - VALVES WITH SYSTEM DESIGNATOR "PD" WERE EXISTING PRIOR TO THE ASSIGNMENT OF THE SYSTEM DESIGNATOR "DR".
 - FLOOR DRAIN IS PROVIDED WITH CAP TO PREVENT WATER FROM DRAINING INTO THE AUXILIARY FEEDWATER PUMP ROOMS.

- REFERENCES:**
- FOR PIPING AND INSTRUMENTATION SYMBOLS, SEE DRAWINGS OF0001 AND OF0002.
 - FOR PLUMBING DETAILS SEE DRAWINGS 9B0175, 9B0176, AND 9B0177.

GREEN HIGHLIGHTED COMPONENTS ARE CREDITED FOR FIRE WATER REMOVAL PER 10 CFR 54.4(A)(1)(3) AND ARE NOT SAFETY-RELATED PER 10 CFR 54.4(A)(1)(1).

LR BOUNDARY DRAWING NO.	REV.
LR-STP-OW-9G069F10006#2	0

4		INCORP REVISION REPORT, SUPERSEDED BY DWG 9G069F10006 *19G069F10006 *2	SIGNATURES ON FILE																					
3		REVISED HEAT TRACING (REF DCAR 53)	SIGNATURES ON FILE																					
2		INCORP DCN #1	SIGNATURES ON FILE																					
1		GENERAL UPDATE	SIGNATURES ON FILE		N/A		N/A		6		INCORP DCN 1 & 2 AND ISSUED FOR CADD CONVERSION		SIGNATURES ON FILE											
0		ISSUED FOR CONSTRUCTION	SIGNATURES ON FILE		N/A		N/A		5		ISSUED FOR UNITIZATION, SUPERSEDING DWG 9G069F10006.		SIGNATURES ON FILE		2-11-87									
NO.	ISSUE DATE	REVISION	ORIG	CKR	RE	DV	SE	NO.	ISSUE DATE	REVISION	ORIG	CKR	RE	DV	SE	PRIORITY	CADD FILE NO.	FISUG. NO.	STJ. NO.	SCALE	DWG. NO.	SHT.	REV.	
		8						6		7						1	FJA047.071			NONE	9G069F10006 *2		6	



PIPING AND INSTRUMENTATION DIAGRAM ISOLATION VALVES CUBICLES BUILDING SUMP PUMP & DRAINS SYSTEM FOR OILY WASTE

1/25/84 02:26:08 TH

238