

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title:                   Advisory Committee on Reactor Safeguards  
                              Reliability and PRA Subcommittee

Docket Number:       (n/a)

Location:               Rockville, Maryland

Date:                    Tuesday, November 16, 2010

Work Order No.:       NRC-551

Pages 1-407

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
+ + + + +  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
(ACRS)  
RELIABILITY AND PRA SUBCOMMITTEE

+ + + + +  
TUESDAY,  
NOVEMBER 16, 2010

+ + + + +  
ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B1, 11545 Rockville Pike, Rockville, Maryland at  
8:30 a.m., John W. Stetkar, Chairman, presiding.

COMMITTEE MEMBERS PRESENT:

- JOHN W. STETKAR, Chairman
- SAID ABDEL-KHALIK, Member
- WILLIAM J. SHACK, Member

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

NRC STAFF PRESENT:

MARK CUNNINGHAM, NRR

DONALD HARRISON, NRR

ALEXANDER KLEIN, NRR

JOHN LAI

MARK SALLEY, RES

SUNIL WEERAKKODY, NRR

GIRIJA S. SHUKLA, Designated Federal Official

ALSO PRESENT:

TOM BASSO, NEI

BIFF BRADLEY, NEI

KEN CANAVAN, EPRI

JIM CHAPMAN, ScienTech

MARDY KAZARIANS, Kazarians & Associates

DOUG TRUE, ERIN Engineering

RICK WACHOWIAK, EPRI

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

## T-A-B-L-E O-F C-O-N-T-E-N-T-S

WELCOME/OPENING REMARKS:

John Stetkar, Chairman (ACRS) ..... 4

NEI (INDUSTRY) PRESENTATION:Fire PRA Impacts to NFPA 805 Transitions:

Biff Bradley, NEI ..... 11

Background on EPRI 1011989 & NUREG/CR-6850:

Ken Canavan, EPRI ..... 22

Industry Fire PRAs Insight:

Doug True, ERIN Engineering ..... 41

Roadmap for Attaining Realism in Fire PRAs:

Doug True, ERIN Engineering ..... 96

Fire Protection Related Methodological and Other  
Issues Impeding the Transition Process

Rick Wachowiak, EPRI ..... 176

Tom Basso, NEI ..... 201

Mark Cunningham, Staff ..... 221

Alex Klein, Staff ..... 222

Fire PRA Related Methodological and Other Issues  
Impeding the Transition Process

Donnie Harrison, NRR ..... 259

Fire PRA Research in Support of NFPA 805

Mark Salley, RES ..... 292

Concluding Remarks From NRR/RES Staff

Sunil Weerakkody, NRR ..... 364

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

T-A-B-L-E O-F C-O-N-T-E-N-T-S (cont.)

ACRS Fact-Finding Status

Mardy Kazarians, Kazarians & Associates ..... 383

Membership Discussion ..... 389

Adjournment ..... 407

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:33 a.m.

CHAIRMAN STETKAR: I guess we'll get started. The meeting will now come to order. This is a meeting of the Reliability and PRA Subcommittee. I'm John Stetkar, Chairman of the Subcommittee meeting.

ACRS Members in attendance, at the moment, are William Shack and Said Abdel-Khalik. Some other of our colleagues may join us later, depending on their availability, I guess.

Girija Shukla of the ACRS staff is the designated federal official for this meeting.

The purpose of this meeting is for the Subcommittee to review the current state of licensee efforts on the Fire Protection Program transition to NFPA 805. We will hear presentations from the nuclear industry and the NRC staff.

We have received written comments from the Union of Concerned Scientists addressing concerns from external stakeholders. We have received no requests for time to make oral statements from members of the public regarding today's sessions.

There will be an open phone bridge line. To preclude interruption of the meeting, the phone

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 will be placed in a listen in mode during the  
2 presentations and Committee discussions. I will open  
3 the phone line for comments from interested  
4 participants at some time before the close of the  
5 meeting, in case anyone wants to make a statement or  
6 add any additional information.

7 The entire meeting will be open to public  
8 attendance.

9 The Subcommittee will gather information,  
10 analyze relevant issues and facts and formulate  
11 proposed positions and actions, as appropriate, for  
12 deliberation by the Full Committee.

13 The rules for participation at today's  
14 meeting have been announced as part of the notice of  
15 this meeting, previously published in the Federal  
16 Register.

17 A transcript of the meeting is being kept  
18 and will be made available, as stated in the Federal  
19 Register notice.

20 Therefore, we request that participants in  
21 this meeting use the microphones located throughout  
22 the meeting room when addressing the Subcommittee.  
23 Participants should, first, identify themselves and  
24 speak with sufficient clarity and volume, so that they  
25 may be readily heard.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Before we get started, I would like to  
2 provide a little bit of background and context for why  
3 we are here and where we are going.

4           This effort, as probably most if not all  
5 of you in the room are aware, is derived from a Staff  
6 Requirement's Memo from the Commission dated June 25<sup>th</sup>  
7 of this year. And I would just like to summarize the  
8 statement in that memorandum, so that we are all clear  
9 on what, at least, our charter is.

10           And it says "The ACRS should conduct a  
11 review and report back to the Commission on the  
12 current state of licensee efforts to transition to  
13 National Fire Protection Association Standard 805.  
14 The review should include methodological and other  
15 issues that may be impeding the transition process,  
16 lessons learned from the Pilot Projects and  
17 recommendations to address any issues identified.

18           The review should determine whether the  
19 level of conservatism of the methodology is  
20 appropriate and whether any adjustment should be  
21 considered. The review should not influence the  
22 staff's actions regarding the Pilot Projects or the  
23 pending license amendment reviews."

24           So that's basically our marching orders.  
25 We have had some discussions among ourselves about the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 most effective way to respond to this SRM.

2 And, first and foremost, I think, one of  
3 our roles is to develop assurance that the technical  
4 information and the guidance methods that are  
5 available are sufficient to provide adequate assurance  
6 that, indeed, we are addressing safety issues in  
7 nuclear power plants and that the staff and the  
8 Commission has a reasonable technical basis for any  
9 regulatory decisions that they make.

10 So because of that thus far, and I think  
11 through the end of our interaction, at least right  
12 now, I'm trying to keep most of the discussions  
13 focused on technical issues, if possible. That  
14 doesn't mean that we can't discuss other programmatic  
15 issues. In fact, I'm very interested in hearing about  
16 those, but I would like, as much as possible, to keep  
17 our discussions focused on technical issues.

18 Internally, the process that we have  
19 established here is that we are, right now, in the,  
20 what I would call, information gathering phase of our  
21 activity. And this meeting and the report from our  
22 consultant, who we will hear from later -- by the way,  
23 for introductions, I forgot to introduce our  
24 consultant, who will be here, Dr. Mardy Kazarians is a  
25 consultant to the Subcommittee for the purposes of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this. We will be here. I have heard he is in the  
2 building, so we will see and hear from him later.

3 As I said, this Subcommittee meeting and  
4 Mardy Kazarians' report will effectively -- and what  
5 I'm calling this information gathering phase, during  
6 this phase, what we are trying to do is develop a  
7 sense of the technical issues that may be most  
8 difficult in terms of either a lack of adequate  
9 supporting information, lack of adequate guidance,  
10 perhaps methods that are still in a state of  
11 evolution, we're not sure.

12 We have had interactions with a number of  
13 stakeholders at the, what I would call, practitioner  
14 level. We will hear later from Dr. Kazarians about  
15 his efforts, but he has been out talking to people  
16 both on the staff and in industry at the level at  
17 which the analyses are being performed. So,  
18 essentially, people who are in the trenches doing the  
19 work to get a sense of where they feel their problems  
20 are, the primary issues that they are facing.

21 This Subcommittee meeting today provides  
22 a forum to hear perhaps some of the same information,  
23 perhaps a different perspective on some of the same  
24 information from both the staff and representatives  
25 from industry.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Going forward, we will take all of this  
2 information. Hopefully by the end of today, although  
3 I can't promise that, we may be able to identify a few  
4 key technical issues. I'm not sure whether we will be  
5 able to accomplish that today and we will talk a  
6 little bit more about that toward the end of the  
7 meeting when we talk about planning for the next  
8 Subcommittee meetings, which are currently scheduled  
9 for December 13<sup>th</sup> and 14<sup>th</sup>.

10           In those Subcommittee meetings, what we  
11 would like to do is to coalesce the information that  
12 we have gathered through this point in the process and  
13 have a reasonably focused technical discussion. In  
14 other words, bring forth the technical issues, any  
15 significant, let me call it that, programmatic issues  
16 that may be involved, make sure that we have a focused  
17 discussion about each of those, so that our  
18 Subcommittee understands -- make sure that we  
19 understand the issue, make sure there is no  
20 misunderstanding between perhaps our interpretation of  
21 what we might have been hearing and others.

22           And if at all possible, identify areas  
23 where there is some agreement that, indeed, a  
24 particular issue may be a thorny problem, what a path  
25 forward might be and try to close out those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 discussions at least in this open Subcommittee forum  
2 to provide the end of the input to our subcommittee.

3 Then what will happen then is our  
4 Subcommittee will write a report to the Full  
5 Committee, essentially, summarizing what we have  
6 learned. The Full Committee will receive the report  
7 probably some time in January. At our February Full  
8 Committee meeting, we, as a Full Committee, will  
9 deliberate on this matter and write a letter report to  
10 the Commission transmitting our findings, conclusions,  
11 recommendations, whatever they may be.

12 And that according to the SRM, that report  
13 is due by the end of February. So that's a bit of  
14 what we are doing, a bit of sort of the philosophy of  
15 the meetings, the time schedule and so forth.

16 We can talk a little bit more about the  
17 schedule and we probably should toward the end of the  
18 meeting. I think we have enough time allocated today  
19 to make sure that we aren't particularly rushed in the  
20 presentations. And I think it's important in terms of  
21 all of the participants' preparation for that, those  
22 December Subcommittee meetings, which I feel are  
23 rather important to our final conclusions, that we  
24 understand what the expectations are, basically.

25 And with that, I will turn it over to Biff

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Bradley.

2 MR. BRADLEY: Okay. Thanks, John. I  
3 appreciate the opportunity to be here today and  
4 discuss these issues with the Committee. And I hope  
5 we can have a productive meeting. Oh, can I get my  
6 slides up, please?

7 CHAIRMAN STETKAR: I have no idea.

8 MR. BRADLEY: Sure. Mouse.

9 CHAIRMAN STETKAR: Ken, move the mouse on  
10 the left.

11 MR. BRADLEY: Oh, there it is.

12 CHAIRMAN STETKAR: There we go.

13 MR. BRADLEY: It's in the folder 11/16.

14 MR. CANAVAN: All right, 11/16.

15 MR. BRADLEY: Got it.

16 CHAIRMAN STETKAR: Way over to the right.

17 MR. CANAVAN: Got it. All by itself.  
18 Which one is you?

19 MR. BRADLEY: Yes, second from the bottom  
20 on the right. Sorry, I didn't realize we had to do  
21 this on our own. You have heard about the budget  
22 cutbacks. The heat goes off in December.

23 CHAIRMAN STETKAR: Okay. I'll bring a  
24 coat to the next Subcommittee meeting.

25 MR. BRADLEY: Okay. Thanks. Ken, why

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't you advance the slide for me?

2 Okay. We do have a team here today to  
3 provide a whole series of presentations. And I don't  
4 want to take too much time, because we have a lot of  
5 technical information to get through today and I know  
6 the schedule can sometimes be a challenge for these  
7 meetings. So I'm going to just briefly set this up  
8 and overview the issue.

9 Ken Canavan of EPRI is going to provide  
10 some management level perspectives. EPRI was a co-  
11 author of NUREG/CR-6850 and is the lead on our  
12 industry effort to achieve improvements.

13 And then I think we are going to get to  
14 the meat of our presentation today. We have two of  
15 the primary consultants in the industry that have  
16 produced a large number of Fire PRAs over the last  
17 couple of years to support NFPA 805 implementation.

18 They have the benefit of insights from a  
19 large body of work they have performed. So we have  
20 moved beyond the pilot stage where we had a couple of  
21 plants. We now have 30 some plants worth of PRAs that  
22 are nearing completion and so we are able to get more  
23 robust insights on the methods.

24 So Doug True and Jim Chapman will be  
25 discussing those insights from the PRAs they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 performed. And then Doug will have a separate  
2 presentation on sort of your issue, John, which is  
3 what are the technical areas that are, from our  
4 perspective, driving the issues and sort of a roadmap  
5 for improvement.

6 And then Rick Wachowiak from EPRI will  
7 talk about the specific activities that industry has  
8 set up over the next couple of years to achieve  
9 improvements to Fire PRA methods.

10 And finally, last, but not least, Tom  
11 Basso from NEI, who is our project manager for 805  
12 implementation, is going to discuss there are some  
13 non-PRA issues that do have an impact. And we need to  
14 get some time to discuss those, so hopefully we don't  
15 squeeze Tom off the end of the agenda at the end of  
16 the morning.

17 Okay. So as a lot of us that have been  
18 around the industry for a long time know, fire  
19 protection has been a challenge for both the industry  
20 and the regulator, I think, going back at least 20  
21 years, at least with my experience. And we remain  
22 hopeful that NFPA 805 can provide a platform to  
23 achieve a closure of some of the longstanding issues,  
24 such as multiple spurious and operator manual actions.

25 We believe this does provide a better

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 safety-focused platform and ultimately can achieve  
2 improvements in both safety-focus and the regulatory  
3 approach.

4 A challenge we have now is achieving  
5 stability in this process. It is a very complex  
6 process. And Tom, who will speak further to this --  
7 but we are observing instabilities going from the  
8 first pilot to the second pilot already. So there is  
9 some concern that with a process this complex, we need  
10 to move toward a stable regulatory state.

11 Fire PRA is a part of that, but there are  
12 other issues as well that are driving that.

13 We do have about half the industry right  
14 now committed to adopt NFPA 805 50.48(c). I think a  
15 lot of the industry is looking at what is going on  
16 with both PRA regulatory stability pilot efforts and  
17 they are holding back on making a decision as to  
18 whether they want to move forward with 805. I don't  
19 anticipate seeing plants come forward, additional 805  
20 plants, until some of these issues are better  
21 clarified.

22 So today, we want to go through some of  
23 the Fire PRA issues as well as some of the other  
24 issues that we believe need some clarification and  
25 stability in order to achieve, I think what, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Commission's goal and our goal as well, would be to  
2 have widespread, you know, adoption of 805. So we  
3 have a mutual goal, so we need to figure out how to  
4 get there.

5 We have actually been discussing these  
6 Fire PRA issues for about nearly three years now.  
7 This was first identified when the quantification of  
8 the early pilot PRAs was nearing completion back in  
9 late 2007. We did provide an initial letter to NRC,  
10 to Mark Cunningham, in January of 2008 that actually  
11 did provide a list of, what we believed to be, some of  
12 the technical issues that were in need of improvement  
13 for Fire PRA.

14 And I think to compare what we had  
15 identified them to today, some of these issues remain.

16 So we have identified some new ones, but the basic  
17 substantive issues were realized three years ago. At  
18 that point, we did enter into a process with NRC to  
19 try to achieve some resolution in the near term to  
20 cause a large number of plants moving to 805 on an  
21 expedited schedule.

22 This was called the FAQ process and over a  
23 couple of years, there were a number of interactions.

24 There were about 15 of there FAQs relating to  
25 different areas of Fire PRA. The FAQ process extends

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 beyond Fire PRA. Most of the FAQs have to do with  
2 non-PRA elements in NFPA 805, but it was believed that  
3 that was a good process to extend over to the PRA side  
4 of the house as well.

5 I think to be honest, we have had some  
6 frustration in that process, in that it was -- we  
7 didn't believe that we were getting timely, effective  
8 technical process progress through those interactions.

9 There was some incremental improvements and we  
10 appreciate that that has occurred, but it is far from  
11 where we need to ultimately get to have realistic Fire  
12 PRA.

13 And late last year, starting in late 2009,  
14 there were no more Fire PRA-related FAQs submitted.

15 CHAIRMAN STETKAR: With this?

16 MR. BRADLEY: Yes.

17 CHAIRMAN STETKAR: If I could ask a  
18 leading question, that last bullet, is that because  
19 you are satisfied as an industry that you basically  
20 asked all the questions that need to be asked and you  
21 are simply waiting for resolution or are there other  
22 questions that you need to ask, but you've just given  
23 up?

24 MR. BRADLEY: It's the later. There are  
25 other issues that we need to bring before the process.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: I would hope, are we  
2 going to hear about some of those?

3 MR. BRADLEY: Yes.

4 CHAIRMAN STETKAR: Okay.

5 MR. BRADLEY: Some of our later  
6 presentations are going into more detail about that.

7 CHAIRMAN STETKAR: Good. Thank you.

8 MR. BRADLEY: Okay. Okay. Following  
9 actually a lot of our interactions through the FAQ  
10 process, we elevated the concern to the Commission  
11 level. We did provide a letter in December of last  
12 year to the Commission discussing our continued  
13 concerns and this was after much of the FAQ  
14 interactions had occurred and our belief that we still  
15 weren't achieving significant improvements to get us  
16 into the -- closer to the realm of realism.

17 And we also, at that time, provided to the  
18 Commission the initial version of our action matrix  
19 and that's industry's plan that Rick Wachowiak will be  
20 talking about later, with many, dozens of, activities  
21 to address many areas of Fire PRAs.

22 We are committed to improving Fire PRA.  
23 There are a lot of reasons besides NFPA 805. Fire PRA  
24 and many other risk applications where a good  
25 realistic Fire PRA would be a tremendous tool to have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and this includes everything from the oversight  
2 process to the maintenance rule to the risk-informed  
3 tech specs.

4 Our goal is to try to achieve, you know, a  
5 level of realism that is compatible with internal  
6 events. Some of our applications are trying to weigh  
7 internal events risk against fire risks, so we need to  
8 be careful that we proceed, you know, judiciously in  
9 those comparisons.

10 So we are going forward and you are going  
11 to hear a lot about our plan. And go ahead and  
12 advance the slide.

13 We are going to come back to this, but I  
14 just wanted to setup the major things we are going to  
15 tell you today. When you look at over 30 PRAs that  
16 have been performed in support of NFPA 805 and you  
17 start looking at some of the intermediate level  
18 results of those models, what we are finding is that  
19 the manner in which fires are characterized, that is  
20 the frequency of ignition, their growth rates, their  
21 heat release rates, when compounded together do not  
22 appear to conform with operating experience when  
23 compared to the actual types and numbers of fires that  
24 we are having.

25 Given that, it would appear that the level

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of quantified risk for damage frequency is overstated,  
2 as compared to operating experience. And we are going  
3 to show some comparisons on some CCDP and other  
4 metrics to provide some evidence of that.

5 We are concerned that the level of  
6 conservatism in fire PRA may or may not be level,  
7 even, and that we have got to be careful that these  
8 conservatisms aren't leading to incorrect decisions  
9 for plant modifications or other actions that fall out  
10 of NFPA 805.

11 I think there are some significant  
12 implications for the 805 submittals and these are --  
13 some of them are regulatory processes used that need  
14 to be considered. We are under an Enforcement  
15 Discretion timeline. There is a strong scheduler  
16 element with NFPA 805 and we have -- the indications  
17 are that the Oconee, the second pilot SE, will be  
18 issued this December, at which point we have a large  
19 number of plants, on the order of 25 plants, that  
20 would have submittals due six months after the  
21 issuance date of the Oconee SE.

22 We are concerned that our timeline to  
23 effect these PRA improvements is not compatible with  
24 the 805 schedule. We are concerned that plants, after  
25 submittal, will be able to make improvements to their

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 model that may obviate or change some of the  
2 commitments or other elements of the submittal that  
3 they have already put on the docket.

4           These submittals are over 1,000 pages  
5 long. There is a lot of work that goes into them and  
6 while it is theoretically possible to come back and  
7 redo your LAR on the basis of new information or  
8 better PRA results, it is extremely burdensome and we  
9 would like to think there is a more efficient and  
10 effective process to recognize that these PRA-based  
11 decisions may change going forward and some  
12 recognition of the need to have an open and reasonably  
13 efficient process to reconsider potential commitments  
14 made in your initial 805 submittal.

15           We do understand the Commission is under a  
16 lot of pressure on schedule on this. There is  
17 external pressure. We recognize that.

18           We did send a letter in just yesterday,  
19 which you may -- probably the Committee hasn't seen,  
20 but some of the staff has probably seen, suggesting  
21 that the idea of having 23 plants come in at the same  
22 time may not be the most efficient or effective way to  
23 pilot 805. Seeing as we have some disconnects between  
24 the first pilot and the second pilot, there appears to  
25 still be an evolving process here as well as the PRA

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issues.

2 So we are looking at -- we proposed a  
3 different, more along the lines of a license renewal,  
4 a sequential type of submittal schedule. The purpose  
5 for that wasn't really to address Fire PRA issues. It  
6 was more to allow for a more efficient review and  
7 structured review and better feedback from one plant  
8 to the next.

9 For plants that happen to be in the front  
10 of the queue, obviously, that wouldn't help, even if  
11 that was approved with a Fire PRA. But I did want you  
12 to be aware that we did send this letter in yesterday.

13 So that's all I really wanted to say today  
14 and I'm going to turn it over to Ken Canavan to pick  
15 up the next part of our presentation.

16 CHAIRMAN STETKAR: Bill?

17 MR. BRADLEY: Yes?

18 CHAIRMAN STETKAR: Before you close, you  
19 mentioned a couple of times, essentially, you  
20 mentioned, the term instabilities. You mentioned  
21 differences in terms of, I would call it perhaps,  
22 lessons learned between the two pilot projects. Are  
23 we going to hear some details about those? Because  
24 I'm pretty interested in that.

25 MR. BRADLEY: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: That's part my charter,  
2 you know, what lessons have we learned from the Pilot  
3 Projects? And we, I believe, I lose track of time, so  
4 don't quote me, some time in the last year had very  
5 brief presentations from both of the Pilot Projects,  
6 but they are a fairly high level, basically, to say  
7 where they were and what progress they were making and  
8 things like that.

9 MR. BRADLEY: Yes..

10 CHAIRMAN STETKAR: So I'm interested if  
11 there are distinct differences, things that, for  
12 example, Oconee had to redo or do differently because  
13 of what they learned, maybe didn't work the way Harris  
14 did it. That's something I'm pretty interested in.

15 MR. BRADLEY: Yes. The answer is yes.

16 CHAIRMAN STETKAR: Okay.

17 MR. BRADLEY: We will be discussing those.  
18 Tom Basso is here today to discuss some of those  
19 issues.

20 CHAIRMAN STETKAR: Okay. Thanks.

21 MR. CANAVAN: Well, good morning. For the  
22 record, I'm Ken Canavan, the Director of Plant  
23 Technology at EPRI. It's always a pleasure to be here  
24 and speak to you guys.

25 I'm a little bit more today about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 historical perspective. And you just heard NEI's  
2 perspective. I think I'll reiterate some of the same  
3 stuff, but I'll give you a little bit more of,  
4 hopefully, a technical slant on it and certainly a  
5 little bit more of a down-in-the-trench type of view  
6 of the last couple of years. It feels longer, I can  
7 say that.

8 Background on EPRI 1011989 and NUREG/CR-  
9 6850. Biff had mentioned this briefly and I actually  
10 thought he was going to use the word coconspirators  
11 there for a second and I don't think I would have  
12 objected.

13 The method was developed jointly between  
14 EPRI and NRC RES. The method outlined in EPRI 1011989  
15 and NUREG/CR-6850 really did succeed in providing a  
16 standard framework pulling together all the elements  
17 that we had learned in the IPE and making those inputs  
18 a little bit more consistent.

19 And in attempting to provide that standard  
20 framework, it, indeed, was an advance on how we were  
21 doing Fire PRAs. Now, I get asked a lot of times  
22 about Fire PRAs and, interestingly enough, I'm going  
23 to diverge for a second and say the word seismic PRAs.

24 The reason why we get into those discussions is we  
25 can do Fire PRAs now and we can do seismic PRAs now

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and we can do other PRAs, but they tend to be, what I  
2 like to refer to, as boutique or unique or one-off or  
3 not as consistent as they could be.

4 The methods are more of the IPEEE-type  
5 error and this was the first step away from those  
6 IPEEE methods. And it was, indeed, a successful first  
7 step.

8 CHAIRMAN STETKAR: Ken, since you are a  
9 coconspirator, and you characterize yourself --

10 MR. CANAVAN: I knew I shouldn't have said  
11 that.

12 CHAIRMAN STETKAR: -- as kind of a knuckle  
13 driving trench sort of guy, so you talked about  
14 standardization of framework and standardization of  
15 methods. I think some of the experience has shown us  
16 that fire risk, you mentioned seismic risk, also, some  
17 of these types of hazards and the evaluation of those  
18 hazards may differ tremendously from plant to plant.

19 Fire, in particular, because of the  
20 specific routing of cables, for example, the specific  
21 configuration of electrical cabinets in a given room  
22 that, although, two plants might be the same general  
23 vintage supplied by the same NSSS vendor, the  
24 architect engineer following whatever deterministic  
25 guidelines for routing cables, you could have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 completely different sources of risk at either of  
2 those plants.

3 I'm kind of interested in hearing people  
4 complain about the methods not being standard enough.

5 Is it that the methods are not as well-defined and so  
6 comprehensive that they can prejudge any possible  
7 condition that you might need at any particular plant,  
8 which is something that no methodology can ever do, or  
9 are there fundamental problems with methods that don't  
10 allow flexibility from plant to plant?

11 MR. CANAVAN: Well --

12 CHAIRMAN STETKAR: Yes, sir.

13 MR. CANAVAN: -- I think --

14 CHAIRMAN STETKAR: And you don't need to  
15 answer that now, but just sort of keep that in the  
16 back of your mind.

17 MR. CANAVAN: Okay.

18 CHAIRMAN STETKAR: Because when we talk  
19 about methods there --

20 MR. CANAVAN: I think you are on to  
21 something.

22 CHAIRMAN STETKAR: Okay.

23 MR. CANAVAN: I think the first step we  
24 took was get sort of a standard high-level framework.  
25 We will talk a little bit more about that in my

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 slides. We also got consistency of inputs. And my  
2 point all along has been as more of these plans come  
3 in, we had two pilots, we certainly didn't see  
4 everything we were going to say.

5 There is a question that you posed is are  
6 we going to see a lot of different things that we  
7 can't possibly cover? I would say no. But right now,  
8 we are covering those type of things at such a high  
9 level, that there is not enough guidance to  
10 effectively assess them. We will talk a little bit  
11 about how we just --

12 CHAIRMAN STETKAR: Okay.

13 MR. CANAVAN: -- already handled that.

14 CHAIRMAN STETKAR: Keep it a little bit,  
15 because it's something --

16 MR. CANAVAN: Sure.

17 CHAIRMAN STETKAR: -- that I have been  
18 curious about.

19 MR. CANAVAN: That's a good one. I like  
20 that.

21 I will point out, that from our  
22 perspective, one of the biggest things that we failed  
23 to do was obtain industry support and perform a full  
24 pilot. We took all the individual tests and we did  
25 it. There is a lot of reasons for that. I could give

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you them all. You know, people got into -- we had a  
2 few people volunteer that got into the effort and  
3 found out how much work it really was and said well,  
4 we really can't do this, lack of drive in the  
5 industry, at the time.

6 In other words, why do a Fire PRA? You  
7 know, this is a nice to do, not an I have to do.  
8 Nobody was committed to transitioning. So CR-68.50  
9 and EPRI 1011989 were not integrated. They didn't  
10 have integrated pilots. They had individual task  
11 pilots. And while that was useful for those  
12 individual tasks, as we can see later, there are some  
13 integrated issues that we stopped it from still today.

14 Okay. So Fire PRA is complex. IPEs were  
15 relatively inconsistent. They relied on judgment.  
16 They had a goal of identifying vulnerabilities. We  
17 are in a different world now. We are looking at a  
18 different application of this study or this type of  
19 work. Keep that in the back of your head.

20 And 68.50 and EPRI 1011989, they aim to  
21 address these failings, these issues of the IPEEE  
22 methods by defining discrete tasks, by applying  
23 simplifications and boundary conditions on the  
24 problem, so fire events were binned, heat release  
25 rates were binned, suppression and control was binned.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 They all were brought together with bins and then  
2 bounding assumptions were employed on the bins, which  
3 is exactly how you do simplified analysis.

4 It is the proper approach. It's the  
5 engineering approach. We use it in internal events  
6 all the time. We model a large LOCA in internal  
7 events. It is actually a range of LOCAs. It actually  
8 goes quite small. It's defined by the ability of the  
9 plant to depressurize. So it's a pretty big range.  
10 We take that big range and then we apply the maximum  
11 success criteria, which represents the double-  
12 guillotine ended break.

13 Now, the beauty of that is we do that even  
14 today in our studies. It doesn't contribute for a  
15 variety of reasons. One is the risk of having the  
16 double-guillotine ended break, as well as large LOCAs  
17 are rare.

18 Number two is there are other things that  
19 contribute that are much higher. And so this doesn't  
20 tend to get a lot of attention, but when those  
21 bounding conditions start affecting how we are going  
22 to do our study or how we are going to interpret the  
23 results, that's when those bounding conditions and  
24 simplifications start becoming important.

25 And as we are going to hear through today,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through a lot of other presentations, I'm sure you are  
2 going to hear from us and perhaps even from the staff,  
3 is that there is an awful lot of these in the area of  
4 fire risk. That's one of the challenges. This isn't  
5 one thing that is contributing. We can't go after one  
6 item.

7           There is a bunch of different  
8 simplifications that come together in different ways  
9 in the studies that make it more challenging. So it's  
10 one thing to go after. Let's just go fix the large  
11 LOCA and life will be great or let's sharpen our  
12 pencils and analyze loss of off-site power a little  
13 better and we'll reduce the risk by 60 percent.

14           There is actually a whole bunch of little  
15 places to go and when you see later the matrix that  
16 Rick Wachowiak puts up, you will see all those areas.

17           Okay. Our perspective on frequently asked  
18 questions, I want to be careful here. We had 15 Fire  
19 PRA-related FAQs that were submitted after the NEI  
20 letter and that's about -- so you might hear slightly  
21 different numbers.

22           Very recently EPRI, I hate to do this to  
23 you guys again, 1019250 or NUREG/CR-6850 Supplement 1  
24 was very recently published. That contains the FAQs.

25       Each FAQ did, indeed, improve the technical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 understanding of the issues that it talked about. And  
2 most of those FAQs individually produced the risk  
3 reduction.

4 I will also point out that every one of  
5 those FAQs is currently in the Action Plan Matrix  
6 still, which means it wasn't completed. So they were  
7 good first steps. If you look in the front of the  
8 Supplement 1, you will find that there is a paragraph  
9 in there that says they are good first steps. And a  
10 lot of them are long-term research items.

11 Now, I want to draw a very big distinction  
12 between very early frequently asked questions, which  
13 were appropriate. They were frequently asked  
14 questions that turned around and said, I would like an  
15 interpretation on this piece of text in 6850 or EPRI  
16 1011989 and those were the right uses of FAQs,  
17 frequently asked questions.

18 Later frequently asked questions,  
19 especially these 15, became this method is missing  
20 from the analysis and I would like to ask a brief  
21 question that resulted in a 100 page response. A 100  
22 page response that contains technical details is not a  
23 frequently asked question, it's a research project.

24 And so I personally believe that the  
25 frequently asked question process suffered from any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 problems, mostly that it was the wrong tool for what  
2 we were trying to do. When it was used right, it  
3 seemed to work well. When we started asking it  
4 questions like, you know, define new methods for X, it  
5 didn't really work well, because it's a research  
6 project and wasn't really given to the frequently  
7 asked question process.

8 What ended up happening is the frequently  
9 asked question process, being the wrong process, was  
10 extremely slow and extremely ineffective at getting  
11 those answers. And basically, it missed its mission  
12 of establishing the realistic Fire PRA methods.

13 CHAIRMAN STETKAR: You mentioned slow and  
14 ineffective. I'm interested in effective. My  
15 experience has been as soon as you talk about  
16 something being a research project, it transitions  
17 from being slow to being geologic. So getting an  
18 answer within a year or so from a frequently asked  
19 question is better than embarking on a multi-year  
20 research project.

21 MR. CANAVAN: Here is --

22 CHAIRMAN STETKAR: Ineffective I'm  
23 interested in hearing about.

24 MR. CANAVAN: Let me give you both.  
25 Interestingly enough, I would agree with your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 statement, except in this case.

2 CHAIRMAN STETKAR: Okay. All right.

3 MR. CANAVAN: And the reason why I would  
4 agree that it goes from slow to geologic, it actually  
5 was reversed, because the number of people involved in  
6 the FAQ process would tend to be much larger. The  
7 public -- the process was public. It became a  
8 nightmare trying to bring along 40 people to make  
9 decisions in the area of fire research, whereas a  
10 small research team might have been more effective.

11 And so I would argue that this process was  
12 difficult to get through. And I don't think you will  
13 get -- I don't think you will have a different comment  
14 that it was difficult to work through from anybody who  
15 was involved.

16 CHAIRMAN STETKAR: We'll ask the staff  
17 about that, too.

18 MR. CANAVAN: Yes, I think you should.

19 CHAIRMAN STETKAR: The ineffective part,  
20 because that implies that I'm interested in, maybe we  
21 will hear about it later or perhaps you could comment  
22 on it, the ineffective statement implies that the  
23 resolutions that you receive, regardless of when they  
24 came in, and whether they were a paragraph or 100  
25 pages, may not have been effective at addressing the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 real effectiveness.

2 MR. CANAVAN: No, I think we were  
3 effective at addressing a small part with a really lot  
4 of resources.

5 CHAIRMAN STETKAR: Okay.

6 MR. CANAVAN: And that were left with even  
7 at least a part that is as big as what we solved.

8 CHAIRMAN STETKAR: Okay.

9 MR. CANAVAN: To continue to solve. And  
10 so it was slow from the perspective of getting it out  
11 timely and it was resource-intensive for what we got.

12 In other words, we put a tremendous amount of  
13 resources into getting a very small answer and we are  
14 left with another bigger part we have to solve later.

15 And you will see that when you see the matrix.

16 CHAIRMAN STETKAR: Okay. Okay.

17 MR. CANAVAN: The correlations.

18 MR. BRADLEY: One more comment just  
19 quickly on that subject. When we get into the  
20 insights today from all the models that we produced,  
21 keep in mind that those are including incorporation of  
22 the FAQs. So every -- the insights that you see, we  
23 have already taken, that will give you a perspective  
24 on what the result was.

25 MR. CANAVAN: Yes. And what I'm trying to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tee up is I just believe that the process is probably  
2 the wrong process, at least it feels wrong because of  
3 the amount of resources. Not that the small answer we  
4 got wasn't a really good small answer, but we paid a  
5 price for it and it was big. I think we could be more  
6 effective.

7 CHAIRMAN STETKAR: Okay. But I'm going to  
8 play a bit of the devil's advocate. We are not -- I  
9 don't want to get into a large debate over these  
10 things. I just want to make sure we understand some  
11 of the things that are being said. There have been  
12 research projects in this Agency that have dragged on  
13 for decades and they still continue under issues that  
14 affect both deterministic and probabilistic regulatory  
15 decisions.

16 MR. CANAVAN: Yes.

17 CHAIRMAN STETKAR: I'll mention GSI-191 as  
18 an example. There are many others that you're  
19 familiar with.

20 MR. CANAVAN: Yes.

21 CHAIRMAN STETKAR: The fact that we are  
22 still learning about those hasn't necessarily stopped  
23 us or prevented us from being able to make at least  
24 current state of the knowledge decisions regarding the  
25 risk of those issues. We might learn more in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 future.

2 MR. CANAVAN: Right. I think --

3 CHAIRMAN STETKAR: You know, what I'm  
4 saying is it's certainly good to strive for  
5 perfection, perfect knowledge, perfect information,  
6 but --

7 MR. CANAVAN: I don't even think we are --  
8 it's not even in the same ballpark.

9 CHAIRMAN STETKAR: Okay.

10 MR. CANAVAN: And I think Rick will take  
11 that up when he --

12 CHAIRMAN STETKAR: I hope we hear about  
13 that.

14 MR. CANAVAN: Okay.

15 CHAIRMAN STETKAR: That portion.

16 MR. CANAVAN: Yes, because he will show  
17 what is remaining in some of these tasks.

18 CHAIRMAN STETKAR: Good.

19 MR. CANAVAN: And I think you will be  
20 surprised at where we are.

21 CHAIRMAN STETKAR: Okay.

22 MR. CANAVAN: The implications. Well, I  
23 put this up in a number of different formats in front  
24 of this Committee and other Committees over time. And  
25 I don't think it's any different. I think the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 original methods contain simplifications and  
2 conservatisms, that that was appropriate.

3 I believe it was expeditious. I do  
4 believe that all simplifications and all conservatisms  
5 erode to the level of realism. It's a question of how  
6 much? And in the large LOCA, that erosion of the  
7 level of realism is acceptable. So when we model the  
8 large LOCA in the PRA, that's acceptable.

9 In other cases, it's not. If you treat  
10 loss of off-site power extremely conservative at your  
11 nuclear unit in the United States when we know it is  
12 generally a large contributor, that would not be  
13 acceptable.

14 I think that the original method did what  
15 it was supposed to do. And what we are talking about  
16 now is not an impugment of the original method, it's  
17 how do we refine it quicker to get more realism to  
18 more appropriately reflect the results that we need it  
19 to reflect in a reasonable fashion with the right  
20 amount of resources in the time that it supports the  
21 submittals.

22 I'm going to point out again, we didn't  
23 pilot it in an integrated fashion, otherwise, we would  
24 have understood a little bit more of this prior to  
25 today. And as we go through more pilots, there is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 some interesting things happening, in that we are  
2 seeing some more of these conservatisms that we didn't  
3 see before, although I don't think that there are lots  
4 of them, but there are a few though.

5 Okay. And just to summarize, I think  
6 getting realistic results and insights is going to  
7 take us -- we are going to have to refine the methods.

8 The rest of these presentations that follow are all  
9 devoted to the questions that I have you all thinking  
10 in your heads, which is, you know, what are the  
11 specific simplifications we are talking about? We're  
12 going to give you a few examples.

13 What are the specific methods and the  
14 methods we are talking about as we move forward? And  
15 we're going to talk about that as well.

16 You shouldn't be surprised that we are  
17 where we are, when we have tried this out twice, one  
18 and a half, number two isn't finished, one and three-  
19 quarters.

20 We are certainly committed, EPRI is  
21 certainly committed to supporting the methods,  
22 enhancements improving the state of the technology.  
23 We want to do that for a variety of reasons, not only  
24 NFPA 805, but other risk applications as well. We  
25 need to make sure that these methods are appropriate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for use in risk-informed decision making in total.

2 I think you are going to find out a lot  
3 through the next series of slide presentations. This  
4 is, you know, all designed to give you information  
5 and, you know, I hope get you thinking, asking us  
6 questions. We will do our best to respond.

7 MR. BRADLEY: Can I say one thing?

8 MR. CANAVAN: Sure.

9 MR. BRADLEY: I forgot to mention as part  
10 of my presentation, you discussed that there was  
11 another Subcommittee meeting in December. We are  
12 going to be providing a technical paper to ACRS that  
13 summarizes the issues. Today's presentation is sort  
14 of a preview of what you are going to see, but we will  
15 be providing a detailed basis paper to the  
16 Subcommittee.

17 MR. CANAVAN: And the Action Plan.

18 MR. BRADLEY: Right.

19 MR. CANAVAN: And the Action Plan moving  
20 forward.

21 CHAIRMAN STETKAR: So talk more. I can  
22 ask you now. Do you have any idea of when that will  
23 be or we can discuss that toward the end of the day.

24 MR. BRADLEY: It will be -- we recognize  
25 your need to have it, something other than the day

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 before than that Subcommittee meeting. Our goal, I  
2 think, is to get it to you a couple of weeks around  
3 that part of the month.

4 CHAIRMAN STETKAR: Let's talk a bit about  
5 that.

6 MR. BRADLEY: Right.

7 CHAIRMAN STETKAR: Because I think after  
8 Mardy Kazarians makes his presentation toward the end  
9 of the afternoon, we do need to discuss a bit about  
10 the schedule, because I want to make sure that those--  
11 it's a two day Subcommittee meeting, so we have a lot  
12 of time scheduled and I want to make sure that we use  
13 that time very effectively.

14 And it's important for us, as Subcommittee  
15 Members, to have input as soon as we can get it. And  
16 I think it's important for all of the other  
17 participants, both the staff and anybody from industry  
18 who is coming in, to, essentially, have some time  
19 perhaps or communications with our staff to understand  
20 what specific topics we actually want to focus on.

21 So that's another reason not to get it in  
22 the day before the meeting. I mean, we read things  
23 pretty quickly, but it's not useful.

24 MR. BRADLEY: Yes.

25 MR. CANAVAN: We want you to have time to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 consider it, so, yes.

2 CHAIRMAN STETKAR: Okay. Thank you.

3 MEMBER SHACK: Just coming back for a  
4 second to your ineffective process, now, what's your  
5 proposal for an effective process?

6 MR. CANAVAN: Good question. I did think  
7 about that a little bit. I guess my real problem is  
8 research performed in extremely large groups and in  
9 the public is -- especially when there is preliminary  
10 results that come out, especially when they might say  
11 things, you know, when you initially screen them, they  
12 might have implications and it's being done on a  
13 public phone call, it's not going to work.

14 People aren't going to be as up front.  
15 They are not going to be as open as they could be. I  
16 know that process doesn't work. The process that we  
17 used with the smaller groups of really involved  
18 industry stakeholders or people, a small group of very  
19 knowledgeable people to create the first iteration on  
20 the method and then allow that method to be slowly  
21 socialized through the community, what happens when  
22 you use this set of plans? To the staff, what  
23 happens? What are your concerns about how you would  
24 review this?

25 And, basically, building out from that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 small group works a lot better than to start with  
2 everybody and try and get agreement. And the fact  
3 process which is really good for answering those  
4 questions that were interpretations of the methods and  
5 it wasn't as good the other way because of that. And  
6 having survived many facts, I just think we could  
7 devise a little bit better of a process.

8 CHAIRMAN STETKAR: Okay.

9 MR. CANAVAN: Thank you.

10 MR. BRADLEY: So would Doug and Jim --

11 CHAIRMAN STETKAR: You've given yourself a  
12 daunting challenge here, Doug, to just get through all  
13 this stuff in one day.

14 MR. TRUE: Yes. Yes, no shortage of  
15 topics discussed today.

16 CHAIRMAN STETKAR: Who's up first, Jim?

17 MR. TRUE: We're going to move together.  
18 Primarily, I'm going to talk and Jim is going to add  
19 in on a few topics.

20 I'm Doug True from ERIN Engineering. And  
21 Jim and I are here for two reasons. One, EPRI asked  
22 us if we would be interested in doing this. And  
23 secondly, because we are both pretty concerned about  
24 this area. We have done a lot of PRAs between our two  
25 companies to support 805 and other Fire PRA-related

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 studies.

2 And we are concerned about the status of  
3 things and the progress that we have been able to make  
4 or were unable to make over the last several years.  
5 So we're going to talk today about insights from the  
6 performance of industry Fire PRAs far beyond the  
7 pilots, but also including some of the insights from  
8 the pilots, too.

9 So, anything, Jim, you want to add?

10 MR. CHAPMAN: And I'm Jim Chapman from  
11 ScienTech. And I'm here to virtually operate Doug's  
12 computer, so let's go.

13 MR. TRUE: Okay.

14 CHAIRMAN STETKAR: When they turn the  
15 ventilation off in December, the migrating remains  
16 pegged, which won't be a problem any more.

17 MR. TRUE: So the purpose of this  
18 presentation is to provide insights from industry PRAs  
19 that have been performed using EPRI 1011989 and NUREG/  
20 CR-6850 with what I'll call NUREG/CR-6850 from this  
21 point forward, including the FAQs that help support  
22 things that Biff said in his first presentation, which  
23 was that the manner in which fires are characterized  
24 doesn't seem to conform with proper experience at the  
25 level of quantified risk.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           It seems to be overstated when you look at  
2 it from an operating experience perspective. And we  
3 have some concerns, particularly as we move forward in  
4 805 and beyond, about the level of conservatisms and  
5 uneven levelness of conservatisms and how they may  
6 mask insights and make decision-making more difficult.

7           So --

8           MEMBER SHACK: Of course, when you are  
9 adjusting an answer to get to an endpoint, that's sort  
10 of an unsatisfactory process, because there are lots  
11 of ways to twiddle the knobs to get to this, you know,  
12 to adjust things at the endpoint. So do you -- is  
13 there more information to deal with, rather than the  
14 fact that you don't like the final answer?

15           MR. CHAPMAN: Yes. It's in the  
16 presentation.

17           MR. TRUE: Yes. And it --

18           MR. CHAPMAN: Yes.

19           MR. TRUE: -- will be in the subsequent  
20 presentation, which I'm going to make. We are,  
21 basically, trying to say that we have been saying for  
22 three years there is a problem. We're going to show  
23 you why we really believe this is a problem. And then  
24 we will talk about how we want to go about solving  
25 that through additional development.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Okay.     So the basic methodology for  
2 constructing a fire scenario involves setting up  
3 individual ignition source bins that have a plant-wide  
4 frequency that is derived from operating experience.  
5 This is the way that 6850 is set up.

6           So plant-wide, there is a fire frequency  
7 for pumps, like for cabinets, transient sources,  
8 diesels, whatever, there are 30 some-odd bins of  
9 ignition sources.   Those ignition frequencies are  
10 allocated to a particular individual source within the  
11 plant, based on an allocation process.

12           For each of those bins, there is a growth  
13 rate assigned and a peak heat release rate,  
14 distribution is a sign that is intended to reflect  
15 that bin.   Suppression is credited both automatic and  
16 manual suppression.   The manual suppression is  
17 credited through a broad class of fires, electrical  
18 fires, oil fires, welding fires, etcetera.

19           You take that input and you put it in the  
20 fire modeling.   We define damage footprint or  
21 sometimes we call it zone of influence that defines  
22 this is what the damage looks like from that  
23 particular ignition source developing in this way.

24           And then we take that damage footprint and  
25 we put it in and connect it to the PRA model and we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculate a conditional core damage probability for  
2 that scenario. It's a step-wise process that has been  
3 laid out. It's not much different than the way we  
4 have always done PRAs.

5 One difference about 6850 that I wanted to  
6 clarify is it has all been more of a cookbook, I  
7 think, than most of the past attempts at this. And I  
8 think that's where some of the issues have come about  
9 in applying it.

10 So when we go to calculate the core damage  
11 frequency for a particular scenario, it becomes a  
12 function of what is the frequency of this particular  
13 fire? What are the characteristics of that particular  
14 fire from a severity perspective? How fast does it  
15 grow? How big does it get? What's the probability of  
16 suppressing that fire versus time? And then what's  
17 the resulting conditional core damage probability that  
18 reflects how likely we are to get from that damage  
19 condition to core damage?

20 One of the challenges we have is that, as  
21 we have gone to apply this, we are seeing that there  
22 are conservatisms that were applied kind of in each  
23 one of these components. And this Ken hit on this a  
24 little bit that these were done in kind of discrete  
25 steps in the process and there were more conservatisms

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 attached to each one.

2 And so when you go and apply to an  
3 individual basis, Ken mentioned, they apply tasks at  
4 individual plants, they looked at it and said okay,  
5 that seems right. Then we look at the next thing, it  
6 seems all right, seems all right.

7 The problem is that is when you combine  
8 them, the combination of those conservatisms, it's  
9 leading us away from realism.

10 CHAIRMAN STETKAR: Doug?

11 MR. TRUE: Yes?

12 CHAIRMAN STETKAR: Let me stop you right  
13 there and how is that different from the conservatisms  
14 that we apply in internal events PRA? When I looked  
15 at the fact that every motor-driven pump is a motor-  
16 driven pump and I have generic data for the frequency  
17 of motor-driven pump failures to start over a broad  
18 class of motor-driven pumps. The success criteria  
19 that I apply for a system in order to do a really  
20 detailed thermal hydraulics analysis would say that  
21 well, there might be a 90 percent probability that I  
22 can get by with one pump, but there is a 10 percent  
23 probability that I might need two pumps for the class  
24 of initiating events that I have grouped together, so  
25 I'm going to use two pumps as my success criteria.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Yes.

2 CHAIRMAN STETKAR: And the timing of the  
3 event is well, I'm going to say that I need to have  
4 injection before a certain time and I'm uncertain  
5 about when the RWST might be drained or when something  
6 might uncover. So I use the shortest of those time  
7 windows and that gives me a time window for operator  
8 response. Those also are cumulative conservatisms  
9 that we live with and are very happy in internal  
10 events PRA.

11 MR. TRUE: I think --

12 CHAIRMAN STETKAR: And this process, to  
13 me, doesn't sound any different than that.

14 MR. TRUE: It doesn't. I mean, in  
15 principle and again as Ken pointed out, the large LOCA  
16 example, it's not that much different. But I think as  
17 you know, what we have done with internal events over  
18 the last two decades or whatever it has been, 15  
19 years, is we have refined a lot of those methods, so  
20 that we are trying to address a lot of those things  
21 that we might have treated very simplistically.

22 There is a lot more plant-specific data  
23 collected to make sure you are reflecting the  
24 particular types of pumps and their application. You  
25 are a lot more sophisticated thermal hydraulic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis to refine the inputs. And that's not --  
2 shouldn't be too surprising that in 20 years of doing  
3 internal events PRAs, rigorously, we have gotten that  
4 far. But today, we have fire PRA methods that they  
5 are. They are just not to that level.

6 And, you know, there shouldn't be a huge  
7 surprise about that.

8 CHAIRMAN STETKAR: How different are these  
9 methods, maybe we will get into it later, than the  
10 methods that were applied 25 years ago during the  
11 first Fire PRAs that were done in the mid-1980s?

12 MR. TRUE: I think in concept they are  
13 quite similar. We have some new wrinkles, spurious  
14 ops, for example, that have come in that weren't  
15 really treated in prior studies. But in principle,  
16 they are similar. But I think that there are some --  
17 the binning and the handing off from task-to-task, I  
18 think has made it a little bit less of a scenario-  
19 based evaluation and more of an, okay, well, this is  
20 an electrical cabinet and I'm going to treat that like  
21 this and I'm going to do this with it and that. It's  
22 just a little bit too discrete.

23 MR. CHAPMAN: I think what you are --

24 CHAIRMAN STETKAR: Are you going to get  
25 into some of that?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Yes.

2 CHAIRMAN STETKAR: Okay. If you are, I'll  
3 let you go.

4 MR. CHAPMAN: I'll show you the results.  
5 But what fundamentally is happening is that the  
6 frequency of severe damage or risk significant damage,  
7 we think is being calculated much too high, at a high  
8 level. I think that's the fundamental difference. I  
9 don't think it's in the actual PRA modeling in terms  
10 of what happened.

11 CHAIRMAN STETKAR: Well, that's -- yes.  
12 And where I'm trying to get to, I hear that, but I  
13 hear it at high levels. So what I'm interested in is  
14 I think one of the things that I would like to come  
15 away with, perhaps in the Subcommittee meeting and if  
16 not, shortly thereafter, is an understanding of is  
17 this a process of conservatisms that are 50 percent or  
18 a factor of 2 too high multiplied together?

19 So you get  $2 \times 2 \times 2 \times 2$  which is 16  
20 factor of conservatism in the result or are there  
21 several conservatisms that are probably within the  
22 range of the uncertainties that we normally accept,  
23 let's say, within internal events PRAs, but one or two  
24 areas where you feel that there are, you know,  
25 substantial conservatisms?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In other words, if it is a factor of 16,  
2 we are getting most of that factor of 16 from one,  
3 rather than the cumulative effect of several things.

4 MR. TRUE: Yes.

5 CHAIRMAN STETKAR: Because that's a much  
6 different perspective on --

7 MR. TRUE: Right.

8 CHAIRMAN STETKAR: -- where do you go from  
9 here.

10 MR. TRUE: We're going to get to this.

11 CHAIRMAN STETKAR: Okay. All right. So--

12 MR. TRUE: I'm just not sure we are going  
13 to entirely satisfy you, but --

14 CHAIRMAN STETKAR: Well, I'm --

15 MR. TRUE: -- because this is, as you  
16 would --

17 CHAIRMAN STETKAR: -- planting the seed  
18 about what I would like to hear.

19 MR. TRUE: As you pointed out early on in  
20 this when Biff and Ken were talking, this is very  
21 plant-specific, there are scenario-specific issues and  
22 it's very hard to make general statements about  
23 anything in this area.

24 CHAIRMAN STETKAR: Okay.

25 MR. TRUE: You will see some general--

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Well, yes, but I'm  
2 hearing general statements here, so I'm trying to pull  
3 you back into --

4 MR. TRUE: Right.

5 CHAIRMAN STETKAR: -- what we are looking  
6 for.

7 MR. TRUE: Right. But --

8 MEMBER ABDEL-KHALIK: General statements  
9 aside, would it be fair to say that course binning is  
10 a common contributor to the conservatisms --

11 MR. TRUE: Yes.

12 MEMBER ABDEL-KHALIK: -- in each of these  
13 four components?

14 MR. TRUE: Yes. Course binning is an  
15 important conservatism that is driving the results, I  
16 believe. But that said, that permeates across all of  
17 these dimensions and across all of the bins to varying  
18 degrees.

19 MEMBER ABDEL-KHALIK: It's, essentially, a  
20 resolution issue?

21 MR. CHAPMAN: It's a resolution and a  
22 knowledge issue, in my mind, in terms of agreement on  
23 prevailing good practices for what might be  
24 appropriate assumptions to adjust what is clearly, in  
25 my opinion, over-predicting results, which we are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 going to get to. It's on Slide --

2 MEMBER ABDEL-KHALIK: Okay.

3 MR. TRUE: We'll get there.

4 MR. CHAPMAN: -- 16, right?

5 MR. TRUE: Yes, we'll get there.

6 MR. CHAPMAN: We have to get there.

7 MR. TRUE: So this is saying, we don't  
8 think there is any one factor.

9 MEMBER ABDEL-KHALIK: Right.

10 MR. TRUE: Not even sure it's a small  
11 handful of factors and the results are very scenario-  
12 specific, which means they are a function of the  
13 plant, a particular location in that plant, ignition  
14 source, what is driving which plant's risk.

15 Speaking of that, this is a little skyline  
16 chart. It's a graph of some results from a selection  
17 of PRAs, literally sort of randomly collected, that I  
18 can pull in through a common format.

19 And what you have on the y-axis is a  
20 fraction of CDF, so it's all on a relative basis. And  
21 across the x-axis in front is the -- each of the  
22 ignition bins from NUREG/CR-6850, the 37 different  
23 bins. And then there are seven plants. We could have  
24 made it more plants, but the message I'm trying to get  
25 across here is, I think, pretty clear.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           First, electrical cabinets, that ridge  
2 running down the middle is important everywhere.  
3 Electrical cabinets are important. Not a huge  
4 surprise there, but they are important.

5           But the other thing you notice is  
6 scattered around in different places you have got  
7 different little bumps that are somewhere between say  
8 10 and 20 percent of the CDF. So if you beat down the  
9 electrical cabinets at a certain plant, you are going  
10 to run into something else pretty fast.

11           CHAIRMAN STETKAR:       This is risk  
12 assessment?

13           MR. TRUE:    It is risk assessment. It's  
14 another reason why we don't believe there is a single  
15 factor that we can -- you know, one technical issue we  
16 can go to just solve that. We can solve this whole  
17 thing.

18           CHAIRMAN STETKAR:   Okay, Doug, but given  
19 the fact that this is risk assessment and you have  
20 very graphically pointed to that very steep, very  
21 large, on a relative basis anyway, ridge line for  
22 electrical cabinets, if I'm hearing that the methods  
23 are insufficient and the numbers are too conservative,  
24 the first thing I'm interested in hearing about then  
25 is what are we doing wrong in evaluating fires in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 electrical cabinets?

2 Because if we are doing that pretty well,  
3 I don't care about the rest of this stuff, quiet  
4 honestly.

5 MR. TRUE: Okay.

6 CHAIRMAN STETKAR: I would like to be  
7 perfect in everything, but if that, indeed, we are  
8 doing fairly well, we have some sort of limit at which  
9 we can expect to have resolution.

10 MR. TRUE: Right.

11 CHAIRMAN STETKAR: So I hope we will get  
12 to talk about a level of that.

13 MR. TRUE: We will. That will actually --  
14 that won't be in this particular presentation, but in  
15 my next one --

16 CHAIRMAN STETKAR: Some time today.

17 MR. TRUE: -- there will be a fair amount  
18 devoted to that particular subject, because it is  
19 important. EPRI has ongoing activities right now  
20 targeting some of the aspects of that.

21 CHAIRMAN STETKAR: Just out of curiosity,  
22 one thing on this slide that I don't see, and I think  
23 I probably know why I don't see it, but I want to hear  
24 it from you, is I don't see anything that says cables.  
25 You have highlighted diesels, battery chargers,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 electrical cabinets, high energy arcing faults,  
2 transformers and, you know, surprisingly not that  
3 there are transformers, but it's a plant-specific  
4 analysis.

5 MR. TRUE: Yes.

6 CHAIRMAN STETKAR: I don't see cable  
7 fires.

8 MR. TRUE: Self-ignited cable fires?

9 CHAIRMAN STETKAR: That --

10 MR. TRUE: They are one of the bins I have  
11 -- personally --

12 CHAIRMAN STETKAR: Yes.

13 MR. TRUE: -- I don't know which bin it  
14 is, but --

15 CHAIRMAN STETKAR: But, essentially, self-  
16 ignited cable fires are not an issue.

17 MR. TRUE: They are not.

18 CHAIRMAN STETKAR: At least across --

19 MR. TRUE: Across this set of plants.

20 CHAIRMAN STETKAR: Okay. And that's  
21 probably because we have learned an awful lot about  
22 the frequency of self-ignited cable fires as opposed  
23 to the consequences.

24 MR. TRUE: Yes.

25 CHAIRMAN STETKAR: Are the electrical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cabinet fires manifesting their damage through that,  
2 through fires in the cabinets themselves or the  
3 ignition of nearby cables?

4 MR. TRUE: Mostly nearby cables.

5 CHAIRMAN STETKAR: Okay. Thanks. That  
6 helps that perspective.

7 MR. TRUE: Okay. So those bins or  
8 resolutions, it's a useful simplification that -- we  
9 think it has really been one of the significant  
10 contributors to the introduction of conservatisms that  
11 had led us away from what we are seeing in the  
12 operating experience and overstates the consequences  
13 for the assigned frequency.

14 See, that's another thing, we've got the  
15 frequency sort of dealt with over here and then we  
16 have the consequences dealt with over here and the  
17 connection to those two isn't always clean. And one  
18 of those will be a little conservative here and it  
19 will be a little conservative here. And then we put  
20 them together and suddenly we find a more significant  
21 issue.

22 I'm going to walk through a simple example  
23 of diesel generator fires. Why did I pick diesel  
24 generator fires?

25 CHAIRMAN STETKAR: Because it's easy to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do.

2 MR. TRUE: Yes.

3 CHAIRMAN STETKAR: I wish you would have  
4 done the one that was important and difficult to do  
5 and that's the electrical cabinet fires.

6 MR. TRUE: I know. And --

7 CHAIRMAN STETKAR: So sometime before the  
8 end of December, we are going to do that.

9 MR. TRUE: We will talk about electrical  
10 cabinet fires. And there are probably other people  
11 who could also participate in that.

12 CHAIRMAN STETKAR: Yes.

13 MR. TRUE: Because, like I said, there was  
14 a lot of work going on right now with EPRI trying to  
15 tackle that one.

16 Diesels are very straightforward to  
17 understand the process and it does a nice job of  
18 illuminating some of the concerns.

19 CHAIRMAN STETKAR: Okay.

20 MR. TRUE: It's not -- you can look back  
21 at the previous slide or two slides ago, whatever it  
22 was, and see there was only one plant where it's  
23 really a significant contributor. It's not -- I  
24 didn't pick it for that reason. I picked it because I  
25 can get through it in a few slides and you get the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 picture real quickly.

2 CHAIRMAN STETKAR: Yes. I understand.  
3 I'm just trying to --

4 MR. TRUE: Okay.

5 CHAIRMAN STETKAR: By the way, it is  
6 interesting that that particular plant shows yard  
7 transformers and diesels as relatively important  
8 contributors.

9 MR. TRUE: Yes.

10 CHAIRMAN STETKAR: Which tells me they  
11 have some problem in their electrical system.

12 MR. TRUE: In their power supply or  
13 something that is gleaning to.

14 CHAIRMAN STETKAR: Yes.

15 MR. TRUE: So diesel generator fires are  
16 Bin 8 of the 37 bins. It applies to diesel generator  
17 rooms. It applies to all the diesel generators at the  
18 site. In the original report, it had a frequency of  
19 around  $2.1 \times 10^{-2}$  that was based on some 49.5 event.  
20 Somebody is going to say 49 and a half, how do you get  
21 half of an event?

22 Well, it's actually 60 events. 39 were  
23 fully counted. There were 21 events that were  
24 indeterminate, which meant that the analyst couldn't--  
25 didn't have enough information from the description of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the fire to exactly weight it in the way that they  
2 knew how significant the fire was, so they have it a  
3 value of .5.

4 CHAIRMAN STETKAR: Doug?

5 MR. TRUE: Yes?

6 CHAIRMAN STETKAR: For the benefit of the  
7 other Subcommittee Members, at some time during the  
8 day, is there going to be a discussion of that  
9 weighting and screening process and the data that was  
10 accomplished as part of the NUREG/CR-6850?

11 MR. TRUE: There will --

12 CHAIRMAN STETKAR: An analysis?

13 MR. TRUE: -- not in detail. What we  
14 have, there is a big project going on right now also  
15 with EPRI and NRC on the Fire Events Database to  
16 enhance that, that we are not going to talk -- we are  
17 going to talk about the fact of what is going on and  
18 some of the aspects of it, but not into the details of  
19 that.

20 CHAIRMAN STETKAR: Can you at least, if  
21 you are not going to talk about -- you know, you  
22 brought up the fact that this was counted as 49.5  
23 events derived from 60. Could you briefly describe  
24 the types of decisions that went in when -- there has  
25 -- I'm stammering here a bit. But there has been a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 lot of discussion about the fact that the fundamental  
2 fire event frequencies are accessibly conservative and  
3 that there is a need to refine the methods to bin the  
4 events together, evaluate the events for whether they  
5 are a valid fire or whatever.

6           Could you at least tell the Subcommittee  
7 for the current database, the data that --  
8 notwithstanding the FAQ resolution, but the current  
9 database that is published in NUREG/CR-6850, what type  
10 of general process was done? You had a collection of  
11 fire events that came from the industry, what was done  
12 with that?

13           MR. TRUE: Well, the author, or sometimes  
14 the authors, review each of those events and use  
15 several criteria to determine whether the fire was a  
16 challenging fire. It had to do with how much was the  
17 dollar value of the damage that was done, if that was  
18 known, the number of fire extinguishers that were  
19 involved in putting out the fire and I think whether  
20 there was damage to any external equipment is another  
21 criteria. So a handful of criteria.

22           Where they could determine that those  
23 criteria were one of those criteria met, they counted  
24 it as a challenging fire. And that's -- on this case,  
25 out of 39 of them, they had a clear enough description

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to be able to make that judgment.

2 In other cases, the database was a cobbled  
3 together selection of information that had been  
4 gathered from the industry and, frankly, some of the  
5 descriptions are not very complete, in fact, pretty  
6 incomplete. And so the analysts were left with, okay,  
7 what do we do with all these events? We know what  
8 happened, we just don't know enough about them.

9 And they had to make some judgment about  
10 whether they were a potentially challenging fire or  
11 not. And where they were, they assigned them an  
12 indeterminant condition and gave them or rated as .5.

13 Some of the fires they were, you know,  
14 self-extinguished or were not a significant threat and  
15 those weren't even counted towards the frequency.  
16 They were kept in the database for information, but  
17 they were not counted towards the frequency.

18 CHAIRMAN STETKAR: So this frequency of  
19  $2.1 \times 10^{-2}$  per year, in a sense is a, I don't know how  
20 to characterize it, severity-informed frequency. In  
21 other words, there had been events that were  
22 characterized as a fire for whatever reason and we all  
23 are familiar with, you know, how reports are written.

24 MR. TRUE: Right.

25 CHAIRMAN STETKAR: But they were

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 characterized as a fire and discarded, because the  
2 people reviewing the data, they concluded that,  
3 indeed, it wasn't a significant fire. Some were  
4 clearly significant, some in between that got counted  
5 halfway, so that the events that are retained, your  
6 49.5 events, are judged by either conclusive evidence  
7 or more expert opinion --

8 MR. TRUE: Yes.

9 CHAIRMAN STETKAR: -- that, indeed, they  
10 were severe enough to be counted as a legitimate fire  
11 for the purposes of this.

12 MR. TRUE: Whole fire or half fire, right.

13 CHAIRMAN STETKAR: Okay. Okay.

14 MR. TRUE: Yes. I don't remember the  
15 exact numbers, but I think in the diesel case there  
16 were another maybe 40 or 50 that were not counted at  
17 all.

18 CHAIRMAN STETKAR: Yes.

19 MR. TRUE: But are in the database, but  
20 aren't counted toward the frequency.

21 CHAIRMAN STETKAR: And that's normal for  
22 anybody's data.

23 MR. TRUE: Yes.

24 CHAIRMAN STETKAR: It's pump broke, fix  
25 pump.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Right.

2 CHAIRMAN STETKAR: Is it a failure or not?

3 MR. TRUE: Yes.

4 CHAIRMAN STETKAR: Okay.

5 MR. TRUE: Yes. So in the FAQ process,  
6 one of the successes that -- it mentions success and  
7 applies here is FAQ-048. EPRI did a bunch of work to  
8 update the fire frequencies. What we found was there  
9 were sort of disproportionate amount of fire  
10 experience in the early operating years, from,  
11 actually pre-operational period up through and until  
12 Appendix R was fully in place, there were a lot more  
13 events than there were in the more recent years.

14 And so EPRI did a report where a  
15 statistical analysis was used, much like we do for  
16 internal events, initiating events. We weighted the  
17 more recent experience more heavily. And that ended  
18 up resulting in about a factor of 4 reduction in the  
19 CDF in this case.

20 CHAIRMAN STETKAR: Doug, did --

21 MR. TRUE: That's a pretty large  
22 reduction, I would say, across the bins. That was one  
23 of the largest.

24 CHAIRMAN STETKAR: It's a surprisingly  
25 large reduction. Did that analysis you performed do a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hierarchical Bayes analysis where you counter the  
2 plant-to-plant variability in the events that you are  
3 looking at?

4 MR. TRUE: I don't remember exactly for  
5 this bin. I know we did in certain bins where we felt  
6 that it was appropriate.

7 CHAIRMAN STETKAR: I know the NUREG/CR-  
8 6850 did that.

9 MR. TRUE: Yes.

10 CHAIRMAN STETKAR: So the uncertainty --  
11 the mean frequencies account for the uncertainty with  
12 plant-to-plant variability. So for example, if you  
13 had one plant that had six diesel fires in it, for  
14 example, it might be an outlier, but it is counted as  
15 an individual, rather than put into just an industry  
16 average.

17 MR. TRUE: Right. We followed a similar  
18 process of 6850, but we ended up dividing the data  
19 into two bins and had the older data and the newer  
20 data and did a Bayes update with the newer data. So  
21 we kept all the older data to inform the prior, but  
22 used the new data as the --

23 CHAIRMAN STETKAR: Did you just use the  
24 new data as evidence, but not on a plant-specific  
25 basis?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Yes.

2 CHAIRMAN STETKAR: Upon a plant-specific  
3 basis or?

4 MR. TRUE: No, not on a plant-specific  
5 basis.

6 CHAIRMAN STETKAR: Okay. The only point  
7 here, people are looking at me saying well, I'm  
8 getting pretty esoteric, you're making a point that  
9 the frequency was reduced by a factor of 4. If you  
10 don't treat the uncertainty correctly, that could be a  
11 fairly high fraction of that reduction.

12 MR. TRUE: Pretty certain.

13 CHAIRMAN STETKAR: Okay.

14 MR. TRUE: That's correct.

15 CHAIRMAN STETKAR: I wanted to make sure  
16 that you did it.

17 MR. TRUE: We could have a whole day  
18 presentation on that single effort report, if you  
19 would like, but that's one step forward we made in the  
20 FAQ process.

21 Ken talked about interim solutions and  
22 ineffective and we made some progress and we got the  
23 frequency down, but there are still some more things  
24 we would like to talk about about this bin. Okay?

25 So we take that plant-wide frequency of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 5E-3 now in our study and we apply it to the plant.  
2 Well, the plant with two diesels and has a frequency  
3 of  $2.5 \times 10^{-3}$  for each of their diesels. A plant with  
4 four diesels has a frequency of  $1.3 \times 10^{-3}$  per diesel  
5 per year. So each diesel room gets allocated its  
6 fraction of that total plant-wide frequency.

7 The next thing we look at is well, how do  
8 we characterize those fires, in terms of what kind of  
9 threat they make to the plant?

10 And the authors of 6850 went through and  
11 looked at the events and said --

12 MEMBER ABDEL-KHALIK: I'm trying to  
13 understand this. The seven recent events --

14 MR. TRUE: Yes.

15 MEMBER ABDEL-KHALIK: -- did these involve  
16 more than one diesel?

17 MR. TRUE: No. All individual diesels.

18 MEMBER ABDEL-KHALIK: All individual  
19 diesels. And so the  $5 \times 10^{-3}$  is a frequency allocated  
20 to fire in an individual diesel or in individual  
21 plants?

22 MR. TRUE: Plants.

23 CHAIRMAN STETKAR: Explain that for the  
24 Committee Members.

25 MR. TRUE: Well, all of the frequencies in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the NUREG/CR-6850 were developed on a plant-wide  
2 basis. It was the number of events divided by the  
3 number of reactor years, basically, that was used in  
4 the calculation. And then for each of the bins, you  
5 go through a process and there is an explanation of  
6 how to do it for each bin type.

7 You allocate that frequency through the  
8 number of components you have of that type in the  
9 plant. And, in fact, this is one of the areas where  
10 EPRI has a research task to go forward and say well,  
11 really, we ought to do this on a component basis  
12 rather than on a plant-wide frequency basis.

13 CHAIRMAN STETKAR: Okay.

14 MR. TRUE: And I have some more  
15 information in the later presentation. It shows you  
16 that variability. And it can be pretty dramatic. A  
17 factor of 8 may be from the top to the bottom in  
18 certain bins. So in some cases, we are overstating  
19 the, potentially, frequency and, in some cases, we are  
20 potentially understating the frequency.

21 But this is the way the process is used.  
22 And we think that's an important thing to address in  
23 this new Fire Events Database Project that is going on  
24 jointly with the NRC and EPRI is going to help tackle  
25 that particular problem.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So those events that allocated frequency  
2 for that particular diesel then is partitioned into  
3 two types of fires, electrical fires were found to be  
4 about 16 percent of the fires and oil fires were 84  
5 percent of them. So that was based on a review of the  
6 events in the Fire Events Database.

7           Electrical fires are characterized by the  
8 electrical components identified in the inventory for  
9 that diesel generator. Oil fires are assigned to  
10 distribution of fires. The first bin is 2 percent of  
11 the fires are assumed to involve 100 percent of the  
12 oil inventory. 98 percent of the fires are assumed to  
13 involve 10 percent of the oil inventory.

14           And then the heat release rate that goes  
15 into the fire modeling is based on if you spill that  
16 oil, whatever your inventory is, you know, if you have  
17 a diesel day tank, they have 500 or 1,000 gallons of  
18 fuel oil in it, either spread that 500 or 1,000  
19 gallons or spread 10 percent of it over whatever area  
20 it can spread, calculate heat release rate, figure out  
21 what is damaged by that heat release rate.

22           If we look back at actual operating  
23 experience that comprised about 84 percent, this is  
24 from the data in the Fire Events Database, the fires  
25 don't really look like that. We've got about half of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 them are coming from exhaust manifold fires, which are  
2 fires that occur inside the exhaust manifold.  
3 Sometimes flames are coming out through a damaged  
4 gasket. Sometimes it's actually internal to the  
5 exhaust.

6 19 percent of them came from turbocharger  
7 fires, a similar kind of thing, with an internal fire  
8 to the engine. 16 percent came from lube oil leaks.  
9 Almost all of those were very small quantities, at  
10 least in the descriptions that were provided. About  
11 10 percent involved some sort of an explosion inside  
12 the crankcase. And about 8 percent involved some sort  
13 of a fuel oil leak, again, a very small quantity.

14 But those don't really align with the 98  
15 percent/2 percent split, both of which involved large  
16 quantities of oil being spread across a large area  
17 generating a very large heat release rate.

18 CHAIRMAN STETKAR: Doug, is the  
19 information on this pie chart available to me if I'm  
20 doing a Fire PRA today?

21 MR. TRUE: I think the Fire Events  
22 Database is available to all EPRI Members, yes. It  
23 may even be publicly available, I'm not sure.

24 CHAIRMAN STETKAR: So that if, for  
25 example, diesel fires, diesel oil fires were driving

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 my risk, I could, in principle, come back to this and  
2 say well, I can now refine a fraction of those fires  
3 that I would expect to be some large pool fire?

4 MR. TRUE: You could.

5 CHAIRMAN STETKAR: Which is where you are  
6 going?

7 MR. TRUE: The problem with the challenge  
8 that the industry is facing is there is a lot of  
9 pressure to stay within the NUREG/CR-6850 method.  
10 Don't deviate from the cookbook, because that's the  
11 cookbook that has been approved.

12 CHAIRMAN STETKAR: That's why I asked that  
13 question. That's what I want. I want to really  
14 understand that also from the industry's perspective.

15 MEMBER ABDEL-KHALIK: This pie chart is  
16 for all 60 events. Is that correct?

17 MR. TRUE: It's for the oil fire fraction.  
18 There is 84 percent of the 60 or whatever.

19 MEMBER ABDEL-KHALIK: Right. What does it  
20 look like for the recent events?

21 MR. TRUE: I didn't do that, but I think  
22 that it is not vastly dissimilar. There are few  
23 exhaust manifold fires, I would say. It might not be  
24 half any more, but still a significant contributor.  
25 But other than that, it's about the same kind of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thing.

2 Certainly, none of them had anything to do  
3 with large releases of oil.

4 MEMBER ABDEL-KHALIK: Right.

5 MR. TRUE: And I don't -- I want to be  
6 careful, because I'm not trying to impugn what the  
7 author is trying to do. They were trying to provide a  
8 method that was traceable, followable, it's probably  
9 conservative, certainly burning up 10 percent of the  
10 fuel inventory is a conservative approach to it. It  
11 is fine. It was a good way to start doing Fire PRAs.

12 We've got to get beyond that and get  
13 ourselves to a level of refinement where we've got  
14 something that matches what we actually see.

15 CHAIRMAN STETKAR: Well, we are running  
16 long, but we have time, I think.

17 MR. TRUE: Yes.

18 CHAIRMAN STETKAR: What I'm trying to get  
19 to is something that you said that there has been  
20 reluctance among people using the methodology to  
21 deviate from numbers that are specified in NUREG/CR-  
22 6850. For example, if I had this information  
23 available to me, I might be able to build a case if I  
24 felt it was cost-beneficial for me to do that in terms  
25 of effort involved versus risk/benefit to present this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information as justification for why I might want to  
2 deviate from that guidance.

3 Because after all, it's a NUREG. It's not  
4 a rule for tables of numbers.

5 MR. TRUE: Yes.

6 CHAIRMAN STETKAR: Okay.

7 MEMBER ABDEL-KHALIK: If instead of having  
8 one bin called diesel generator oil fires, I had five  
9 bins that addressed each one of the leaks, would that  
10 refinement improve the process?

11 MR. TRUE: In this -- that philosophy of  
12 having more bins would definitely improve the process,  
13 but make doing the PRA a little more complicated.

14 MEMBER ABDEL-KHALIK: Right.

15 MR. TRUE: Of course. So it's just a  
16 tradeoff here. I think that certainly if you had a  
17 different damage vector you were going to apply to  
18 exhaust manifold fires, fuel oil leak fires, then that  
19 would definitely change the result.

20 Right now, basically, if you take even the  
21 10 percent fire and put it in a diesel room, you are  
22 going to burn the room up. I mean, you don't even  
23 have to do a calculation. You are going to burn the  
24 room up.

25 CHAIRMAN STETKAR: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: So that's --

2 CHAIRMAN STETKAR: I think the only  
3 downside of, you know, creating yet even more well-  
4 defined bins is we did that 30 years ago in collecting  
5 things like valve data. We had valves defined to such  
6 a fine level of detail that it was difficult to  
7 populate the bins, most of the bins, with any failures  
8 at all.

9 MR. TRUE: Right.

10 CHAIRMAN STETKAR: And in practice, when  
11 you look at failure events, now, people are much  
12 better at reporting information, there is much better  
13 communications these days, but you still eventually  
14 get to the pump broke, fix pump sort of issue that  
15 there still needs to be judgment. So just having more  
16 bins to throw things into, in some cases, makes the  
17 data analysis job more difficult.

18 MR. TRUE: Exponentially more difficult.

19 CHAIRMAN STETKAR: And inserts more  
20 uncertainty in the thing that you are actually  
21 deluding yourself you know more about.

22 MR. TRUE: Right, yes.

23 CHAIRMAN STETKAR: So there is that fine  
24 line.

25 MR. TRUE: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Anyway, I'll let you  
2 get going.

3 MR. TRUE: So that's the -- we kind of  
4 captured this, I think. So our heat release rate  
5 doesn't really align with this experience.

6 So to just kind of summarize here, FAQ-048  
7 results in a significant decrease in the emission  
8 frequencies. We have got this issue of allocation  
9 process, so a plant with more diesels has more -- has  
10 a lower per room frequency.

11 The heat release rate doesn't seem to  
12 match the actual fires, most of them were localized.  
13 Again, the data isn't particularly complete on this,  
14 but most of them didn't involve any kind of actuation  
15 of automatic suppression. Most of them didn't even  
16 demand a plant shutdown.

17 And yet, we have put them into the PRA as  
18 burning up the room, we have to shutdown the plant.  
19 We have got an initiating event and we are now  
20 contributing to risk and --

21 MR. CHAPMAN: And even at 5E-3 per year,  
22 you would expect to see an event of this severity  
23 every couple years.

24 MR. TRUE: Right.

25 MR. CHAPMAN: And, obviously, we are not.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: And that's another thing to  
2 calibrate whether the 5-3 crosses 100 plants, because  
3 it's a plant-wide frequency is about a probability of  
4 .5 per year we would have a fire like that.

5 CHAIRMAN STETKAR: A diesel fire?

6 MR. TRUE: A diesel fire.

7 CHAIRMAN STETKAR: A major fire.

8 MR. TRUE: A diesel fire that's  
9 characterized as --

10 CHAIRMAN STETKAR: Well, a diesel fire  
11 that was severe enough for you to include it in the  
12 database. So I'm not -- apparently, we are seeing  
13 those because that's the frequency.

14 MR. TRUE: Right. But not with 10 percent  
15 of the oil spill burning up the room.

16 CHAIRMAN STETKAR: That's different.  
17 That's different.

18 MR. TRUE: Right. No, right.

19 CHAIRMAN STETKAR: Okay.

20 MR. TRUE: It's a disconnect between the  
21 ignition frequency and --

22 CHAIRMAN STETKAR: Not a --

23 MR. TRUE: -- the severity.

24 CHAIRMAN STETKAR: Right. But we are not  
25 saying that we would expect to see that severe oil

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fire every other year.

2 MR. TRUE: Yes, pretty much.

3 MR. CHAPMAN: That's how it has been  
4 modeled.

5 MR. TRUE: Pretty much.

6 CHAIRMAN STETKAR: That's the way it is  
7 being modeled? Well --

8 MR. CHAPMAN: For the most part.

9 MR. TRUE: Yes. How do I go back?

10 MR. CHAPMAN: For the most part.

11 CHAIRMAN STETKAR: Okay.

12 MR. TRUE: So what we do is we take that  
13 5-3 and we multiply it times .85 and then we multiply  
14 it times .98.

15 CHAIRMAN STETKAR: Okay.

16 MR. TRUE: So it's not quite 5-3, but it's  
17 close.

18 CHAIRMAN STETKAR: Okay. I see it, yes.

19 MEMBER ABDEL-KHALIK: And so how is that  
20 original assumption made?

21 MR. TRUE: I don't know. I was not an  
22 author of the document.

23 CHAIRMAN STETKAR: The assumption --

24 MEMBER ABDEL-KHALIK: The 2 percent.

25 CHAIRMAN STETKAR: -- on the bottom is the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one we're challenging, right?

2 MEMBER ABDEL-KHALIK: Right, right.

3 CHAIRMAN STETKAR: That's the --

4 MEMBER ABDEL-KHALIK: Yes. How was that?

5 MR. HYSLOP: I believe that -- my name is  
6 JS Hyslop. I have done the research and I was the PM  
7 of 6850. The assumption held across the board for  
8 pumps, all oil fires, it wasn't just for diesel, we  
9 find for certain cases, like main feedwater pump  
10 fires, that it is much too large and we have addressed  
11 the fact.

12 There was an expert solicitation among the  
13 authors of 6850 with 2 percent and 10 percent. The  
14 question I want to ask you, Doug, when you were  
15 talking about the frequency of diesels, was that  
16 including the failure suppression and those things?  
17 Because when you look at diesel fires as big as you  
18 are talking about, there is more than just the  
19 frequency involved.

20 There is the failure to fire protection  
21 systems to act and all that. So that's the frequency  
22 that you compare.

23 MR. TRUE: So maybe I better wait. You  
24 are -- well-put, JS. I apologize.

25 MR. HYSLOP: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Actually, the frequency that we  
2 should be seeing is about every other year, we should  
3 be seeing a fire big enough to actuate automatic  
4 suppression in a diesel generator. Most plants have  
5 automatic suppression in their diesel room, so you  
6 would expect that to be the state that you would see  
7 at that frequency. So that was a good point, JS.

8 Okay. So we think we have demonstrated  
9 there is a disconnect here with the operator  
10 experience.

11 Okay. So much spurious ops, one of the  
12 big issues that we are facing in the industry right  
13 now is addressing this issue of spurious operations.  
14 And it's an essential part of the transition to  
15 adopting 5048(c). Our operating experience has shown  
16 that we haven't had a spurious op since Browns Ferry  
17 back in 1975.

18 So we went back and pulled out an  
19 intermediate state for some PRAs to see what does the  
20 Fire PRA predict would be the frequency of a spurious  
21 operation? We take the assumptions in 6850 and we  
22 apply them. What would we calculate as our frequency  
23 plant-line frequency as spurious ops?

24 And so we looked at a couple of PRAs.  
25 This is not a small task, so I only picked a couple of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plants to do this on. We happened to have their data  
2 in a relatively convenient form. So we focused on  
3 CDF, but there are a lot of intermediate states and  
4 spurious operations are included in the fire  
5 scenarios.

6 So what we did was we went through a PRA  
7 and we looked for scenarios that had one or more  
8 spurious operations involved. Many fires that have  
9 one spurious op, have more than one spurious op in the  
10 way they are modeled in the Fire PRA.

11 But in two of the plants that we -- in  
12 these two plants we looked at, the frequency came out  
13 around  $4 \times 10^{-3}$  per year plant-wide is the frequency  
14 of fire at those plants that would lead to one or more  
15 spurious operations.

16 We also did, Jim and I did, kind of the  
17 back-of-the-envelope check against another study done  
18 by his guys and we concluded that it was about in the  
19 same range. It might be a little higher, it might be  
20 a little lower, but it's in about the same kind of a  
21 range.

22 So if you take that  $4 \times 10^{-3}$  and spread it  
23 across the industry, we would expect to see a fire  
24 involving a spurious op every two or three years.  
25 Yet, as I said, we haven't seen one since 1975. So we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think this is another demonstration of the disconnect  
2 between what we are putting into the PRA, what we are  
3 calculating, versus what we are seeing in operating  
4 experience.

5 CHAIRMAN STETKAR: Can I ask you something  
6 kind of JS was asking you is that frequency of .0041  
7 after failure of the spurious suppression system to  
8 extinguish the fire before you achieve target damage?

9 MR. TRUE: Yes, it is. The problem is,  
10 and we will talk about this some more, that unless you  
11 have automatic suppression, which is actually not that  
12 common in plants, as you know, we are not getting a  
13 whole lot of credit for --

14 CHAIRMAN STETKAR: Suppression.

15 MR. TRUE: -- main suppression, because  
16 the fire growth rate is so fast.

17 CHAIRMAN STETKAR: But you are saying that  
18 that is close to a multiplier on the fire frequency by  
19 the Commission.

20 MR. TRUE: Yes.

21 CHAIRMAN STETKAR: Okay.

22 MR. TRUE: Okay. So we think we are  
23 overstating the frequency.

24 So fire risk. Now, obviously, it is  
25 really difficult to compare a CDF calculation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operating experience and then draw any conclusions,  
2 because we haven't had any fire core damage events to  
3 look at, fortunately.

4 But we can look within the PRA kind of  
5 like we did on the spurious ops side. We can look at  
6 the high CCDP scenarios. And we have a lot of  
7 industry programs. NRC looks at high CCDP conditions  
8 through the Accident Sequence Precursor Program and  
9 through the Reactor Oversight Process all the time.

10 So we can go into the PRA, see what the  
11 representative frequencies of fires are for each plant  
12 for those scenarios that have high CCDPs. And then we  
13 can compare that frequency of high CCDP conditions to  
14 industry experience and see how we come out.

15 In the ASP Program, they maintain a list  
16 of the significant precursor events. Those are events  
17 where the conditional core damage probability is  
18 greater than or equal to the  $10^{-3}$ . And every year  
19 they put out a trend on high CCDP events, which were  
20 those with values greater than  $10^{-4}$ .

21 The significant precursors are relatively  
22 rare. There hasn't actually been one in the U.S.  
23 operating experience in the last eight years. Davis-  
24 Besse was the last significant precursor. And of the  
25 34 for the whole operating experience of the industry,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 only one of those involved a fire and that was the  
2 Browns Ferry fire.

3 CHAIRMAN STETKAR: Is that because -- I  
4 can ask the staff, but is that because they don't have  
5 fire models, so they don't run fires through their  
6 fire models to see whether there are significant  
7 precursors?

8 MR. TRUE: I'll let you ask the staff that  
9 question.

10 CHAIRMAN STETKAR: Okay.

11 MR. TRUE: But I what I will say is that  
12 you don't need a fire model to do a CCDP. You have a  
13 fire.

14 CHAIRMAN STETKAR: Right.

15 MR. TRUE: It causes damage.

16 CHAIRMAN STETKAR: Right.

17 MR. TRUE: You can go to your spar model,  
18 plug that damage in and calculate a CCDP. So the lack  
19 of fire models is --

20 CHAIRMAN STETKAR: Well, except for things  
21 like --

22 MR. TRUE: -- not --

23 CHAIRMAN STETKAR: -- spurious operations,  
24 which --

25 MR. TRUE: Well, that's on the other side.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This is only looking at CCDPs, which is why --

2 CHAIRMAN STETKAR: But the CCDP I have to  
3 understand whether I have a spurious operation, don't  
4 I?

5 MR. TRUE: Well, but the event would have  
6 either had one --

7 CHAIRMAN STETKAR: Oh, I see, I see. I  
8 see what you are saying, yes.

9 MR. TRUE: The event was the event.

10 CHAIRMAN STETKAR: Yes, yes, you're right.

11 MR. TRUE: So it either had a spurious op  
12 or not.

13 CHAIRMAN STETKAR: Right.

14 MR. TRUE: You had damage or not.

15 CHAIRMAN STETKAR: Yes. Yes.

16 MR. TRUE: You had suppression or not. It  
17 was what it was. Okay?

18 MR. CHAPMAN: You're going to like this  
19 next slide. It's small numbers.

20 MR. TRUE: You want to do it?

21 MR. CHAPMAN: No, no, no.

22 MR. TRUE: Okay.

23 MR. CHAPMAN: You're doing great.

24 MR. TRUE: I broke it into three pieces,  
25 because I want to give you the data first. So the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 left column is some set of plants. The middle column  
2 is from those Fire PRAs for those plants, what's the  
3 predicted frequency of conditional core damage  
4 probability, events involving conditional core damage  
5 probabilities greater than  $10^{-3}$ ?

6 And you will see it's actually pretty  
7 tightly grouped in the  $10^{-3}$ s with the plant being  
8 maybe a little bit higher, but sort of the low  $10^{-3}$ s.

9 On the right column, we have the high CCDP  
10 events, which are the ones that attract annually and  
11 by the ASP Program. CCDPs greater than  $10^{-4}$  and those  
12 again are pretty tightly packed also in the low  $10^{-2}$ s.

13 CHAIRMAN STETKAR: And this is the result  
14 of three of four different teams, correct?

15 MR. TRUE: Yes.

16 CHAIRMAN STETKAR: At least three?

17 MR. TRUE: Three different teams.

18 CHAIRMAN STETKAR: Your team, my team and  
19 another team?

20 MR. TRUE: And another one, yes. So this  
21 is not one analyst's perspective.

22 CHAIRMAN STETKAR: Okay.

23 MR. TRUE: It's multiple PRAs across --

24 CHAIRMAN STETKAR: Different types of  
25 plants.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: -- different types of plants.

2 CHAIRMAN STETKAR: Yes.

3 MR. TRUE: Different analysts and  
4 approaches.

5 CHAIRMAN STETKAR: Right.

6 MR. TRUE: Okay. So if we take that  
7 frequency and again try and turn it around, what  
8 should we be seeing from an operating experience  
9 perspective? We should be seeing a high CCDP fire or  
10 significant precursor event about once every one to 10  
11 years in that range, every few years. And the high  
12 CCDP events, we should be seeing one, two or three  
13 each year. We should be seeing lots of them.

14 In reality, we haven't had a  $10^{-3}$  since  
15 Browns Ferry. And the latest ASP report shows data  
16 from 2001 to 2009 and there are none in that period.  
17 I'm pretty sure there are none before, but there is  
18 not a ready resource I can go to to look at that. The  
19 ASP Program folks would have to tell -- say whether  
20 there were any that had that high CCDP in the previous  
21 time.

22 But even still, even in the nine years, we  
23 should have seen, you know, 10 to 30 of them probably  
24 in the industry and we haven't seen any.

25 MR. CHAPMAN: And a couple of points.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Each of these plants has on average 1,000 ply damage  
2 states, so it's not for a lack of effort.

3 And the second point is with the exception  
4 of one plant, these results reflect design or  
5 procedure changes or commitments that are resulted in  
6 reduction in the calculated risk factor of 3 to 5 or  
7 in one case much higher.

8 So if you reflect back prior to those  
9 conditional decision --

10 MR. TRUE: Right.

11 MR. CHAPMAN: And again, as best we can  
12 tell, the evidence is clear and it is driven by the,  
13 in my opinion, excessive frequency of damage to risk  
14 significant equipment that we are not observing. And  
15 that's the intent of this chart. Okay.

16 MR. TRUE: Okay. To be clear about what  
17 Jim said about the status of these, some, most of  
18 these PRAs they have already finished their analysis.  
19 They have committed to mods as part of their  
20 transition to 805. And the models reflect those  
21 improvements they have already made.

22 So the pre-mod value would be --

23 CHAIRMAN STETKAR: In effect, what you are  
24 saying is --

25 MR. TRUE: Which is real comforting, yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: -- it follows the state  
2 of the practice of doing a PRA according to the  
3 guidance and data that are available. This is what --  
4 with whatever plant-specific improvements each of  
5 these individual plants decided to make, for whatever  
6 reason --

7 MR. TRUE: Form whatever reason.

8 CHAIRMAN STETKAR: For whatever reasons.  
9 Each of these plants would expect to see this type of  
10 result.

11 MR. TRUE: And that would even -- and  
12 since that is a --

13 CHAIRMAN STETKAR: These are results from  
14 the PRA.

15 MR. TRUE: Yes, yes.

16 CHAIRMAN STETKAR: Yes.

17 MR. TRUE: No. This is --

18 CHAIRMAN STETKAR: I mean, you know, if  
19 they were projecting forward.

20 MR. CHAPMAN: Yes.

21 COUNCIL MEMBER THOMAS: Right, projecting.  
22 That's an important point. It is projecting forward,  
23 whereas --

24 CHAIRMAN STETKAR: Right. Projecting.  
25 No, let's look at this closely.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: -- past experience, which is  
2 what I'm focusing and comparing to would have been  
3 expected to be higher than that.

4 CHAIRMAN STETKAR: Right. The absolute --  
5 well, I understand why you want it conditionable, so  
6 that's -- go on. This is good.

7 MR. CHAPMAN: Well, this is the way to  
8 gain insight.

9 CHAIRMAN STETKAR: Yes.

10 MR. TRUE: Okay. So this is the SECY that  
11 talks about the 2001 to 2009 experience. For eight  
12 events, none of them had fire, involved fires.  
13 Whereas, the PRAs would have predicted something like  
14 9 to 30 or however you want to count industry-wide for  
15 the same period. So we think we have learned. We  
16 think there is a significant disconnect there.

17 All right. ROP is another place where  
18 CCDPs are looked at. And you are well-familiar with  
19 any CCDP or CDP we are going to value around  $10^{-6}$  is  
20 considered or below  $10^{-6}$  is green.  $10^{-6}$ ,  $10^{-5}$  is why we  
21 own up to yellow and red.

22 Today there have been no actual fire  
23 events. I'm talking about fires in plants that had  
24 either a yellow or red finding, so that drops us down  
25 to  $10^{-5}$ . I haven't been able to check -- I haven't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 checked this, because it's a lot of data to go  
2 through, but I don't believe there are actually any  
3 whites that are fires.

4 But I know it is true that none were  
5 yellow or red. Whereas, our models would have  
6 predicted that many of those would be happening each  
7 year. So again, we think we have got this disconnect  
8 in both the spurious ops and in the CCDP calculations.

9 And that rose -- both directly contribute to our fire  
10 spars that we have being higher than we think they  
11 should be.

12 Okay. Masking of risk insights. I don't  
13 have to tell you guys this, but the PRA policy  
14 statement, obviously, pushes us towards a more  
15 realistic approach to doing PRAs. And one of the  
16 reasons that that is important is that if you aren't  
17 realistic, you can mask important insights. And as  
18 Ken talked about in his large LOCA example, as an  
19 unimportant contributor, you can tolerate  
20 conservatisms. But when it is a very large  
21 contributor, you have to really focus on whether those  
22 conservatisms are skewing your insights and results.

23 And this kind of goes to the conversation  
24 we had about internal events and the refinements we  
25 have been through over the years to attack those more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 obvious conservatisms in the dominant contributor  
2 internal events.

3 But there is another interesting aspect to  
4 this that may not be obvious to everyone and that is  
5 that there is a difference in vocation for a  
6 likelihood conservatism, that is when you have  
7 overstated a probability of something happening or  
8 frequency of something happening versus when you  
9 overstate damage.

10 Likelihood conservatisms, we will say that  
11 I decide that my initiating event frequency, whether  
12 it is a fire or anything else, I have overstated it by  
13 a factor of 10, when I do a delta risk calculation on  
14 that compared to 1174, I will be biasing that delta  
15 high, because my input is a factor of 10 higher and my  
16 delta is going to be a factor of 10 higher.

17 So maybe that you can tolerate that in a  
18 risk-informed decision-making approach. But when you  
19 have conservatisms in damage vectors or damage  
20 predictions, you have the opposite problem. You have  
21 introduced new dependencies into the process, this  
22 fire causes this damage, so that you may actually  
23 understate any delta risk. I'm going to show you a  
24 little example of how that plays out.

25 I have a cabinet here and I have got a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 couple of cable trays nearby to that. I have some  
2 fire that has some heat release rate of X and I  
3 calculate some zone of influence for that fire. And  
4 that zone of influence catches both of those trays.

5 If I want to calculate the CDF from that  
6 particular scenario, I have a frequency of that  
7 scenario that would include the ignition frequency,  
8 nonsuppression and all those things and then a CCDP.  
9 My CCDP would be calculated with both System 1 and  
10 System 2 fails, because both of the cable trays are  
11 affected by that zone of influence.

12 Okay. Now, let's say I have a smaller  
13 fire, my heat release rate I'm predicting is lower and  
14 I have a smaller zone of influence and now I'm only  
15 going to be damaging System 1. When I look at the CDF  
16 for that scenario, I have the same frequency, a  
17 different CCDP now, because I only have System 1 fail,  
18 so my CCDP is going to be smaller, because I have more  
19 capability remaining available.

20 So my CCDP for Scenario A where I have the  
21 most damage is going to be much greater probably in  
22 order of magnitude or more greater than the CCDP where  
23 I only have the one system failed. And my CDF, of  
24 course, would be expected to be larger. I have more  
25 damage to my important system. I would have a larger

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CDF. Okay. So that's my baseline risk.

2 I could be comfortable with this. If I  
3 want a conservative result in my baseline risk, I can  
4 -- ZOI A gives me a conservative baseline risk result.

5 If I then look at a second scenario where  
6 I'm interested in looking at a delta risk, I have a  
7 system out of service, it looks like my animation is  
8 messed up here, where I have System 2 out of service,  
9 my CDF in that case is the same as it was before,  
10 because it doesn't matter whether System 2 is in or  
11 out of service, because if it's damaged by the fire,  
12 it doesn't matter.

13 For ZOI B, the smaller zone of influence  
14 though, now, I have a different scenario where my CCDP  
15 is a lot higher, because by taking System 2 out of  
16 service, I have, essentially, disabled it and that  
17 gives me a larger CCDP. And I end up with, in that  
18 case, System 2 out of service, a CCDP being the same.

19 And so my CDFs end up being the same.  
20 There was my -- sorry about that. But the problem is  
21 is that if I'm looking for a change in risk, if I'm  
22 doing a tech spec submittal or I'm doing an evaluation  
23 of NOAD or something, my -- if I have a more  
24 conservative zone of influence, I'm not measuring the  
25 change in risk associated with that equipment out of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 service.

2 I'm going to say there is no change in  
3 risk. And really, if a more realistic ZOI was  
4 applied, there might be a fairly potentially  
5 significant change in risk from having that piece of  
6 equipment out of service.

7 MR. CHAPMAN: And independent of the  
8 methods, you know for sure that the conditional  
9 probability of it being bigger than smaller is a small  
10 conditional probability.

11 MR. TRUE: Right.

12 MR. CHAPMAN: The problem is the modeling  
13 of the stuff, which is why Douglas picked two  
14 alternatives. A where I get both systems, B where I  
15 only get System 1, but it's real. That's one of the  
16 challenges.

17 CHAIRMAN STETKAR: Well, I see what you  
18 are doing. I'm not sure I agree with the thing you  
19 are calling S(i), because I think those are actually  
20 different frequencies in the real world.

21 MR. TRUE: They can be.

22 CHAIRMAN STETKAR: No, they will be.

23 MR. TRUE: No. Well, I'm sorry.

24 CHAIRMAN STETKAR: They will be because  
25 you are talking about a frequency of a particular fire

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 severity there to get -- the CCDP is simply what is  
2 damaged and what happens in the rest of the plant with  
3 whatever succeeds and fails. So that's irrelevant of  
4 the fire frequency or the fire -- the frequency of a  
5 particular damage footprint.

6 MR. TRUE: Okay. So we take our --

7 CHAIRMAN STETKAR: So they can't have the  
8 same frequency.

9 MR. TRUE: Let's take our diesel generator  
10 case. We had a --

11 CHAIRMAN STETKAR: We're going to have to  
12 stop for a break here pretty soon.

13 MR. TRUE: Okay. Well, I think I have one  
14 set left.

15 CHAIRMAN STETKAR: Yes.

16 MR. TRUE: But let's take the diesel  
17 generator case. So I have a ZOI that is based on an  
18 oil leak that burns up everything in the room and  
19 probably if I have offset power going through that  
20 room, it knocks that out too.

21 CHAIRMAN STETKAR: Yes.

22 MR. TRUE: Okay? That's an assumed ZOI.  
23 In reality, the ZOI should be applied, it appears from  
24 the operating experience, to be much smaller than  
25 that, right? So I get a conservative estimate in my

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 baseline risk by using the current assumptions on  
2 diesel impacts, but I completely obscure any decision-  
3 making about the significance of those fires.

4 CHAIRMAN STETKAR: I understand. I want  
5 to talk about --

6 MR. TRUE: That's one of the frequencies -  
7 -

8 CHAIRMAN STETKAR: -- that later.

9 MR. TRUE: The frequency, the way it is  
10 applied right now in 6850, is the same for the risk.

11 CHAIRMAN STETKAR: Because the stylized  
12 way is the zone of influence.

13 MR. TRUE: Because the stylized way is --  
14 yes.

15 CHAIRMAN STETKAR: Okay. That's -- I want  
16 to get back to that later, but after --

17 MR. TRUE: Okay.

18 CHAIRMAN STETKAR: -- you know, this.

19 MR. TRUE: All right. Last one. So I  
20 think I have made -- hopefully I have made these  
21 points already. We think that the simplifications are  
22 driving the results. It's a compounding of  
23 conservatisms. There is not a simple fix for that.  
24 We don't think we are comporting with operating  
25 experience. And we are worried about making good

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 decisions and it's a complicated problem, both for 805  
2 and beyond in trying to use these PRAs out further.

3 CHAIRMAN STETKAR: Thanks for your time.

4 MR. TRUE: Thank you.

5 CHAIRMAN STETKAR: Any questions,  
6 Subcommittee Members? Okay. With that, we're going  
7 to recess. We will come back at, I'll be generous,  
8 10:40, that will be 17 minutes.

9 MR. TRUE: Thanks.

10 (Whereupon, at 10:23 a.m. a recess until  
11 10:41 a.m.)

12 CHAIRMAN STETKAR: Okay. We're back in  
13 session. And I guess we will hear more from, I don't  
14 know, Doug and Rick, I guess.

15 MR. TRUE: Yes. Do you want to introduce  
16 yourself?

17 MR. WACHOWIAK: Yes. I'm Rick Wachowiak  
18 from EPRI. And mainly I'm up here to ease the next  
19 transition into the next presentation, but also to  
20 answer any questions associated with what we are doing  
21 to try to solve some of these problems.

22 MR. TRUE: Okay. And I'm Doug True from  
23 ERIN. And we are going to talk about what we have  
24 come to call the Roadmap for Attaining Realism in Fire  
25 PRAs. It's an activity that EPRI started really back

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in late 2009 when the first Action Matrix was put  
2 together.

3 And I have been asked to pull that  
4 together into a report with the help of NEI, Fire  
5 Bureau Task Force to identify the important areas  
6 where the assumptions and simplifications are unduly  
7 influenced in the results.

8 And the key objectives of this report,  
9 which is the report that Biff mentioned to you that  
10 you will get in a couple of weeks here, is to look at  
11 or identify the key areas, illuminate what the causes  
12 are, identify and organize a set of reasonable near  
13 term research activities and then inform and update  
14 the EPRI Fire PRA Action Matrix itself.

15 So we have a connection to what the PRA  
16 were telling us and what we need to be doing in these  
17 research areas.

18 The way we went about this is that we set  
19 up kind of a framework of categories of types of  
20 issues. The Fire PRA is a -- the fire analysis is  
21 really a continuum. There is some adverse condition  
22 that exists that leads to a fire event, some incipient  
23 period, eventually smoke, then flame and then the fire  
24 grows into some growth phase or, as we call it, the T-  
25 squared burning phase, hits some peak and then drops

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 off.

2 As we go through that, we have a number of  
3 constituents that feed into those pieces. And we have  
4 just used this as a framework to kind of identify  
5 categories of activities that we have put into the  
6 Fire PRA Action Matrix.

7 So I'm going to start with this first  
8 category, which is all of the things related to the  
9 Fire Events Database, estimation of ignition  
10 frequencies, severity characterization and  
11 nonsuppression probabilities.

12 And in the Action Matrix in the report, we  
13 have identified four major areas. I'm going to talk  
14 to your -- because we have limited time and I think we  
15 are going to have a hard enough time getting through  
16 just the first blue bullets there. But the report  
17 goes into some detail on all four of these.

18 The first really important activity  
19 relates to the characterization of the data, the Fire  
20 Events Database and the calculation of fire ignition  
21 frequencies. We made some progress in FAQ-048, but we  
22 are moving forward with that to get us both more data,  
23 more recent data, better data and a better technical  
24 basis for some of the ignition frequencies and other  
25 characterizations throughout the Fire PRA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The next one deals with the incipient and  
2 growth phase of the fire and oil fire severity. We  
3 talked a little bit about the diesel generator oil  
4 fire and JS mentioned that the same oil fire model is  
5 used elsewhere, that's another area where we think  
6 some additional refinement would be helpful.

7           CHAIRMAN STETKAR: Okay. Let me ask you,  
8 I'm going to keep pressing you guys to get specific  
9 about something eventually. Oil fire severity, I  
10 haven't see a Fire PRA in years where oil fires were  
11 at all important. So you apparently have. Are they?

12           MR. TRUE: Yes, can be.

13           CHAIRMAN STETKAR: No. I understand they  
14 can be.

15           MR. TRUE: No, I mean --

16           CHAIRMAN STETKAR: In practice --

17           MR. TRUE: -- I wouldn't say in every  
18 single plant they are, but there are certain plants --

19           CHAIRMAN STETKAR: Well, your little  
20 histogram there tells me that maybe in one of the  
21 seven plants they might have been, because only one of  
22 the seven showed diesels as being important.

23           So I'm curious about, you know,  
24 highlighting oil fire severity as a significant issue  
25 that we need to address as an area of conservatism

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 versus other things.

2 MR. TRUE: Yes.

3 CHAIRMAN STETKAR: Now, I want to get away  
4 from this one-size-fits-all that we have to make  
5 everything perfect. I want to understand what it is  
6 that we need to address that is, indeed, really  
7 driving the conservatism --

8 MR. TRUE: Within oil fires --

9 CHAIRMAN STETKAR: -- across the board.

10 MR. TRUE: -- there are actually three  
11 parts. I'll get to this actually.

12 CHAIRMAN STETKAR: Yes.

13 MR. TRUE: But there are actually three  
14 parts. There is diesel pumps and transformers.

15 CHAIRMAN STETKAR: I understand.

16 MR. TRUE: And you saw that transformers  
17 were also important in a number of things.

18 CHAIRMAN STETKAR: Yard transformers,  
19 you're going to have a difficult time convincing me  
20 that they don't blow up.

21 MR. TRUE: And in-plant transformers,  
22 right, right.

23 CHAIRMAN STETKAR: Okay.

24 MR. TRUE: It's not a one-size-fits-all  
25 solution either.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay.

2 MR. TRUE: Right? So anyway, incipient  
3 detection fire suppression is another aspect we're  
4 going to cover. We covered before, we're not going to  
5 talk about today.

6 CHAIRMAN STETKAR: There is a FAQ out by  
7 the way on incipient, how to handle incipient  
8 detection.

9 MR. TRUE: There was a FAQ.

10 CHAIRMAN STETKAR: Are you going to talk  
11 about that later?

12 MR. TRUE: In fact, there was a FAQ-048 on  
13 ignition frequencies also. We'll be addressing that.  
14 There was a FAQ on incipient detection and there was  
15 a FAQ on fire suppression.

16 CHAIRMAN STETKAR: Okay.

17 MR. TRUE: Also as Ken mentioned, most of  
18 those FAQs got some interim solution for them, where  
19 we made some refinement, but the slow process that was  
20 coming vast resources, we didn't get as far as we  
21 would like to have. And it is still important.

22 The incipient one, I'll just stress,  
23 because I don't talk about it later, the answer in the  
24 FAQ is if you do exactly what Harris did, then you can  
25 do this. Well, that may not be exactly what every

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plant is going to be able to do. There is a lot of  
2 plant-to-plant variability that there is really no  
3 guidance on how to implement incipient detection and  
4 credit it in your PRA.

5 CHAIRMAN STETKAR: Sorry, I thought the  
6 methodology in the FAQ is different from what Harris  
7 did. The staff accepted what Harris did was okay.  
8 Nod your head.

9 MR. TRUE: I don't --

10 CHAIRMAN STETKAR: Harris did their  
11 analysis before the methodology --

12 MR. TRUE: Yes, that's true.

13 CHAIRMAN STETKAR: -- and model and the  
14 FAQ came out.

15 MR. TRUE: Yes, right.

16 CHAIRMAN STETKAR: Okay.

17 MR. TRUE: Yes. But the -- so, yes. The  
18 licensee --

19 CHAIRMAN STETKAR: It had to do with the  
20 way Harris did it or you could kind of do it --

21 MR. TRUE: Right, right.

22 CHAIRMAN STETKAR: -- the way the FAQ  
23 does.

24 MR. TRUE: Right. But the FAQ leaves a  
25 lot of the branch probabilities open in the model. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the structure was basically the same. You can follow  
2 Harris and do exactly that, I misspoke, or you have to  
3 go off and develop your own bases for all these branch  
4 points in the event tree and the FAQ.

5 And what we believe needs to be done is  
6 that needs to be further developed, so that we can  
7 make that usable as a mitigation capability for other  
8 plants and repeatable. Harry?

9 MR. BARRETT: Yes, my name is Harry  
10 Barrett, NRC staff. I was heavily involved with  
11 Harris SE development. What we allowed Harris to do  
12 was use the methodology they had, but we wanted them  
13 to update it to the FAQ methodology, because they used  
14 a much more simplified approach.

15 The difference between what Harris has  
16 done or what the FAQ is doing and what you are talking  
17 about is area-wide detection has not been -- there has  
18 been no methodology that has been put forth to the  
19 staff that we an end up reviewing for area-wide use of  
20 incipient detection.

21 We have done it for cabinets with limited  
22 caveats. There are some caveats that we provided in  
23 there. If you end up meeting those caveats, then you  
24 are going to end up using incipient detection for  
25 electrical cabinets. But area-wide, there is a lot of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issues there that we need to work through that have  
2 not been either proposed or reviewed. So there is  
3 more work to do for the area-wide use of it.

4 MR. TRUE: Sure. Okay.

5 CHAIRMAN STETKAR: Thanks, Harry.

6 MR. TRUE: Okay. So fire event data  
7 characterization and this Fire Events Database  
8 activity, I'll go through this pretty quickly. But  
9 the events in the current Fire Events Database we  
10 talked about the half events and full events. And so  
11 it's sort of a little bit of a mixed bag and the  
12 authors, I think, had a really tough job of trying to  
13 link what happened in the plants to what we tried to  
14 model.

15 So we are trying to go back and get that  
16 database squared away, so that those links can be  
17 better, so we can do a better job on suppression, a  
18 better job on characterization of the severity, a  
19 better job on ignition frequencies and extend the data  
20 up past 2000 where the last database stopped. Get a  
21 more robust event descriptions and a more traceable  
22 scheme for how those were all categorized and the  
23 bases-wide. You know, get rid of the .5 kind of  
24 things where there is not an adequate description.

25 And then we also know long-term if we are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 moving into an era of risk-informed performance-based  
2 fire protection. We are going to need to have a long-  
3 term basis for maintaining that data and analyzing it.

4 Those are all parts of the program that is ongoing  
5 right now.

6 On fire ignition frequencies, this  
7 allocation technique has some limitations. We talked  
8 about it doesn't really comport with all of the ways  
9 that we do current data analysis and it doesn't  
10 totally handle the plant-to-plant variability issues.

11 And another area which we are concerned  
12 about a little bit is the transient ignition  
13 frequencies don't have a good way of addressing  
14 administrative control. So, in effect, if you have an  
15 area that is a transient-free zone, it could be  
16 treated the same way as an area that is not a  
17 transient-free zone, which means the administrative  
18 controls we put in place to control transients don't  
19 really -- aren't really reflected in the PRA  
20 calculation. It doesn't seem to follow.

21 CHAIRMAN STETKAR: Now, that's -- let me  
22 see if I can understand this. On the last bullet, you  
23 are not arguing about the plant level frequency of  
24 transient fires. It sounds like it is the --

25 MR. TRUE: Allocation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: -- allocation of those  
2 transients among specific compartments for my plant.

3 MR. TRUE: Yes.

4 CHAIRMAN STETKAR: Because of the way I do  
5 business at my plant. Okay.

6 MR. TRUE: This --

7 MR. HYSLOP: Doug, excuse me.

8 MR. TRUE: Yes?

9 MR. HYSLOP: There is a range allowed, the  
10 GSI Level where adjusted transients are low, medium  
11 and high. It's true that, you know, you will assume  
12 some sort of transient below. In any case, you don't  
13 say that there are no transients in this particular  
14 area, because there are violations of that.

15 MR. TRUE: Right.

16 MR. HYSLOP: So we do include that. But  
17 there is an adjustment mechanism.

18 MR. TRUE: There is. It's pretty crude.  
19 Based on insights from some of the PRAs, it needs to  
20 be readjusted.

21 CHAIRMAN STETKAR: Okay. Are transient  
22 fires -- there's feedback here. Are transient fires  
23 typically contributing significantly?

24 MR. TRUE: It really is plant-specific.

25 CHAIRMAN STETKAR: It is plant-specific.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: There is one plant that has got  
2 a pretty significant fraction coming from that.

3 CHAIRMAN STETKAR: Okay.

4 MR. TRUE: That I know of.

5 CHAIRMAN STETKAR: Okay.

6 MR. TRUE: Maybe others, but --

7 CHAIRMAN STETKAR: But it's not the same?  
8 You know, I'll go back to that histogram that showed-  
9 -

10 MR. TRUE: Right.

11 CHAIRMAN STETKAR: -- cabinet fires.

12 MR. TRUE: We're going to get to the  
13 electrical.

14 CHAIRMAN STETKAR: No. I know you will,  
15 but I'm trying to understand, you know, across the  
16 span of things where the different contributors are.  
17 You mentioned oil fires and --

18 MR. TRUE: Right.

19 CHAIRMAN STETKAR: -- I challenge you on  
20 that. So I was trying to understand where the  
21 transient fires are across the board.

22 MR. TRUE: It's not across the board.

23 CHAIRMAN STETKAR: Okay.

24 MR. TRUE: And as I said in that chart,  
25 the problem is certainly electrical cabinets we can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pull out right away.

2 CHAIRMAN STETKAR: Yes. Okay.

3 MR. TRUE: Beyond that, then you get into  
4 stuff. And as we said in the results presentation,  
5 it's not like we are just a little bit off in  
6 predicting these things. We are -- we think we are  
7 way off --

8 CHAIRMAN STETKAR: Okay.

9 MR. TRUE: -- in predicting them. And so  
10 if you drop that one bar down, you are still going to  
11 run into other things that are going to keep you from  
12 getting to where we are lining up with our operating  
13 experience. But that's our belief.

14 CHAIRMAN STETKAR: Well, eventually, I  
15 mean, you are going to talk about operating  
16 experience. But I'll tell you, a  $10^{-5}$  frequency per  
17 year, we have to operate the industry in the United  
18 States for 1,000 years and expect to see one core  
19 damage event per year. So operating experience on  
20 absolute core damage frequency isn't going to win a  
21 lot of things.

22 MR. TRUE: But that's why --

23 CHAIRMAN STETKAR: Conditional core damage  
24 probability or frequency of severe damage in fires.

25 MR. TRUE: Right, right. But that's why

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we went -- that's why we approached it the way we did  
2 and we think that's showing that we are off by a  
3 significant amount in those intermediate states, based  
4 on operating experience.

5 CHAIRMAN STETKAR: Okay.

6 MR. TRUE: Obviously, not CDF.

7 CHAIRMAN STETKAR: Okay.

8 MR. TRUE: The next few slides I don't  
9 want to spend too much time on them. I just went  
10 through a batch of PRAs that we had in the database.

11 MEMBER ABDEL-KHALIK: I'm trying to sort  
12 of cycle through what you just said. I mean, if --  
13 you know, the whole argument is that whatever you  
14 calculate doesn't match the operating experience, if  
15 you're going to go ahead and tweak this process so  
16 that ultimately you would match the operating  
17 experience, what is the value of this exercise? What  
18 additional insights would you gain then?

19 MR. TRUE: I don't think it's our intent  
20 to tweak it to get it to match the operating  
21 experience. I think that we are saying that we are no  
22 where near operating experience right now. And that  
23 means that we are skewing our perspective on what the  
24 results are.

25 As we bring that closer on an average

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 level to the industry operating experience, you will  
2 still get plant-specific insights, because you still  
3 have a room with a cabinet that is near an important  
4 set of cables or a pump that is near some important  
5 target that will come out of that study for the plant-  
6 specific results.

7 So we will always get plant-specific  
8 insights in these studies. But the base risk values  
9 we are coming out with, we don't think reflect  
10 anything like what we are seeing in operating  
11 experience.

12 MEMBER ABDEL-KHALIK: Okay. Just keep  
13 going. I'll just continue to process what you just  
14 said, because I think this is sort of a circular  
15 argument that -- well, how good a match would you need  
16 to be able to derive that benefit?

17 MR. TRUE: Derive that benefit?

18 MEMBER ABDEL-KHALIK: The benefit of  
19 gaining insights on an individual plant basis.

20 MR. TRUE: I think that I'm not saying  
21 that you can't get insights even from the current  
22 method. You can get insights. The problem is --  
23 well, two problems. One is knowing that the insight  
24 that says this is more important than that may not be  
25 correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Right.

2 MR. TRUE: Because if you have  
3 characterized this as a 10 percent oil -- of all the  
4 oil burning at the same time and this one is something  
5 more realistic, you might get a completely skewed  
6 perspective. So that's one problem.

7 MEMBER ABDEL-KHALIK: Right.

8 MR. TRUE: The other is, at the end of the  
9 day, outside of 805, we want to use these Fire PRAs to  
10 make risk-informed decisions. And even within 805, we  
11 need to make risk-informed decisions about changes to  
12 the plant. And in that case, you need to make sure  
13 that that risk calculation is giving you good  
14 calculations of the impacts of your decisions, whether  
15 it is trying to make an enhancement or whether it is  
16 to a decision on whether you take something in or out  
17 of service.

18 You know, on my maintenance condition or a  
19 tech spec condition or a NOAD or whatever, so we need  
20 a result that we can compare to internal events.  
21 Because if we have fire masking everything else, then  
22 the rest of it --

23 MEMBER ABDEL-KHALIK: Well, but --

24 MR. TRUE: Artificially, artificially  
25 masking the results.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Artificially, but it  
2 might.

3 MR. TRUE: It might.

4 CHAIRMAN STETKAR: We have done a heck of  
5 a lot of things on these plants to drive down internal  
6 event risk. And just to say that we want -- it's our  
7 desire to have the absolute core damage frequency from  
8 fires to be smaller than the internal event core  
9 damage, because --

10 MR. TRUE: That isn't what I was saying at  
11 all.

12 CHAIRMAN STETKAR: -- we know that.

13 MR. TRUE: That's not at all what I was  
14 saying.

15 MR. CANAVAN: This is Ken Canavan. If I  
16 might make a comment? I guess my thought on this is  
17 that when -- we are trying to verify that the model  
18 even is within a workable set of parameters. If you  
19 can't match operating experience, you can't use 4  
20 CCDP. You can't trust core damage, which means you  
21 can't make decisions with it.

22 And so at least those decisions need to be  
23 very, very high level decisions. Things like this, no  
24 credit for transient combustible control and, while  
25 let's say limited control of transients, how can you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 make a change to your plant if your model doesn't  
2 reflect transient combustible controls that are in  
3 place? You get no credit for it, so why do it?

4 You could take this even further, in my  
5 humble opinion, at say stuff like why would I protect  
6 something when the zone of influence says it has  
7 failed, because I did it conservatively, why would I  
8 protect that train? I don't get anything from  
9 protecting it. Or I think I'm getting a lot for  
10 protecting it, the opposite. I think, you know, the  
11 zone of influence fails it, so I'm going to make this  
12 big mod, spend all this money, resources and effort  
13 for something that really you didn't need to do.

14 And so I guess it is fidelity of the model  
15 to be able to be used is what the real question is in  
16 my mind.

17 CHAIRMAN STETKAR: Thanks.

18 MR. CANAVAN: Thank you.

19 CHAIRMAN STETKAR: Thank you.

20 MR. WACHOWIAK: And I think if we weren't  
21 more than on order of magnitude away from the  
22 operating experience, we probably wouldn't be bringing  
23 this up. If it was, you know, in the right order of  
24 magnitude, we would say, yes, we are predicting pretty  
25 well. But we're more than an order of magnitude high

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on these intermediate results and it's just not -- it  
2 doesn't match what we see.

3 MR. TRUE: Okay. So the next series of  
4 graphs just show some inventories of different bins.  
5 And shows the variation across the industry as  
6 compared to some median value. And then on the right  
7 hand side, I have showed kind of relative frequencies  
8 to the average, which essentially the averages would  
9 be the plant-wide smearing across all of those.

10 In this case, it's about a factor of 4. I  
11 mean, one plant has 400 or so cabinets, another one  
12 has 1,300. And this is done on a per unit basis, not  
13 a per site basis.

14 CHAIRMAN STETKAR: Let me see if I  
15 understand this though. Right now, essentially,  
16 people are using that word median, right? It's the  
17 frequency of cabinet fires on a plant level basis?

18 MR. TRUE: Yes, something like the median.

19 CHAIRMAN STETKAR: Some -- I don't want to  
20 argue median.

21 MR. TRUE: Right.

22 CHAIRMAN STETKAR: It's that horizontal  
23 line there somewhere.

24 MR. TRUE: Right.

25 CHAIRMAN STETKAR: Does that mean that if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 instead of quantifying a frequency on a per plant and  
2 allocating it by cabinets in my plant for the largest  
3 inventory of cabinets you have there on a factor of 2  
4 perhaps conservative on a per cabinet basis --

5 MR. TRUE: Yes.

6 CHAIRMAN STETKAR: -- and for the smallest  
7 plans on the factor of about 2 optimistic?

8 MR. TRUE: Actually, the other way around.

9 CHAIRMAN STETKAR: I'm sorry, the other  
10 way around?

11 MR. TRUE: Yes, the other way around. If  
12 you have more cabinets, you have a lower per cabinet  
13 frequency.

14 CHAIRMAN STETKAR: Yes, you're right. I'm  
15 sorry.

16 MR. TRUE: Right.

17 CHAIRMAN STETKAR: I'm trying to make a  
18 point.

19 MR. TRUE: Right.

20 CHAIRMAN STETKAR: But doing it wrong.  
21 But the fact of the matter is, in terms of frequency,  
22 at least for this example, I'm talking about a factor  
23 of 2 at the most?

24 MR. TRUE: Yes.

25 CHAIRMAN STETKAR: In terms of --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Well, from high to low it's a  
2 factor of 4. But for an individual plant --

3 CHAIRMAN STETKAR: Yes, but for an  
4 individual, you know --

5 MR. TRUE: Right.

6 CHAIRMAN STETKAR: Given the fact I'm  
7 going to randomly sample my plant as being one of  
8 these --

9 MR. TRUE: Right.

10 CHAIRMAN STETKAR: -- I'm probably at most  
11 a factor of 2 off, either high or low.

12 MR. TRUE: Right.

13 CHAIRMAN STETKAR: You know.

14 MR. TRUE: Right.

15 CHAIRMAN STETKAR: Okay.

16 MR. TRUE: And relative to the overall  
17 impact, that's probably pretty small. But it is --

18 CHAIRMAN STETKAR: Well, that's -- see,  
19 this is where I'm trying to get a handle on is that,  
20 you know, is it 2 to the 4<sup>th</sup> or is it --

21 MR. TRUE: Yes.

22 CHAIRMAN STETKAR: -- something like that,  
23 different?

24 MR. TRUE: So I'm ready to go through each  
25 one of these.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Yes.

2 MR. TRUE: The same basic message. This  
3 one has a little bit broader span, because of a couple  
4 of outliers.

5 CHAIRMAN STETKAR: Yes.

6 MR. TRUE: This one is --

7 CHAIRMAN STETKAR: This one is not so--

8 MR. TRUE: -- tighter maybe. This one is  
9 kind of all over the place.

10 CHAIRMAN STETKAR: Yes.

11 MR. TRUE: And maybe a factor of 8 range  
12 on this. So but it just shows you that there is this  
13 variability we haven't accounted for that we could and  
14 we actually intend to as we go forward. The owners  
15 groups are collaborating with EPRI on this database  
16 effort. They are out collecting information from the  
17 plants and inventories. And we are going to feed that  
18 back into an improved allocation process that will be,  
19 I think, generally more component-based, rather than  
20 just smeared across the number of components.

21 CHAIRMAN STETKAR: Rick, are you going to  
22 talk more about that later or not?

23 MR. WACHOWIAK: In general, I'm going to  
24 say that we are doing it.

25 CHAIRMAN STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACHOWIAK: But the specifics, no.

2 CHAIRMAN STETKAR: To do this, you  
3 actually need a lot of information from all of the  
4 plants --

5 MR. WACHOWIAK: That's correct.

6 CHAIRMAN STETKAR: -- and the industry,  
7 basically, component counts.

8 MR. WACHOWIAK: Right.

9 CHAIRMAN STETKAR: We have not done that  
10 at all for any internal event data period.

11 MR. TRUE: Right.

12 CHAIRMAN STETKAR: So why is it so  
13 important to do that, except for perhaps diesel  
14 generators, which everybody seems to like to count?  
15 And there are small numbers of it. People don't go  
16 out and count up the number of pumps in their plants  
17 particularly. They count up, approximate, number of  
18 pump demands, approximate total number of pump  
19 operating hours, which we then combine together into  
20 generic data.

21 MR. TRUE: That's not so true any more,  
22 John. I think that under our Maintenance Rule, we are  
23 pretty -- for the risk significant components, where  
24 we track pretty closely --

25 CHAIRMAN STETKAR: Yes. Has it been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 factored back into any generic databases though?

2 MR. TRUE: Sure.

3 CHAIRMAN STETKAR: Is my point. Okay.

4 MR. TRUE: Yes, because EPICs, the staff  
5 should probably talk about that, but NUREG/CR-6928  
6 actually relies on EPICs.

7 CHAIRMAN STETKAR: Has more of that?  
8 Okay.

9 MR. TRUE: And those are the monitored  
10 components under the Maintenance Rule, a fixed set of  
11 those. And they keep -- it's always reported  
12 regularly on hours of operation. They are allowed, in  
13 some cases, to estimate, but demands are also  
14 provided. And they do, I know, a really nice job, I  
15 think, on the data analysis with them.

16 CHAIRMAN STETKAR: Okay.

17 MR. TRUE: And it's also subdivided beyond  
18 just pumps. You know, it would be service water  
19 pumps, CCW pumps, safety injection, oxygen --

20 CHAIRMAN STETKAR: Once you start counting  
21 them.

22 MR. TRUE: Yes, yes.

23 CHAIRMAN STETKAR: It's pretty amazing.

24 MR. TRUE: So I think it's a pretty good--  
25 that NUREG/CR-6928 is a really good resource for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 industry.

2 CHAIRMAN STETKAR: Okay. Okay. Thanks.

3 MR. TRUE: Okay. So the database and  
4 ignition frequencies, the current FAQ requires  
5 reliance on some of the old data for several of the  
6 bins and, in fact, electrical cabinets, which is the  
7 ridge, were required to use both the new data and the  
8 old data from the EPRI work.

9 And so part of the agreement was that once  
10 we collected all the new data, then we would be  
11 allowed to use the improved result of that analysis.  
12 And that's -- for the retro-cabinets, it is about, I  
13 think, a 40 percent or a 60 percent reduction in that  
14 ridgeline that would occur, if you just relied upon  
15 the new EPRI data.

16 CHAIRMAN STETKAR: When you say new data,  
17 is it -- you said you are collecting data post-2009  
18 and weighting that more heavily than the old data.  
19 You are not discount -- discarding the old data, are  
20 you?

21 MR. TRUE: No, no.

22 CHAIRMAN STETKAR: Okay.

23 MR. TRUE: We are not discarding the old  
24 data. But the new data I was referring to there was  
25 the FAQ, the work that EPRI did that fed to the FAQ.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 That has a new set of --

2 CHAIRMAN STETKAR: Yes.

3 MR. TRUE: -- ignition frequency bins that  
4 weighted the post-1990 data more heavily. But it kept  
5 the old also. We are required to use that value as  
6 well as the overall value from 6850. There is about a  
7 60 percent difference or 40 percent difference, I  
8 can't remember which it is in the actual cabinet  
9 ignition frequencies between those two, which directly  
10 propagates into that ridgeline.

11 So if you use the EPRI results, in  
12 general, you would see a pretty good shrinkage of that  
13 in that bar. But we are not allowed to do that until  
14 we collect the new data and then --

15 CHAIRMAN STETKAR: Is the new data still  
16 treating every cabinet as equal? For example --

17 MR. TRUE: In the first pass it will.

18 CHAIRMAN STETKAR: All right.

19 MR. TRUE: In the first pass we are going  
20 to do exactly what 6850 did. We are going to use the  
21 same allocation technique.

22 CHAIRMAN STETKAR: Right. Let me ask you,  
23 why are you doing that? This is the industry, why are  
24 you doing that?

25 MR. TRUE: It's a matter of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 expeditiousness. It's in particular to get that done  
2 as soon as possible.

3 CHAIRMAN STETKAR: Well, that's what you  
4 did before and you found out it wasn't very good. So  
5 why are you perpetuating that expeditious treatment of  
6 something that we know is not very good?

7 MR. TRUE: Well, we are expediting the  
8 second phase also, but it just takes longer than the  
9 first phase.

10 CHAIRMAN STETKAR: But you are talking  
11 about the integrated frequency of a fire with the  
12 associated heat release rate. I'm interested in the  
13 frequency of fires that happen in telephone cabinets  
14 that probably don't have very substantial heat release  
15 rates compared to the frequency of fires that happen  
16 in 480 volt switchgear which probably do have  
17 substantial heat release rates.

18 So how is this new effort helping the  
19 process?

20 MR. TRUE: The new effort is helping the  
21 process by giving us more data to support the --

22 CHAIRMAN STETKAR: Same old binning.

23 MR. TRUE: -- current binning and then in  
24 the next phase, it will attack the allocation piece of  
25 it and will provide an improvement.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: In how many years?

2 MR. TRUE: I don't remember the schedule  
3 for that. I think it is next year we will have the  
4 first phase done and I think it is the beginning of  
5 the following year or something like that the second  
6 level will be done.

7 CHAIRMAN STETKAR: Any fundamental reason  
8 why you just couldn't do it once next year?

9 MR. TRUE: I think that there is another  
10 issue related to implementation that everyone's PRA is  
11 set up with the current method. And so if you give  
12 them new improved data, that level lower -- that will  
13 almost certainly lower this key bin, particularly,  
14 electrical cabinets by a substantial amount. Then  
15 they can just plug that in and they are done.

16 If you go back to a new method, then the  
17 whole process of calculating --

18 CHAIRMAN STETKAR: Yes, the whole  
19 allocation process is all different therefore.

20 MR. TRUE: That is --

21 MR. HENNEKE: Yes, Dennis Henneke of GE  
22 Hitachi, representing the Owners Group, BWR Owners  
23 Group. We are collecting the information for the  
24 component counts. And remember, only half the plants  
25 are doing Fire PRA. So the other half we have to go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 collect the data and we have to -- we are having to  
2 then go do walkdowns. So that's slow.

3 We could collect the first half and call  
4 it good, but --

5 CHAIRMAN STETKAR: But then you are  
6 artificially restricting the new data.

7 MR. HENNEKE: Yes. So it's based on the  
8 plants we have.

9 CHAIRMAN STETKAR: When you apply the  
10 frequency of --

11 MR. HENNEKE: So we are trying to collect  
12 data from the majority of the plants or most of them  
13 before we implement it. So that's been very slow. We  
14 were hoping to finish it at the same time, but it is  
15 lagging behind a good, I don't know, five or six  
16 months or something like that.

17 MR. TRUE: It's particularly problematic  
18 for the BWRs, because relatively few BWRs are going to  
19 805.

20 CHAIRMAN STETKAR: You're right. Thanks,  
21 Dennis. I didn't even think of that.

22 MR. WACHOWIAK: The PWRs are a little bit  
23 farther ahead on that.

24 CHAIRMAN STETKAR: But as soon as you say  
25 that you are dealing with a subset of 50 percent of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the population in the denominator, if you will, of the  
2 fire frequency versus 100 percent in the numerator,  
3 and given the rare event nature and the plant-to-plant  
4 variability, you want to be sure you have the whole  
5 population. So okay, understood.

6 MR. HARRISON: John, can I clarify one  
7 thing?

8 CHAIRMAN STETKAR: Yes.

9 MR. HARRISON: This is Donnie Harrison  
10 from the NRC staff. Even though there is only about  
11 half the industry going to 805, there is a significant  
12 number of plants doing other applications that will  
13 need to have a Fire PRA.

14 So it would be naive to assume that other  
15 half is not going to provide component counts to  
16 improve the Fire PRAs. The reality is the majority of  
17 them will be wanting to do tech spec initiatives that  
18 need it. So there should be some incentive for the  
19 entire industry to try to provide that information.

20 CHAIRMAN STETKAR: Yes, I understand. You  
21 know, it's pretty critical of them in terms of what  
22 the industry is proposing to do and the time line.  
23 Obviously, a particular plant, it's a voluntary  
24 process where they want to do a particular risk-  
25 informed application, so they then need to make that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 value judgment about when they, you know, calculate  
2 their fire frequencies or the inventory of equipment.

3 So I understand that problem now. Thanks.

4 MR. TRUE: Okay. I wasn't quite done with  
5 this. We will also be able to deal with these  
6 indeterminant events. And, in fact, as far as this  
7 process, we are going back and collecting some of the  
8 older data also as well as the post-2000 data to try  
9 and build and fill-in some of the blanks for some of  
10 the more significant pathed events.

11 The other thing that we are trying to get  
12 out of this work is that right now, all the fire  
13 events are treated as being at the beginning of this  
14  $t^2$  growth phase. And the reality is, even if you read  
15 the descriptions currently, they are far from that,  
16 many of them. Some of them, I think Ken Canavan's  
17 favorite example is the diesel generator panel  
18 lightbulb that sparked and flamed and went out, got  
19 treated as if it was, you know, a full-on electrical  
20 cabinet fire.

21 So as part of this data collection effort,  
22 we are also trying to get a better handle on where we  
23 are in the actual progression of the fire as part of  
24 this evidence. So we are gathering not just the  
25 significant fires, but also some of the less

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 significant ones to see if we can get a better handle  
2 on this progression through the incipient kind of pre-  
3 fire stage before we get to the  $t^2$  phase and make a  
4 better connection between those.

5 CHAIRMAN STETKAR: So the goal then is not  
6 only to develop a better frequency ultimately on a  
7 component-specific basis, so the frequency of pump --

8 MR. TRUE: Right.

9 CHAIRMAN STETKAR: -- fires accounting  
10 for, you know, plant-to-plant variability, both in the  
11 inventory of pumps and the inventory --

12 MR. TRUE: Right.

13 CHAIRMAN STETKAR: -- of fires is within  
14 that category to develop a conditional probability of  
15 fires of a certain severity?

16 MR. TRUE: Well, I think we want to --

17 CHAIRMAN STETKAR: Is that what it is?

18 MR. TRUE: -- see what all the data tells  
19 us before we exactly say how we are going to frame  
20 that. But we are collecting enough data to be able to  
21 get a more refined treatment of that, however that  
22 ultimately falls-out. And this is, again, a joint  
23 effort between EPRI and NRC. There is a lot of back  
24 and forth on the approach and the rules and while  
25 industry is collecting the data and doing the first

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 run analysis, that both of us are working on it.

2 CHAIRMAN STETKAR: Okay.

3 MEMBER ABDEL-KHALIK: A lot of plants have  
4 roving fire watches.

5 MR. TRUE: Yes.

6 MEMBER ABDEL-KHALIK: And that would  
7 impact to the extent to which the fire progresses.

8 MR. TRUE: Yes.

9 MEMBER ABDEL-KHALIK: At the end of the  
10 day, if a plant goes through this entire process, they  
11 may do away with those fire watches. How do you  
12 account for that change?

13 MR. TRUE: That's a good question. I  
14 don't think we have tackled that or accounted for that  
15 question. It is true, I can't speak specifically to  
16 roving fire watches, but it is true, if you look at  
17 the data, the vast majority of the fires were detected  
18 by someone's nose.

19 MEMBER ABDEL-KHALIK: Right.

20 MR. TRUE: And not by some alarm or  
21 something that came in or actuation of a suppression  
22 system or something.

23 MEMBER ABDEL-KHALIK: Right.

24 MR. TRUE: It's quite early in the  
25 process. And I don't know that we have an answer to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that, to your specific question about how the  
2 truncation of roving fire watches might impact that.  
3 I don't know. I don't know that we have before and  
4 after data on how many roving watches there are today  
5 versus future which you would have to have in order to  
6 do that.

7 MEMBER ABDEL-KHALIK: But if you are  
8 extracting data that would give you an idea about the  
9 extent to which the fire progresses and a significant  
10 parameter that impacts the extent to which the fire  
11 will progress, you know that that will ultimately  
12 change.

13 MR. TRUE: It could.

14 MR. WACHOWIAK: In the new database, the  
15 data structure includes information on how the fire  
16 was detected. And so the new data structure will tell  
17 you which fraction of fires, if you will, were  
18 detected by the fire -- by somebody being near it  
19 versus automatic detection.

20 So we recognize that that's an important  
21 piece of information. And in the new data coding, we  
22 are asking for that information, so that that can be  
23 factored in. It's not necessarily there in the old  
24 data.

25 MR. TRUE: Another thing about the roving

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fire watches, there is a disconnect with the Fire PRA,  
2 too, because the way that the events, and we will talk  
3 about this just in a minute here, electrical cabinets  
4 are assumed to progress from the event in the database  
5 to full-on fire in 12 minutes.

6 Well, the roving fire watches are there  
7 once a shift, twice a shift, something like that, so  
8 they are not really going to be helpful in that  
9 period. It's really the longer period in between in  
10 that development phase that they actually come into  
11 play.

12 So let me also say that, and you sort of  
13 brought this up, but it also applies elsewhere, having  
14 this better database with more complete data and these  
15 additional fields are going to also give us good input  
16 into other activities like nonsuppression, like  
17 control of fires versus suppression of fires that we  
18 can feed into other parts of the Fire PRA.

19 So this is a really important foundational  
20 piece for getting ourselves in a good position to  
21 improve the Fire PRAs as we go forward.

22 CHAIRMAN STETKAR: I hate to ask this, but  
23 why wasn't this done back, you know, five years ago  
24 when NUREG/CR-6850 was developed? Originally, Fire  
25 Events Databases that people put together 25 years ago

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looked at the types of things that you are looking at,  
2 except for the fact that they couldn't count piece  
3 parts among plants.

4 But they looked at when the -- you know,  
5 how was the fire detected, estimates of the size.  
6 Now, that might have been crude, you know, small,  
7 medium, large type fires before it was extinguished.  
8 I'm curious why a lot of this stuff wasn't done, you  
9 know, to assist -- and you probably worked during  
10 this, so --

11 MR. TRUE: I wasn't involved. I wouldn't  
12 want to speculate. JS maybe has something to --

13 MR. HYSLOP: JS Hyslop with Research. The  
14 existing Fire Events Database developed by EPRI does  
15 have places to put detection, who detected it. It has  
16 places for all those, but often, as it was, it was  
17 filled out incompletely or sparsely.

18 CHAIRMAN STETKAR: Okay.

19 MR. HYSLOP: And so that was the  
20 circumstance. And so the 6850 EPRI 1011989 Team went  
21 forward with what they had.

22 CHAIRMAN STETKAR: With what they -- okay,  
23 okay.

24 MR. HYSLOP: Yes.

25 CHAIRMAN STETKAR: Thanks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Okay. Incipient growth phase  
2 of the Fire Events Database, as I mentioned, all the  
3 events in the database were treated as being right at  
4 the beginning of this growth rate. And the results of  
5 that is because that growth rate is assumed to be  
6 fairly rapid, taking electrical cabinets, for example,  
7 being 12 minutes, then it is, basically, a very  
8 limited window for any kind of suppression or control,  
9 which is not what we actually see in the field, but  
10 it's an artifice of the calculation.

11 CHAIRMAN STETKAR: Okay. When you say  
12 it's an artifice of the calculation, who made the  
13 decision, when and why, to treat these fires that way?

14 MR. TRUE: The authors of 6850, I can't  
15 speak for them as to why, it was probably their best  
16 estimate at the time with the data they had available  
17 to make the -- to decide how to treat it. I'm sure  
18 they did it with all the intentions of it being a  
19 reasonable set of assumptions.

20 CHAIRMAN STETKAR: Well, what I'm trying  
21 to get at is did they do it with the intent of being a  
22 reasonable set of assumptions or did some individuals  
23 in isolation do it because it was an expedient way to  
24 do something that they felt was probably conservative,  
25 but not ridiculous?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: I can't answer that.

2 CHAIRMAN STETKAR: Okay.

3 MR. TRUE: I mean, I have my own opinions  
4 about --

5 CHAIRMAN STETKAR: That's all right.

6 MR. TRUE: -- that, but I wouldn't want to  
7 speculate.

8 CHAIRMAN STETKAR: I would like to  
9 understand that, because I see a lot of -- I mean, we  
10 can talk about ignition frequencies, which is  
11 certainly a big important part of the problem. But  
12 that first bullet there, the assumed status of the  
13 fire at the point of ignition --

14 MR. TRUE: Right.

15 CHAIRMAN STETKAR: -- and the way it is  
16 treated going forward in the PRA modeling is a key  
17 assumption.

18 MR. TRUE: Yes.

19 CHAIRMAN STETKAR: Understanding the basis  
20 for that --

21 MR. TRUE: It's a key assumption.

22 CHAIRMAN STETKAR: -- assumption and the  
23 potential amount of realism or conservatism that is in  
24 that assumption, I think, to me, is pretty important,  
25 especially given, you know, cabinet fires.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: We are actually going to talk  
2 about that.

3 CHAIRMAN STETKAR: There is a principle  
4 for everything with cabinet.

5 MR. TRUE: We are going to talk about that  
6 in some detail, John.

7 CHAIRMAN STETKAR: I'll let you go.

8 MR. TRUE: But Dennis wants to add  
9 something.

10 MR. HENNEKE: Yes, Dennis Henneke, GE  
11 Hitachi. I was a reviewer on 6850 and I had -- a  
12 number of these counts you see are in Volume I. 6850  
13 there were open comments on control of fires, all  
14 these things. This particular one,  $t^2$  growth came  
15 from the two sets of tests where the heat release  
16 rates were based on and it was the growth in the tests  
17 themselves, they were piloted tests where they have a  
18 Bunsen Burner in the bottom and they grew, so they  
19 curve fit and used some extra judgment to pick a  
20 single  $t^2$  growth of 12 minutes from those tests.

21 CHAIRMAN STETKAR: But those are people  
22 doing fire growth tests within a cabinet given a pre-  
23 existing ignition source.

24 MR. HENNEKE: Yes, yes.

25 CHAIRMAN STETKAR: And that is not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 integrated with actual operating experience.

2 MR. TRUE: We are going to get to that.

3 CHAIRMAN STETKAR: Yes.

4 MR. TRUE: We have a bunch of slides on  
5 that.

6 CHAIRMAN STETKAR: Go for it.

7 MR. TRUE: We'll get to that. Okay. Oil  
8 severity. Just with the highest level, we think that  
9 the treatment -- I think it was probably a  
10 conservative assumption. Let's see how this works out  
11 kind of thing. And we found that that is true.

12 FAQ-044 addressed that for main feedwater  
13 pump fires, because what we found was if you use those  
14 assumptions, you burn down the turbine building pretty  
15 much every time, then that wasn't very helpful to the  
16 analysis.

17 So we now adjusted the main feedwater pump  
18 oil fire distribution from the 98.2 percent thing we  
19 showed before to a new one. But there were other  
20 components that need that same kind of treatment also,  
21 pumps, transformers and diesel generators.

22 CHAIRMAN STETKAR: Was that adjustment  
23 based on actual experience data?

24 MR. TRUE: Yes, a combination. Mostly  
25 experience, but there were some, obviously, judgments

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 involved.

2 Okay. We'll turn now to Category II, the  
3 Fire Growth Rate, which also is going to include this  
4 12 minute thing as well as the peak heat release rate  
5 discussion.

6 I want to talk about fire growth  
7 assumptions, peak heat release rates and detail. We  
8 have some other areas we think need some further  
9 refinement. Again, a lot of these were FAQs that got  
10 to some state, but we think need some further  
11 development. Energy arcing faults, bus duct energy  
12 arcing faults, sensitive electronic equipment and how  
13 that is treated.

14 Electrical cabinet propagation within the  
15 -- propagation within the cabinet and then fire  
16 modeling. There is a NUREG out for drafts, there is  
17 work going on currently on refining that method. I'm  
18 going to talk about these first couple here in some  
19 more detail.

20 Fire growth assumptions. Electrical fire  
21 growth rates is very course and don't really address  
22 much in the way of their bin. There are a handful of  
23 bins, but they really only look at a cabinet and what  
24 type of cable is in the cabinet and maybe the quantity  
25 of cabinets, but doesn't always address things like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ventilation, limited conditions. It certainly doesn't  
2 address the voltage of the cabinets and so it's a very  
3 course approach.

4 And we have the other problem of the fires  
5 in the database don't appear to be right there where  
6 they are ready to grow and then we connect those  
7 events to this 12 minute growth thing. And that 12  
8 minutes turns out as pretty limiting in terms of  
9 intervention actions and doesn't allow us to get  
10 credit for much in the way of detection control or  
11 suppression.

12 Improved database is going to help this,  
13 but I want to go through some of the background on  
14 this. So the 12 minute growth rate assumption comes  
15 from a series of tests that were done and, basically,  
16 the majority of those tests were done in a situation  
17 where they put a polyethylene bucket that -- a quart  
18 of acetone and a pound of kimwipes in there, fluffs up  
19 the kimwipes and lit it on fire and had a flame of the  
20 height of about 33 feet high and it burned for about  
21 35 minutes.

22 CHAIRMAN STETKAR: Just to make sure for  
23 the transcript, that's a flame height of 3 feet high,  
24 right?

25 MR. TRUE: 3 feet.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay.

2 MR. TRUE: What did I say?

3 CHAIRMAN STETKAR: 33.

4 MR. TRUE: Oh, 3 feet. I stuttered I  
5 guess. 3 feet. And then, you know, the first test  
6 they did it, that wasn't enough, so they had to  
7 separate the cable bundles apart, so there was more  
8 surface area on the cables to make sure that they  
9 caught on fire.

10 So this was a test that was done for a  
11 very specific purpose. It was to look at, you know,  
12 the maximum magnitude you might see out of this. But  
13 it became a reference point for how we are trying to  
14 realistically portray a PRA.

15 CHAIRMAN STETKAR: I don't remember, Doug,  
16 do you remember the date on that NUREG? Was it --

17 MR. TRUE: Oh, it was probably in the late  
18 '80s because 450 was 11/15 and that was late '80s. So  
19 it was probably in that mid to late '80s, I would  
20 guess.

21 So if we -- out of this NUREG there is a  
22 graph that actually shows just the heat release rate  
23 of the ignition point. And it shows that in, lo and  
24 behold, about a 12 minute period, that buck of  
25 kimwipes and acetone gets up to a limit, burns for a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 while and then eventually tapers off.

2 If we take that trace and we look at it  
3 compared to some of the other tests that we have that  
4 are used to actually set the heat release rates for  
5 the fires in the cabinets, here is a set of five  
6 traces. A couple of interesting points.

7 The first two tests, ST1, down there in  
8 the solid black line, actually didn't even ignite the  
9 cables, didn't have any propagation at all. I'm  
10 sorry, that's ST2. ST1, there was no burning. The  
11 second one, it burned the cable locally, but never  
12 actually propagated.

13 If we overlay that curve I just showed you  
14 from the ignition source only, you can see that it  
15 basically overlaps those first two tests, which makes  
16 sense. If there was no real burning propagation, you  
17 would expect to get about the same curve.

18 The problem comes in that the peak heat  
19 release rates that are shown in ST5 and 4 and 3 are  
20 the peak heat release rates that are used to set the  
21 peak heat release rates or at least inform the peak  
22 heat release rates in the analysis, but they don't  
23 actually subtract out the heat release rate input from  
24 the fire.

25 So at 136 kilowatts that are shown up

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there in ST5, there is a data point in there, but 30  
2 kilowatts of that is actually coming from the fire,  
3 not from the panel itself.

4 So we have got a little disconnect here in  
5 how the data was interpreted. Even if you accept the  
6 fact that kimwipes and acetone are relevant to the  
7 ignition of a fire that we see in our Fire Events  
8 Database, there is a disconnect in the way this was  
9 applied.

10 Certainly, the way it has been applied is  
11 conservative. Certainly, it would reflect that of  
12 significant, more significant impact than we might see  
13 from the real events. But it -- there is just a  
14 disconnect in this. And it is interesting that the 12  
15 minutes is pretty consistent across all the studies.  
16 In fact, there is quite a table, maybe even in here,  
17 that is in 6850. It shows they are all about the  
18 same. And I was like why are they all the same? It  
19 doesn't make sense it would grow at the same rate.

20 Well, it's because the flames are getting  
21 big at that rate and that's the peak point that occurs  
22 right after that flame builds up.

23 CHAIRMAN STETKAR: Do you have any --  
24 maybe this is a leading question, if I drop the peak  
25 heat release rate, you know, give me the 12 minutes,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 but if I drop the peak heat release rate from 135 down  
2 to 100 kilowatts, 90 kilowatts whatever make a lot of  
3 very big difference on the zone of influence?

4 MR. TRUE: Yes, it does.

5 CHAIRMAN STETKAR: Okay.

6 MR. TRUE: 12 minutes is --

7 CHAIRMAN STETKAR: The 12 minutes is more  
8 important than --

9 MR. TRUE: -- more important.

10 CHAIRMAN STETKAR: -- the magnitude of  
11 this.

12 MR. TRUE: But the problem -- yes, right.

13 CHAIRMAN STETKAR: Okay. That's --

14 MR. TRUE: There are some other issues,  
15 too.

16 CHAIRMAN STETKAR: No, no, I am just  
17 trying to get a feel for --

18 MR. TRUE: Yes, I think that's a fair  
19 question.

20 CHAIRMAN STETKAR: All right.

21 MR. TRUE: The other thing is that a lot  
22 of the tests in order to get a big fire going with all  
23 that nice acetone and kimwipes in there, the doors are  
24 open to make sure there is plenty of air to feed the  
25 fire. Well, of course, when you walk through a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 nuclear power plant, you don't see a lot of electrical  
2 cabinets with their doors open.

3 So there is actually work going on with  
4 EPRI that we're looking at this ventilation limited  
5 condition where we have less flow of air that may be  
6 controlling the rate of growth in the rate of peak  
7 heat release rate from those fires. So that's that.

8 My other favorite test is PCT4 there where  
9 they put 15 gallons of, essentially, gasoline in the  
10 bottom of the cabinet, that's also used to inform the  
11 growth rate in the peak heat release rate information,  
12 too.

13 And then you also see that benchboard and  
14 vertical are kind of altogether. That happens also in  
15 the assignment of the peak heat release rates.  
16 Benchboard cabinets are like the control room type  
17 cabinets versus a vertical cabinet, more like a, you  
18 know, electrical distribution cabinet.

19 Whoops. There is also a mixture of  
20 qualified and unqualified cables that are included in  
21 the tests. And our ST1 and ST2, this is a table that  
22 actually shows that time to peak heat release rate, so  
23 this is the thing that comes up with the 12 minutes.  
24 It was actually 11.4 and they rounded it up to 12.  
25 And you can see they are all pretty consistent in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 their growth rate, which, given the ignition source,  
2 that's not entirely surprising.

3 And another concern that we have is that  
4 the qualified and unqualified cables are not aligned  
5 with the rules in 6850 on how you assign the peak heat  
6 release rates. So that when we look at the results of  
7 the peak heat release rate stuff in 6850, it doesn't  
8 really fit.

9 Now, if you look at the conclusions, these  
10 are actually cut and pasted right out of 4575, it says  
11 that qualified cable fires invertible cabinets do not  
12 spread without the cabinet -- throughout the cabinet.

13 This is with the acetone, with the heptane or  
14 whatever in there. They don't spread.

15 Unqualified cables easily ignite and  
16 propagate through the cabinet. And it does say that  
17 the burning rate is affected by the ventilation  
18 method, whether you have constraints or not. But  
19 those weren't carried forward in the assignment in  
20 6850 of the heat release rates completely.

21 CHAIRMAN STETKAR: Doug, before -- I don't  
22 know which way you went on that one, but for my  
23 benefit and I think others on the Subcommittee, we are  
24 talking about heat release rates from cabinets. Now,  
25 you are talking about qualified versus unqualified

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cables within the cabinet.

2 In a practical PRA, I mean, the ones that  
3 have been, you know, done that you are familiar with,  
4 is there -- when you are developing a cabinet heat  
5 release rate, when you are going through the analyses,  
6 is it more important to understand that in terms of  
7 damage within the cabinet and the time to damage  
8 within the cabinet or is it for cables outside?

9 MR. TRUE: The cables outside.

10 CHAIRMAN STETKAR: Okay. The only reason  
11 I'm getting to that is the implications of maybe I  
12 don't need to know an awful lot of details about  
13 precisely what is in that cabinet, if I'm not looking  
14 at within cabinet things. Some of the implications  
15 from what you have shown here, at least led me to --

16 MR. TRUE: Are --

17 CHAIRMAN STETKAR: -- the conclusion that  
18 gee, I really need to know a lot of details about  
19 precisely what is in that cabinet, if I'm going to do  
20 that within that cabinet.

21 MR. TRUE: If you are going to do it  
22 within the cabinet. And that typically has not been  
23 done. It is mostly the external, which also then  
24 feeds the spurious op phase.

25 CHAIRMAN STETKAR: No, I understand that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 But I'm trying to get to in terms of what -- back to  
2 the ridgeline, in terms of what is driving the  
3 ridgeline, is that primarily within cabinet fires that  
4 you feel could be further refined to limit the damage  
5 within a cabinet or is it primarily external damage  
6 from the cabinet?

7 MR. TRUE: Primarily external.

8 CHAIRMAN STETKAR: Okay.

9 MR. TRUE: There is some internal, but  
10 primarily external.

11 CHAIRMAN STETKAR: Yes, but, in that  
12 sense, it's the cabinet-related heat release rate.

13 MR. TRUE: Yes.

14 CHAIRMAN STETKAR: And the time to  
15 develop, you know --

16 MR. TRUE: Right.

17 CHAIRMAN STETKAR: -- the peak heat  
18 release rate --

19 MR. TRUE: Right.

20 CHAIRMAN STETKAR: -- from the cabinet.  
21 Okay. It's important to know what kind of cabinet  
22 and, you know, general inventory of, I'll use the  
23 technical term, stuff that's in that cabinet, but not  
24 as important compared to doing a detailed within  
25 cabinet fire --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Right.

2 CHAIRMAN STETKAR: -- ignition growth.

3 MR. TRUE: Now, there has been some  
4 dialogue about trying to model inside a cabinet and no  
5 one has --

6 CHAIRMAN STETKAR: That's --

7 MR. TRUE: -- that much confidence in the  
8 firewall.

9 CHAIRMAN STETKAR: Well, and if you tried  
10 to do that through your, what is it, 1,362 cabinets in  
11 the plant, it would be --

12 MR. TRUE: Right.

13 CHAIRMAN STETKAR: -- difficult.

14 MR. TRUE: Right.

15 CHAIRMAN STETKAR: Okay.

16 MEMBER ABDEL-KHALIK: I --

17 MR. WACHOWIAK: Go ahead.

18 MEMBER ABDEL-KHALIK: I guess, okay, I  
19 listen to this and you think, you know, who in his  
20 right mind would design, you know, a set of  
21 experiments in this manner to give you these two  
22 parameters, the heat release rate and the time to  
23 growth?

24 What was the rationale for running the  
25 experiments the way they were run?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: These were not PRA studies.  
2 These were fire protection studies.

3 MEMBER ABDEL-KHALIK: I understand.

4 MR. TRUE: These were done to try and burn  
5 things to see how -- the manner in which things  
6 propagate. What happens if you have a big fire going,  
7 what happens. And in that sense, and there is ongoing  
8 research that is being done the same way, let's burn  
9 the stuff up and see how bad it looks.

10 MEMBER ABDEL-KHALIK: But the basic  
11 experiment was not to get the two parameters that you  
12 are looking for.

13 MR. TRUE: No.

14 MEMBER ABDEL-KHALIK: Is it?

15 MR. TRUE: No, it was not its purpose.  
16 And it is, in fact, very hard to devise a test to get  
17 what we want. And, in fact, I believe there was work  
18 done by Sandia where they tried to start a fire by  
19 creating a fault and they couldn't get it to  
20 propagate.

21 CHAIRMAN STETKAR: Right.

22 MR. TRUE: But we know they propagate,  
23 because we have fires.

24 MEMBER ABDEL-KHALIK: Well --

25 MR. TRUE: I mean, so it's not that we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think the fires don't happen. We know they happen.  
2 It's just that you devise a test. It's a lot easier  
3 to devise a test that provides an envelope than it is  
4 to give you a realistic distribution of what is going  
5 on.

6 And I've got to give credit to the  
7 authors. They acknowledge that and they tended to put  
8 the results from these kind of fires at the high end  
9 of the distribution, 98<sup>th</sup> percentile or 75<sup>th</sup> percentile  
10 of the distribution. But it still pulls everything  
11 way up. And when you fit the code back, your bottom  
12 end doesn't really go down to even where we believe  
13 the real results are, particularly in light of all  
14 these other factors of ventilation, qualified cables  
15 and things that aren't accounted for.

16 MEMBER ABDEL-KHALIK: I'm just trying to  
17 figure out if this is a doable problem in terms of  
18 coming up with realistic data.

19 MR. TRUE: I think the work -- and we  
20 should -- maybe next time we should spend a little bit  
21 of time talking about the work that is going on right  
22 now with EPRI where they are trying to derive better  
23 information about these more limiting cases for  
24 specific cabinet configurations that will help us  
25 break that bin apart into the ones that matter.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   There are bins -- places where this  
2 probably applies.

3                   CHAIRMAN STETKAR: I think Said said that  
4 it's all telegraph. Certainly, in December we will  
5 want to hear more about this.

6                   MR. TRUE: Okay.

7                   CHAIRMAN STETKAR: From all interested  
8 parties.

9                   MR. TRUE: All right.

10                  CHAIRMAN STETKAR: The whole topic and  
11 I'll integrate it in terms of fire ignition frequency  
12 with corresponding heat release rate for electrical  
13 cabinets.

14                  MR. WACHOWIAK: Yes, we should be ready to  
15 talk about that in December.

16                  CHAIRMAN STETKAR: I hope so, because --

17                  MR. WACHOWIAK: Right now --

18                  CHAIRMAN STETKAR: -- if you are not, we  
19 are going to have some difficulties as a Committee.

20                  MR. WACHOWIAK: -- the report is in the  
21 middle of the technical review process. So --

22                  CHAIRMAN STETKAR: I mean, I've heard  
23 enough, you know. We have heard enough, I think, this  
24 morning and through other things that this is one of  
25 the larger, if not the, you know, tip of the iceberg,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if you will, in terms of issues that people are  
2 struggling with. And in our charter in trying -- in  
3 terms of trying to understand the source of the  
4 problem, if it is a problem, and what may be done,  
5 which is where Said is kind of headed, as much as you  
6 can enlighten us in December --

7 MR. TRUE: Okay.

8 CHAIRMAN STETKAR: -- on this particular  
9 topic. And there may be others, but this one  
10 certainly.

11 MR. TRUE: Okay. So This growth rate has  
12 a lot of ramifications. You know, those were tests,  
13 as you pointed out, Said, designed to cause damage and  
14 all the fires in 6850 are treated as propagation is  
15 possible. The growth rate was set by this transient  
16 ignition source, basically, acetone and kimwipes, set  
17 the ramp up. We got the gasoline test, open and  
18 closed doors, qualified/unqualified cables, doors open  
19 on cabinets. There just needs to be additional  
20 refinement to this bin.

21 And, you know, for a first cut, let's go  
22 try this and see what the results look like. You  
23 know, it was a fine attempt, but we're finding that it  
24 is, obviously, not comporting with our operating  
25 experience, so we think we need to go back and make

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this refinement. It's the main theme of today.

2 It's hard to really figure out exactly how  
3 this plays out in the CDF. I think it is probably on  
4 the order of a factor of 2-5 on overall CDF. It may  
5 be more that than depending on how much credit you  
6 take during the growth rate.

7 CHAIRMAN STETKAR: Given the presentation,  
8 I'm surprised that you are saying only 2-5, but --

9 MR. TRUE: Well, that's just the growth  
10 rate. The peak heat release rate is another factor.

11 CHAIRMAN STETKAR: Oh.

12 MR. TRUE: So we will be talking about  
13 that --

14 CHAIRMAN STETKAR: Okay.

15 MR. TRUE: -- next.

16 CHAIRMAN STETKAR: You are just talking  
17 about the 12 minutes.

18 MR. TRUE: This is the 12 minutes.

19 CHAIRMAN STETKAR: Okay.

20 MR. TRUE: Just the 12 minutes.

21 MEMBER ABDEL-KHALIK: 2-5 here?

22 CHAIRMAN STETKAR: No, no. Okay.

23 MR. TRUE: So the bins are pretty simple.  
24 They -- it's a mix-and-match of test results to  
25 assign those and we will get into this in a little bit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 more detail. Distribution doesn't seem to comport  
2 with what we have seen in experience.

3 And another problem, and I apologize to  
4 the authors of 6850, but it's not exactly clear how  
5 they got to the conclusion they got to in assigning  
6 all the CDP heat release rates. I think we need to  
7 get to a more scrutable process for doing that.

8 And in today's time, it wouldn't really  
9 meet what we expect out of a PRA in the PRA Standard,  
10 for example, on how you do an expert judgment.

11 So it's a simple scheme. I think we have  
12 got that coming out. Electrical cabinets are a major  
13 contributor. We think we are overstating those  
14 effects in the spurious ops that come from that. And  
15 then we think it is going to make it difficult to make  
16 some decisions going forward.

17 CHAIRMAN STETKAR: Let me ask you, Doug,  
18 another kind of question. It's clear again from that  
19 ridgeline that we saw in the other slide that  
20 electrical cabinet fires are a major contributor.  
21 And, you now, your assertion is that that is not  
22 consistent with actual operating experience.

23 So it overstates the effects of fires. Do  
24 you have any sense at all whether we are somehow  
25 skewing the relative effects from fires in different

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 types of cabinets compared to, I'll use, operating  
2 experience or what you might expect given what you  
3 have looked at in terms of the data and sources?

4 So for example, it's not just are we  
5 overstating the absolute magnitude from the cumulative  
6 effects from all electrical cabinet fires, given that  
7 we are treating telephone cabinets the same as, you  
8 know, 13kV switchgear with some minor differences?

9 But are we skewing the results because of  
10 that treatment, such that certain types of cabinets in  
11 certain configurations might present a higher relative  
12 risk than what we are calculating compared to other  
13 cabinets in other configurations that would be much  
14 lower?

15 MR. TRUE: I think so.

16 CHAIRMAN STETKAR: Which comes back to the  
17 fidelity of how do you understand the risk results.

18 MR. TRUE: I think Harris struggled with  
19 this, too, and one of their dominant contributors was  
20 a low voltage electrical cabinet. And yet, it was  
21 treated in the same bin as the, you know, 4kV  
22 switchgear with the same peak heat release rates.

23 And so my sense is, and we haven't got an  
24 operating experience basis clearly put together that  
25 says that it doesn't match up with operating

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 experience, but my sense is, if you look at the events  
2 in the database, and you look at what we are  
3 calculating, we are -- we do need to sort of segregate  
4 out different types of cabinets more.

5 CHAIRMAN STETKAR: So, you know, what I'm  
6 saying is presume that the cumulative frequency of  
7 those fires remained the same, it's just that we  
8 allocated them differently and developed different  
9 heat release rates as a function of cabinet type --

10 MR. TRUE: Yes. I think --

11 CHAIRMAN STETKAR: -- you know, in  
12 principle some cabinets might be worse. We might have  
13 a higher frequency of more damaging fires that would  
14 reach cables at a larger distance above a cabinet, you  
15 know, Configuration X --

16 MR. TRUE: Yes.

17 CHAIRMAN STETKAR: -- compared to a  
18 different configuration where we are underestimating.

19 MR. TRUE: I think high energy arcing  
20 falls in not electrical cabinets.

21 CHAIRMAN STETKAR: High energy arching  
22 falls is a way to get around that.

23 MR. TRUE: There's another one though  
24 where I think we sort of treat everything as being  
25 susceptible and I think the evidence says maybe not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 everything is susceptible, which means that we are --  
2 because we smear it --

3 CHAIRMAN STETKAR: Yes.

4 MR. TRUE: -- across those, which means we  
5 are understating the risk for a certain part of it and  
6 overstating the risk for another part. So yes, I  
7 think that exists in electrical cabinets and --

8 CHAIRMAN STETKAR: Okay.

9 MR. TRUE: -- in other areas --

10 CHAIRMAN STETKAR: Okay. I was just  
11 trying to get your sense --

12 MR. TRUE: -- of the --

13 CHAIRMAN STETKAR: -- a little bit,  
14 because --

15 MR. TRUE: Yes. I think --

16 CHAIRMAN STETKAR: -- I'm sensing not just  
17 the overall, it's the fidelity of the risk assessments  
18 as they are currently being developed to understand  
19 the contributors to risk, whatever the absolute  
20 magnitude of that risk is.

21 MR. TRUE: Right.

22 CHAIRMAN STETKAR: Because decisions are  
23 made based on those.

24 MR. TRUE: Right, exactly. And I think  
25 that's what we are concerned about is that we get the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wrong dominant contributors and we don't have the best  
2 basis for making our decisions.

3 MR. HYSLOP: JS Hyslop with Research.  
4 There was a FAQ where we did distinguish among high  
5 energy arcing faults between low and medium volt  
6 cabinets for frequency. And so we have done that.  
7 And the model that we used is based on an event. And  
8 so we didn't use all high energy arcing fault events  
9 in establishing frequency as well, so there has been  
10 some specialization.

11 CHAIRMAN STETKAR: Okay. Thanks.

12 MR. TRUE: Okay. This is a table out of  
13 6850 that -- this is the table that covers electrical  
14 cabinets. So there are five bins and you decide what  
15 kind of a cabinet you have and then you allocate your  
16 frequency to that cabinet based on which one of these  
17 categories it fits into.

18 I just want to highlight a couple of  
19 things on here. The first two are qualified cables.  
20 The other three are for unqualified cables. The first  
21 two, the 98<sup>th</sup> of the first row, which was one cable  
22 bundle and the second row is the 25<sup>th</sup> percentile, the  
23 second row.

24 CHAIRMAN STETKAR: Before you get into all  
25 of the numbers, let me just understand. You say,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 again, if I'm doing my PRA today -- you can keep the  
2 qualified underlined there. If I have a cabinet and I  
3 say my cabinet has qualified cables, does that mean  
4 every single millimeter of cable in that cabinet must  
5 be a qualified cable, if it's not, then I have, by  
6 definition, a cabinet that has unqualified cables?

7 MR. TRUE: I think that's the way it has  
8 been implemented.

9 CHAIRMAN STETKAR: That -- when you say  
10 think, is it? I don't know.

11 MR. TRUE: I am pretty sure. Dennis is  
12 nodding back there. I'm pretty sure that's the way it  
13 is being implemented.

14 CHAIRMAN STETKAR: Okay. So as long as I  
15 have one unqualified cable in this cabinet, and this  
16 could be an electronics cabinet that has got, I don't  
17 know, a couple of miles of qualified cables in it, but  
18 as long as I have on unqualified cable in it, it's --  
19 they apply the unqualified criteria?

20 MR. TRUE: Yes, and I think the general  
21 approach to this has been set up, so that people will  
22 tend to default to the more conservative --

23 CHAIRMAN STETKAR: Okay.

24 MR. TRUE: -- position.

25 CHAIRMAN STETKAR: I just wanted to make

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sure how -- whether there was any thought about, you  
2 know, the majority is qualified or --

3 MR. TRUE: The cable trays are the same  
4 way.

5 CHAIRMAN STETKAR: The cable trays are the  
6 same?

7 MR. TRUE: Yes, one unqualified cable,  
8 then it is --

9 CHAIRMAN STETKAR: Okay. Thanks.

10 MR. TRUE: Okay. I should maybe explain  
11 this before I jump into it, too. So the distribution  
12 of heat release rates was -- were anchored to a 98<sup>th</sup>  
13 percentile and 75<sup>th</sup> percentile and then a distribution  
14 was fit into those to give you the distribution for --  
15 of different peak heat release rates for your  
16 analysis.

17 So and those peak heat release rates, the  
18 anchor points, were set based on tests. And it turns  
19 out that the 98<sup>th</sup> percentile in the first room was  
20 anchored, for a single bundle, to a test of  
21 unqualified cable. And the 75<sup>th</sup> percentile on the  
22 multiple cable bundle was anchored to that same test  
23 result.

24 Well, if you look at the results of 4527,  
25 it says "Qualified cable and unqualified cable behave

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 entirely differently and will propagate fire.  
2 Qualified cable won't propagate."

3 So we have already mixed and matched now  
4 our test results, which are unqualified and applied  
5 them to qualified cables.

6 The 702 one that the industry likes to  
7 bandy about, the 700 kilowatt fire, is actually a  
8 benchboard test with open doors. It's like, you know,  
9 just open the whole thing up and lots of cables in it.

10 And that is being applied, essentially, into almost  
11 all of the cabinets, because we can't go and open  
12 every single cabinet. And so if we can't open it to  
13 prove there is only one cable bundle, we're going to  
14 have to assume there is multiple cable bundles.

15 So we end up anchoring ourselves to these  
16 two tests that have, arguably maybe, less connection  
17 to what our real design is than we would like.

18 CHAIRMAN STETKAR: Just out of curiosity,  
19 was the benchboard test done with only qualified  
20 cables in those bundles or were they --

21 MR. TRUE: I don't recall.

22 MEMBER SHACK: The benchboard with  
23 qualified cable.

24 MR. TRUE: Qualified.

25 CHAIRMAN STETKAR: I knew you would have--

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I saw you looking.

2 MEMBER SHACK: Right.

3 CHAIRMAN STETKAR: Okay. But that's a  
4 fully ventilated --

5 MR. TRUE: Yes.

6 CHAIRMAN STETKAR: -- configuration?

7 MR. TRUE: Yes, with a much -- with a  
8 quite large combustible loading also.

9 CHAIRMAN STETKAR: Yes, yes.

10 MR. TRUE: Because it's, you know --

11 CHAIRMAN STETKAR: It's a benchboard.

12 MR. TRUE: -- it's a benchboard. All  
13 kinds of stuff here.

14 Okay. Transient ignition sources, there  
15 are three bins that, based on different locations in  
16 the plant --

17 CHAIRMAN STETKAR: Could you go back to  
18 that? Again, it is too hard to run the numbers right  
19 now, but either for the paper or when you come back in  
20 December, I would be curious to see what the real  
21 parameters of those distributions are. You know,  
22 you're showing 98 and 75<sup>th</sup>. I would like to see what  
23 the fifth and median and the mean are.

24 MR. TRUE: Yes, there is another table  
25 that has all that in it in 6850.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay.

2 MR. TRUE: Yes.

3 CHAIRMAN STETKAR: In 63?

4 MR. TRUE: Yes, it's in 6850.

5 CHAIRMAN STETKAR: I'll find it then.

6 Never mind.

7 MR. WACHOWIAK: And I think what you will  
8 find is that for the qualified cable bin, more than  
9 one bundle, the smallest allowable heat release rate  
10 associated with the fifth on the bin still gives you a  
11 fire that affects things outside the cabinet.

12 MR. TRUE: It is.

13 MR. WACHOWIAK: Even though the conclusion  
14 of the report was if you have qualified cable, it  
15 doesn't affect the outside of the cabinet.

16 CHAIRMAN STETKAR: I was just curious  
17 whether -- I didn't have a sense and I don't remember  
18 that distribution that -- going from the 98<sup>th</sup> to the  
19 75<sup>th</sup> on that second line is a pretty broad range.

20 MR. WACHOWIAK: And it's a gamma  
21 distribution.

22 CHAIRMAN STETKAR: Yes. I don't have a  
23 sense of the gamma as well.

24 MR. WACHOWIAK: There is a table that  
25 elaborates that in 6850.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay. But the key is,  
2 you said even the fifth percentile is large enough to  
3 get you admission from -- at some reasonable distance  
4 above the top of the cabinet.

5 MR. TRUE: Think of the vertical cabinet,  
6 that's where they actually did strictly vertical  
7 cabinets. The maximum peak heat release rate that was  
8 observed was more around 100 kw.

9 MR. WACHOWIAK: Maybe under 100.

10 MR. TRUE: 80 or 90.

11 MR. WACHOWIAK: Yes.

12 MR. TRUE: Yes. And I'm not sure that  
13 accounts for the subtracting out of the source either,  
14 so they are much, much lower than 700. Not that 700  
15 couldn't happen in a certain circumstance.

16 CHAIRMAN STETKAR: Oh, sure, yes.

17 MR. TRUE: But we are applying that now to  
18 every cabinet, essentially, in the whole plant.

19 CHAIRMAN STETKAR: Telephone cabinet, in  
20 principle.

21 MR. TRUE: Yes, yes. Okay. Transient  
22 ignition sources. There are three bins that are  
23 basically divided into different portions of the  
24 plant. The heat release rate data for those are based  
25 on tests that were performed on trash bags that had

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transient combustibles in them, which is, you know,  
2 fine. It was a calculation done to see how much heat  
3 you could get out of a trash bag that was set on fire.

4 The problem is that if we look at the Fire  
5 Events Database, the events that we are dealing with  
6 are not trash bags. There are very few events that  
7 have anything to do with a bag of trash that got lit  
8 on fire.

9 Most of them are things like space  
10 heaters, extension cords, some kind of scaffolding  
11 that got caught on fire and there is only one in the  
12 whole database that had anything to do with a trash  
13 receptacle was put into it.

14 And so again, we have got a disconnect  
15 between modeling it as these events cause this  
16 frequency, which causes this heat release rate, and  
17 that heat release rate is pretty substantial from the  
18 ignition -- transient ignition sources.

19 So we think that is overstating the  
20 transient combustibles. You asked earlier, John, how  
21 many plants will be affected by that. It's very  
22 plant-specific. There are some that would be affected  
23 by improving this.

24 CHAIRMAN STETKAR: Yes, the whole issue of  
25 heat release rate, given the fact that we are talking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about transients, is a little more difficult in terms  
2 of uncertainty. I'm not quite sure how a databased  
3 approach might address that issue.

4 MR. TRUE: Well, again, the Fire Events  
5 Database will help us a little bit more in  
6 understanding what the real events are. But you ought  
7 to count the real events to the --

8 CHAIRMAN STETKAR: Well, people don't have  
9 all that many transient fires. Whether you are  
10 cutting fires during shutdown there is public good.

11 MR. TRUE: Well, those are bins. Well, I  
12 mean, could --

13 CHAIRMAN STETKAR: No, I -- yes.

14 MR. TRUE: Right. So other sources. We  
15 have been talking about electrical cabinets primarily.

16 CHAIRMAN STETKAR: Yes.

17 MR. TRUE: And there are issues there that  
18 need to be worked through. There are other problems  
19 we think that exist and other contributors that pop up  
20 from time to time in plants. And, in fact, Table G-1  
21 of 6850, in a couple of cases, basically, took  
22 electrical cabinet fire test data and applied it to a  
23 pump and a fan and said we know this is conservative,  
24 but it's what we have. So they applied it.

25 So in the pump electrical fires, it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anchored to the 98<sup>th</sup> percentile and 211, again, the  
2 same test as the vertical cabinets. And there is a  
3 note that specifically points to those pumps and  
4 motors and says those are -- no, it's not down there.

5 We know it's conservative, but it's the best we could  
6 do.

7 CHAIRMAN STETKAR: Now, again, before we  
8 get to the framework here. If I think going forward  
9 you have talked a lot about cabinet heat release rates  
10 and the source of the estimates for those and you  
11 talked a little bit about transients and there are  
12 some other things that there might be concerns.

13 In terms of trying to focus on issues  
14 where right now, you know, given the knowledge that we  
15 have about the PRAs that, let's say Harris and Oconee,  
16 had been submitted and the other NFPA 805 Projects  
17 that are -- must be fairly well along in their Fire  
18 PRA Analysis.

19 Is it possible to say that we can focus on  
20 one or two areas in terms of heat release rate  
21 analyses that will solve the vast majority of problems  
22 or do we need to equally address every possible bin in  
23 terms of heat release rates, because we can't be  
24 confident until we do that?

25 MR. TRUE: Well, the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Of course, I'm going  
2 to --

3 MR. TRUE: -- spectrum, right?

4 CHAIRMAN STETKAR: Well, yes.

5 MR. TRUE: So --

6 CHAIRMAN STETKAR: But honestly, in terms  
7 of pragmatism, I'm looking for issues that the  
8 industry has found to be very, very significant in  
9 areas where, in a sense, you get the most return on  
10 investment in terms of doing whether it is additional  
11 experimental testing or whether it is a more elaborate  
12 expert elicitation process using, you know, a broader  
13 source of other types of test data, I'm not sure what.

14 But in terms of expediency and pragmatism, you know,  
15 are there specific areas that the industry would say  
16 yes, indeed, these should be addressed today to give  
17 us higher confidence in the studies that are being  
18 done today?

19 MR. TRUE: Yes.

20 CHAIRMAN STETKAR: Whereas, other issues  
21 yes, indeed, there are concerns. You know, you have  
22 highlighted a few on this slide. But in practice, at  
23 least where we are today, there is a less compelling  
24 reason to launch off into, you know, running tests on,  
25 you know, pump fires or something like that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Yes. I think --

2 CHAIRMAN STETKAR: You don't have to  
3 answer that right now, necessarily, but think about it  
4 a little bit and maybe by the end of the day, you  
5 might confirm --

6 MR. TRUE: I understand where you are  
7 coming from and I understand the motivation. And I'm  
8 going to partially satisfy you, I think.

9 CHAIRMAN STETKAR: Okay.

10 MR. TRUE: Certainly, electronic cabinets  
11 are an area of focus.

12 CHAIRMAN STETKAR: Okay.

13 MR. TRUE: And the first database chart we  
14 put up pointed that out.

15 CHAIRMAN STETKAR: Yes.

16 MR. TRUE: It's certainly an area of  
17 focus. And there are a couple of aspects of it. The  
18 heat release rates on the growth rates are important.  
19 The ignition frequencies, I think, are important.

20 CHAIRMAN STETKAR: Yes.

21 MR. TRUE: So I think we've got to do the  
22 ignition frequency work, right? Electrical cabinets  
23 certainly are a first priority and there is already  
24 work going on on that.

25 CHAIRMAN STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: The problem, this will be the  
2 dissatisfying part of that, is that, I think, those  
3 little blips that are out there are problematic for  
4 that individual plant, for that individual scenario.  
5 And right now the way that the process works is you  
6 are pretty much expected to follow 6850 as a cookbook  
7 and the standard for justifying a deviation is quite  
8 high.

9 CHAIRMAN STETKAR: Okay.

10 MR. TRUE: And so we are -- even those  
11 individual utilities where -- there are individual  
12 problematic scenarios hanging out there, if we don't  
13 try to do a more broad assessment than just electrical  
14 cabinets. In terms of priority, electrical cabinets  
15 and data are definitely first priority. We are  
16 working those.

17 The other ones, you know, it's going to be  
18 a case-by-case basis.

19 CHAIRMAN STETKAR: Okay. You know, some  
20 people, at one time, had really badly operated  
21 turbine-driven auxiliary feedwater pumps on a plant-  
22 by-plant basis that might have been maintenance or  
23 whatever.

24 MR. TRUE: Yes.

25 CHAIRMAN STETKAR: They got over that, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know, internal event. So again, what I'm trying to  
2 focus on is right now the areas that, across the board  
3 in the industry, would have the most benefit.  
4 Recognizing that, you know, hopefully the process is  
5 not going to end at the end of 2011.

6 MR. TRUE: No.

7 CHAIRMAN STETKAR: Well, no. Regardless  
8 of whatever timescales they are on.

9 MR. TRUE: Right.

10 CHAIRMAN STETKAR: PRA is a continuing  
11 process.

12 MR. TRUE: Right.

13 CHAIRMAN STETKAR: So you can always  
14 collect better data.

15 MR. TRUE: Okay. I want to go to the last  
16 one and this will actually bring up another one, I  
17 think, that is important, too, which this is the hot  
18 shorts and then moving into likelihood of how we  
19 translate that into the CCDP calculation.

20 CHAIRMAN STETKAR: Is this just -- it's  
21 noontime, Doug, can you finish up the last two or  
22 three in about 15 minutes?

23 MR. TRUE: Yes.

24 CHAIRMAN STETKAR: Do you think?

25 MR. TRUE: I can do it in 12 --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay. You're doing a  
2 heroic effort, so --

3 MR. TRUE: -- less than that.

4 CHAIRMAN STETKAR: If you can get through  
5 this in about 10 to 15 minutes, it's great.  
6 Otherwise, I was going to take a break.

7 MR. TRUE: Yes, no, I'm -- we're good.

8 CHAIRMAN STETKAR: Okay.

9 MR. TRUE: So hot shorts, I'm not going to  
10 go in through any of these in any detail, but I think  
11 hot shorts remain an area that we would like to get  
12 better refinement on. The DC Circuit testing has just  
13 been done. Right now, we are basically being forced  
14 in the DC Circuits to assume that if a hot short  
15 occurs, it stays forever.

16 And there will definitely be some  
17 improvement if we could assume that that cleared  
18 eventually and the tests will help us do that and that  
19 will feedback, because that affects things like some  
20 of the seal injection isolation systems and other  
21 things that are important risk contributors. So hot  
22 shorts is another priority area, I think, in the DC  
23 testing that has been done. It will help inform that.

24 Although again, we are making a leap from  
25 a test that was designed to burn to how do you apply

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that into a PRA.

2 CHAIRMAN STETKAR: Well, but again, given  
3 ignition, the test that they did, they were looking at  
4 the conditional probability of hot shorts. So they  
5 weren't concerned with the ignition frequency.

6 MR. TRUE: Right.

7 CHAIRMAN STETKAR: I mean, it's supposedly  
8 in the PRA, you have taken care of both the ignition  
9 frequency, the detection suppression frequency to the  
10 point where you don't get, you know, fire, cable  
11 burning.

12 MR. TRUE: Yes, right.

13 CHAIRMAN STETKAR: So, you know, in that  
14 sense, I think the tests that they did answered this  
15 conditional probability of hot shorts, given fire  
16 burning. They weren't trying to necessarily grow the  
17 fire over a period of time.

18 MR. TRUE: Right.

19 CHAIRMAN STETKAR: Yes, the tests weren't  
20 designed to do that.

21 MR. TRUE: Right.

22 MR. WACHOWIAK: You just need to be  
23 careful interpreting the information.

24 CHAIRMAN STETKAR: Yes, well, obviously.  
25 And it's a limited set of tests. Got it, you know,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all of that is taken into consideration. You  
2 mentioned DC Circuits and I know the testing was just  
3 done, I guess, this year. Again, coming back to sort  
4 of the pragmatism and expedience, is the evidence and  
5 the sort of comfort level with the evidence for AC  
6 Circuits given the FAQ responses on, you know, timing  
7 of the duration of those hot shorts, is the industry  
8 fairly comfortable with those?

9 MR. TRUE: On AC, you're speaking of?

10 CHAIRMAN STETKAR: For AC, yes.

11 MR. TRUE: I think that it is not our top  
12 priority.

13 CHAIRMAN STETKAR: Okay. So DC is the --

14 MR. TRUE: I think DC --

15 CHAIRMAN STETKAR: There is enough plants  
16 with enough DC Circuits in critical?

17 MR. TRUE: Because of the way we are being  
18 forced to bound it as a --

19 CHAIRMAN STETKAR: Yes, yes. But I mean,  
20 it's in terms of --

21 MR. TRUE: -- permanent --

22 CHAIRMAN STETKAR: -- the inventory of DC  
23 Circuits and their function within plants, the DC  
24 Circuit issue is --

25 MR. TRUE: Is more important.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: -- more important?

2 MR. TRUE: Yes.

3 CHAIRMAN STETKAR: Okay.

4 MR. TRUE: Today.

5 CHAIRMAN STETKAR: Today.

6 MR. TRUE: Then we have an interim  
7 solution, too, for that.

8 CHAIRMAN STETKAR: Yes, okay. I was just  
9 trying to get a handle on it.

10 MR. TRUE: HRA, I shouldn't skip over HRA,  
11 because it is also an important area. There is a  
12 NUREG that was put out and a senior reg on human  
13 reliability in 1921 that came out that got a lot of  
14 feedback from the industry on how it was to be. And  
15 it has been going through a revision. That's  
16 something else that will be important to getting us  
17 further along in terms of the --

18 CHAIRMAN STETKAR: On the other hand, in  
19 terms of, you know, what we are faced with here, HRA  
20 will be a continuing issue, internal events/external  
21 events, Level 1/Level 2, you know, you name it. And,  
22 therefore, in terms of pointing specifically to HRA,  
23 although there may be different types of problems that  
24 need to be addressed within a Fire PRA, it is not  
25 something that I think, you know, merits a lot of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 focused attention right now.

2 MR. TRUE: We can't hold up all progress  
3 until we solve the human reliability.

4 CHAIRMAN STETKAR: Absolutely not.

5 MR. TRUE: That's for sure.

6 CHAIRMAN STETKAR: And what I'm saying is  
7 that right now the industry has a variety of different  
8 methods for doing HRA. And I think in fire risk  
9 assessment, we are, basically, going to have to live  
10 in that environment until, you know, more  
11 comprehensive progress is made, you know, across the  
12 whole industry.

13 So in terms of things that says, you know,  
14 why should we not perform NFPA 805 Fire PRAs today or  
15 that we don't have the same confidence in those PRAs  
16 as we would for internal events, HR -- you can list  
17 HRA as an area of uncertainty, but it's the same  
18 uncertainty that applies across the board.

19 MR. TRUE: It's a little bit different. I  
20 think Dennis is probably going to answer this, so I'll  
21 let him.

22 MR. HENNEKE: For the control room  
23 actions, even the local actions, those methods do work  
24 and they have uncertainty, but people have been able  
25 to apply with these factors.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           What really is the key is the methods that  
2 are presently usable are not usable for control room  
3 evacuation, either a functional failure or evacuation  
4 to the smoke. And there is a lot of discussion about  
5 how operators are not willing to leave this. I'll  
6 never leave, all that kind of stuff.

7           So right now, the methodology, basically,  
8 gives you a .1 for control room evacuation using  
9 shutdown panel or a 1.0 if you have functional  
10 failures of your primary systems. There's no HRA  
11 involved in that. It's a point estimate of a screen  
12 evaluation and that's what is being used out there.

13           CHAIRMAN STETKAR: Okay.

14           MR. HENNEKE: Roughly speaking, that's  
15 about 10 percent of the core damage for an average  
16 PRA.

17           CHAIRMAN STETKAR: Okay. That's an  
18 interesting insight.

19           MR. HENNEKE: So it's really that control  
20 room evacuation where HRA is key.

21           CHAIRMAN STETKAR: Okay. But you are  
22 saying that people aren't really doing, what I would  
23 consider, an HRA for that, they are simply assigning  
24 under some conditions, taking no credit for  
25 controlling an alternate location. In another case,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 saying there is a .1 failure, right?

2 MR. HENNEKE: Simply because if you use  
3 Swain and Guttman or any other method, it doesn't  
4 apply. You can't really easily use it, because it's  
5 not a matter of  $10^{-3}$  for turning the control room  
6 switch the wrong way.

7 CHAIRMAN STETKAR: Yes.

8 MR. HENNEKE: It's making decision of when  
9 the smoke is too much.

10 CHAIRMAN STETKAR: Yes.

11 MR. HENNEKE: When you have to leave.  
12 When you have had enough functional failures that tell  
13 you to leave, you know, what is their training? That  
14 kind of stuff. So it's a different thing than any of  
15 the HRA methods can do.

16 CHAIRMAN STETKAR: Okay.

17 MR. TRUE: Thanks, Dennis. Okay.

18 MS. COOPER: Susan Cooper, NRC Office of  
19 Research.

20 MR. TRUE: Yes.

21 MS. COOPER: I don't know what John is  
22 going to want to hear in December, but I guess based  
23 on what Dennis just said, I would be very interested,  
24 as part of the Joint EPRI/NRC Team that has been  
25 developing the Fire HRA Guidelines, to hear more about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this, because at least so far as the industry folks  
2 that have been on the team, the feedback I have heard  
3 is that this was not an important issue.

4 So I would like clarification.

5 CHAIRMAN STETKAR: Susan, I agree with  
6 you. You know, we could spend probably a week of  
7 Subcommittee meetings on anything that anybody could  
8 put up on a bullet in terms of fire analysis.

9 What I'm trying to do for, at least the  
10 December Subcommittee meeting -- because we are,  
11 indeed, goal-driven here on the ACRS and our goal is  
12 to submit a report to the Commission by the end of  
13 February, with that goal in mind, what I'm trying to  
14 do is to understand a bit more about what are the  
15 important issues that we really do want to talk about  
16 in December?

17 Right now, you have mentioned HRA. I now  
18 understand a little bit more that HRA, in particular,  
19 for control room evacuation may be an issue. I'm not  
20 yet sure where that issue fits into the grand scheme  
21 of all of the issues that we have been hearing about,  
22 whether it merits, you know, further detailed  
23 discussion in December or not. It's on the list.  
24 It's not off the list, but I understand a lot more  
25 than I did 10 minutes ago about what it is.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: All right.

2 CHAIRMAN STETKAR: Thanks.

3 MR. TRUE: Okay. The last one, PRA model  
4 advancement. This is tying in of the PRA model to the  
5 damage. And one of the things which we have recently  
6 been discussing is the fact that, basically, every  
7 fire is assumed to lead to a plant shutdown of some  
8 kind, a plant -- either a controlled shutdown or a  
9 reactor trip. It's basically an assumption. It's not  
10 mechanistically-driven in the method.

11 And if you look at the real events, a  
12 large number of them don't lead to plant shutdown.  
13 And this may be an area where like the diesel  
14 generator fire, for example, if we burn the diesel up,  
15 we assume we trip the -- we have to trip the plant, it  
16 creates a probability we lose off-site power. It  
17 creates a demand for the diesel we just burned up.

18 When the case, that's not really what is  
19 happening at all in the fires that we have seen. So  
20 there is a connection there that may merit some  
21 additional evaluation. It could be significant in  
22 certain areas. There are other areas where the fire  
23 doesn't really cause it.

24 CHAIRMAN STETKAR: Okay. In my  
25 experience, that hasn't ever been a real issue.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Typically, the areas of the plant that are  
2 troublesome, it's relatively clear you are going to  
3 get some sort of transient event.

4 MR. TRUE: I think that's less clear now.

5 CHAIRMAN STETKAR: Is it?

6 MR. TRUE: Yes.

7 CHAIRMAN STETKAR: Okay. Okay.

8 MR. TRUE: Well, I wouldn't say -- I mean,  
9 I'm not saying that those areas aren't also there and  
10 unimportant. But I think it is --

11 CHAIRMAN STETKAR: Do you see  
12 contributions for --

13 MR. TRUE: -- this is a little on where  
14 you get this disconnect, you know, of are we being too  
15 conservative by assuming that is going to cause a  
16 problem?

17 CHAIRMAN STETKAR: Well, no, no. I  
18 understand that.

19 MR. TRUE: Oh, okay.

20 CHAIRMAN STETKAR: It's just in practice  
21 how much of the overall results are being driven by  
22 that, in some cases, an artificial assumption of a  
23 plant trip given a fire in this particular location?  
24 Because in many cases, if the location is relatively  
25 benign, it doesn't make any difference whether you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have a plant trip or not. Do you know what I mean?

2 MR. TRUE: There is that --

3 CHAIRMAN STETKAR: The conditional core  
4 damage probability is relatively -- well, it would be  
5 a lot lower if you didn't have the plant trip.

6 MR. TRUE: Right. I'm not going to go  
7 through these, because we have already hit them  
8 multiple times as we have gone through it. This is  
9 kind of our summary of those three points that Jim and  
10 I set out to make and then kind of tried to reiterate  
11 some of the inputs to here.

12 And we think there are a lot of areas  
13 where expedited research is needed and this is where I  
14 was going to hand off to Rick, but I guess that is  
15 going to be after lunch.

16 CHAIRMAN STETKAR: Yes, that will be after  
17 lunch.

18 MR. TRUE: All right.

19 MR. WACHOWIAK: We're not too far behind.

20 CHAIRMAN STETKAR: Hum?

21 MR. WACHOWIAK: We're not too far behind.

22 CHAIRMAN STETKAR: We're not, don't worry.  
23 Doug did a heroic job. I'm really impressed.  
24 Thanks. Any questions from Subcommittee Members?

25 If not, we will recess for lunch. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here, I'm going to be kind of a jerk. I'm going to  
2 bring us back at 1:00.

3 MR. TRUE: I think that's fine.

4 (Whereupon, the meeting was recessed at  
5 12:12 p.m. to reconvene at 1:02 p.m. this same day.)  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

1:02 p.m.

CHAIRMAN STETKAR: We're a little bit behind schedule. Some heroic efforts have been made to see if they can bring us back on. Finish up I guess with Rick Wachowiak's presentation from EPRI and Tom Basso from NEI, and then bring the staff up as soon as we can.

MR. WACHOWIAK: Okay. Thank you. I'm Rick Wachowiak from EPRI and I am the project manager for the Fire PRA Program at EPRI.

And we've heard a little bit this morning about some of the issues that we're having with the Fire PRAs. And we want to let you know that there are things going on to resolve some of these, and my presentation is focused on what is it that we're doing to address some of these areas.

If any of you may have seen in the past the Fire PRA Action Plan or the Action Matrix, I think it was mentioned earlier today, it was initiated late 2009 to try to tabulate and make specific the things that we need to work on to address some of these issues. And it's a living document. It's being updated as new issues are identified and as other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 issues are being closed.

2 We have various organizations that lead  
3 the different activities, so some of it's EPRI, some  
4 of it's NEI. We've got the owner's groups involved.  
5 And to be comprehensive the matrix includes activities  
6 that the NRC is doing and that dovetails in with the  
7 work that we're doing in the industry.

8 For example, the DC circuit testing that's ongoing  
9 right now is one of those activities that's done that  
10 way.

11 As Doug mentioned, we're writing a paper,  
12 a road map to identify what the issues are and it  
13 aligns with the matrix. And as a matter of fact, when  
14 you get the road map you'll also have a copy of the  
15 matrix that goes along with it.

16 Our organization reports to NSIAC. We  
17 have an executive oversight committee and I'll show,  
18 you know, the type of people involved and who's  
19 involved with this. And we're coordinated through  
20 NEI.

21 I think we tried to make the point most of  
22 the day that if a Fire PRA is biased, it can mask  
23 important events and it can ultimately lead to making  
24 the wrong decisions. And sometimes it's changes that  
25 are made that don't improve safety. And in some of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the evaluation of comparative risk-type events we may  
2 come to the wrong conclusion.

3 So our focus is to increase the level of  
4 realism to the extent that we can so we can support  
5 risk-informed applications to really get rid of the  
6 large departures from realism, get things back into  
7 the right order of magnitude, if you will, on some of  
8 these subsidiary or some of the intermediate metrics  
9 so that we have confidence in our PRAs.

10 Ultimately we'd like to have compatibility  
11 with the Internal Events PRA. That's a goal. Our  
12 matrix outlines those activities that we're doing to  
13 do that.

14 I said I was going to show the industry  
15 organization. NSIAC we've got our Executive Oversight  
16 Group. Includes executives from several of the  
17 utilities and we report to them frequently on what  
18 we're doing, and they're very interested in how we're  
19 proceeding and how it's going to help them solve their  
20 problems.

21 Over at the bottom, as I said, we have  
22 different leads that are running various projects.  
23 When I get to the next slide I think I have a few  
24 things that I can point out there. But it's the  
25 entire industry that's helping work with this. Some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are led by EPRI, some are lead by the owner's groups,  
2 various activities.

3 So one box off to the side, the Technical  
4 Oversight Group, I think the question came about on  
5 what we were going to do instead of working on the  
6 FAQs, you know? So we had this FAQ process that we  
7 didn't think was quite appropriate for some of these  
8 new methods or things that weren't covered by the  
9 documentation in 6850. What we're trying to do  
10 through this process is develop methods or data or  
11 practices that can be used.

12 And then we have an industry expert team  
13 that is going through and looking at these things and  
14 critiquing and providing comments back. We'll call it  
15 a peer review of sorts for these methods. But  
16 ultimately we want to make sure that it's scrutable  
17 and that some of the questions; you know, why did you  
18 do it that way, those types of things are documented  
19 from this review process and make that available to  
20 those that need to review the methods and things that  
21 we're endorsing.

22 CHAIRMAN STETKAR: Rick, let me see if I  
23 understand that. This Technical Oversight and Peer  
24 Review Team, is the process that you're proposing is  
25 that for a particular issue, whatever it is, that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 industry will develop a proposed methodology?

2 MR. WACHOWIAK: Yes.

3 CHAIRMAN STETKAR: And run it through, you  
4 know, this oversight committee, let's say, and then  
5 submit that to the staff for concurrence, or is this a  
6 wholly -- I'm trying to understand how this closes the  
7 loop in terms of staff confidence that indeed the  
8 method can be applied from whatever's being submitted  
9 to them.

10 MR. WACHOWIAK: Right.

11 CHAIRMAN STETKAR: Or is it just you're  
12 just going to do it and float it out there and let  
13 them look at the submittal?

14 WACHOWIAK: No, what we would like to do  
15 ultimately is figure out how in that oversight and  
16 review team, how the NRC fits in in that portion of  
17 the process.

18 CHAIRMAN STETKAR: Okay. And that hasn't  
19 been done yet?

20 MR. WACHOWIAK: We don't have that worked  
21 out yet.

22 CHAIRMAN STETKAR: Okay.

23 MR. WACHOWIAK: In the DC circuit testing,  
24 we have a combined expert review panel that's working  
25 right now. That's one of the things that we're doing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In the heat release rate reports, we're doing it on  
2 our own and as soon as we're happy with that, we'll be  
3 bringing the NRC in to take a look at some of this.  
4 On the Fire Events Data Base side, that was divided up  
5 into chunks and some of the original methods were  
6 worked with the NRC and approved before they took the  
7 next step.

8 So we're trying to find the most efficient  
9 way to do this, but we don't have that answer yet.

10 CHAIRMAN STETKAR: Okay. Thanks.

11 MR. WACHOWIAK: And that's just an example  
12 of some of the people that are on the current review  
13 team for some of the projects that we've got going on  
14 right now. That list will change depending on what it  
15 is that we're specifically looking at.

16 So I mentioned the action matrix. So if  
17 anybody can read anything that's on there, great. It  
18 covers everything that Doug talked about this morning.

19 So we're done. No.

20 What I'm trying to show here is that we  
21 have the matrix. It's broken. It covers  
22 approximately three years, spills into the fourth year  
23 for the horizon that we're looking at right now. We  
24 do have specific activities that are on there. And as  
25 you could see from the presentation this morning

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they're broken up into the category one-type events,  
2 the initiating event-sort of things. And then the  
3 next category is the fire modeling heat release rate-  
4 sort of things. And then the implementation and the  
5 PRA things. And then that fourth category is our  
6 ongoing activities such as training and standards  
7 development. And also this review of methods has also  
8 been down in the bottom.

9 MEMBER ABDEL-KHALIK: Now, let me ask you  
10 a big picture question.

11 MR. WACHOWIAK: Okay.

12 MEMBER ABDEL-KHALIK: What drove you into  
13 this; you know, we heard many examples this morning,  
14 is that the predictions are inconsistent with actual  
15 data, right? And you said that if we were within the  
16 same order of magnitude, we wouldn't have gone that  
17 route.

18 MR. WACHOWIAK: Yes, looking it that way.

19 If we thought that the predictions were accurate, we  
20 probably would not be going through as many of the  
21 different activities here and trying to refine things  
22 quite as much. It would be good enough. It would be  
23 good enough.

24 MEMBER ABDEL-KHALIK: I'm trying to get to  
25 the point of when would you stop? When do you know

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that you've got this right? Okay?

2 CHAIRMAN STETKAR: That's a good question.

3 MR. CANAVAN: My answer is usually a  
4 little flippant to that, which is right after we  
5 finish internal events, which we're still working on.

6 But the majority of the matrix activities, the things  
7 we think that really impact results and consistency,  
8 according to the schedule, is in 2014 for the known  
9 items. So I think we have a schedule that leads us  
10 through mid-2014.

11 MEMBER ABDEL-KHALIK: But I'm not worried  
12 about a schedule. Okay?

13 MR. CANAVAN: Right.

14 MEMBER ABDEL-KHALIK: But my question  
15 doesn't really pertain to schedule.

16 MR. CANAVAN: When do you know?

17 MEMBER ABDEL-KHALIK: Right. When do you  
18 know and --

19 MR. CANAVAN: Where is our monitoring in  
20 feedback loop in this process?

21 MEMBER ABDEL-KHALIK: And if I were to  
22 just use your qualitative assessment, if you're within  
23 the same order of magnitude would that alleviate your  
24 primary concern that the Fire PRA may be biased and  
25 can mask important events if you are within an order

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of magnitude?

2 MR. WACHOWIAK: Of --

3 MEMBER ABDEL-KHALIK: How close --

4 MR. WACHOWIAK: -- the experience? How  
5 close do we need to be?

6 MEMBER ABDEL-KHALIK: Right, in order --

7 MR. WACHOWIAK: That's --

8 MEMBER ABDEL-KHALIK: -- to alleviate that  
9 concern.

10 MR. WACHOWIAK: That's a good first cut at  
11 looking at this. Industry-wide, when we're close on  
12 some of these intermediate things that we can measure,  
13 you know, things that we could see some of or maybe  
14 have seen some of and that we would predict on the  
15 same order of magnitude, that's the first place to  
16 start looking. But remember from Doug's chart that  
17 there are individual plants that have individual  
18 problems. So if five plants have one problem and  
19 nobody else has it, well for those five plants that's  
20 still a big deal that may need to be addressed.

21 So as a first cut we're getting close when  
22 we can say that the predictions made with the Fire  
23 PRAs are in the ballpark for where we're going. But  
24 we still have to look at the individual outliers for  
25 the individual plants and see if there are outliers

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there.

2 So I think what we eventually will do with  
3 this is we've got some of the things that we know now,  
4 okay, the data base, which I'll talk about a little  
5 bit more in a minute, we know now. We know what we  
6 need to do to extract frequencies from that. We have  
7 some other things on heat release rates, so for  
8 electrical cabinets. We have a process that we're  
9 going through for that.

10 And I think what would be nice to come out  
11 of this is we have our big hitter that are generic-  
12 type examples and that it leaves behind it a process  
13 that others can use in more of an individual style to  
14 attack things that are important for a handful of  
15 plants but maybe are not important across the board.  
16 And I think if we can do that, leave some sort of a  
17 process that's repeatable and scrutable and acceptable  
18 then we would have done what we tried to accomplish.

19 MEMBER ABDEL-KHALIK: I guess I haven't  
20 heard the answer to my question, but other than, you  
21 know, we'll know when we get there.

22 MR. WACHOWIAK: At this point it's we'll  
23 know when we get there.

24 MEMBER ABDEL-KHALIK: Okay.

25 MR. WACHOWIAK: All right. The intent of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this was to show that we do have a multitude of  
2 activities here and they are laid out in a schedule.  
3 What tends to be in this is the activities that are  
4 early on and ongoing right now are associated mostly  
5 with the things that were in the ridge, the electrical  
6 cabinet sorts of things. So that's what we're  
7 focusing on now there, and on the data base. The data  
8 base is key to understanding all of this.

9 So I broke out from the matrix the first  
10 activity, which is the Fire Events Data Base. We  
11 worked with the NRC early on to determine are the  
12 fields that need to be collected in this data base.  
13 How do we categorize things within the data base? And  
14 a report was produced a while back that said, okay,  
15 this is what the data base is going to look like, and  
16 this is how we're going to gather the data, and this  
17 is how we're going to make sure that the data is  
18 complete this time. That's activity 1.1.1. We've  
19 moved into the next activity, which is where we went  
20 out to all the plants and requested information from  
21 the plants so that we can get started populating this.

22 The great thing here is we've had 100  
23 percent response from the industry. The industry  
24 thinks this is very important and they're working with  
25 us to make sure that we have a complete data base

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here.

2 MEMBER ABDEL-KHALIK: Again, you know, I  
3 asked the question earlier about roving fire watches.

4 MR. WACHOWIAK: Yes.

5 MEMBER ABDEL-KHALIK: And you indicated  
6 that the data would designate when a fire was observed  
7 by one of those fire watches and what the state of the  
8 fire was. But ultimately the goal of the licensees is  
9 to eliminate these --

10 MR. WACHOWIAK: Right.

11 MEMBER ABDEL-KHALIK: -- roving fire  
12 watches. And the question then is would whatever data  
13 you collect be applicable to the end state where the  
14 plants are going to be?

15 MR. CANAVAN: Yes. I think it's a  
16 different question that you're asking. So for  
17 example, you'll be able to tell from the data, you'll  
18 be able to interrogate how detection occurred. There  
19 is a field for detection and it will be automatic,  
20 manual, person in the field.

21 Right now we don't credit manual fire watch. It  
22 doesn't affect the frequency. It doesn't affect the  
23 occurrence of fires. We could get 100 fire watchers,  
24 put them in the plant, nothing changes.

25 MEMBER ABDEL-KHALIK: But in the end if

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 people eliminate these --

2 MR. CANAVAN: Right.

3 MEMBER ABDEL-KHALIK: -- roving fire, you  
4 will not have that avenue for detection.

5 MR. CANAVAN: True.

6 MEMBER ABDEL-KHALIK: And yet the data  
7 reflects --

8 MR. CANAVAN: Yes.

9 MEMBER ABDEL-KHALIK: -- the fact that  
10 many of these fires are actually detected by people  
11 walking around the plants because that's their job.

12 MR. WACHOWIAK: Now let me just be clear  
13 on how we're doing some of this. The data that's  
14 going to be coded into the data base are not only the  
15 fires that have progressed into the fire state. The  
16 things that could progress into the fire state but  
17 were stopped short of that, my understanding is those  
18 are in the data base. They're just not counted  
19 against the frequencies that are generated out of the  
20 data base.

21 So I think what Ken was saying is if you  
22 went back into the data base when we were done and  
23 interrogated what credit did we get for these roving  
24 fire watches; maybe it's just fire watches in general,  
25 but if you could break it down from that, then what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you could say is the data now -- the frequencies now  
2 contain this much credit for that. And if I'm going  
3 to eliminate a fire watch, you would have to add a  
4 factor to bump that up.

5 MEMBER ABDEL-KHALIK: Or the other way?

6 MR. WACHOWIAK: Or the other way. If you  
7 were adding, you could bring it down.

8 MR. CANAVAN: So I guess my point would be  
9 we want the model to reflect what factors affect the  
10 model. So you have to have them in there so that if  
11 you were to, for example, come up with a situation  
12 where you have a multi-million dollar mod, you're  
13 choosing not to do because you can augment the fire  
14 watch and maybe not need to do that. There would be  
15 some kind of way to figure out, well, what credit do  
16 you get for a fire watch versus a modification versus  
17 other alternatives? And so the point would be to be  
18 able to assess all of the factors in some way that  
19 affect either fire ignitions, growth propagations down  
20 the road. Have the model have some fidelity so it has  
21 more usefulness.

22 MR. WACHOWIAK: So to get back to one of  
23 the questions from earlier on the diesel generator  
24 information, how was this coded? How was this put  
25 together? That data base basically started with a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pile of information and they tried to put it into a  
2 data base format that could generate frequencies.  
3 Here we're starting with what information do we need  
4 to perform these analyses? The first cut is to go and  
5 find out how many records we need to ask from the  
6 industry. So that was the first cut. We said do a  
7 keyword search of your corrective action data base.  
8 Find anything that might remotely be associated with  
9 fire, smoke, any of these things. We'll go through  
10 and find the ones that say, yes, this looks like it's  
11 a fire event.

12 Then we're going to ask you for your  
13 entire record of that event. We take that, put it  
14 into the data base and, you know, there have been some  
15 other presentations on this at other forums, but the  
16 way the data base is set up is it then tells you,  
17 okay, here's the missing information. And before you  
18 can close that record out in the data base, we have to  
19 get the information from the plants to fill the entire  
20 data base out.

21 So the indeterminate events shouldn't be  
22 there anymore. The things that the data base is  
23 intended to generate frequencies or insights for, all  
24 those fields are there and all the fields that are  
25 necessary to generate that information must be input.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So it's a long process, but we're in the  
2 stage now where we've got the information, the initial  
3 screening has been done for some of the plants and now  
4 we're getting the corrective action reports from the  
5 plants and populating the data base. At some point  
6 now, we think it's going to be within the next couple  
7 of quarters, we'll bring NRC in. I think I sent a  
8 proposal out to J.S. earlier last week, late last week  
9 explaining how we'd like them to come in and take a  
10 look at what we're doing. So they had agreed on what  
11 goes into the data base up front. We're populating  
12 it. We would like them to have confidence by looking  
13 at how we're populating it. Take a look at some of  
14 the records. Are we doing this right? And we'll see  
15 how we go forward from that point on.

16           The last thing that I want to mention on  
17 here is when we get the data from -- is it 2000 to  
18 2009?

19           MR. CANAVAN: Yes, 1999 to 2009.

20           MR. WACHOWIAK: 1999 to 2009. When that  
21 data's in, that's not the end. The plan is to take  
22 this forward. We're working with INPO to have an  
23 ongoing data collection process that will keep this  
24 data base up to date and fully populated.

25           CHAIRMAN STETKAR: Rick, when you were

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 talking you just mentioned something that kind of  
2 piqued my curiosity. This enhanced data base that  
3 you're developing, how far back into history does it  
4 go? Back to day one at each plant?

5 MR. WACHOWIAK: 1999.

6 CHAIRMAN STETKAR: 1999? You're  
7 artificially restricting it to --

8 MR. WACHOWIAK: No, we have other  
9 information from the --

10 CHAIRMAN STETKAR: -- 10 years of data, 12  
11 years of data? I mean, that would be troublesome, I  
12 think.

13 MR. MAYS: I'm Steve Mays from ERIN  
14 Engineering and I'm doing the data base work, so the  
15 request for information from the plants went from the  
16 2000 to 2009 period for the CR searches. But we're  
17 including in the data base all of the events from the  
18 previous Fire Event Data Base from 1990 through 1999  
19 that were either challenging events or undetermined  
20 events. So those will be pulled forward into the data  
21 base as well.

22 CHAIRMAN STETKAR: That's still only 20  
23 years. My question is --

24 MR. MAYS: It is 20 years worth of  
25 information, yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: My question is why  
2 don't we go back through day one at each of the plants  
3 to understand what fires have happened?

4 MR. MAY: Well --

5 CHAIRMAN STETKAR: Fires are not something  
6 that happens at the problem plants every day.

7 MR. MAY: Well, you're right. The problem  
8 is documentation and ability to get information from  
9 those. Plus the study that was done in the EPRI  
10 report that updated the frequencies did a study of the  
11 fire frequencies as a function of time showed that the  
12 pre-1990 period was in a different population, so  
13 we're basically gathering data from the current time  
14 period because that's when the data analysis suggests  
15 is appropriate.

16 CHAIRMAN STETKAR: I saw that study and I  
17 had some questions about where the arbitrary lines  
18 were drawn in terms of where the inflection points  
19 were.

20 I hearken back to an EPRI effort back in  
21 the 1980s to prove that indeed losses of off-site  
22 power were reducing year by year by year until they  
23 increased over two or three years. Then people  
24 changed the statistics and the way they counted  
25 things. And then people stopped doing that trending

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis only because there indeed are site to site  
2 and year to year variability in these rare events.  
3 It's not something that happens everyday, you know?  
4 So discarding something on the order of let's say 15  
5 years of industry operating experience from the middle  
6 '70s or 10 years back to 1980 when we changed a lot of  
7 the fire protection requirements strikes me as being a  
8 bit curious.

9 MR. MAY: Well the data, it's not being  
10 discarded. If you recall the update that was done  
11 used the already generated frequencies from that thing  
12 in a two-stage process as a prior.

13 CHAIRMAN STETKAR: I understand that, but  
14 they're restricted by the bins and the information  
15 that you had available. So you're proposing here a  
16 complete restructuring of that binning process --

17 MR. MAY: Well, we have --

18 CHAIRMAN STETKAR: -- by component type  
19 and essentially by severity or detection time and  
20 things like that, however it's --

21 MR. MAY: And you don't have that  
22 information for those old events. Well, we'll have  
23 the information back as far as 1990. But to the  
24 extent that we don't have the information beyond that,  
25 that limits what you can potentially do with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 rearranging binning from a statistical standpoint.

2 MR. CANAVAN: And I'd also be careful on  
3 referring to them as rare though, because the events  
4 in the data base indeed aren't rare. There's 2,800  
5 events in the data base right now and we're collecting  
6 another several thousand events. So we're not really  
7 rare. The big ones that we had, Browns Ferry, a  
8 generator exploded or a fire occurred, they might be  
9 something we want to go back and see.

10 CHAIRMAN STETKAR: I'm just trying to  
11 insert the sense that you're trying to reduce  
12 uncertainty in the generic data and try to make that  
13 generic -- increase the confidence in those  
14 frequencies by defining a larger number of fire events  
15 bins, if you want to call them that, and trying to  
16 develop more information about, you know, detection  
17 time, severity of the fire and things like that. I  
18 think that's all really, really good.

19 On the other hand, at times we've learned  
20 that by restricting the time scale of your data base,  
21 if indeed there are rare events that we're talking  
22 about, you can actually increase the uncertainty. You  
23 know, having one event, you know, at one plant,  
24 period, with a total exposure period of 20 calendar  
25 years for all of the plants indeed can insert higher

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 uncertainty than having one event at one plant over a  
2 total industry experience of 30 or 35 years, in a  
3 bayesian sense.

4 MR. CANAVAN: I think I understand where  
5 you're headed, and I think we can look at the older  
6 data and make sure we're not missing any nuggets of  
7 information that are important to keep and to retain  
8 maybe not as a prior. So for example, if we look at a  
9 bin and we find out a cabinet went on fire in 1978 and  
10 it was a true real cabinet fire, we don't want to  
11 throw that out. I understand that. But if you look  
12 back at some of that data into the '60s and '70s --

13 CHAIRMAN STETKAR: No, no, no. No, I  
14 understand the limitations.

15 MR. CANAVAN: -- you just can't get there.

16 CHAIRMAN STETKAR: Right.

17 MR. CANAVAN: And so I think including it  
18 -- but I understand --

19 CHAIRMAN STETKAR: There might be creative  
20 ways to treat that earlier experience.

21 MR. CANAVAN: I agree, to take a look and  
22 see what we can see.

23 CHAIRMAN STETKAR: We can talk more about  
24 this in December.

25 MR. CANAVAN: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: We're obviously going  
2 to talk about and put it on your hit list, you know,  
3 data base in December.

4 MR. HYSLOP: Yes, the FAQ-048 -- J.S.  
5 Hyslop -- researched, part of the purpose said that we  
6 needed to do more research and collect more data, and  
7 that was also to verify the trend, at 1990 to confirm  
8 that the trend existed. And the trend itself is what  
9 established the treatment of the old data versus the  
10 new.

11 PARTICIPANT: Right. Thanks.

12 MR. WACHOWIAK: Okay. I'm going to move  
13 on. Conclusion for my portion, once again I just want  
14 to let you know that we are doing things about what  
15 we've been talking about all morning. We're focused  
16 on increasing the realism. We think that the data  
17 base is one important piece of it and some of these  
18 other methods that we're looking at especially with  
19 the heat release rates in the cabinets. That's  
20 another thing that we're focusing on.

21 We've been working with NRC on several of  
22 these tasks. I listed a few there where we've worked  
23 together under a Memorandum of Understanding that EPRI  
24 and the NRC has to share data or some of these  
25 activities. And once again, we have a road map

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 report. It's going to include the matrix and all the  
2 activities and the current status of those activities.

3 It will be provided as Biff said in the upcoming  
4 weeks. And that will set us up for the December  
5 meeting.

6 CHAIRMAN STETKAR: Rick, I want to make  
7 sure I understand a little bit of what you said. On  
8 this sort of summary and conclusion slide you've  
9 highlighted three specific areas where you're working  
10 with RES on the Fire Event Data Base, the DC testing  
11 and Fire HRA, and we discussed all of those to a  
12 greater or lesser extent this morning.

13 You mentioned orally the heat release  
14 rates, although that for whatever reason didn't make  
15 the --

16 MR. WACHOWIAK: We haven't figured out how  
17 we're engaging the NRC on the heat release rates yet.

18 I picked these three because these are the three that  
19 really are --

20 CHAIRMAN STETKAR: Those are your --

21 MR. WACHOWIAK: -- those are the ones that  
22 have activities right now.

23 CHAIRMAN STETKAR: Right. And I'll come  
24 back to challenge you that we've heard a lot about the  
25 fire events and the binning of the events and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 credibility of the events. We heard a little bit  
2 about DC testing and that it may be an important  
3 contributor to risk at a number of plants. We heard a  
4 little bit about the HRA. That didn't seem to be as  
5 important.

6 The question is; I recognize you have  
7 ongoing projects with RES, are all of these equally  
8 important to solving the problems of me if I'm doing  
9 my fire PRA today?

10 MR. WACHOWIAK: Yes, I think the Fire HRA  
11 is an activity that was --

12 CHAIRMAN STETKAR: It's been going on for  
13 awhile.

14 MR. WACHOWIAK: The report is winding down  
15 right now. That's going to publication. I picked  
16 these because these were the things that are happening  
17 today.

18 CHAIRMAN STETKAR: Okay. Understand.

19 MR. WACHOWIAK: We know we need to engage  
20 the NRC on the heat release rates.

21 CHAIRMAN STETKAR: But you haven't?

22 MR. WACHOWIAK: But we haven't done that  
23 yet.

24 CHAIRMAN STETKAR: Okay.

25 MR. WACHOWIAK: And the intent is to do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that and once we figure out what we want to say to the  
2 NRC. We've got to get to that point.

3 CHAIRMAN STETKAR: Okay.

4 MEMBER ABDEL-KHALIK: How much  
5 experimental work is involved in Action Matrix?

6 MR. WACHOWIAK: Experimental work? When  
7 you take a look at the full expanded, you'll see  
8 several testing activities that are in there. Most of  
9 those are the activities that the NRC is sponsoring.  
10 I don't think we have any independent testing  
11 activities in the --

12 MR. CANAVAN: Incipient detection is the  
13 only one that's planned and we were hoping that that  
14 would be a joint effort between us and the NRC.  
15 That's the only physical testing schedule that we have  
16 currently.

17 MR. WACHOWIAK: And remember, this is the  
18 Fire PRA Action Matrix. And as Doug mentioned  
19 earlier, it's hard to set up PRA tests. You know, you  
20 have fire tests and fire modeling tests and things  
21 like that.

22 CHAIRMAN STETKAR: That's true, but I mean  
23 if the staff can set them up, you guys could set them  
24 up, too.

25 MR. WACHOWIAK: I'm through. Want me to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 find your --

2 CHAIRMAN STETKAR: Thank you. Any more  
3 questions for EPRI, because I think as I understand  
4 it, Tom's going to come back and talk now about  
5 important related but slightly different issues.

6 (No audible response.)

7 MR. BASSO: Thank you. Good afternoon.  
8 My name's Tom Basso from NEI. Do want to apologize,  
9 the handouts are from an earlier presentation, so I  
10 did update the presentation that's on the screens.

11 I do want to first start by saying though,  
12 you know, that the industry and staff have worked  
13 extensively to successfully resolve a lot of technical  
14 and process issues, you know, in transitioning the  
15 pilot plants and implementing 805. However, this has  
16 come about with the commitment and application of, you  
17 know, significant effort, you know, by the industry  
18 and by the staff. And I believe an outcome of this  
19 assessment and looking at some of the impacts to the  
20 transition could at least maybe arrest some of the  
21 expansion of the required transition efforts or bring  
22 them more towards the originally expected efforts.

23 I do want to say that an incremental  
24 increase in the requirements of expectations at this  
25 time from the pilot submittals or reviews can have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 significant schedule and financial impacts to  
2 remaining non-pilot stations, and I'll go through some  
3 of the examples. So we really want to get to a  
4 predictable and a stable environment in order for the  
5 non-pilots to transition effectively.

6 Go to slide two, please. As I did  
7 mention, significant effort and resources have been  
8 applied to developing the requirements and guidance  
9 for the NFPA transition, however, recent issues with  
10 potential impacts to 805 transition, you know, have  
11 come to light. The most significant one is the  
12 expectation to demonstrate safe and stable for  
13 indefinite period. And I'm going to go into some  
14 detail on that particular example.

15 That also will highlight some of the other  
16 issues, including deferral of resolutions of pilot  
17 issues by issuing implementation actions, you know, or  
18 licensing conditions. And also, one of the other  
19 issues is the request for additional technical  
20 justification for licensees to retain continued  
21 acceptance of pre-transitional licensing basis.

22 CHAIRMAN STETKAR: Tom, you going to give  
23 us some examples, specific examples of each of those?

24 MR. BASSO: Yes, I can give you specific  
25 examples towards the end.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Because it's a little  
2 difficult to understand. Thanks.

3 MR. BASSO: Well this first example  
4 highlights the first two bullets. And, you know, 805  
5 defines safe and stable, you know, specifically as the  
6 ability to maintain sub-criticality with reactor  
7 coolant temperature at or below hot shutdown for BWRs  
8 and hot standby for PWRs. And with the definition of  
9 safe and stable in mind, one of the nuclear safety  
10 goals in 805 is to provide reasonable assurance that  
11 any fire during any operation mode plant configuration  
12 would not prevent the plant from achieving and  
13 maintaining fuel in a safe and stable condition. So I  
14 really highlighted the reasonable assurance, so keep  
15 that in mind.

16 Next slide, please? If you look at the  
17 Harris safety evaluation, you know, per their safety  
18 evaluation the licensing basis for Harris is to  
19 achieve and maintain safe and stable hot standby  
20 condition. However, they did have previous actions to  
21 be performed including actions and equipment to  
22 achieve cold shutdown. They retained those actions.  
23 The staff in their review found that the basis was  
24 acceptable because those actions are not required to  
25 meet the nuclear safety performance criteria, but they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 were defense in depth actions --

2 CHAIRMAN STETKAR: Tom, were those  
3 analyses done to support Appendix R-type?

4 MR. BASSO: Those were Appendix R actions.

5 CHAIRMAN STETKAR: Okay. Okay.

6 MR. BASSO: That's correct.

7 CHAIRMAN STETKAR: Okay.

8 MR. BASSO: Okay. Ocone proposed in  
9 their LER that the unit may remain in hot standby for  
10 the event and safe and stable condition would be  
11 deemed fulfilled if achieved for 72 hours. So they  
12 established a 72-hour criteria.

13 The licensee deemed such a time period to  
14 be sufficient to provide assurance that the  
15 performance criteria of 805 were maintained, and that  
16 included the nuclear safety goal of reasonable  
17 assurance.

18 Ocone did receive an RAI on their  
19 position of safe and stable. And as shown there, the  
20 RAI, it was requested that the licensee should be  
21 expected to demonstrate that safe and stable  
22 conditions be maintained indefinitely.

23 So, you know, although 805 doesn't  
24 specifically define the time period for safe and  
25 stable, indefinite is neither found explicitly or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 implicitly, you know, in the rule or guidelines  
2 regarding safe and stable. You know, additionally the  
3 expectation, you know, to demonstrate the safe and  
4 stable conditions can be maintained indefinitely, you  
5 know, doesn't align with the nuclear safety goal to  
6 provide reasonable assurance.

7 CHAIRMAN STETKAR: So if I can understand  
8 this; thanks for the examples, that this concept of  
9 safe and stable is essentially, if I translated it  
10 into PRA speak, the long-term success criteria for my  
11 PRA?

12 MR. BASSO: That would be correct.

13 CHAIRMAN STETKAR: Okay.

14 MR. BASSO: Yes.

15 CHAIRMAN STETKAR: And there's still  
16 consternation among the industry and apparently  
17 questions being asked by the staff regarding what that  
18 success state is?

19 MR. BASSO: Yes. I know there was some  
20 discussion as to a 24-hour period, because that's the  
21 way the --

22 CHAIRMAN STETKAR: No. Yes, that's --

23 MR. BASSO: -- risk models are run and  
24 what Harris, or I mean Oconee came in with was 72  
25 hours.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay. Interesting.  
2 Now, I understand the concern.

3 MR. BASSO: Okay.

4 CHAIRMAN STETKAR: Yes.

5 MR. BASSO: Next slide? So just some of  
6 the impacts that this recent treatment of safe and  
7 stable has is, you know, Oconee's now going to have to  
8 reanalyze all the components and cables associated  
9 with going to and maintaining hot shutdown.

10 CHAIRMAN STETKAR: Yes, let me interrupt  
11 you there, because I'm trying to make notes here.  
12 You're saying Oconee is reanalyzing all components  
13 going to hot shutdown for the specific purpose of  
14 confirming that they can maintain those conditions  
15 indefinitely?

16 MR. BASSO: I'm not going to say that  
17 they're doing it for indefinite period, but that's  
18 -- you know, I haven't seen --

19 CHAIRMAN STETKAR: But they are actually  
20 making an effort to reevaluate things rather than --  
21 does that imply that they weren't successful in  
22 convincing the staff on the RAI response that 72 hours  
23 was acceptable?

24 MR. BASSO: That's correct. I haven't  
25 seen the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: By the way, we  
2 have --

3 MR. BASSO: The final RAI response has not  
4 been published.

5 CHAIRMAN STETKAR: For your information,  
6 as far as what we've seen as a subcommittee, we have  
7 access to the Harris safety evaluation.

8 MR. BASSO: Yes.

9 CHAIRMAN STETKAR: I haven't and I don't  
10 think any of the other subcommittee members has seen  
11 anything on Oconee because it hasn't been released yet  
12 from the staff.

13 MR. BASSO: Right.

14 CHAIRMAN STETKAR: So that's a bit of my  
15 question, you know, to you on Oconee because --

16 MR. BASSO: Right. And I've not seen the  
17 file either.

18 CHAIRMAN STETKAR: Okay.

19 MR. BASSO: And I'm not sure if it's going  
20 in as an implementing action or it's going to be a  
21 license condition. I don't know that.

22 CHAIRMAN STETKAR: But the fact of the  
23 matter is Oconee is doing reanalysis work --

24 MR. BASSO: Yes.

25 CHAIRMAN STETKAR: -- as a result of that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 concern.

2 MR. BASSO: Right.

3 CHAIRMAN STETKAR: Thank you.

4 MR. BASSO: Yes. Now, for the non-pilots,  
5 you know, they've aligned their evaluations to support  
6 their licensing applications, you know, with the pilot  
7 process and specifically with Oconee, because Oconee  
8 being the last pilot, a lot of the changes implemented  
9 from Harris were factored into Oconee's LER. So a lot  
10 of the non-pilots really modeled their evaluations  
11 after that. So with this treatment, you know, they're  
12 going to have to make changes, and in some cases  
13 extensive analysis. And at this late time in the  
14 process it's going to challenge some of them meeting  
15 the June 2011 date, particularly those stations that  
16 have to analyze the cold shutdown. So some of them  
17 may have to go down to cold shutdown for this.

18 CHAIRMAN STETKAR: Because of the  
19 indefinite nature of that implication?

20 MR. BASSO: Yes, because they may not be  
21 able to show that they can stay in a hot shutdown.

22 CHAIRMAN STETKAR: For some period of  
23 time?

24 MR. BASSO: For some period of time.

25 CHAIRMAN STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BASSO: Yes.

2 CHAIRMAN STETKAR: Thank you.

3 MR. BASSO: So, you know, thinking of one  
4 of the perceived benefits of 805 from the onset and  
5 its development and rulemaking was with the risk-  
6 informed performance-based standard. The need to  
7 transition to cold shutdown was no longer a specific  
8 requirement and that achieving a safe and stable state  
9 would provide benefit to the licensees in the form of  
10 flexibility and meeting the rule. You know, that's  
11 potentially no longer the case for a number of the  
12 stations. And, you know, with the transition you  
13 expect to get some reductions in operating and  
14 training and maintenance costs. You know, this latest  
15 treatment in fact will drive some of the plants to be  
16 more -- could be more restrictive in Appendix R.

17 CHAIRMAN STETKAR: Do you have a sense,  
18 Tom -- this again is putting you on the spot, so you  
19 can say you don't know. This honestly, the reason  
20 I've asked a few questions, is the first time I've  
21 heard about this notion of this particular issue, the  
22 appropriate stable end state as being a significant  
23 issue. And I've seen words about it, but I didn't get  
24 the sense that it was as important as your  
25 presentation seems to indicate. And that last bullet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on this slide it says that this might drive plants to  
2 more restrictive conditions in Appendix R, which  
3 obviously, you know, if I'm a plant decision maker and  
4 I look at the expense of doing a PRA and if it might  
5 indeed impose more restrictive conditions than what I  
6 think I might be able to achieve at a lower cost, I'm  
7 not going to do it.

8 Do you have a sense of what fraction of  
9 the industry might be driven away just on the basis of  
10 this issue, the uncertainty of what a stable end state  
11 is? Is it a significant issue in the industry, or is  
12 it more of a contributing uncertainty?

13 MR. BASSO: I think it could be a  
14 significant issue for those who might be thinking  
15 about ultimately transitioning to 805.

16 CHAIRMAN STETKAR: Okay.

17 MR. BASSO: I think those that are already  
18 in the process, they're so deep in the process at this  
19 point.

20 CHAIRMAN STETKAR: Yes, this is just more  
21 --

22 MR. BASSO: It's just going to be more  
23 work.

24 CHAIRMAN STETKAR: More work like Ocone.  
25 Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BASSO: And it could delay them in  
2 getting their submittals in in June.

3 CHAIRMAN STETKAR: Yes. Yes. But you  
4 think it's important enough that it might tilt the  
5 balance on a plant-specific basis for committing in  
6 the future?

7 MR. BASSO: I believe so.

8 CHAIRMAN STETKAR: Okay.

9 MR. BASSO: This was the number one issue  
10 when we had, you know, an industry call, you know,  
11 recently on concerns with the non-pilots.

12 CHAIRMAN STETKAR: Oh.

13 MEMBER ABDEL-KHALIK: Even if they know  
14 clearly what the definition of safe and stable might  
15 be that would affect people's decision in the future?

16 MR. BASSO: They would have to factor that  
17 into their cost benefit of transitioning and whether  
18 or not -- if it doesn't add the benefits of not having  
19 to go to cold shutdown, you know, it's just going to  
20 be a major factor in that.

21 MEMBER ABDEL-KHALIK: Good.

22 MR. BASSO: Okay. Next slide? Okay. So  
23 and I'll give you just maybe one other example. So at  
24 this point we're near completion of the pilots. In  
25 development of the non-pilots, you know, it's critical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we consistently apply the regulatory and issued  
2 criteria and guidelines. As I mentioned, any changes  
3 to requirements to a final review creates an  
4 instability and could significantly impact non-pilots  
5 since their analysis -- it really mimics, you know,  
6 the pilot plants.

7           Uncertainties for non-pilots have been  
8 created by deferring the resolution of some pilot  
9 issues by issuing implementation actions or licensing  
10 conditions. With the delay of resolutions, non-pilot  
11 stations will have to apply the guidance that they  
12 interpret to their specific situation without insights  
13 from the pilot process.

14           CHAIRMAN STETKAR: You have an example of  
15 that?

16           MR. BASSO: I'll give you one. One  
17 example is there were questions about Oconee's Fire  
18 PRA and the license condition that kind of closed or  
19 didn't really answer those questions yet was for  
20 Oconee to go and do a peer review of their Fire PRA.  
21 So some of the non-pilot plants that were waiting to  
22 see how some of those questions would be closed or  
23 resolved aren't going to have that before Oconee does  
24 their peer review, which I believe is scheduled for  
25 some time in the fall or later next year.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: But the key is that  
2 it's issued as an implementation action or a license  
3 condition, so therefore the staff can write the safety  
4 evaluation report regardless of what the ultimate  
5 conclusion from that peer review is?

6 MR. BASSO: That's correct.

7 CHAIRMAN STETKAR: And it will then become  
8 -- I can ask the staff about what happens to it then.  
9 Thanks.

10 MR. BASSO: Okay. So really in closing,  
11 you know, although I don't have many recommendations  
12 for some of the issues that are license conditions or  
13 implementing actions, I think the resolution for safe  
14 and stable, you know, we can achieve that through our  
15 closure. We have an open FAQ-08-0054 that does have  
16 safe and stable, you know, in that. So we do have an  
17 opportunity to provide I would say better guidance or  
18 more definitive guidance on safe and stable there.

19 CHAIRMAN STETKAR: And that one's still  
20 open?

21 MR. BASSO: That one is still open.  
22 That's in FAQ --

23 CHAIRMAN STETKAR: Since it's 08, it's  
24 been open now for two years?

25 MR. BASSO: It's gone through a number of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 changes.

2 CHAIRMAN STETKAR: Okay.

3 MR. BASSO: Yes. So and I really can't  
4 over stress the need to attain, you know, a stable and  
5 predictable environment at this point in time in the  
6 process.

7 MR. MOULTON: This Charles Moulton, NRC  
8 staff, the frequently asked questions process owner.  
9 That FAQ-08-0054 has not been opened for two years  
10 with the staff. We received that this year. The  
11 numbering system is based on when the NEI task force  
12 first develops the question, not when it's submitted  
13 to the staff for review.

14 CHAIRMAN STETKAR: Thank you.

15 MR. MOULTON: So that has only been under  
16 review for a few months now, not a couple of years.

17 CHAIRMAN STETKAR: Thank you for  
18 clarifying that. That helps because I just go by the  
19 year issuance. Thanks.

20 PARTICIPANT: Was the time frame April?

21 MR. CANAVAN: April was the time frame.

22 CHAIRMAN STETKAR: April of 2010.

23 PARTICIPANT: Was it April it was  
24 submitted?

25 CHAIRMAN STETKAR: If this is an important

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issue, why did you wait for two years to finally send  
2 it up to the staff:

3 MR. CANAVAN: Well, I think 54 came out  
4 very late in the year. I was just looking at the  
5 number 54. That's probably pretty late in the year.  
6 So it's probably late '08, gone through --

7 CHAIRMAN STETKAR: Fine, I'll give you a  
8 year and three-quarters then.

9 MR. CANAVAN: No, then it gets submitted  
10 into the process with the staff and with the  
11 resolution. The resolution comes along with the FAQ.

12 CHAIRMAN STETKAR: That's not what I  
13 heard.

14 MR. BASSO: Yes, the issue about  
15 indefinite didn't come out until the third set of  
16 Harris RAIs.

17 CHAIRMAN STETKAR: Oh, okay. So second  
18 set, third set.

19 MR. BASSO: Oconee. I'm sorry.

20 CHAIRMAN STETKAR: Oconee?

21 MR. BASSO: So it didn't come out --

22 CHAIRMAN STETKAR: So are you saying that  
23 the uncertainty over what is actually interpreted as a  
24 long-term safe and stable state has evolved from  
25 whatever the original words are in FP-08-05 and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 NUREG/CR 6850, but has evolved from Harris to Ocone  
2 to the current conditions? Am I hearing that we're  
3 less certain today than we were two years ago?

4 MR. BASSO: No, no. The words have  
5 changed. The position of what was accepted by the  
6 licensee has changed.

7 MEMBER ABDEL-KHALIK: I guess it wasn't  
8 the issue for Harris because they went to cold  
9 shutdown.

10 PARTICIPANT: No, they didn't.

11 MR. BASSO: No.

12 MEMBER ABDEL-KHALIK: They didn't?

13 MR. BASSO: They didn't go to cold  
14 shutdown. They had defense in depth actions that --

15 CHAIRMAN STETKAR: They didn't take credit  
16 for those actions. They simply mentioned -- they  
17 didn't take credit for them, as I understand it, in  
18 their submittal.

19 MR. BARRETT: Hold on.

20 CHAIRMAN STETKAR: They just mentioned  
21 them. Let me finish my erroneous interpretation.

22 MR. BARRETT: Yes.

23 CHAIRMAN STETKAR: Then you can correct  
24 me. I'm allowed to make mistakes. And then they  
25 credited those additional actions but only in their

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 defense in depths nature, like to provide additional  
2 assurance for satisfying the defense in depth issues.

3 Now, you can correct me.

4 MR. BARRETT: Yes, the way the Harris  
5 safety evaluation was written and the way it was -- it  
6 based on the idea that they could maintain hot standby  
7 indefinitely. So while they were doing cold shutdown  
8 repairs or doing manual actions to get the cold  
9 shutdown systems returned to service, they could  
10 maintain hot standby and there was no time limit on  
11 how long they could do that. That's why the SE is  
12 written the way it is. It's that defense in depth  
13 actions really don't matter because they can maintain  
14 hot standby forever.

15 CHAIRMAN STETKAR: Okay.

16 MR. BARRETT: And that's the way the SE  
17 was written. And that's not really inconsistent with  
18 the way we asked Ocone. They said we've got a time  
19 limit of 72. And we said what do you do after 72  
20 hours? And they couldn't tell us specifically as far  
21 as the way the RAIs were answered. So, you know, I  
22 mean, the rule says safe and stable and it doesn't  
23 have a time limit. So we're looking at it that you  
24 need to be able to show you maintain the reactor safe  
25 for whatever time you need.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: At the moment I don't  
2 want to open up a debate. We're a little bit behind  
3 time. I don't want to open up a debate over Harris  
4 and Oconee versus Harris and Oconee primarily because  
5 it's sort of non-productive in this environment. And  
6 in particular, our committee has been told that we're  
7 to benefit from the lessons learned from Harris and  
8 Oconee. So understanding kind of the evolution of  
9 this issue of concern I think is important to us.  
10 There's nothing that our committee is going to  
11 recommend that will have any bearing whatsoever on the  
12 Harris or Oconee, you know, licensing application  
13 reviews or anything. So that's why I want to kind of  
14 stop a little bit of the discussion that I saw growing  
15 up here.

16 MR. BASSO: Yes, my point --

17 CHAIRMAN STETKAR: But it is a real --

18 MR. BASSO: -- in bringing it up is, you  
19 know, the non-pilots are facing now that issue.

20 CHAIRMAN STETKAR: And that is relevant to  
21 our activity here, so I appreciate that.

22 MEMBER ABDEL-KHALIK: For the record do we  
23 have copies of your revised slides?

24 MR. BASSO: I'll send them to you.

25 CHAIRMAN STETKAR: Make sure. Yes, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have to put the change.

2 PARTICIPANT: It's actually on this  
3 computer.

4 MR. WACHOWIAK: Yes, it's actually on  
5 there. It's installed on the computer, so we can send  
6 you copies.

7 CHAIRMAN STETKAR: Tom, anything else?

8 MR. BASSO: That's all I have.

9 CHAIRMAN STETKAR: Any other subcommittee  
10 members have any questions for EPRI or NEI?

11 (No audible response.)

12 CHAIRMAN STETKAR: Nothing? We'll have a  
13 chance at the end.

14 Thank you. Thank you, thank you very  
15 much.

16 MR. BASSO: Thank you.

17 CHAIRMAN STETKAR: And thank you for  
18 really heroic efforts to partially get us back on  
19 schedule.

20 And with that, I guess we'll call the  
21 staff up. Mark?

22 MR. CUNNINGHAM: First of all, I'm Mark  
23 Cunningham from the Division of Risk Assessment in  
24 NRR. I'd like to thank the committee for the  
25 opportunity for us to give you an assessment of where

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we are with respect to the transition to NFPA 805.

2 Just by way of background, I got involved  
3 in this now just over three years ago when I came to  
4 NRR, and I think there were several things that all of  
5 us in the division have worked for over that three-  
6 year period, things like the reliability or the  
7 predictability of the process that we're using as  
8 these plants transition. We've always been interested  
9 in the issue of ensuring that the PRA that supports  
10 these 805 applications meets the intent of the PRA  
11 policy statement, particularly the realism of it. So  
12 we've done a lot of work over the last couple of years  
13 to develop regulatory guidance and a standard review  
14 plan, to develop inspection guidance and to use those  
15 and base those and learn from the pilot to pilot  
16 applications.

17 So I think we've made a lot of progress  
18 over the last few years in improving the  
19 predictability of it. I think we made progress too on  
20 the issue of the realism of the Fire PRAs, the 6850  
21 Supplement 1 is an example of that. So I think we  
22 have a sense that we're in a good shape today to be  
23 able to move onto the non-pilots. I think we have a  
24 good situation with the two SEs that are coming out,  
25 have come out or are coming out. So you'll hear a lot

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 more about that this afternoon from Donnie and from  
2 Alex.

3 We fully understand that there are issues  
4 that are still out there that could make things more  
5 predictable and the PRAs more reliable and more  
6 realistic. You'll hear from Mark Salley on what's  
7 going on in research in terms of that. So there are  
8 still issues that need to be resolved and still  
9 improvements that we could make, but I think we're in  
10 a good enough state now to be comfortable with moving  
11 on in a timely basis the application of 805 to the  
12 large number of non-pilots.

13 With that kind of introduction, I'll turn  
14 it over to Donnie and Alex for the gory detail.

15 MR. KLEIN: Thank you, Mark. Good  
16 afternoon. My name is Alex Klein. I'm the NRR Fire  
17 Protection Branch Chief and I've got in the audience  
18 with me several of my staff members who have been very  
19 involved in the reviews of these pilot plant license  
20 amendment requests.

21 You heard from Harry Barrett. You heard  
22 from Chuck Moulton. Harry, as you're aware was the  
23 lead reviewer for the Harris safety evaluation along  
24 with members from Donnie Harrison's group. And Chuck  
25 Moulton is the backup to the primary project manager

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for the Oconee SE. As you're aware, the Oconee SE is  
2 under development right now. That's why that lead  
3 person is not here today.

4 Anyways, if I could go to the objective  
5 slide. Really what I wanted to do here today is to  
6 just give you a flavor for what we did kind of for the  
7 pilot plants, the challenge ahead of us with respect  
8 to these large number of license amendment requests  
9 coming from the other plants. We call them the non-  
10 pilots, for lack of a better word at this point.

11 I'll touch upon the NFPA 805  
12 infrastructure development that the staff has been  
13 working on along with the industry. You've heard a  
14 lot of that already today in terms of the FAQ process  
15 and the FAQs that we've worked on, and then some of  
16 the lessons learned.

17 Next slide, please? With respect to the  
18 Shearon Harris and Oconee transition to NFPA 805, I  
19 think you're all very well aware that we issued the  
20 safety evaluation for the Shearon Harris plant back in  
21 June of this year. But if you look back a little bit  
22 from that half year, I can take you back several  
23 years, actually maybe take you back a little bit more  
24 than that, NFPA 805 itself is a consensus standard.  
25 And by that I mean that we had different stakeholders

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 involved through the National Fire Protection  
2 Association that led that effort to develop to NFPA  
3 805. There were representatives from industry,  
4 insurance, government agencies such as the NRC and so  
5 forth. So all the major stakeholders were involved.

6 That was issued in 2001. Then in 2004 is  
7 when we actually issued the voluntary rule under 10  
8 CFR 50.48(c). So about three years passed for us to  
9 go through that rulemaking. So that took us to 2004.

10 If you look at that top bullet, it was  
11 about one year later, almost exactly one year later  
12 that Shearon Harris came in with a license amendment  
13 request. And you'll see I'm not going  
14 chronologically, but there's a reason why I'm doing  
15 this. It's because, as I indicated, Harris is done at  
16 this point with their transition. So they submitted  
17 their license amendment request in 2005. Excuse me,  
18 they submitted their Letter of Intent in 2005. They  
19 submitted their license amendment request to  
20 transition in 2008. And then of course in 2010 is  
21 when we issued the safety evaluation.

22 Duke Energy actually preceded the Letter  
23 of Intent by Progress by about four months or so, that  
24 time frame. They submitted their license amendment  
25 request about the same time frame as Harris did. They

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 submitted a revised license amendment request earlier  
2 this year, in the April time frame. You can see the  
3 dates up there for the major rounds of RAIs that the  
4 staff has issued to Oconee. And right now we have a  
5 tentative date to issue a safety evaluation in 2010  
6 for the Oconee plant.

7 CHAIRMAN STETKAR: Alex?

8 MR. KLEIN: Yes?

9 CHAIRMAN STETKAR: In this forum is there  
10 -- can you give us a brief summary of the need? Why  
11 did Duke submit a revised license amendment request?

12 MR. KLEIN: Actually what I don't have in  
13 here, John, is I think Shearon Harris did the same  
14 thing.

15 CHAIRMAN STETKAR: Oh, did they?

16 MR. KLEIN: Yes.

17 CHAIRMAN STETKAR: Okay.

18 MR. KLEIN: And I don't recall the exact  
19 date.

20 CHAIRMAN STETKAR: Okay.

21 MR. KLEIN: But Shearon Harris also  
22 submitted --

23 CHAIRMAN STETKAR: (off microphone) the  
24 whole time line?

25 MR. KLEIN: Yes, I don't have the full

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time line. Just for brevity it's --

2 CHAIRMAN STETKAR: Okay.

3 MR. KLEIN: That's why I -- because Harris  
4 is done, I figured that --

5 CHAIRMAN STETKAR: Yes, was --

6 MR. KLEIN: But there is no distinction  
7 there in terms of --

8 CHAIRMAN STETKAR: Okay. Thanks.

9 MR. KLEIN: -- what the two pilots did in  
10 terms of their license amendment requests.

11 CHAIRMAN STETKAR: Okay. I just wanted to  
12 understand if there was something unique to Duke that  
13 they had to, you know, jack up the roof and put a new  
14 house under it or something like that that Harris  
15 didn't need to do. Thanks.

16 MR. KLEIN: Okay. You're very well aware  
17 that about half the fleet is transitioning to NFPA  
18 805. I've got some numbers up there. You're aware  
19 that of the non-pilots 47 units have sent in a Letter  
20 of Intent to adopt NFPA 805. We expect that most of  
21 these licensees, those 47 units, will submit their  
22 license amendment requests to us in 2011, calendar  
23 year 2011. There are some plants that will submit in  
24 2012 only because they started the process later.  
25 Some of the multi-unit licensees staggered their

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 start, their transition. One unit has not started  
2 their transition yet, although they've told us that  
3 they intend to do that, and that's the Perry plant.  
4 And one unit has withdrawn their transition to NFPA  
5 805, and that's the Monticello plant.

6 Next slide, please? With respect to the  
7 infrastructure products, we talked a little bit about  
8 some of this, but what I wanted to let you know is  
9 that with respect to NFPA 805, when the rule was  
10 issued in 2004 approximately a year later the staff  
11 issued Regulatory Guide 1.205. And the staff worked  
12 with the industry. They put together their own  
13 guidance document under NEI 04-02 that was issued back  
14 in September of 2005.

15 The staff continued to work with the  
16 industry as we worked through the pilots, as we met  
17 with the pilots; and I'll give you some flavor of that  
18 a little bit later on. We understood the lessons  
19 learned. We took their frequently asked questions  
20 that had been closed out through our process and we  
21 worked with the industry to reissue Reg Guide 1.205.  
22 They worked on a reissuance of their own guidance, NEI  
23 04-02. Issued that in December 2009. Excuse me,  
24 April of 2008. And then we issued our Reg Guide at  
25 the end of 2009. We came to the ACRS. I think you're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 very well aware of that change, of that new revision.

2 At the same time, last year we also issued a Standard  
3 Review Plan for NFPA 805 plants.

4 You've heard talk about NUREG/CR 6850. I  
5 won't go into that in too much detail. September 2005  
6 was the issuance date of that document. The  
7 Supplement 1 that some folks mentioned here today,  
8 that was issued just a couple of months ago, September  
9 of 2010. And what that supplement included, I  
10 believe, was something on the order of 15 frequently  
11 asked questions that were closed out by the staff in  
12 working with the industry. And I'll talk a little bit  
13 more about the FAQ process itself, at least my views  
14 on the FAQ process. The 15 or so FAQs that are  
15 included in Supplement 1, a lot of them had to do with  
16 how you count things in the plant. Some had to do  
17 with probabilities and a couple of them had to do with  
18 fire modeling.

19 The frequently asked questions process,  
20 I'll talk separately about that in a little bit.

21 The staff is also working on an NFPA 805  
22 inspection procedure.

23 CHAIRMAN STETKAR: Alex, I know you're  
24 going into the frequently asked questions in a little  
25 more detail, but how does the staff and the industry

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 interpret a closed frequently asked question? So for  
2 example, Supplement 1 of NUREG/CR 6850 was issued in  
3 December 2010. It compiles some number of frequently  
4 asked questions and the resolutions of those  
5 questions.

6 MR. KLEIN: Yes.

7 CHAIRMAN STETKAR: Now, those questions  
8 have been in progress over some preceding period of  
9 time.

10 MR. KLEIN: Correct.

11 CHAIRMAN STETKAR: In fact some of them I  
12 think were resolved, you know, maybe a year or more  
13 ago, or at least there's documentation out there that  
14 seemed to indicate that there was agreement. Is it  
15 the staff and the industry's conclusion that something  
16 is not resolved until it's published in an update to  
17 NUREG/CR 6850 and until that point it's still an open  
18 issue and could change?

19 MR. KLEIN: Well, the way the staff looks  
20 at it is in terms of a regulatory footprint. What is  
21 the right regulatory footprint to put on this? And by  
22 following our own internal processes for putting the  
23 right regulatory footprint on this, we do it either  
24 through a NUREG 6850-kind of thing, or we do it  
25 through our Reg Guide, the update to 1.205.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: So for example, the FAQ  
2 responses, even though there might be concurrence on  
3 them and they might be closed, they're not interpreted  
4 as Interim Staff Guidance or -- they are interpreted  
5 as Interim Staff Guidance?

6 MR. KLEIN: They are interpreted as  
7 interim staff position on those issues.

8 CHAIRMAN STETKAR: Okay.

9 MR. KLEIN: But as I indicated, it's  
10 putting the regulatory footprint on it.

11 CHAIRMAN STETKAR: No. Yes, okay.

12 MR. KLEIN: Yes, the purpose of these  
13 closure memos that go out mostly under my signature  
14 and made publicly available is to give licensees some  
15 certainty that we've closed this issue out, at least  
16 we've reached technical agreement on the issue. And  
17 in order to put the right regulatory footprint on it,  
18 we just need to take that extra step of issuing a  
19 revising Regulatory Guide, which we did at the end of  
20 the last year. We included as many closed FAQs as we  
21 could into that update of that Reg Guide issued last  
22 year. Yes. So and then that puts the final  
23 regulatory footprint on it. In the meantime, as you  
24 said, it's an interim staff position at this --

25 CHAIRMAN STETKAR: Okay. There's some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 uncertainty that it might change from a strict  
2 licensee perspective?

3 MR. KLEIN: Well, from a strict  
4 perspective I think that probability is extremely low  
5 to have that happen, because we've reached consensus  
6 with the staff on it.

7 CHAIRMAN STETKAR: Okay.

8 MR. KLEIN: We've got multiple  
9 concurrences on these FAQs.

10 CHAIRMAN STETKAR: Thanks.

11 MR. KLEIN: With respect to the last  
12 bullet, the inspection procedure, this is something  
13 that licensees of course are very interested in, how  
14 will the staff inspect these plants that have already  
15 transitioned to NFPA 805? And the staff is currently  
16 undertaking a major effort to develop an inspection  
17 procedure. In fact, the staff is intending to perform  
18 an internal tabletop exercise with some of our  
19 regional inspectors very shortly. We'll then hold a  
20 public meeting. We'll discuss it with licensees. At  
21 some point we'll finalize the inspection procedure,  
22 perhaps sometime early next year. My understanding is  
23 that the Harris plant may exercise and do a self-  
24 assessment using that inspection procedure. Staff may  
25 observe and we would look at how well that's done, how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 well it works through a self-assessment with the  
2 licensee. We may tweak the procedure if necessary.  
3 And then I believe that the Harris plant is scheduled  
4 for a triennial sometime in 2011. So the staff  
5 themselves will exercise that triennial inspection  
6 procedure in 2011 with the Harris plant.

7 CHAIRMAN STETKAR: This is a bit of a  
8 stretch from our charter, but it's somewhat relevant  
9 in light of the presentation that we just heard; and  
10 that is, as I understand it there was some uncertainty  
11 in the interpreted requirements, let's say, for the  
12 non-pilot plants, and maybe from others who were  
13 contemplating transitioning to NFPA 805, regarding  
14 technical issues that conceivably could have been  
15 resolved in an FAQ but; the example was brought up for  
16 Ocone, have been pushed off into either a license  
17 condition or some other venue that I assume will then  
18 be closed out through the inspection process. Is that  
19 the way it's going to work?

20 MR. KLEIN: Not necessarily.

21 CHAIRMAN STETKAR: Okay.

22 MR. KLEIN: Some of these items are either  
23 going to be implementation items, could be a license  
24 condition. The inspection procedure itself is written  
25 at a higher level than that. It won't go into

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specifics in terms of, you know, looking to close out  
2 some of these issues. I think the staff at NRR's  
3 preference would be to close out these issues in a  
4 more generic manner. For example, the issue with safe  
5 and stable that was brought up. If it's in FAQ-54 --  
6 I've not read FAQ-54; my staff has. If it's in there  
7 and FAQ-54 was just issued to the staff, we'll work  
8 with the industry to address that.

9 CHAIRMAN STETKAR: I guess what I was  
10 asking is using that as an example. But a more  
11 generic question is if there are lingering questions  
12 regarding methodology or the interpretation and the  
13 application of a specific part of a methodology, and  
14 that for the purposes of the SER the staff was  
15 confident enough to issue the safety evaluation but  
16 recommended or required that the licensee enhance or  
17 improve that methodology, that's a question of now  
18 uncertainty in terms of what is the acceptable  
19 methodology, you know, looking forward to a new plant.

20 And the question is if those will be closed out under  
21 the inspection process, are we relying on inspectors  
22 to make decisions about methodology issues? We've run  
23 into this in a few other places, so --

24 MR. KLEIN: Yes, and the answer -- if I  
25 can jump in. The answer to that is no.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay.

2 MR. KLEIN: That's not the intent. I  
3 don't want to talk about Ocone because that would be  
4 pre-decisional.

5 CHAIRMAN STETKAR: Sure. Right.

6 MR. HARRISON: It's still under review.  
7 But an example from the Harris review, incipient  
8 detection. They had their model. We found that based  
9 on their application we could approve them for  
10 transition to 805 using their model. Right? We did  
11 the review of it. We saw it. We understood it. We  
12 could approve the application. However, as part of  
13 805 there's also self-approval subsequent to  
14 transition. In that context we said we weren't  
15 comfortable with them using that model not knowing the  
16 changes that were being made, what they could find and  
17 how they would use the model in the future. So in  
18 that sense we put in a condition that said you need to  
19 convert over to the FAQ-approved model to go forward  
20 to do the self-approval for your applications. So it  
21 was one of when we saw it and we can look at it, we  
22 can make that determination. We can actually write a  
23 safety evaluation that found that to be acceptable.  
24 But if we're going to let you do self-approval, we  
25 want you using something that we've agreed to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 methodology on already. So that's one where they were  
2 limited in the license condition as an implementation  
3 item, I believe, that they had to use the -- before  
4 they could do the self-approval for a risk-informed  
5 piece they had to convert over.

6 CHAIRMAN STETKAR: Okay.

7 MR. HARRISON: Okay?

8 CHAIRMAN STETKAR: I think it got it.

9 MR. KLEIN: Next slide, please? Some  
10 other infrastructure development activities. As I  
11 mentioned to you, you know, with the time line at the  
12 beginning here when the rule was first issued and when  
13 the pilot plants issued their Letter of Intent, as  
14 soon as that process started the staff held pilot  
15 observation meetings with the two pilot plants. It  
16 was periodic. It was perhaps once every couple of  
17 months, once every two to three months, and then it  
18 accelerated as we got into it a lot more.

19 So we held periodic meetings between us  
20 and the pilot plants. I think we gained a lot of  
21 knowledge. Industry gained a lot of knowledge through  
22 those pilot observation meetings. We at the same time  
23 in those years also held a number of public workshops  
24 or meetings with the industry to allow other  
25 stakeholders, the non-pilot plants, if you will, some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of our public stakeholders, to participate and hear  
2 what's going on with the pilot plant transitions.

3 With respect to the frequently asked  
4 questions process, this was a process that was started  
5 as a result of interactions with the industry. I  
6 think the industry proposed some sort of process being  
7 put together so that we can address in a collaborative  
8 manner some of the issues that were identified,  
9 whether they be technical issues, some of the  
10 technical issues you heard today, whether they be  
11 process issues, programmatic issues or what have you.

12 So we put together a program. And we've met monthly  
13 since the development of that program. I think we're  
14 up to fifty-some-odd meetings at this point. So we  
15 were able to resolve a number of FAQs, and I'll get  
16 into that in a second. What I wanted to do is give  
17 you a flavor for the interactions that the staff has  
18 had with the licensees over the past three or four  
19 years, not only the pilot plants.

20 Next slide, please? With respect to some  
21 of the issues resolved during pilot transition, I'm  
22 not going to spend a lot of time on this, but I wanted  
23 to give you a flavor again on what some of the things,  
24 some of the issues that were identified that we worked  
25 through with the pilot plants. Certainly when the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 staff receives a license amendment request there's an  
2 acceptance review process that we go through. Because  
3 these license amendment requests were fairly complex,  
4 both the staff and the industry were learning at the  
5 same time. What is it that we need to have in a  
6 license amendment request? What minimum information  
7 is it that we're looking for? So that was a bit of an  
8 iterative process that we worked through with the  
9 pilots.

10 Recovery actions. I think you've heard  
11 about those in past meetings. My view is that we've  
12 been able to address that issue and we've come to  
13 resolution that in fact that's been documented in the  
14 last update to our Reg Guide 1.205.

15 Fire PRA quality was addressed, and that's  
16 with respect to, you know, the scope of the Fire PRA.

17 Some of the peer review findings, how were they  
18 addressed? The resolution of PRA-related FAQs. And  
19 as you well know, the incipient detection as it was  
20 applied at the Harris plant.

21 We talked about radioactive release  
22 transition. There's a requirement in NFPA 805 to  
23 address radioactive release. Well, we worked through  
24 that issue.

25 Non-power operations transition is another

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 major issue that we resolved with the industry through  
2 the pilot process.

3 And then the NFPA 805 monitoring program,  
4 because NFPA 805 requires, the standard requires that  
5 licensees have a monitoring program. Well, to what  
6 extent do licensees need to have a description, the  
7 information, just what level of detail is required in  
8 these license amendment requests? I think we've been  
9 able to work that out through the two pilots so that  
10 the industry well understands at this point what it is  
11 that the staff is looking for.

12 Next slide, please? I talk a lot about  
13 some of these. In actuality slide 8 is actually a  
14 duplicate of one of the other slides, so in brevity  
15 I'm going to go onto slide 9, if I could.

16 As I indicated, as lessons were learned  
17 through the pilot process we went through a process  
18 where we could at least document what some of the  
19 interim staff positions are, and that's the FAQ  
20 process. The FAQ process, as indicated, was  
21 established in 2006. So here we are in 2010 and we've  
22 held monthly meetings, public monthly meetings in a  
23 very open collaborative way with the industry. At  
24 this point 49 FAQs have been processed. Out of those  
25 49 five remain open. FAQ-54, I think you heard before

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is one of them. There are actually I think two or  
2 three FAQs that we've reached technical agreement on  
3 with the industry. When I say that, the staff is in  
4 the process of issuing a closure memo once we've  
5 reached technical agreement on that.

6 CHAIRMAN STETKAR: Alex, if it's only down  
7 to a handful or less than a handful right  
8 now --

9 MR. KLEIN: Yes.

10 CHAIRMAN STETKAR: -- can you give us some  
11 indication of the issues that are related to that  
12 handful?

13 MR. KLEIN: Sure.

14 CHAIRMAN STETKAR: If you don't have it  
15 right off the top of your head or --

16 MR. KLEIN: I do have it in a general  
17 sense, but I've got my FAQ process owner and I've got  
18 Harry who knows these FAQs like the back of his hand.

19 But the FAQs in a general sense have to do  
20 with radioactive release. And I think that one is on  
21 a path to closure. Help me out here, guys. There  
22 were --

23 MR. MOULTON: Well, let me take over.

24 MR. KLEIN: Sure.

25 MR. MOULTON: Okay. There's currently

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 five FAQs that lack --

2 MR. HARRISON: Identify yourself.

3 MR. MOULTON: This is Chuck Moulton, NRC  
4 staff. I'm the FAQ process owner. There are  
5 currently five FAQs that lack a closure memo. The  
6 first one has to do with risk recovery actions.  
7 That's in the closure process right now.

8 CHAIRMAN STETKAR: Recovery actions in  
9 what -- the definition of what is a recovery action?

10 MR. MOULTON: What risk calculations need  
11 to be submitted for recovery actions.

12 CHAIRMAN STETKAR: Essentially the 1.205-  
13 type --

14 MR. MOULTON: Yes.

15 CHAIRMAN STETKAR: -- issue of -- okay.  
16 And that's still nominally -- is there anything more  
17 than what was in 1.205 on that one? Again, I hate to  
18 belabor these things, but --

19 MR. BARRETT: Harry Barrett.

20 CHAIRMAN STETKAR: -- (off microphone)  
21 this is technical and not programmatic, so --

22 MR. BARRETT: FAQ 30 basically gives you  
23 the detail guidance to transition existing operator  
24 manual actions to recovery actions.

25 CHAIRMAN STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BARRETT: Decide whether or not you  
2 need to do a delta risk and what you do with that  
3 delta risk as far as approval.

4 CHAIRMAN STETKAR: Okay.

5 MR. BARRETT: If it's a previously  
6 approved recovery action, then you end up basically  
7 passing it through.

8 CHAIRMAN STETKAR: Grandfather it, yes.

9 MR. BARRETT: If it's -- yes, grandfather.

10 CHAIRMAN STETKAR: Okay.

11 MR. BARRETT: But you still end up  
12 considering that in the overall risk structure.

13 CHAIRMAN STETKAR: So it's just more  
14 elaboration on the detail?

15 MR. BARRETT: Yes, it's more detail on how  
16 to do that process.

17 CHAIRMAN STETKAR: Okay. Okay. And that  
18 one in your -- that's close to --

19 MR. BARRETT: No, we have technical  
20 agreement. We just have to write the closure memo.

21 CHAIRMAN STETKAR: Okay. All right.

22 MR. MOULTON: Next one is FAQ No. 38. We  
23 also have reached technical agreement on that one;  
24 awaiting closure memo. That one has to do with  
25 multiple spurious operations.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Let's see.   FAQ-53, which we're still  
2 working on.   It's open.   It has to do with the  
3 physical characteristics of kerite cables.   There are  
4 research activities and testing ongoing on that that  
5 we're awaiting.

6           CHAIRMAN STETKAR:   That's strictly for  
7 kerite cables?

8           MR. MOULTON:   Yes.

9           CHAIRMAN STETKAR:   I'll throw it out to  
10 the folks behind us, or maybe you know.   What fraction  
11 of the plants have substantial problems with kerite  
12 cables?

13          MR. BARRETT:   Oh, I'd probably say between  
14 10 and 20 percent of the plants.

15          CHAIRMAN STETKAR:   I was going to say,  
16 they're not in wide --

17          MR. BARRETT:   It's not in wide use,  
18 but --

19          CHAIRMAN STETKAR:   So closure of this one  
20 isn't a big picture one for the industry?

21          MR. BARRETT:   Depends on whether or not  
22 you're one of the plants that has it.

23          CHAIRMAN STETKAR:   No, I understand.   But  
24 this is obviously a focused plant-specific concern.

25          MR. BARRETT:   Yes.   Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay. Could be very  
2 important, but for a small fraction of the plants.  
3 Thank you. And that one's still open you said?

4 MR. MOULTON: Yes, it is.

5 CHAIRMAN STETKAR: Okay.

6 MR. MOULTON: Next one is FAQ No. 54,  
7 which you have already heard about. That's still  
8 open.

9 And then the fifth one is FAQ No. 56,  
10 which as to do with radioactive release transition  
11 information that licensees need to submit to us. And  
12 that one is in the closure process. The closure memo  
13 has been written and it's in the concurrence chain  
14 currently.

15 CHAIRMAN STETKAR: And is that similar in  
16 nature to the guidance regarding treatment of non-  
17 power operation modes, I mean in the sense of how you  
18 need to think about it, the types of analyses that  
19 need to be done short of, you know, a level two PRA-  
20 type of --

21 MR. MOULTON: Oh, I'm not sure this has  
22 much technical --

23 CHAIRMAN STETKAR: Okay. That's all I  
24 wanted to hear.

25 MR. BARRETT: It's even less. It is more

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 qualitative than that.

2 CHAIRMAN STETKAR: Okay. So am I correct  
3 then -- make sure I understand the -- of the five the  
4 kerite cables is open and it's still under discussion?

5 MR. MOULTON: That's right.

6 CHAIRMAN STETKAR: The issue of what  
7 defines safe and stable is open and still under  
8 discussion?

9 MR. BARRETT: That's part of the FAQ-54,  
10 which is compliance with chapter 4, which encompasses  
11 a whole lot of issues. It's a fairly good sized FAQ  
12 and covers a major part of the analysis process.

13 CHAIRMAN STETKAR: All right. That's  
14 appropriately vague. I mean, the industry brought up  
15 the definition of safe and stable as their concern  
16 highlighted under that particular FAQ.

17 MR. BARRETT: Yes.

18 CHAIRMAN STETKAR: Are there other  
19 significant technical issues under that FAQ that  
20 remain --

21 MR. BARRETT: I would say no, because the  
22 FAQ is basically writing down exactly what was done  
23 for the pilots as far as the documentation of how you  
24 met chapter 4.

25 CHAIRMAN STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BARRETT: There hasn't been a lot of  
2 issues back and forth between the staff and the  
3 industry on those issues.

4 CHAIRMAN STETKAR: Okay.

5 MR. MOULTON: Yes, we actually received  
6 FAQ-54 in September of this year, so it's only been a  
7 couple months.

8 CHAIRMAN STETKAR: Okay. But we can read  
9 thousands of pages in a week, so --

10 MR. CANAVAN: Just a quick thought on  
11 that. Is that when you originally --

12 CHAIRMAN STETKAR: Ken, you got to come to  
13 the microphone.

14 MR. CANAVAN: Ken Canavan. I just have a  
15 quick question. It's noted as an '08 FAQ. So you're  
16 saying September of this year is the first time you  
17 ever saw that FAQ? Is that correct?

18 MR. BARRETT: Yes, that's correct. The  
19 task force had that FAQ in development for that long.

20 MR. CANAVAN: It's never been submitted to  
21 you? It hasn't been in the FAQ log?

22 MR. BARRETT: It's been in the FAQ log,  
23 but they never gave it to us.

24 CHAIRMAN STETKAR: We can resolve the  
25 timing of who saw what when, you know, offline. I was

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just trying to get an understanding on the number of  
2 items and what technical issues are covered by those  
3 items.

4 MR. HENNEKE: Okay. This is Dennis  
5 Henneke with GE Hitachi. I was the author of five of  
6 the 15 FAQ for Fire PRA. I heard the word "consensus"  
7 and I heard the word "agreement," and I'm going to  
8 disagree with those words. Of those five, four of the  
9 words were changed in the Interim Staff Guidance,  
10 three of them significantly. So what we do is we  
11 would submit something. Like a hot short duration, I  
12 submitted that one. It was a fairly major effort of  
13 work. I gave an interim solution to DC circuits  
14 waiting DC circuits testing. Two-and-a-half years ago  
15 it was ready to go. That got pulled on the Interim  
16 Staff Guidance. So industry is left without a  
17 solution for three years when we had that solution  
18 three years ago.

19 Same thing on transient fires. I had a  
20 transient fire T-squared of six minutes. I submitted  
21 that. I disagree with the staff on it. They put in a  
22 two minutes on a six minutes. And now the industry  
23 doesn't know which to use, two or six because there's  
24 no guidance on how to use those.

25 The other one was on cabinet sealed but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not well sealed cabinets. We submitted a motor  
2 control sensor, significant. We submitted a severity  
3 factor for that and that got disagreed with.

4 So it's not a consensus process. It's one  
5 of the reasons that I personally -- I had no support  
6 from the owner's group on these FAQs. Just refuse to  
7 submit them because it's not a consensus process.  
8 It's we submit it. The staff goes to consensus,  
9 changes it and then issues the Interim Staff Guidance.

10 CHAIRMAN STETKAR: Okay.

11 MR. HENNEKE: And that's really where a  
12 lot of the problems lie. And we had solutions to a  
13 number of problems that got pulled and we continue to  
14 work on them today.

15 CHAIRMAN STETKAR: Let me try this,  
16 because I think I see a couple of different opinions  
17 here: For December what I'd like the industry to do -  
18 - and hopefully we can communicate on both sides, is  
19 that it sounds like there are some FAQs that the staff  
20 has essentially signed off as closed and yet there may  
21 still be substantial disagreement among people in the  
22 industry over whether or not that's an adequate  
23 closure or whether indeed all of the issues were  
24 addressed. Is that, from industry's perspective  
25 anyway, a fair characterization?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (No audible response.)

2 CHAIRMAN STETKAR: I see nodding heads for  
3 the record. If we could for December, because we  
4 don't have the time to do it today, list the top --  
5 you know, I don't want 49, the top four or five, if  
6 that's the appropriate number, of those FAQs for which  
7 you still feel that there is substantial uncertainty  
8 or substantial technical disagreement. Because this  
9 is important. It doesn't impart uncertainty, you  
10 know, if I'm doing a PRA going forward. I may  
11 understand what the staff currently will accept, but I  
12 may not understand whether that's the most reasonable  
13 technical position.

14 So if you could take the action item to  
15 highlight the four or five or something, how many  
16 there are, not 49, and what the issue is so that we  
17 can understand what that issue is from a technical  
18 perspective. You mentioned the industry had proposed  
19 something and the staff came back and issued something  
20 else. And if the staff could also -- if we can get  
21 some communications there so that we can understand,  
22 you know, where the staff's closure sits in that  
23 space, I think it would help me an awful lot in terms  
24 of understanding, you know, how far apart you are,  
25 what the issues are and then how important those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 particular issues might be to fidelity of the final  
2 PRA results. In other words, I don't care if you  
3 don't agree if it's something that doesn't make any  
4 difference, quite honestly. I mean, I do eventually  
5 because I'd like to have perfection in everything.  
6 You understand?

7 PARTICIPANT: (Off microphone.)

8 CHAIRMAN STETKAR: Okay. We can go back  
9 over this, you know, at the end.

10 MR. BRADLEY: Are you talking about any  
11 FAQ or PRA-related FAQs?

12 CHAIRMAN STETKAR: PRA-related FAQs,  
13 because I'm still trying to keep us as much as  
14 possible out of the process-type issue, which is why  
15 on that one FAQ I wanted to focus more on what the  
16 technical issue was, you know, rather than how you  
17 demonstrate compliance with every line item in chapter  
18 4.

19 Okay. Thanks. Any other discussion on  
20 that part of the FAQs?

21 (No audible response.)

22 CHAIRMAN STETKAR: As I said, at the end  
23 of the meeting we'll try to come back and go over some  
24 of these things for preparation for the December  
25 meeting.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MOULTON: I'd just like to add you  
2 might want to examine Regulatory Issue Summary 2007-  
3 19. It describes the FAQ process.

4 CHAIRMAN STETKAR: 2007-19?

5 MR. MOULTON: Nineteen, yes.

6 CHAIRMAN STETKAR: Thank you.

7 MR. KLEIN: A full disclosure, however, to  
8 clarify what Chuck just said. When we tried to  
9 address some of these PRA-related FAQs through the  
10 2007-19 process, we met with the industry and we came  
11 up with a modified approach, if you will, or process.

12 Just so you know that there was a different process,  
13 a slightly different process from the 2007-19 process  
14 to close out these PRA FAQs that had kind of been  
15 sitting there. And so we wanted to move them along  
16 and get them closed out. So we initiated a different  
17 approach for that, just so you're aware.

18 CHAIRMAN STETKAR: So I'm interested in  
19 process, but less interested in --

20 MR. KLEIN: Understand.

21 CHAIRMAN STETKAR: -- understanding  
22 what --

23 MR. KLEIN: Understand.

24 CHAIRMAN STETKAR: -- the disagreements  
25 over what the technical issues are right at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 moment.

2 MR. KLEIN: Okay. So anyway my last  
3 bullet. You know, I want you to get the flavor that  
4 the FAQ process I believe has had a significant impact  
5 on transition. I think it's had a positive impact, a  
6 substantial impact. To me it's been a positive  
7 impact. I think that we wouldn't be here today  
8 discussing some of these items and wouldn't be where  
9 we are today without that FAQ process having been  
10 implemented.

11 So next slide, please? I just want to  
12 touch upon some of these. These are some of the FAQs  
13 that I'm using as examples that were sometimes  
14 characterized too as FAQs that could potentially be  
15 showstoppers if they weren't resolved in some  
16 consensus-type manner. Some of these are process  
17 issues, not necessarily technical issues. So for  
18 example, the fire protection engineering evaluation  
19 one, I think you're very well aware of that one, so I  
20 won't go into any detail. The non-power operations  
21 FAQ I mentioned to you we've reached resolution on.  
22 And then incipient detection, Harry Barrett had given  
23 you some indication there. These were all very  
24 important FAQs for the industry to gain some alignment  
25 on with the staff, and I believe that we've done that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 My last slide talks about some of the  
2 lessons learned with respect to non-PRA implementation  
3 issues. And I'll just go quickly through this because  
4 I know that you want to hear the meat of it from  
5 Donnie and from Mark when they come up here.

6 That first bullet talks about FAQ-8.

7 The second bullet there talks about again  
8 the recovery actions that have to do with the primary  
9 control stations. We came to you I think the summer  
10 and fall of last year and we had a very detailed  
11 discussion with you folks on risk of recovery actions.

12 This implementation of safe and stable  
13 concept under NFPA 805, quite frankly this is the  
14 first time, at least to me, that it's been  
15 characterized the way it has been by the industry. I  
16 believe that we are treating both Harris and Oconee  
17 the same way. You heard the slide up there from NEI.

18 They quoted the regulation. The words in the  
19 regulation out of NFPA 805 are what they are. The  
20 staff has to reach some conclusion with the licensees,  
21 the license amendment requests. And quite frankly,  
22 it's the licensees that choose how they want to  
23 address safe and stable. They have to demonstrate to  
24 us and we have to get reasonable assurance that they  
25 can achieve and maintain safe and stable. So I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 believe that we've worked it out with the Harris  
2 plant.

3 Oconee, because it's still pre-decisional  
4 at this point, we're still going through the RAI  
5 process. So I don't want to delve into that too much  
6 more.

7 CHAIRMAN STETKAR: Just out of curiosity;  
8 and we probably won't have an opportunity here,  
9 curious if indeed the interpretation of safe and  
10 stable is indefinite safe and stable and if the  
11 interpretation for some plants is that indefinite  
12 means cold shutdown. What assurance do I have that  
13 cold shutdown can be maintained indefinitely, that the  
14 equipment will continue to run forever and that water  
15 will never boil away and that operators are always  
16 perfect after some indeterminate period of time? So  
17 why does simply achieving cold shutdown provide  
18 assurance that I have indefinite safe and stable  
19 conditions any more than being at hot standby for 72  
20 hours or hot standby for 18 minutes, or you know, some  
21 other time period, or you know, without being flip, 24  
22 hours, which is typically the time window for most PRA  
23 studies?

24 MR. KLEIN: Right. NFPA 805, the  
25 standard, does have a definition about what safe and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 stable is. And as I indicated it's up to the licensee  
2 to meet that definition of what they believe safe and  
3 stable is and how they can meet that. So whether it's  
4 hot standby, hot shutdown, cold shutdown, if that's  
5 the end state that they choose to be at for that  
6 indefinite time period, they'll have to demonstrate  
7 that to us.

8 So I don't know if you want to add  
9 anything more with respect to the 24/72?

10 MR. HARRISON: Yes, I'll say two things.  
11 One is they need to describe their program. Right?  
12 And again, just in reference Ocone did originally  
13 propose a 24-hour time. Their basis was because  
14 that's what the PRA uses. Safe and stable is not a  
15 PRA issue. Safe and stable is a deterministic issue.

16 And so in that context if you've got a PRA and you  
17 know at hour 25 all the equipment goes away because of  
18 some phenomena, your mission time would not be a 24-  
19 hour mission time. It would be a 25-hour mission time  
20 and those all would be failures. Right? The same  
21 thing would apply in that sense, that parallel world  
22 of the licensee that establishes a time for achieving  
23 safe and stable and then says, well, that's great.  
24 How are you going to maintain it long term? You need  
25 to describe that. You can't just say I made it for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 two days or I made it for three days and now I don't  
2 have to tell you anything else. It's got to be a  
3 complete story to be able to say how am I achieving  
4 and maintaining safe and stable? Again, that's not a  
5 PRA question. That's a deterministic question. So  
6 you need to describe it.

7 CHAIRMAN STETKAR: Okay. All right.  
8 Well, I'm assuming this will come up in December and  
9 we'll hear a little bit more details from everyone  
10 regarding what that definition means, because I'm  
11 reading, "The nuclear safety" -- from NFPA 805, the  
12 2001 version, "The nuclear safety goal is to provide  
13 reasonable assurance that a fire during any  
14 operational mode and plant configuration will not  
15 prevent the plant from achieving and maintaining the  
16 fuel in a safe and stable condition."

17 Doesn't say indefinitely. It just says  
18 "and maintaining."

19 PARTICIPANT: Right.

20 CHAIRMAN STETKAR: Now, I'm not sure what  
21 that means. So it's not a very good definition.  
22 Whoever wrote NFPA 805 obviously had never thought  
23 about doing risk assessment, otherwise they wouldn't  
24 have been this vague.

25 So I understand the industry's desire to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 understand whether that means 24 hours, 72 hours or,  
2 you know, the history of the universe and whether or  
3 not it requires a quantitative evaluation to  
4 demonstrate indefinite times, which is really  
5 difficult, or whether quantification of stable  
6 conditions for some agreed upon period of time with  
7 qualitative evaluations of capabilities beyond that is  
8 acceptable.

9 MR. KLEIN: Okay. My last bullet in  
10 regards to the monitoring program. What the staff  
11 learned is during the reviews of the pilot plant  
12 license amendment requests we believe that the  
13 description of the monitoring program needs to be more  
14 detailed. And we had RAIs with both Harris and with  
15 Ocone that provided those licensees the opportunity  
16 to provide those details back to the staff with  
17 respect to what we would need to see at the time of  
18 submittal for a monitoring program.

19 And we used the word "mature" here because  
20 I think when we first received these license amendment  
21 requests the description of the monitoring program,  
22 what the attributes might be, what the criteria are  
23 and so forth, were basically lacking out of those  
24 license amendment requests. So just wanted to point  
25 that out.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           That's my very last bullet and that  
2 concludes my presentation.

3           CHAIRMAN STETKAR: Donnie, this is just a  
4 timing -- roughly how long do you expect?

5           MR. HARRISON: I was allocated like an  
6 hour-and-a-half. I don't expect to be anywhere near  
7 that. I've taken a different approach in dealing with  
8 methods, so --

9           CHAIRMAN STETKAR: What I was going to ask  
10 you though is once you get into this do we have a  
11 steamroller going that is difficult to interrupt in  
12 about somewhere in the next half hour, or --

13          MR. HARRISON: We can interrupt.

14          CHAIRMAN STETKAR: Okay. Thanks.

15          MR. HARRISON: There are easy stopping  
16 points.

17          CHAIRMAN STETKAR: Go forth and start.

18          MR. HARRISON: Okay. I'm Donnie Harrison.

19           I'm the PRA Licensing Branch Chief in NRR.

20           You heard this morning and a little bit  
21 this afternoon about the methods issues by the  
22 industry. You're going to hear about research  
23 activities on refining modeling after me, so I'm not  
24 really going to spend a whole lot of time on Fire PRA  
25 methods.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'm going to talk about -- at least what's  
2 on the slide here is other issues. And I'm really  
3 focused on the things I've seen or heard that are  
4 impeding or could impede a licensee transitioning to  
5 NFPA 805. These are kind of my perspectives, my  
6 opinions on what I've heard and seen.

7 What I've done is I've categorized them  
8 into four basic areas to talk about. One is what I  
9 call the Internal Events PRA/Fire PRA carryover  
10 issues. There's risk-informed application issues.  
11 There's Fire PRA peer review issues. And then there's  
12 just the scope of the 805 transition application. And  
13 then I want to close with a slide on what I see as the  
14 path forward.

15 Before I jump in though I think from a  
16 general sense given where the pilots are right now  
17 we're showing that you can transition. You can use a  
18 Fire PRA that's good enough to transition to 805.  
19 There may be issues. There may be things that  
20 licensees would prefer not to have to do in the area  
21 of doing modifications versus analysis, but it's  
22 possible to make the transition. So I'll repeat that  
23 at the end when I get done.

24 Internal events carryover. For most  
25 licensees the internal events were developed many,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 many years ago, decades ago. They've been refined  
2 numerous times over the last couple of decades. They  
3 were probably peer reviewed over a decade ago.  
4 Depending on if they've made upgrades to their  
5 methods, they may have been re-peer reviewed in that  
6 last decade or they may have voluntarily done some  
7 peer reviews in the last decade.

8 The issue when it comes to transition to  
9 805 is if you've got a peer review on your Internal  
10 Events PRA and you haven't resolved findings from that  
11 peer review, those issues linger and they carry right  
12 over into the Fire PRA. And so in addressing  
13 transition to 805, since we build the Fire PRA off the  
14 Internal Events PRA, you get this synergistic effect  
15 in the issue. And so issues that aren't resolved need  
16 to be resolved before you transition, otherwise you'll  
17 end up with the potential of trying to resolve  
18 internal event findings in the midst of your Fire PRA  
19 review and causing delays. And again, this is all  
20 what impedes transition. This would delay your  
21 ability to transition.

22 The other point is if you're in the midst  
23 of your application, if licensing makes an application  
24 to us and in the midst of our review needs to do a  
25 major change to their Internal Events PRA, that will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 directly impact their Fire PRA and could change some  
2 of their analysis. And that would also impede their  
3 ability to transition. So there's this synergist  
4 effect that we need to be aware of. It does happen  
5 and it's just more of, at least in my presentation, a  
6 reality check. These things do happen and we need to  
7 be ready for it.

8 CHAIRMAN STETKAR: They do happen and have  
9 happened already?

10 MR. HARRISON: Do happen. Have happened.  
11 Yes.

12 CHAIRMAN STETKAR: Oh, okay.

13 MR. HARRISON: Yes, some of these were  
14 issues within the pilots.

15 Risk-informed applications. Here's  
16 another thing that does happen and will happen likely.

17 We have an industry of 104 plants. Some of them are  
18 very active when it comes to doing risk-informed  
19 applications. Some have done maybe one or two risk-  
20 informed applications in their life time. So you have  
21 a mixed bag of experience. Those that have limited  
22 experience, especially for an application such as NFPA  
23 805 it's a large application and you're changing your  
24 entire fire protection program and its complexity.  
25 This can create problems for inexperienced or limited

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 experience licensees.

2 The other issue here is though the Fire  
3 PRA methods have been around for 25-30 years, most of  
4 the licensees, their experience in doing Fire PRA is  
5 dated, if they still even have that experience. So  
6 there's a learning curve that's occurring within the  
7 industry and that can be a painful process. I refer  
8 to it as like your muscles atrophy. You used to be an  
9 athlete and now you're older and you don't exercise  
10 anymore. One day you wake up and the doctor says you  
11 have to start exercising again. The muscles hurt when  
12 you start back up. Right? So we're going through a  
13 little bit of pain in that learning curve.

14 And then the reality check is the third  
15 bullet. Within NFPA 805 we've had essentially in the  
16 last really five years, five-six years three things  
17 occur simultaneously. You've got a new Fire PRA  
18 methodology guidance. It's an improvement over what  
19 was there 25-30 years ago, but it is new guidance. It  
20 does different things. So you have to learn that. At  
21 the same time we have a new Fire PRA standard that's  
22 encompassed in the ASME/ANS standard. So that's how  
23 you're going to tell if your PRA's good enough for  
24 your application. And now we have this large  
25 application called NFPA 805 or 10 CFR 50.48(c). All

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 those are coming together at the same time. That's an  
2 impact you need to be aware of, but it's also a  
3 reality of typically that's the only way things get  
4 done is you have to have an application to drive for  
5 methods to be developed. And once you start going  
6 down that path the standards have to make sure that  
7 you can do it well enough to support the application.

8 So even though all these three things come together,  
9 it's not unusual. This is typically what -- one  
10 things motivates the other.

11 CHAIRMAN STETKAR: Donnie, recognizing  
12 that, you know, the staff has finished the Harris SE  
13 and that the Oconee is pre-decisional so you can't  
14 really talk too much about details of that, have you  
15 run into instances during the pilot projects where  
16 there are inconsistencies among those last three  
17 bullets, the guidance in the NUREG and interpretation  
18 of what the standards require and what may be required  
19 to conform with some interpretation of NFPA 805, for  
20 example?

21 MR. HARRISON: I would say within the  
22 implementation guidance that went with 10 CFR 50.48(c)  
23 there was the original issue of Reg Guide 1.205.  
24 There were things within that guidance that -- what  
25 drove us to develop a revision one to that last year

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was the fact that we saw lessons learned from the  
2 pilot that our guidance needed to be fixed. There  
3 were a couple of things I think we actually missed  
4 within the requirements of 805. And so I think within  
5 the last bullet in particular there was that issue.

6 The issue on Fire PRA methodology  
7 conservativisms, refinements --

8 CHAIRMAN STETKAR: Yes, that doesn't  
9 really --

10 MR. HARRISON: That doesn't really --

11 CHAIRMAN STETKAR: I was more considering,  
12 you know, that people had pointed out is the quality  
13 of my PRA adequate, which is sort of focused at the  
14 second bullet, the standards.

15 MR. HARRISON: Right. Right.

16 CHAIRMAN STETKAR: Do I meet capability  
17 categories 1, 2 or 3?

18 MR. HARRISON: Right.

19 CHAIRMAN STETKAR: But it does fold over  
20 into the methods that you're using.

21 MR. HARRISON: It does.

22 CHAIRMAN STETKAR: For example, how do you  
23 treat data? How do you treat uncertainties? You  
24 know, that sort of thing.

25 MR. HARRISON: It has that relationship.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I think there was a complaint at one point about the  
2 standard that it actually was referring back to the  
3 NUREG/CR as examples of how to do some things. And  
4 the standards not supposed to tell you how to do a  
5 thing. It's supposed to tell you what's good enough  
6 to achieve a certain thing. So there's been  
7 interaction in that within the Fire PRA standard to  
8 remove those how-to guidance from the standard.

9 The other part of that is even within NFPA  
10 805 application, depending on what the applicant, the  
11 licensee's proposing, may change what level of quality  
12 you need in the Fire PRA standard. The example I  
13 would give, Oconee has made a submittal with  
14 modifications that make it a risk decrease  
15 application. Okay? So after the transitioned to 805  
16 the risk has gone down. Right? The standard, the  
17 quality standard for that PRA is less than what would  
18 be one where it's marginally got a risk increase and  
19 you're at a threshold of being unacceptable risk  
20 increase.

21 CHAIRMAN STETKAR: Yes. Interesting.

22 MR. HARRISON: So even within an 805  
23 application you can have two plants come in with two  
24 different approaches. That drives the quality  
25 requirements on them. So you can live with one that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 maybe not as strong in a PRA as well as the other one.

2 So again, that's a phenomena of how the  
3 regulatory guidance allows the mixing of modifications  
4 with the application. We're going to touch on that  
5 just briefly.

6 CHAIRMAN STETKAR: Okay.

7 MR. HARRISON: The next topic I want to  
8 talk about is the Fire PRA peer reviews. And again, I  
9 have not been a peer reviewer on a Fire PRA. That's  
10 an industry activity that's performed. The staff  
11 typically looks at the findings of the peer review  
12 teams and evaluates that, how they've been resolved.

13 CHAIRMAN STETKAR: Before you launch into  
14 this, because I think this is maybe an interesting  
15 topic, correct me if I'm wrong, did Oconee and Harris  
16 have peer reviews?

17 MR. HARRISON: No.

18 CHAIRMAN STETKAR: Okay.

19 MR. HARRISON: No. Within the original  
20 Reg Guide 1.205 it stated that the staff would do the  
21 review of the PRA recognizing that they were pilots.  
22 That's something unique to the pilots, is the staff  
23 did the review.

24 CHAIRMAN STETKAR: So you served the  
25 surrogate peer review process for those?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: Yes and no.

2 CHAIRMAN STETKAR: Okay.

3 MR. HARRISON: The staff followed the  
4 guidance on the peer review guidance and were  
5 qualified per that guidance that existed at the time.

6 I believe it was a draft of the standard at the time.

7 But the outcome of those reviews were follow-on RAIs.

8 The outcome of the Oconee one was a statement of a  
9 need for at least a focused scope peer review of  
10 elements that weren't complete. So there were  
11 outcomes that were slightly different than what a peer  
12 review would be.

13 CHAIRMAN STETKAR: But in a nutshell you  
14 haven't yet seen an application that indeed has been  
15 through the industry peer review process, is that  
16 right?

17 MR. HARRISON: Correct.

18 CHAIRMAN STETKAR: Okay.

19 MR. HARRISON: We have observed a peer  
20 review. We actually attended one; the staff did, and  
21 observed the performance of a peer review at one of  
22 the plants to get some -- and again, I think at one of  
23 these I have the comment that to gain confidence and  
24 understand the issues of those peer reviews.

25 So again, the industry conducts the peer

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 review. We see the findings. So the observation of  
2 the one peer review is to gain some of that. We've  
3 talked about do we need to see additional peer reviews  
4 to gain further understanding and confidence in the  
5 process.

6 We did a similar thing on the Internal  
7 Events PRA when that standard went out in about the  
8 2005 time frame. We went on five different pilots and  
9 did some checking to see how the guidance worked with  
10 our understanding. So we're doing it a slightly  
11 different way, but still trying to gain that  
12 confidence in the process.

13 CHAIRMAN STETKAR: Okay. Thanks.

14 MR. HARRISON: Okay. The things that can  
15 impede transition. Again, a peer review team is  
16 looking at the plant's PRA. If that plant is using  
17 some unique method or unreviewed model of some new way  
18 of splitting out the data and refining the heat  
19 release rates, peer review teams are usually on site  
20 for only a week. Jim, correct me if I say this wrong,  
21 they usually have a month before and a month after.  
22 Right? If all of a sudden a new method pops up that  
23 they've never seen before, that can cause them  
24 problems within the peer review. They can't get their  
25 job done effectively or they're making decisions on a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 methodology that they haven't really had enough time  
2 to think about.

3 And as a result I think it becomes a  
4 natural thing that says, well, if you use NUREG/CR  
5 6850, the peer review team's going to have an easier  
6 time performing your peer review. If you deviate from  
7 that, then it's a peer review team that's going to set  
8 a high bar for justifying that or they're going to say  
9 you don't meet the capability category, because they  
10 just don't have the time to be able to do that.

11 In response to what was going on, I've  
12 been told the industry kind of responded to the fact  
13 that these peer reviews were holding NUREG/CR 6850 as  
14 the standard, as the only acceptable method. And as a  
15 result they've their peer review guidance. They've  
16 created this task force on PRA methods so that the  
17 peer review team has an outlet, if you will, where  
18 they can take a method and say we haven't had the time  
19 to evaluate and accept this. We'll push that off to  
20 the task force to review and evaluate that and bring  
21 it back to us.

22 The change in peer review guidance also  
23 results in us having to maybe ask some different RAI  
24 questions or get different information from a  
25 submittal because of the new guidance that they've

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 published for the peer review teams, but that's a  
2 fairly minor issue. That just means we have to change  
3 the way we get information. That's all.

4 CHAIRMAN STETKAR: Well and in practice  
5 you haven't tested those waters yet either, right?  
6 Looking at a peer review-approved difference in  
7 methodology, let's say, compared to --

8 MR. HARRISON: Right. And I'm going to  
9 hit that on my next slide in a minute.

10 The big one on this one is that last  
11 bullet there, which is because of the scheduling for  
12 Fire PRA peer reviews. The licensees are lining up to  
13 do these -- submit the applications in June of this  
14 coming year. They need to get their PRA peer reviews  
15 done before that. You had a whole wave come through  
16 then. Some of those set dates for peer reviews and  
17 then when the peer review date came their PRA wasn't  
18 done. So the peer reviews reviewed what was  
19 available, but they were incomplete peer reviews and  
20 that would basically drive you to another peer review.

21 So you'd have to at least come back and re-look at  
22 those things that were not peer reviewed and make sure  
23 that those meet the standard. That can cause cycling.

24 It causes time for the peer review teams to keep  
25 coming back, but it also causes -- the licensee loses

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that time preparing for the peer review. They're not  
2 ready. They still do it, but then they've got to now  
3 fix everything and come back and do it again three,  
4 six months later. So that just recognizes -- that  
5 slows the process down. It's going to delay making  
6 submittals.

7 CHAIRMAN STETKAR: Is there a -- I'm  
8 trying to think how to ask this question  
9 appropriately. You emphasize the inefficiency of --  
10 it's a kind of compounded inefficiency of trying to  
11 meet a specific submittal date, submitting something  
12 that may not be complete, but you have to get a time  
13 slot for your peer review because there's a limited  
14 number of, you know, quite honestly people who are  
15 capable of performing technically competent peer  
16 reviews. I suspect that's a fairly small number of  
17 people. And then learning that, you know, your peer  
18 review has told you you're inadequate because, you  
19 know, you're not finished. Shouldn't have been a  
20 surprise to you, but it is.

21 From a technical perspective -- at the  
22 moment I don't care too much about scheduling.  
23 Industry doesn't want to hear that. From a technical  
24 perspective; it would be better if I asked the  
25 industry this and they may want to consider commenting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 later, are we running a risk of having inadequate peer  
2 reviews simply because of the volume of studies that  
3 are on the table, let's say, and the limited number of  
4 really experienced peer reviewers that are out there  
5 capable of doing these things? Or do we have  
6 sufficient resources to have assurance that from your  
7 perspective when you do receive a license amendment  
8 request with the supporting analyses and the results  
9 of a peer review you can say yes indeed you have  
10 confidence that that peer review was technically  
11 adequate to essentially relieve you of some of your  
12 independence burden in terms of looking at every  
13 single technical detail and perhaps the way that you  
14 had to do it under the Ocone and Harris submittals?

15 You know, I don't know what the answer to  
16 that question is, but I'd be interested in any  
17 insights I could get, either from you or the industry.

18 MR. HARRISON: Yes, I love speaking for  
19 the industry, but --

20 CHAIRMAN STETKAR: Yes. I've heard of it  
21 a bit so this is the appropriate time to kind of ask  
22 it.

23 MR. HARRISON: And I think you've  
24 certainly also heard the concerns from the industry  
25 about resources, limited resources. And when you do a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 peer review oftentimes in the industry peer review  
2 process, as you commit to give up a staff member to do  
3 a peer review, if you get a peer review. And so that  
4 becomes also, if your NFPA 805 plant and you're trying  
5 to develop the Fire PRA to come in and now you have to  
6 give up a person because you just got peer reviewed,  
7 that does impact your ability in moving forward, to  
8 make changes to your Fire PRA moving forward. I think  
9 that's the reality of the limited resources and the  
10 process of how the peer review functions. I'd invite  
11 the -- if the industry wants to make a statement on  
12 that.

13 CHAIRMAN STETKAR: I don't know if anybody  
14 that's in the back --

15 MR. BRADLEY: Biff Bradley, NEI. It's  
16 certainly a challenge for us to do this many peer  
17 reviews on the schedule we're on. I think within the  
18 boundary conditions of what we've been talking about  
19 today with evolving methods that's another challenge.  
20 And Donnie I think correctly framed the way we're  
21 trying to deal with that by having these  
22 -- we can't put the onus of every method review on the  
23 peer review team in a one-week peer review, otherwise  
24 that does detract from the overall review.

25 I think we are doing a reasonable

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 technical job on these reviews. The owner's groups  
2 resources are limited. A number of these reviews are  
3 getting contracted out separately now because the  
4 owner's groups just -- for some of the reasons Donnie  
5 indicated with the horse trading reviewers and such,  
6 eventually you just run out of a spot in the queue and  
7 you have to do something else.

8 In a perfect world I would love to have  
9 more time to get these models developed and get this  
10 full value of peer review that I think we get out of  
11 say internal events where we have a very mature method  
12 and a large team of, you know, expertise.

13 Our peer review guidance does have  
14 qualifications. You know, the teams are good. You  
15 know, the peer reviews that take place, there are some  
16 very good individuals. They're very tough.

17 CHAIRMAN STETKAR: Okay.

18 MR. BRADLEY: I would welcome anyone to  
19 come observe one of these reviews. I think we're  
20 pretty tough on ourselves. And, you know, so --

21 CHAIRMAN STETKAR: That last point is what  
22 I was -- again, you know, I'm sympathetic to resource  
23 limits. I'm sympathetic to scheduling. I'm  
24 sympathetic to people who perhaps don't understand  
25 when they should call. But that again is a different

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issue. The point that you made that the peer reviews  
2 that are being performed, regardless of whatever  
3 constraints that are being performed, are indeed  
4 technically confident reviews and indeed are not  
5 simply, you know, pass throughs to check off a, you  
6 know, schedule requirement. That's in terms of our  
7 concern, I think.

8 MR. HARRISON: Yes, and I would state that  
9 the peer review that the staff observed was a  
10 contracted peer review and we were impressed by the  
11 team. They were industry experts. So it wasn't --  
12 well, I'll say it wasn't a no-name team.

13 CHAIRMAN STETKAR: Yes.

14 MR. HARRISON: It was well-recognized  
15 people on the team that were experts in Fire PRA --

16 CHAIRMAN STETKAR: Good.

17 MR. HARRISON: -- and their elements.

18 CHAIRMAN STETKAR: Good, good.

19 MR. HARRISON: Again, the industry in  
20 dealing with some of these methods, new methods that  
21 are being proposed developed a task force and I think  
22 that's an appropriate thing. I champion the idea of  
23 developing that Fire PRA methods task force to address  
24 new methods. And again, here's my reality check.  
25 When a peer review turns that over to a task force to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 address, you've just added another layer of review,  
2 and that takes time. So you've gone from a one-week  
3 peer review to now it's being pushed off to a task  
4 force who's now going to look at that method. It may  
5 take time for them to look at the method and then to  
6 provide feedback back to the licensee in the peer  
7 reviews. So it's just a timing element of that. And  
8 again, that's just a reality.

9 The other part is is the task force comes  
10 back and either modifies or rejects what the licensee  
11 has proposed as a method. Then that would require the  
12 licensee to change their PRA method. And again,  
13 potentially that may drive you to now another peer  
14 review of whatever new method you might be using. So  
15 just again, this is just how the process works, or  
16 should work. And in the ideal world everything that  
17 goes to the task force will be perfect and they'll  
18 come back and tell every licensee that these new  
19 methods they've come up with are wonderful and well-  
20 documented and justified. I don't think that's going  
21 to help and we don't live in an ideal world.

22 We could either take a break now, John, or  
23 we could wait another four slides. I'll give you the  
24 option.

25 CHAIRMAN STETKAR: We're going to take a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 break now because I am incapable of estimating the  
2 time to go through four slides. So we will recess  
3 until 3:25.

4 (Whereupon, at 3:09 p.m. off the record  
5 until 3:24 p.m.)

6 CHAIRMAN STETKAR: We're back in session.  
7 Donnie, carry on, sir.

8 MR. HARRISON: Okay. The last topic I  
9 wanted to talk about was the scope of 805 transition.  
10 The licensee does a Fire PRA but they've got an  
11 application in mind when they do it in this case.  
12 It's not like the Internal Events PRA where you build  
13 an Internal Events PRA and then you start looking for  
14 applications. Here you've got the application in mind  
15 and building a Fire PRA for that application.

16 And I just want to make some points. The  
17 staff doesn't mandate how you do your PRA. The  
18 licensee decides on the level of detail and realism  
19 that they want to have in their Fire PRA to support  
20 the application they need to make. We evaluate the  
21 adequacy of that model for that application, but  
22 ultimately it's the licensee that makes that decision.

23 The other thing; I think you heard a  
24 little bit of this earlier, is Fire PRAs are built off  
25 the Internal Events PRA and they use a progressive

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 screening approach typically. So what you do is you  
2 start at a screening level, a higher level and you  
3 slowly work in. What that allows you to do is focus  
4 in on those areas that have the highest risk. As you  
5 find things that are of low risk, you leave them and  
6 you move on. Those areas that get screened out under  
7 that process obviously are conservative because they  
8 may have been using screening methods. But again,  
9 like most things if I use a conservative approach and  
10 it gives me an answer I can live with, I don't mind  
11 letting it be conservative.

12 So the licensee then has options. He can  
13 retain that conservative screening approach if the  
14 results are acceptable, or he can make some decisions.

15 If he's got a high-risk area and he needs to deal  
16 with that and the screening method doesn't support  
17 leaving it as it is, he's got choices. He can  
18 implement a plant mod or he can refine models. He can  
19 try to do things to bring that risk down either  
20 analytically or in physical reality.

21 And there are some considerations that go  
22 along with that. How much time does he have? How  
23 much effort is it going to take? How hard is it going  
24 to be justify what he's doing? And how much is it  
25 going to cost? So those are four elements that every

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 licensee has to consider. What we've seen in the two  
2 pilots is plant modifications was an easier path, if I  
3 can say it that way, as opposed to trying to justify  
4 method modeling differences, modeling refinements and  
5 timing as well as cost of doing those analyses and how  
6 much effort it would take.

7 The good thing about plant modifications  
8 is that they can reduce risk in areas that are not  
9 just a fire risk. Matter of fact, the major benefit  
10 of some of the modifications proposed by the Harris  
11 pilot and the Oconee pilot, their biggest risk  
12 reductions are in the non-fire areas. I believe  
13 there's the alternate reactor coolant pump seal  
14 injection modification for Harris. There is the  
15 protected service water for Oconee. Both of those  
16 have large risk reductions for the plant associated  
17 with things that have nothing to do with fires.

18 The reality check on that is though most  
19 of them are being implemented after we issue our  
20 safety evaluation. So the issue for the staff is  
21 they've taken credit for a modification in their PRA  
22 supporting their application. How do we assure that  
23 that modification lives up to the credit they've given  
24 it? And so again that can drive you to an  
25 implementation item or a license condition as part of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 providing assurance after you install it and implement  
2 the modification, that it actually achieves what you  
3 said it could achieve. Especially if it's a case  
4 where you're going to be having to lay new cable and  
5 the concern becomes are you going to route in an area  
6 that you hadn't originally thought you were going to  
7 route it and now that's a fire-exposed cable and it  
8 maybe doesn't achieve the fire credit you thought it  
9 would. So that becomes a critical part of the  
10 decision making process for the staff in looking at  
11 some of these future mods that are credited in the  
12 application.

13 It can also result in limitations being  
14 placed on the ability to what I call self-approval to  
15 be able to implement the plant change evaluation and  
16 approve modifications during that transition or  
17 implementation period. If it's going to take you two  
18 years to get that modification installed, well your  
19 plant really doesn't have the credit that you've  
20 actually told us it had until that modification goes  
21 in. So for you to make plant change evaluations in  
22 the interim, you're doing it without actually knowing  
23 what the plant risk is at the time you're actually  
24 making the change. So that can result in us also  
25 limiting the ability of licensees to make self-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 approval changes, especially for the risk-informed  
2 pieces that you're taking those credits for.

3 Here I just want to talk about the fact  
4 that this is a large application. You're entirely  
5 rewriting your licensing basis for fire protection,  
6 both deterministically and now you're adding a risk-  
7 informed approach to it. You're adding self-approval.

8 You're adding a whole lot of things that weren't  
9 there. Some things you have to go back and reverify.

10 If you've had operator manual actions that you've had  
11 approved in the past, you have to verify that they're  
12 still feasible, you can still do them under the  
13 deterministic side.

14 You may also need to look at some of those  
15 operator manual actions and find out that they're  
16 recovery actions. And now you have to do a change in  
17 risk evaluation. You have to provide a delta risk  
18 calc associated with those recovery actions.

19 My last major bullet here is on the fact  
20 that what I call we're not getting clean transitions.

21 People come to do NFPA 805 for a reason. It's not  
22 because they're just wanting to transition from  
23 Appendix R and come over and there's no benefit to  
24 them. They just want to do the right thing. That's  
25 not what's happening. They want to do the right

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thing, but they want to do it and still get credit for  
2 some variance they may have to the deterministic  
3 requirements and they'd like to keep those variances  
4 and make them part of their licensing base.

5 So it's not simply just transitioning from  
6 the old program to the new program and nothing really  
7 changes. It's transitioning over and, oh, by the way,  
8 I want to make sure that variance that I currently  
9 have now is okay by the regulator and he'll accept  
10 that and not make me have to fix it. So the method  
11 lets you do that. It does muddy the water because now  
12 I'm doing transition and I'm doing plant change  
13 evaluations at the same time and I'm bring two  
14 different concepts in at the same time. So you can  
15 have numerous change in risk calculations you have to  
16 do when you find these variances from the  
17 deterministic requirements. You have to look at not  
18 just the individual variances, but then you have to  
19 look at the cumulative impact of all those variances.

20 And if you make Fire PRA simplifications, you can  
21 create conservative change in risk calculations.

22 An example I would give you for that is  
23 805 applications are not affected by being  
24 conservative in the base model creating non-  
25 conservative deltas. We actually have, if you will,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 maybe a potential for a conservative with a  
2 conservative, because the way the pilots are doing  
3 their delta risk calculations is assuming without the  
4 variance a room is perfect. It's zero risk. So  
5 they're taking the entire risk of the room or the  
6 affected area and they're saying that's my delta.  
7 That's what Harris I believe did. So if you calculate  
8 the variance delta, all of that is the delta for a  
9 room. It makes it a conservative delta, and again if  
10 you can live with that conservative delta, then that  
11 makes it easy for us to approve it.

12 CHAIRMAN STETKAR: Donnie, you've  
13 mentioned several different delta risk calculations,  
14 some that are associated with --

15 MR. HARRISON: There's risk of recovery  
16 actions.

17 CHAIRMAN STETKAR: -- recovery actions,  
18 some that are associated with retained deviations from  
19 deterministic criteria. How are all of these rolled  
20 together, or are they? And, you know, is it applied  
21 at a plant level? Is it applied at a compartment  
22 level? Is it applied at an issue level? You do  
23 eventually some type of comparison against 1174 I'm  
24 assuming.

25 MR. HARRISON: Correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: How is that done?

2 MR. HARRISON: Steve, do you want to give  
3 an answer?

4 MR. DINSMORE: Yes, this is Steve Dinsmore  
5 in the PRA Branch in NRR. I work with Donnie. I'm a  
6 senior reviewer.

7 Effectively the individual fires are  
8 disjointed initiating events, so you can kind of just  
9 add up the different deltas. Is that what you were  
10 asking? How do you get the cumulative or how do you  
11 do the individuals?

12 CHAIRMAN STETKAR: What I'm asking is, you  
13 know, I thought I heard Donnie saying things like,  
14 well, for this particular location my delta risk is X.  
15 Does that delta risk for this location mean anything,  
16 or is it simply the overall delta risk at a plant  
17 level compared to that -- what? Compared to a perfect  
18 plant?

19 MR. DINSMORE: Compared to a plant that  
20 does not have the failures associated with the  
21 variance from the deterministic requirement that they  
22 discovered.

23 MR. HARRISON: Yes, the delta's backwards  
24 in what we normally do. It's instead of having a base  
25 model and figuring out what the risk increase is,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you're figuring out where you are with the variance  
2 and --

3 CHAIRMAN STETKAR: The base model presumes  
4 the risk was zero?

5 MR. HARRISON: That's what they've been  
6 doing. Nothing says you have to do it that way.

7 CHAIRMAN STETKAR: Okay.

8 MR. HARRISON: You could build one that  
9 says here's my base model, if I met the regulations,  
10 so I don't have a cable that runs through there that  
11 I'm not supposed to have. I just remove that and I  
12 leave the rest of the model alone. Then I build it  
13 with the cable in there like it exists and I do the  
14 delta between those two. But then I'm building two  
15 models. Right? What's happening is is the plants  
16 -- again, they're coming into this not like the  
17 internal events era. They're coming into this Fire  
18 PRA with the application in mind. So they're building  
19 their 805 PRA. Right? They're not building a base  
20 perfect plant PRA. So they're coming in with the 805  
21 plant and then they're just saying, well, I'll just  
22 take the hit for that variance and that becomes my  
23 delta.

24 CHAIRMAN STETKAR: Right.

25 MR. DINSMORE: Steve Dinsmore again. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 believe Oconee subtracts the two.

2 CHAIRMAN STETKAR: Okay.

3 MR. HARRISON: I think Harris probably  
4 -- yes, but --

5 MR. HARRISON: I was referring to Harris,  
6 yes.

7 CHAIRMAN STETKAR: But the key is that the  
8 staff's examination of that delta risk is done at the  
9 plant level, is that correct?

10 MR. DINSMORE: At the fire area and the  
11 plant level.

12 MR. HARRISON: They have to show it's  
13 acceptable by the fire area and then they have to do a  
14 cumulative impact and show the plant total risk delta  
15 is acceptable. Again, you have to keep in your mind  
16 for transition you're allowed to offset fire risk  
17 increases with, if you choose, non-fire risk-related  
18 decreases. So if you add a modification, you can take  
19 credit for that to bring a risk down. Right? So you  
20 might have a room that is actually above our  
21 acceptance criteria but the total plant risk is  
22 actually below our risk criteria.

23 CHAIRMAN STETKAR: But that would be  
24 considered okay?

25 MR. HARRISON: Can be considered. It

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 depends. You could find a room that's so high above  
2 the acceptance guidelines that they have to fix  
3 something to bring it down. You could actually have a  
4 plant area that has to be fixed even though the total  
5 plant risk is acceptable. Because you have to do  
6 both. You have to find them both acceptable.

7 MR. DINSMORE: These things again are  
8 disjointed, so you can add them. So if you get a big  
9 minus in one room, and a small -- well, relatively  
10 large plus in another room, then you add them up to  
11 get your total. So that's how you can do them both at  
12 the same time, or that's how you could have -- one  
13 room is going to increase at 1.6 times 10 to the minus  
14 6, but your total delta, when you add up all the other  
15 rooms, is minus 5 times 10 to the minus 6 or  
16 something.

17 CHAIRMAN STETKAR: Okay.

18 MR. HARRISON: Again, the point of the  
19 slide is exactly what you're making though. It's not  
20 easy.

21 CHAIRMAN STETKAR: No, it's not.

22 MR. HARRISON: It's not a straightforward  
23 risk-informed application. There are things you're  
24 doing. You're looking at the world backwards because  
25 you're looking at it from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a --

2 CHAIRMAN STETKAR: Well --

3 MR. HARRISON: -- perfect and you're  
4 looking at --

5 CHAIRMAN STETKAR: But from what I've  
6 heard that's an individual licensee's decision.

7 MR. HARRISON: It is.

8 CHAIRMAN STETKAR: Because they could  
9 indeed calculate two risk numbers and subtract the  
10 two.

11 MR. HARRISON: That's correct.

12 CHAIRMAN STETKAR: You know, maybe it's  
13 not. So in terms of that conservatism, that's  
14 essentially a self-imposed accepted conservatism of  
15 how they calculate that delta.

16 MR. HARRISON: Correct.

17 CHAIRMAN STETKAR: All right.

18 MR. BARRETT: Harry Barrett. I just want  
19 to point out the NFPA 805 standard requires you to do  
20 the analysis on a fire area basis. And when you do  
21 the fire risk evaluation you have to evaluate the risk  
22 of that fire area. So you have to do it on a fire  
23 area basis and you then also have to sum them up.

24 MR. HARRISON: Right.

25 MR. BARRETT: You can't do both.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: Right. And within the 805  
2 there's a paragraph that says you have to do it fire  
3 area by fire area and compare the risk using CDF and  
4 LRV. And then the next paragraph talks about  
5 cumulative impact has to be evaluated and determined  
6 to be acceptable also. So both pieces are within 805.

7 Again, that's a little more complicated than most  
8 risk-informed applications that typically look at  
9 what's the delta associated with the total change, as  
10 long as they're related changes.

11 And with that, I want to come and just  
12 close with a path forward. I think the industry's  
13 task force is a needed thing. The staff plans to  
14 interact with the task force. We're still kind of  
15 working through that process. We're still going to be  
16 engaging on Fire PRA concerns and working with  
17 industry on those.

18 As Fire PRA methods, as the industry  
19 identifies conservatisms; and I appreciate the morning  
20 presentations, because some of those were the first  
21 times the staff is actually hearing specific examples  
22 of conservatisms, where they're actually being  
23 identified by the industry. We need to go further  
24 into that. We need to address those issues and work  
25 together to come to resolution. And I personally

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't have a vested interest in task force fact  
2 process. My interest is are we working towards a  
3 resolution? There's a fact process there that can be  
4 used. We did struggle a couple years ago with that  
5 process. We worked out some specific tweaks to the  
6 method to make it work for the Fire PRA stuff, so it's  
7 a valid approach. We've put out the Supplement 1 to  
8 the NUREG/CR 6850.

9 And, Ken, I'm never going to be able to  
10 figure out the EPRI numbering scheme, so it's 1,000 or  
11 whatever, 1 million-something.

12 We're going to continue to interact with  
13 the industry. I think a big thing, and I really  
14 didn't touch on it, is the need to develop and train  
15 more industry and staff in Fire PRA methods. There's  
16 an EPRI research Fire PRA course. They're adding  
17 modules to it it seems like every year or two to  
18 expand it. And for us to move forward that's a  
19 critical area that needs to be carried forward.

20 And again, as demonstrated by the two  
21 pilots, you can get through the process and you can  
22 come to an application and transition to 805. No  
23 licensee has gained the ideal solution of coming over  
24 and not having to make modifications or not having to  
25 deal with certain recovery actions and deal with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issues, but the process does work. And it's shown to  
2 be of benefit from a risk perspective at the two  
3 pilots due to modifications that make the plant  
4 physically safer. And again, we just need to work  
5 through the issues.

6 And with that, I'll see if you have  
7 anymore questions.

8 CHAIRMAN STETKAR: Any questions?

9 (No audible response.)

10 CHAIRMAN STETKAR: Thank you. Next?

11 MR. SALLEY: I'm Mark Salley. I'm going  
12 to talk to you guys a little bit about fire research.  
13 And any questions or anything as I go through it,  
14 please stop me and I'll be happy to tell you where  
15 we're at and what we're doing.

16 The goal here is to give you a high-level  
17 view of what we're doing. A couple underlying or  
18 underpinning items. We want to continue to improve  
19 the state of the art and to expand the knowledge base.

20 So continue to refine things, to improve our methods,  
21 to improve our data sets, and that's what we're  
22 looking for in research in the fire protection area.  
23 So again, that's the goal here is that, you know, we  
24 continue to advance the state of the art and the  
25 sciences.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Next slide? Just a talk a second about  
2 how do we do research? How do we get projects? I  
3 mean, what's our process for doing that? There's  
4 basically three methods that the Office of Research in  
5 total uses.

6           The first one is a formal office to  
7 officer user need request. For those of you who are  
8 not familiar with that, one of the offices, NRR, NMSS,  
9 will come to research at the office director level and  
10 say we would like you to do X. And the office  
11 director will agree to do that, and this is how our  
12 scheduling and our manpower and our budget come  
13 together. With the tasks, for example, one, we're  
14 working with NRR in the fire protection area is there  
15 are 32 unique separate tasks within that one letter.  
16 So it's one agreement that has a number of different  
17 tasks that we work on.

18           And with that, having so many tasks and  
19 diverse tasks, the offices will sit down at the  
20 working level now at mine and Alex' level and we'll  
21 discuss, okay, you know, NRR, here's your user need  
22 request. There are 32 unique items in there. What's  
23 your priority? I can't do them. You know, I've got  
24 roughly 8, 10 people. I can't do them all at once.  
25 And Alex and NRR and Donnie will sit down and say,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 okay, this is the most important thing we need right  
2 now, so we'll make this a high-priority. You know,  
3 these can wait a year or two for. Make these medium.

4 These are long-term. We'll make them low. So that's  
5 how we set our priorities.

6 It's not that I sit down and say, you  
7 know, I really want to explore sprinklers, so we're  
8 going to do sprinklers. It doesn't work that way at  
9 all. So it's definitely driven by that user need.  
10 And again, NRR is the big user with us. We do do some  
11 work with NMSS and very little with New Reactors at  
12 this point. But NRR is our big customer.

13 The other of course is at the agency. If  
14 the commission level wants us to do something,  
15 obviously we'll do that.

16 And the final term is, a little part of  
17 what we do is our long-term research where we tend to  
18 look at things and say, okay, this is something that's  
19 going to be coming down the road in the future. We  
20 want to get a leg up on it and we'll start doing some  
21 work. So that's how our priorities are defined for us  
22 in the Office of Research.

23 Start at the top with the methodology.  
24 Again this is a joint document. It was developed over  
25 a number of years. It was a partnership under our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Memorandum of Understanding with EPRI in fire  
2 research. At the time it was state of the art, which  
3 was 2005. Of course now it's been used a little bit  
4 and it's getting some use, and we're learning things  
5 with it as it's used, as you would expect.

6 There were a number of FAQs that  
7 questioned or had questions about the methodology. I  
8 believe there were 15 of them. Those have all been  
9 resolved and we've come to agreement on that, and  
10 we've published Supplement 1 to this. So you have to  
11 go to 6850 on the Web page and you can see there will  
12 be a supplement underneath it. You can download the  
13 questions and answers to that. So we're pretty  
14 current.

15 MEMBER SHACK: Now is Supplement 1 still a  
16 co-development?

17 MR. SALLEY: Yes.

18 MEMBER SHACK: Okay.

19 MR. SALLEY: Yes, we worked together on  
20 this. And I kind of skipped over my slide about  
21 partnerships in there, but the ability to work with  
22 industry under the MOU is really valuable. I'm a very  
23 big believer in that. It allows us a number of  
24 things. It allows me access to talent that they have  
25 that I don't. One who comes to mind is Dan Fong. In

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an electrical space Dan is excellent and just EPRI  
2 bringing him to the table and allowing us to talk with  
3 him and how we do our testing and that is hugely  
4 valuable. With the DESIREE test I'll talk a lot about  
5 the ability for them to get things for us and to help  
6 us. Really, it takes the quality of the product,  
7 which is what I'm worried about, and it really  
8 increases the quality. So it's a very good thing.

9 If you talk to my folks, obviously it's  
10 much easier to do it your way and not have to deal  
11 with anybody else. It's kind of like being single  
12 versus being married. But in the end it's the good  
13 thing to go with.

14 CHAIRMAN STETKAR: Mark, you mentioned  
15 earlier that the research programs are user need  
16 driven.

17 MR. SALLEY: Yes.

18 CHAIRMAN STETKAR: And that your primary  
19 customer is NRR.

20 MR. SALLEY: Yes.

21 CHAIRMAN STETKAR: How through this  
22 collaborative process with industry does industry's  
23 user needs -- how are they reflected in terms of your  
24 research priorities and budget? So for example, if  
25 industry identified a particular issue, which they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have in the past and still continue to do, is there a  
2 process that that achieves some sort of elevated  
3 recognition in your user needs requests that  
4 eventually get filtered down to your budgets and  
5 schedules in terms of organizing, you know, your  
6 limited resources, whether it's testing or, you know,  
7 going out for validation of computer codes, or  
8 whatever it is, you know, you do under your program?

9 MR. SALLEY: At the highest level the  
10 office director, Dr. Sheron, about annually he will  
11 have a meeting with the CEO-type of EPRI and they'll  
12 go through all the programs. And fire is just one  
13 addendum of many that are in there. And they'll  
14 generally hit the high points to make sure that, you  
15 know, these are the top three that we're working on,  
16 same top three, and can we work together on these? So  
17 they'll do that at a very high level.

18 For years Ken and I; and Rick is picking  
19 that up that Ken's been promoted, we'll discuss, try  
20 to look a little bit ahead of where the troops are  
21 working and say, okay, what are we thinking about next  
22 and, you know, what's high priority for you? What's  
23 high priority for us?

24 We don't do everything together. And I  
25 was, you know, listening to their presentation, and I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 wanted to make that clear, that there are certain  
2 testing programs that EPRI thinks are important and  
3 they're going their way about it, and an example being  
4 the heat release rate in cabinets. To be truthful,  
5 I'm going to talk about that in a little bit, I had a  
6 program to kick off. And we were starting to get it,  
7 but we were looking much more experimental. We were  
8 looking at, okay, we've looked at this test, this test  
9 and this test. Where are the holes at? You know,  
10 where do we need to go do some experiments and pick  
11 that out?

12 But when EPRI said, no, we've got a big  
13 program going on this, okay, I'll back that one off.  
14 You go and do your work and, you know, we will -- big  
15 program and the fact they're not doing experiments,  
16 but they're looking at --

17 CHAIRMAN STETKAR: Yes. Okay. You're  
18 going to get to cabinets, I'm sure.

19 MR. SALLEY: So, yes.

20 CHAIRMAN STETKAR: So we'll talk more  
21 about that --

22 MR. SALLEY: So, you know, that was one  
23 where --

24 CHAIRMAN STETKAR: -- when you get to  
25 cabinets.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SALLEY: -- EPRI is working --

2 CHAIRMAN STETKAR: But that's a good  
3 example in terms of what at least I think we heard  
4 this morning as an issue that seems to be a source of,  
5 you know, uncertainty or consternation about perhaps  
6 excessive conservatism where there were allegations  
7 that the available test information might not at all  
8 be relevant to a real world situation. But kind of  
9 when pressed, you know, the industry says, well, we're  
10 sort of looking to research to do that testing. And  
11 if you're saying, well, we're not going to do that  
12 type of testing, I'm not sure how this process really  
13 works.

14 MR. SALLEY: To be truthful, with that  
15 program we've looked at it. We have a user need line  
16 item on that. It's not a very high priority as some  
17 of the others --

18 CHAIRMAN STETKAR: Okay.

19 MR. SALLEY: -- within NRR. But we do  
20 have a lot of data, but there are holes in the data.  
21 And we were going to go and start, if you will,  
22 plugging the holes. But before we go and charge and  
23 do that, I want to give industry the benefit of the  
24 doubt and let's see what they come up with.

25 CHAIRMAN STETKAR: All right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SALLEY: And then we'll do it.  
2 Likewise, with our cable tray program, I'm going to  
3 talk to you about CHRISTIFIRE. You know, that's one  
4 that we're strictly going alone. That's something  
5 that -- it actually was a long-term need a few years  
6 ago that we saw from our PIRT that, you know, hey, we  
7 need better data here. Let's start thinking about  
8 this. As we discussed it with NRR they said, hey,  
9 that's a user need item. Let's get it in there. So  
10 that was a nice one that matured into a real program.  
11 And again, that's one we're going alone.

12 So I just wanted to make the point that  
13 industry and NRC do have independence. There are a  
14 lot of things we work on together when we can and  
15 there are things that they think are priority they  
16 work on and I have other priorities. So that's the  
17 point I wanted to make.

18 CHAIRMAN STETKAR: Thanks.

19 MR. SALLEY: Big question with 6850, and  
20 this is the one that I've been wrestling with for  
21 about a year now. We're going to talk a little bit  
22 about 6850 as how and when do we revise this? When do  
23 you say the state of the art has significantly  
24 advanced; it's now time to come out with revision?  
25 You know, does the state of the art change in six

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 months, six years, 60 years? When does that occur?  
2 How does that occur? You know, that's the hard one  
3 for me to put my finger on, and I'm working with that  
4 right now.

5 Just look at 6850 for a second. Look at  
6 the document. You know, you got 18 specific chapters  
7 in there which are all unique tasks. You got 23  
8 separate appendices which again tie back and support  
9 the chapters and the tasks. So you're covering a lot  
10 of things from human factors to circuit analysis to  
11 fire dynamics. You know, you've got a very broad  
12 brush of the Fire PRA that compromises 6850. When do  
13 you revise it? How do you revise it?

14 What I'm kicking around or what I've been  
15 proposing to industry now and we're in the discussion  
16 phases is that I'd like to go with a modular-type  
17 update where we can take a piece of it, a certain  
18 subject area that we've done tests, we've got better  
19 data, it's now time for -- it's matured further.  
20 Let's update it. But again, I need to work very  
21 closely with this because you have to remember this is  
22 a jointly-owned document. I can't just take 6850 and  
23 revise it. Ken and Rick, they just can't run and  
24 revise it. That's not success. We developed it  
25 together; we need to continue to work on it together

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with that collaboration. So that's kind of where  
2 we're at, and this in the discussion phases right now.

3 Next slide I'll give you just an example.

4 MEMBER ABDEL-KHALIK: Chapters are  
5 sufficiently stand alone with limited impact on other  
6 chapters that you can --

7 MR. SALLEY: That's part of the challenge.  
8 That's a part of the challenge. I don't think that  
9 the authors originally ever intended it to be a  
10 modular replacement. They wrote a document. They  
11 wrote a report. And you got to remember too, 805 it  
12 was used for, but it actually had a different meaning  
13 when it was started out. It was a fire re-  
14 quantification, which led to the SEP, which is how the  
15 inspectors do it. So it's a very interesting  
16 document.

17 CHAIRMAN STETKAR: An example, Said; and  
18 I'm a bit familiar with, and we heard a little bit  
19 about it this morning, the criteria that you use under  
20 the current data collection process for determining  
21 whether a fire is challenging, presuming that you know  
22 everything there is to know about that fire, so you  
23 have perfect knowledge, you then determine whether  
24 it's a challenging fire or not a challenging fire.  
25 That determination in principle effects parametric

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 values that you would use for detection and  
2 suppression. Because essentially you've already  
3 screened out some events as being non-challenging so  
4 that, for example, some parameters that you use for  
5 detection and suppression efficiency might change  
6 depending on how you do that data sorting. So those  
7 two essentially talk to one another in a sense, or,  
8 you know, in human reliability --

9 MEMBER ABDEL-KHALIK: I'm sure there are a  
10 lot of --

11 CHAIRMAN STETKAR: -- in terms of, you  
12 know, available time versus time required to perform a  
13 detection suppression capability.

14 MR. SALLEY: There is no easy answer.

15 CHAIRMAN STETKAR: It's not --

16 MEMBER ABDEL-KHALIK: There are a lot of  
17 cross links between the chapters.

18 MR. SALLEY: Yes, if you take a look on  
19 the next slide, supporting my modular theory or  
20 concept, there are two examples. When we look at  
21 chapter 9 it deals with the circuit failure analysis.

22 Okay? We've just completed the DC testing that I'm  
23 going to talk to you about. Tomorrow we kick off an  
24 electric circuit PIRT panel and we also then will  
25 follow that up with a PRA group that follows the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 electricals and say, okay, what's my probability? So  
2 the bottom line is we're going to refine and come up  
3 with some more information and a lot more data sets on  
4 how to do circuit analysis.

5 When we have that program completed; say a  
6 year from now that program should be complete, we've  
7 got that information, but you still have the old  
8 information in 6850. Do I take that and say, okay,  
9 we're going to start revising 6850 and we'll use this  
10 information in five years when 6850 is revised, or can  
11 I say reality 2012 I can have this on the street and  
12 6850, the people can start using it?

13 The same is true of the Appendix R. No  
14 pun intended, but Appendix R of 6850 is cable fires.  
15 I heard from industry meetings that, you know, folks  
16 we were doing some fire modeling with the cable trays  
17 early on said this is way too conservative. And I  
18 looked just a little bit at what was going on and the  
19 fires were big. And we said, you know, why is the  
20 fire so big? How is this happening? When we looked  
21 at the methods that were developed in 6850, they  
22 didn't account for the fuel being consumed. So the  
23 fires tend to go on infinitum.

24 As we now look at the CHRISTIFIRE Program,  
25 we can characterize, okay, here's show the fire burns.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Here's how it, you know, consumes the fuel. Here's  
2 how it reaches a steady state. Well, we can now get  
3 to that steady state. They're always on an incline,  
4 so in that one, yes, they're conservative.

5 So how can I best get that information  
6 into the PRA practitioners' hands is the question that  
7 Rick and I are discussing right now with the NRC and  
8 with industry.

9 CHAIRMAN STETKAR: During this process,  
10 you know, we hear a lot of concerns about excessive  
11 conservatism, and you just brought up an example where  
12 the most recent testing may confirm some sources of  
13 conservatism in the current models. To simply say  
14 that something is conservative doesn't leave me  
15 feeling very well because, you know, there are a lot  
16 of sources of conservatism.

17 The question is is the conservatism enough  
18 that it makes a pragmatic difference in either the  
19 level of effort that's required to do the PRA; which  
20 is a resource issue, I'll admit, or the overall  
21 technical conclusions from those analyses, which is,  
22 you know, more along the lines of what we're concerned  
23 with here? Do you think about that?

24 MR. SALLEY: All the time.

25 CHAIRMAN STETKAR: Okay. Glad to hear you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think about it. How is that determination factored  
2 back into, for example, this idea of, well, do we  
3 update the guidance today or do we wait, you know, for  
4 a different process, update it five years from now?  
5 Nice to know information, but not necessarily critical  
6 for me to do my job today. That's the degree of, gee,  
7 we've learned something that's really important, that  
8 what we're doing today is either really conservative  
9 and that conservatism really makes a difference. Or  
10 conversely, what we're doing today is really  
11 optimistic and that optimism makes a difference, which  
12 we've learned also in the past. That obviously needs  
13 to be reflected to the users as soon as possible  
14 compared to something that, well, maybe we're, you  
15 know, 15 percent conservative.

16 MR. SALLEY: I really see things as  
17 refinement. What I'm saying is I really don't see any  
18 eureka's coming out of here.

19 CHAIRMAN STETKAR: Okay.

20 MR. SALLEY: Case in point -- and I was  
21 thinking about some of the --

22 CHAIRMAN STETKAR: That's important  
23 information, by the way.

24 MR. SALLEY: I don't see the eureka's. I  
25 mean, let's go back to 1997, okay, when the whole

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 circuit thing and the multiple spurious was all just  
2 like a -- it was like a storm and it was brewing. And  
3 we had RIC presentations. And we sat in the ACRS room  
4 back there in '98; I was in NRR, and you know, pounded  
5 on tables and circuits don't fail. You can't have  
6 multiple spurious, you know? They don't fail this  
7 way. They short to ground. You don't see all this.  
8 And we had all those heated debates until the tests  
9 were run and then all of a sudden there was like a  
10 eureka moment here. No, this really does happen and,  
11 no, we can see percentage of this and we can  
12 understand thermoset and thermoplastic, and cables  
13 feel differently. And since then we've been refining  
14 that. And so we've been on a continuous refining  
15 method from a this can never happen to no, it does  
16 happen and now we need to understand what and why and  
17 how it happens. So we've been continually refining  
18 it. DESIREE is our latest one that goes from an AC to  
19 an DC and we continue to refine it. So I see us  
20 really on the refining role.

21 The second part with this conservatism,  
22 the sword cuts both ways. I would love in a perfect  
23 world that everything I had in research and everything  
24 that was done in 6850 was guaranteed 100 percent  
25 conservative and I spend the rest of my career with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 research in my branch. And we just pick a topic at a  
2 time and we whittle it out. And we just keep  
3 whittling out, you know, here's a percent here and  
4 here's a percent there, and we're going to get all  
5 this conservatism out of here and get it down to  
6 reality, whatever reality is. That's not going to  
7 happen.

8 And I think we can see that, too -- case  
9 in point, I'm going to talk a little bit about high-  
10 energy arcing faults, is when the team put 6850  
11 together, they used the best information they had  
12 available at the time. If you remember San Onofre had  
13 the nice high-energy arcing faults. And, wow, lot of  
14 good data, lot of good photographs. And if you look  
15 at the appendix in 6850, it's pretty much San Onofre.

16 Now, say there's an engineer looks at it  
17 and says if it's 480-volt or 4,160, does it make a  
18 difference? Well, intuitively I want to say yes, but  
19 then we've now said all high-energy arcing faults are  
20 San Onofre. This past year, right, Robinson. Whole  
21 different event here. Wait a minute. Wait a minute.

22 This happened in a conduit? No, no, no, no. This  
23 happens in switchgear. Well, no it happened in  
24 conduit. And it talked about zones influences. Well,  
25 they're too conservative. Well, what the regions are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 telling me is, hey, we're taking your method. We're  
2 applying it to Robinson. You're not conservative. As  
3 a matter of fact, it goes out further. Okay?

4 So the conservatism, that sword is two-  
5 edged. I mean, anytime we open anything up and look  
6 at it, we'll say yes it's conservative. We're going  
7 to go in there and grab that conservatism and rip it  
8 out of there. Not always. So, I mean, that's why we  
9 continue to research. But I really see it as  
10 refinement. Like I said, I don't see this eureka  
11 moment that's going to come down. And I'll show you  
12 some of the DC stuff, and it's pretty exciting, but  
13 it's not eureka.

14 CHAIRMAN STETKAR: We're going to run  
15 short on time here, and I want to keep you moving, but  
16 in many cases listening to what you say is I tend to  
17 translate it back into something that people aren't  
18 doing in the fire analyses and that's quantifying the  
19 uncertainties. In other words, if the information  
20 that we have today has a certain amount of uncertainty  
21 in it, indeed I can put some sort of distribution to  
22 that, calculate, you know, some mean value or  
23 something like that. Refinements later on  
24 theoretically should reduce the uncertainty, one would  
25 hope that. From what I hear you saying is that as we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 become more refined our uncertainties might be  
2 growing, which to me says maybe we're not really  
3 thinking about those uncertainties either from the  
4 parametric specification, you know, the data in point,  
5 or from the users of that information to say, well,  
6 this is our estimate of the risk today, but we're not  
7 certain within a factor of; pick a number, 200.

8 In any of the stuff that you've done have  
9 you characterized the uncertainties, the variability  
10 from what you see?

11 MR. SALLEY: Uncertainty is always going  
12 to be the bogeyman under the bed. I mean, I'm firmly  
13 convinced of that and there's never going to be  
14 anything that's going to be that guaranteed certain.  
15 The closest one that I watch is probably a simpler  
16 one, and that's the fire model team as they deal with  
17 the parameters inside the fire models. And I'm  
18 watching them wrestle with uncertainty, and boy, that  
19 is a job. I mean, to really -- when you look at the  
20 fire models and the different parameters as what's  
21 going in, you know? Do I use the right K-RO-C? Was  
22 that the correct density? You know, at what point do  
23 you get to -- what's the classic -- if a butterfly  
24 flaps its wings in Brazil does it cause a tornado in  
25 Texas? You know, where is the butterfly effect, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 uncertainty and how does that migrate through? You  
2 know, that is the challenge and I think it's always  
3 going to be there.

4 You know, in fire modeling, from my own  
5 experience, if I'm not sure of the K-RO-C, I'll pick  
6 the high, I'll pick the low, I'll run the model and  
7 I'll roll it into the world of sensitivity. And so,  
8 okay, from a sensitivity standpoint, eh, little bit,  
9 or you know, high or low. But that uncertainty is  
10 always going to be the challenge. You know,  
11 Commissioner Apostolakis just did a paper or gave a  
12 talk at the NEI Fire Forum as a matter of fact on the  
13 uncertainty of uncertainties and --

14 PARTICIPANT: Unknown of unknowns.

15 MR. SALLEY: -- unknown of unknowns.  
16 Thank you. That's why he's here. Keep me honest.

17 But the unknown of unknowns. And that's  
18 always going to be a part of it.

19 CHAIRMAN STETKAR: Okay. Thanks. I know  
20 you want to get through some of the --

21 MR. SALLEY: Yes, and I will try to move  
22 quick and like I said, I want to give you a high-level  
23 view. But please the main thing is to answer your  
24 questions, so stop me whenever.

25 HRA, another one. And you want to talk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about uncertainty? I mean, that's a hard subject. We  
2 have a joint team going with NRC and EPRI. They have  
3 completed a NUREG. NUREG's out for public comment. I  
4 think it's pretty well-received. Got a lot of  
5 comment. And I'll say the same thing: Any time we  
6 put a NUREG out, whether the people praise it or hate  
7 it, either way is good as long as they're reading it  
8 and giving us comments. The problem is when you put a  
9 NUREG out and you get zero comments. Then you know  
10 you've missed the mark. So this one had a lot of  
11 comments and I'll take that as a compliment of the  
12 team. And they're working them through. So we look  
13 at the spring of next year of hopefully getting that  
14 issued final. You'll see that we've included it in  
15 some of the training.

16 But with the HRA, there's the SRM project.

17 And fire is a part of that project, so we need to  
18 work in with the larger community. And I know Susan  
19 Cooper is working very close with her colleagues up in  
20 research and we'll see that happen.

21 CHAIRMAN STETKAR: Yes, and we have a  
22 subcommittee that's been following that pretty  
23 closely. We just recently had a meeting on it. That  
24 again, that issue will not be solved universally in  
25 the immediate future.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SALLEY: No. Fire had a real need  
2 though, and I really credit Susan and her team and the  
3 EPRI effort because they're the 805, and HRA is a very  
4 important factor. So I think they may have got a  
5 little ahead of the wave and tried to give us some  
6 tools to use, and that's where that's at.

7 Next slide? Fire modeling. We're  
8 starting to pick up some momentum here. You know,  
9 we've got the internal document we use for our  
10 inspectors, 1805, to get them into the fire dynamics.  
11 We've got some time for a refresh, if you will.  
12 There has been new models developed. The THIEF model  
13 that came out of CAROLFIRE to predict cable damage,  
14 which is one of the keys things, so that's being  
15 incorporated. And you'll be seeing that coming out  
16 here. Dave Stroop has got that going to publishing  
17 here hopefully before the end of the year. So we're  
18 continuing to keep that alive and move that forward.

19 CHAIRMAN STETKAR: Here again, is there a  
20 substantial difference -- you have to remind what  
21 THIEF does, Mark, because I can't remember, but it's  
22 the conditional probability of cable damage given a  
23 fire? Is that it's primary --

24 MR. SALLEY: Yes.

25 CHAIRMAN STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SALLEY: That's the best example,  
2 John, to use in this, if you want to see state of the  
3 art and progression over time. When we went to the  
4 SDP back around 2000 and started working with the  
5 inspectors on it, when they would do a calculation, a  
6 simple hand calculation, if they knew that a cable  
7 failed at say 700 degrees Fahrenheit and the cable was  
8 in the hot gas layer, they did a hand calc and they  
9 got 700 degrees, as soon as they got 700 degrees, they  
10 said I got 700. Immediate cable failure. I've got  
11 the circuit doing a hot short, whatever. THIEF came  
12 along and says wait a minute, you know, cables have  
13 mass. We looked at this, said yes, they don't  
14 instantly fail as soon as they see 700 degrees  
15 Fahrenheit. It isn't like an off/on switch. There's  
16 thermal inertia they've got to overcome. The cable's  
17 got to fail. And we did some of that work. THIEF was  
18 the one that came along and did a 1D heat transfer.  
19 So now we can take it from an instant failure to,  
20 okay, what is the heat flux over the period of time on  
21 that cable to get to the failure?

22 CHAIRMAN STETKAR: As a practical  
23 standpoint, do you see substantial increases in time  
24 to cable failure? Because that's the whole key of,  
25 you know, when I start doing my detection suppression

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis.

2 MR. SALLEY: From going to the temperature  
3 turns 700 degrees? Until that? Yes, there's going to  
4 be -- it's a good refinement. That takes a good chunk  
5 of conservatism out.

6 CHAIRMAN STETKAR: Okay. But are we  
7 talking about, you know, the difference between zero  
8 time and two minutes, or are we talking about zero  
9 time and an hour?

10 MR. SALLEY: Depends on the fire. No, I  
11 mean, look at Appendix R space. Appendix R told you  
12 that, okay, when you go -- you have the fire started  
13 at T0 in the compartment. At T0-plus all cables are  
14 damaged. That was like, wow. You know, that's  
15 conservative.

16 CHAIRMAN STETKAR: Yes.

17 MR. SALLEY: And then we said no, we got  
18 to wait now with the SDP and, you know, when do you  
19 get the realistic fire that actually give the  
20 temperature that does that? So, you know, some of  
21 that conservatism was taken away from Appendix R.  
22 THIEF again takes it to the next level. And THIEF is  
23 modeled much like the RTI on how does a sprinkler head  
24 -- I mean, that's where we stole the idea. You know,  
25 how does a sprinkler head operate? That sprinkler

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 head is 160 degrees Fahrenheit. As soon as it sees  
2 165, does it immediately do this? No, it takes a  
3 little time to heat up. You got to heat the element.

4 That's why the elements have gone from being so fat  
5 to being so skinny, because now they heat up. They're  
6 quicker. And NIST did that back in the early '80s.  
7 We basically stole that and move that over to cables.

8 We didn't invent anything. That's again just  
9 refinement. You know, we continue to refine things.

10 So 1805 should be coming out this fall  
11 with fire modeling. Again we've done a lot of work  
12 here. Again, a project that I would hesitate to say  
13 that industry would have had a hell of a time doing it  
14 by themselves or we would have had again a hell of a  
15 time doing it by ourselves was doing a V&V. V&Vs are  
16 intense. I mean, that's seven volumes of work. And  
17 this is a good one where we collaborated. We picked  
18 the five most useful models to the NRC and the  
19 industry and we've got a V&V.

20 You know, my goal is to -- now that we  
21 have it and we've used it a little bit, we've learned  
22 a little bit more about it, I want to go back and do  
23 it again. And we've got some more fire tests. And  
24 again, here comes the uncertainty. You know, we can  
25 tighten some things up. We found some additional

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tests and NIST did none. So we can go back in, and  
2 again it's that fine tuning piece that I see us doing.

3 We ran a PIRT. And again, the PIRT, one  
4 of the big items that came out of the PIRT was the  
5 cables, that, you know, you really don't understand a  
6 lot of things. You really need to focus in. And the  
7 cable burning was the one that clearly came to the  
8 top, which was why we started that work from the PIRT.

9 The last piece there, NUREG 1934. Again a  
10 joint document between industry, EPRI and NRC  
11 research, is the application guide. You know, fire  
12 model is nothing new. NIST has been doing this for 30  
13 years. And, you know, it's interesting talking with  
14 some of the stuff they do. The forest fires in  
15 California, they're over there modeling that. When  
16 the *Valdez* had the spill in Alaska, one of the things  
17 was is it better to burn the oil off on the water or  
18 try to, you know, contain it? And they did fire  
19 modeling work in that. World Trade Center, they did a  
20 lot of experiments and fire modeling on that. So it's  
21 used pretty much everywhere.

22 Now the nuclear community. Nuclear plants  
23 are very different than any other building, we all  
24 know that. Design's different. What we worry about.  
25 You know, life safety for us to protect the reactor.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 For the rest of the world it's get everybody out of  
2 the building. So there are unique things about what  
3 we do and what our targets are. Our targets aren't  
4 people. Our targets tend to be cables. Our  
5 constructions tend to be different than a room like  
6 this with a nice flat ceiling versus the congestion we  
7 see in a power plant.

8 So we need an applications guide to get  
9 people to be doing quality models. So that's the  
10 piece we're working on right now. And again, you can  
11 take that to some uncertainty.

12 When you try to run V&V, what we did the  
13 V&V, we asked the question how good are the models?  
14 What does the model do with good input? Now the  
15 question is with the applications guide is how good is  
16 the modeler, because he's the one that -- you know,  
17 garbage-in-garbage-out-kind of thing. So we broke  
18 that problem into two pieces and now we're working on  
19 the second piece.

20 And it was refreshing; well, it didn't  
21 make my day, but we put that out in January for review  
22 and we had a lot of comments. Problem was they were  
23 all very good comments. And I had originally been way  
24 over zealous and I wanted this document to be the end-  
25 all, be-all for fire modeling. You can't do that. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the team basically had to reel me in a lot and  
2 calibrate me and say people know, they have to know  
3 how to run a model. We're not going to teach them how  
4 to run a model. They need to know the basics. Now,  
5 we need to take them into the nuclear environment, and  
6 that's where that document's going to go.

7 So we look for that to be hopefully here  
8 near the end of the year. That's going to come out  
9 again and we want to run it for public comment again  
10 because we had so many last time. So just to be fair  
11 to everyone, we're going to put it out again for 30  
12 days. So that's where fire modeling is at.

13 Next slide? Okay. Now into the good  
14 stuff. CHRISTIFIRE. This is an experimental program  
15 that we're running right now. It's just starting up.

16 You know, an odd thing, since Browns Ferry  
17 '75 we've been burning cables. If you go back and  
18 look at some of the earliest stuff we've done, we were  
19 burning cables. And one of the things that happened  
20 here, which again is so important having a partner  
21 like NIST, is the measurement system. How do you  
22 measure fire? And there was a lot of stuff that came  
23 out in the '80s after we had burned all those cables  
24 that said now this is how you measure. You know, you  
25 can do this. You know, oxygen consumption and c-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 telemtry working off the load cells. This is how you  
2 can come up with heat release rates and terms that had  
3 kind of come up after we had done our burning.

4 So it's now important for us to use our fire  
5 models. One of the key drivers, probably the most  
6 important thing you're going to load in that fire  
7 model is that heat release rate. How big is the fire?

8 And this is what we want to get off the cable tray.  
9 So this is something we're studying now with these  
10 cable tray fires. Again, ignition. Ignition is hard.

11 On solid combustibles ignition can be very complex.  
12 It's not as easy as a flammable liquid where you can,  
13 you know, do a Cleveland cup-type test and say, okay,  
14 at this temperature gasoline ignites at minus 34 and  
15 we can get that data. Solids tend to be a little more  
16 complex. But we're looking at the ignition. And the  
17 key here is the flame spread, too. How fast does the  
18 flame travel down the cables?

19 We look for there to be multiple phases in  
20 this project. We just wanted to get the first one in  
21 to see if we could do what we wanted to do. We look  
22 for this to really advance Appendix R, Section 6850  
23 when we have it completed. The document is out right  
24 now for public comment, so you may have seen this.  
25 We've put it out for public comment in fact because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we're inventing actually new models in here. FLASH-  
2 CAT is a new model and it's a model that's designed to  
3 predict how a flame will travel down a cable tray.

4 Next slide? Again, this first phase is  
5 just to get the basics, to get our understandings.  
6 There's a lot of complexity that gets into the cable  
7 routing in a plant. You know, how the cables are  
8 orientated. We focused on flat horizontals here. You  
9 know, whether they're 45 or vertical that's going to  
10 make a difference. We all understand that.

11 A big one, fire-retardant coatings. What  
12 are they going to do to this? And this is one that,  
13 you know, you look at this industry; and I've been  
14 around a little bit now, you go to things like fire-  
15 retardant coatings and say what is the standard for  
16 fire-retardant coatings? Well, you kind of fail open  
17 because they're kind of -- we can't find one. It's  
18 not like I can take UL XXX And this is how you do a  
19 test for a fire-retardant coating and we grade them A,  
20 B, C and D, or 1, 2 and 3, but we don't. So what you  
21 see post-Browns Ferry in '75 was people took stuff  
22 that basically had come out of the coal mine industry,  
23 was where the cable coatings were used. And they put  
24 everything on from grade A to grade Z, and it makes  
25 the problem a lot more complex. So we need to start

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looking and seeing just how complex.

2 Cable tray covers. Lot of people use  
3 those for Reg Guide 175 compliance. We were just up  
4 at Susquehanna a little bit ago and I noticed that,  
5 man, they got cable tray covers everywhere. I think  
6 that's going to make a very significant thing as to  
7 the how the flame spreads with those covers on there,  
8 as well as the heat release rate.

9 And then we can get into the finer fire  
10 dynamics things now, like if you look at a cable  
11 tunnel, for example, in a BWR where you're going down  
12 to an intake pumping station. You get a nice cable,  
13 which is almost like a mine shaft, and you start  
14 getting a nice ventilation flow through there. Then  
15 you can say, wow, this is really going to impact it.  
16 So one of the finer things in the later stages we'll  
17 look at is the wind-aided flame spread in the fire  
18 dynamics.

19 Next slide? We did three different levels  
20 of testing from a small scale that we would do in a  
21 standard cone-type apparatus to what NIST invented  
22 here, if you will, is an intermediate scale where  
23 we're using radiant panels to heat up the cables, to  
24 our favorite of all fire tests, which is the full-  
25 scaled. We did 75 small scale on the cables, 32 like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this of the intermediate scale and 26 of the full  
2 scale. And again, the variables are very interesting,  
3 and you'll see that in the report. It's not as simple  
4 as the most massive cable gives you the biggest fire,  
5 because it didn't work that way.

6 Now, if you can think about something  
7 simple. Gabe here was an Eagle Scout, so we'll get  
8 into the Boy Scout stuff. If you take a two-by-four,  
9 you know, if I build a fire in the woods, if I cut it  
10 up into small pieces, twigs, I can start it very nice  
11 and easy and I can get a fire. But if I try to take  
12 the solid mass of that two-by-four and ignite it, it's  
13 very difficult.

14 The same is true of your cable trays. If  
15 we have a cable tray that's extremely loaded and  
16 packed solid such that it's a solid block of polymers  
17 versus one where the cables are kind of spaced out and  
18 we now get air, so air can entrain through it, you  
19 know, we tend to get some different burning rates.

20 Just to give you a flavor here, here's one  
21 of the 26 full-scale tests in super high speed. So  
22 this is typically what we were doing in NIST.

23 It's kind of worth seeing here what these tests look  
24 like, and it will give you a feel for again where this  
25 conservatism comes on.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Well, our videos, I'm sorry, are not going  
2 to work.

3 CHAIRMAN STETKAR: All right.

4 MR. SALLEY: But we can give these to you.  
5 But we have 26 full-scale. And again, you can see  
6 the -- we'll have to go with the still pictures.

7 CHAIRMAN STETKAR: On CHRISTIFIRE; I  
8 haven't had a chance to read the report yet, Mark, did  
9 you load these trays up to like 40 percent full or so?

10 MR. SALLEY: That's what we were trying.

11 CHAIRMAN STETKAR: Okay.

12 MR. SALLEY: And again, when you start a  
13 project like this, where do you begin?

14 CHAIRMAN STETKAR: No, that's -- I was  
15 just curious what sort of --

16 MR. SALLEY: Yes, and that's kind of what  
17 we were seeing. I mean, what we're looking at too is  
18 at the fundamental level; and that's the key here is  
19 the fundamental level. I like the world when it's  
20 thermoset and thermoplastic because it gives me kind  
21 of nice end zones to work with, and we're going to  
22 talk about a cable called kerite here that doesn't  
23 want to play in either one.

24 But what we did was we did a series of  
25 tests where we did thermoset and then thermoplastic,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and then said, okay, what kind of different results  
2 are we getting? It's very clear as to how we get the  
3 different combustions.

4 DESIREE. These are the videos I'm sorry  
5 you're going to miss, because they're quite exciting.

6 But this is the DC testing program, and this is just  
7 a still out of there.

8 Next slide? Again, refinement. When  
9 industry started their testing program, what we were  
10 looking at was the AC circuits. We followed up when  
11 the industry program completed. There were a number  
12 of unanswered questions which led to RISK 2004-03 that  
13 basically said there was a number of unanswered  
14 questions. Research responded to that by doing the  
15 CAROLFIRE Program to answer those questions. And  
16 again, we were looking at AC source for power.

17 2006, Harry, when he was still at Duke,  
18 they had done some DC testing. And they had some  
19 things that didn't fall within how the AC worked, and  
20 it was some different looking things happened. So  
21 that was laying on the table. We picked it up with  
22 DESIREE, which is the DC testing.

23 Next slide? And the approach was very  
24 similar to CAROLFIRE. This program we started off on  
25 our own. And talking with Ken there was an interest

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from industry to contribute with this, to be a part of  
2 it. And we said sure, we can work something out. We  
3 had modified the MOU. And it was a very good move for  
4 I think NRC and industry, because it opened a lot of  
5 doors to things, and I'll show you some of that here.

6 Again, the key here is to better understand how the  
7 DC circuits respond to fire damage. That's the whole  
8 role of this.

9 Next slide? We followed the CAROLFIRE  
10 format where we used the penlight apparatus, which is  
11 this device. Never work when you want them to. I'm  
12 having all kind of technical difficulties. It is a  
13 cylinder device, which is the old sketch device from  
14 the EQ days. We have a nice controlled radiant heat  
15 flux that we can load down onto the cable so it's a  
16 very controlled environment and we can understand the  
17 cable response.

18 And then we go to the good old  
19 intermediate scale, which is actually an ASTM standard  
20 room-size burn. We built the top of it and we can put  
21 the cable trays either in the plume region or in the  
22 hot gas layer to see how they respond.

23 We did 59 small scale tests and 16 of the  
24 intermediate scale tests as DESIREE.

25 Next slide? This is really valuable and I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 got to take my hat off to Ken Canavan, because he  
2 really put the time helping us here and doing this.  
3 When we started this out, this program -- and it's I  
4 guess what, about \$800,000 in testing on this one?

5 Gabe's the project manager for this.

6 You know, one of the things is going to be  
7 buying the batteries for DC. So basically we'd clear  
8 out every Wal-mart within a 50-mile radius of  
9 Albuquerque, New Mexico to assemble a battery bank,  
10 which we were in the process of getting ready to do.  
11 But talking with Ken and some of the experts in  
12 industry, they said you really want to use station  
13 batteries and you really need to find a set. And it  
14 was lucky here that Ken located a -- North Anna's  
15 Technical Support Center was getting ready to a  
16 battery change on the old batteries. They had gone  
17 through their life cycle and were timed to be changed  
18 out. So it was wonderful that he was able to pick  
19 those up. Now, shipping those wet from North Anna to  
20 Albuquerque, New Mexico, Ken can write a little book  
21 on that, because if anything could go wrong, it did go  
22 wrong.

23 But nevertheless, we got them there and we  
24 tested with realistic batteries. And so this gives us  
25 a test now that we have real power source, you know,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not a bunch of DieHards strung together. But that's  
2 what the test configure looked like. It's basically a  
3 shipping container and we built a battery rack inside,  
4 much like you'd find.

5 Next slide? Again, looked at the common  
6 things to be looking for in a plant. DC motor  
7 starters, small solenoid-operated valves, a control  
8 for a circuit breaker, another solenoid valve and then  
9 a large coil to try to represent a PORV. Again  
10 working with industry saying, okay, what do you got in  
11 DC space that you're worried about from a risk  
12 significance? Again, it aided us here.

13 Next slide? It's also too for me to  
14 recognize that we worked very close with NRR on that  
15 to answer their questions. This is where the user  
16 need piece comes in. Harry Barrett was extremely  
17 instrumental working with us to make sure that we had  
18 realistic testing.

19 We preformed the testing. It's  
20 interesting, the DC circuits in the plants tend to be  
21 ungrounded, so you don't have that nice ground plane  
22 that you have in the AC circuits. That's going to  
23 come into play here.

24 And then we also -- because we were set  
25 up, we could do some additional testing. And the key

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one here is the kerite. Again, the biggest champion  
2 for this is Harry Barrett, who I have to take my hat  
3 off to him, to get us -- re-prioritized a bunch of  
4 work to get that kerite testing in here. The kerite  
5 testing is being performed right now as we speak.

6 Next slide? It's not a eureka moment, but  
7 it's a little bit of an eye-opener here, is a  
8 difference between the AC failure and the DC failure.

9 One key difference. After all the AC testing that  
10 industry had done and we had done, we never really saw  
11 an open circuit. Okay? We'd see the cables get  
12 damaged. The jacket's clearly gone. the insulation's  
13 burned. If it's thermoplastic, it's dripped down to  
14 the bottom of the tray. If it's thermoset, it tends  
15 to be there and charred, but it's there. The copper's  
16 almost always -- every test the copper always survived  
17 the fire.

18 And here with the energetic fault, we  
19 actually saw open circuits. So if you can think of  
20 somebody arc welding in the cable tray, that's kind of  
21 what it looked like if the video would have worked.  
22 And we literally saw a lot of the copper get blown  
23 away and you can see the copper slag. This is the  
24 bottom of the penlight facility. So that was a  
25 difference, a big difference between the AC and DC.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   Next slide? Here's the video that won't  
2 run. I apologize. My bad for not bringing a separate  
3 copy.

4                   Failure is much more energetic in DC than  
5 AC. So if you had to ask me today would AC bound DC,  
6 the answer I'd probably give you is I don't think so.

7                   DC is probably going to be more of a bounding case  
8 than the AC consideration.

9                   The arcing tended to act like a pilot.  
10 Remember I was saying about the combustion phenomena  
11 that we're studying in this. You know, for the solids  
12 to be there they have to get volatile. They start  
13 giving off their gas, getting volatile. You mix with  
14 the oxygen. You now need some form of heat, some  
15 spark, if you will, to ignite that and to give you  
16 combustion. The shoring of the cables, something  
17 Steve Nolan saw 20 years ago in Sandia tests, we tend  
18 to show that again. Yes, those arcs tend to be the  
19 ignition, the sparkplug, if you will, to get the  
20 cables to burn.

21                   Fuse sizing was important and it often  
22 dictated with the arcing and the hot shorts.

23                   Next slide? Obviously, and this is kind  
24 of an obvious one, that the larger fuses take longer  
25 to clear than the smaller fuses. You know, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 breakers kind of had us spoiled in the AC testing,  
2 because the breakers tend to be quick. You know, they  
3 tend to pick faults up very quick and to clear the  
4 circuit. We didn't see that with the fuses. As a  
5 matter of fact, in some of the larger fuses we didn't  
6 see the fuses clear. We saw the cable actually become  
7 an open circuit before that fuse cleared. So that was  
8 kind of --

9 CHAIRMAN STETKAR: Is that right? You  
10 actually --

11 MR. SALLEY: Yes. Next slide? Un-  
12 grounding. You know, you could theoretically say that  
13 the cable tray itself could form now a nice path for  
14 one circuit to short to the cable tray, the other one  
15 short to it and now the plus, for example, would come  
16 across, and lo and behold, we saw that. So you do see  
17 the raceway actually become a path to conduct the  
18 electricity in the end-grounded system. So the end-  
19 grounded system does bring some unique things in.

20 Next slide. The key here is I've kind of  
21 given you my off-the-cuff look at, you know, what we  
22 saw or what I saw the actual guys doing the work do.  
23 That's kind of meaningless. It's just nice. The key  
24 here now is the real work is beginning. Tomorrow  
25 actually the first panel comes in. We have Brookhaven

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 National Labs coming in. They're going to run a PIRT.

2 Actually it's going to be a PIRT and an expert  
3 elicitation. Here again we've tried to work very  
4 close within industry. Both panels will be eight  
5 people. Four we've picked from the NRC National Lab  
6 side and we've had four come from the industry  
7 experts. So we wanted a nice balanced panel. So it's  
8 not going to be lopsided in any way. It will be a  
9 truly balanced panel.

10 The first one, the PIRT meeting, again  
11 Brookhaven is running the PIRT for us. It will be a  
12 formal PIRT and it is going to be the electrical  
13 experts. And the question's going to be -- and I kind  
14 of want to get out of the tail-wagging-the-dog mode of  
15 testing circuits and what I want this panel to tell  
16 me, is there anything left on the table that I need to  
17 be looking at?

18 If you remember the original NEI testing,  
19 NUMARC back then, halfway through the test program all  
20 of sudden CPTs came up, control power transformers.  
21 And that was the silver bullet that prevented the hot  
22 short. And for one that was tuned so tight, it  
23 greatly cut down on the number of them. But when we  
24 did subsequent testing it didn't come out to be that  
25 silver of a bullet, if you will. Here we are into the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 third phase and DC coming up.

2 So what I'm saying is I feel that I'm  
3 being reactive rather than being proactive and that  
4 PIRT allows me to be proactive. That's what I learned  
5 from the fire modeling PIRT. So this electrical group  
6 is going to go there and see is there anything else on  
7 the table? Did we miss anything? Let them look at  
8 this data. You know, they're the experts. We've  
9 given them all the data sets. They've got the full DC  
10 data set. We haven't published it final yet. We're  
11 giving it to them in draft. They have everything.  
12 They've got the earlier CAROLFIRE work and they've got  
13 the original NEI work and that's going to be their  
14 basis to look at it and say, okay, is there anything  
15 else we need to look at in cable space? We've looked  
16 at AC, we've looked at DC. We understand intra-cable  
17 failure versus inter-cable failure. We understand end  
18 devices and how that matters to do a pull-in on a  
19 coil. We understand the role of the CPT and how  
20 closely that can be and how it affects, and to  
21 basically ask all the electrical engineering  
22 questions.

23 Upon the completion of that panel, we  
24 immediately go into the second panel, and this one  
25 will be structured more as an expert elicitation. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this one will bring in the PRA experts and say, okay,  
2 the electrical experts have looked at this. Here's  
3 what they've come up with. Here's what they've  
4 concluded from all this test series. Now the question  
5 becomes for 805 space what are the probabilities of  
6 this type of cable and this configuration giving you  
7 that short? And we'll let the PRA community bring  
8 that. So we'll get the physics part done and then  
9 we'll go into the PRA community.

10 So hopefully that will be about a year  
11 from now that will be completing. Starting tomorrow  
12 is the first panel and these panels will run through  
13 the winter, into the spring and I would hope they'll  
14 conclude up in the summer of next year and we can get  
15 the reports finalized. Again, it will be a full  
16 structured elicitation with Brookhaven leading it.

17 Next slide? You heard a bit about  
18 training. Training is kind of an interesting role for  
19 research. I mean, I really enjoy the training part of  
20 this that we get to do. It's funny, you just can't  
21 take 6850, mail it to Chattanooga and say come up with  
22 a class. I think that would be a disaster. So we  
23 have to bring the experts to bear to actually do the  
24 training. And we've had some very good experts. And  
25 the beauty of this right now at this point is very

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 many of the people who are the authors of 6850 are the  
2 ones who are giving the training. So you really can't  
3 ask for too much more than to have a class from a  
4 textbook from the person who wrote the textbook. So  
5 we've been very lucky with that.

6 We do it again with EPRI and we do  
7 alternating years. This year was the NRC's year. We  
8 just completed the two classes. I don't want this  
9 program ever to go static. It needs to grow and  
10 develop. A big addition this year was to add a full  
11 track or a full class, if you will, on HRA. So we've  
12 gone from three classes to four classes.

13 We've also done something very  
14 interesting. NRC hosted in 2008 and we videotaped  
15 both sessions and we saved all the slides. And I had  
16 a number of college students over the summer and they  
17 basically got to learn a little bit about Fire PRA by  
18 going through all the presentations. And we basically  
19 created an early form of a distance learning class.  
20 If you remember how distance learning started with the  
21 universities, they would often send you the VHS tapes  
22 and the book and you'd watch the tapes and the  
23 professor would lecture and go through it. We've kind  
24 of tuned that up a little bit.

25 But that's the MARIAFIRE. It's a CP,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which is a conference proceeding. And it fills that  
2 need right now today if you needed to say I need, you  
3 know, some -- my goal from the NRC was we hire some  
4 new folks, they go into the region. They're going to  
5 start doing Fire PRA. And the old answer was, well,  
6 gee, make sure you get signed up for next year when  
7 EPRI and NRC put on the training. So that person goes  
8 into this nine-month I'll go do something else. Well,  
9 right now you can take this off the shelf and you can  
10 start learning on your own. And it also gives you  
11 ability of some of the industry presentations and what  
12 Donnie was saying, that if you haven't done it for  
13 awhile, you had the training two years ago and today  
14 all of a sudden you need to exercise it, it gives you  
15 a good refresher.

16 MEMBER ABDEL-KHALIK: I have a question  
17 about your previous slide.

18 MR. SALLEY: Yes? Sure.

19 MEMBER ABDEL-KHALIK: If the members of  
20 these panels were to listen to the talk we listened to  
21 this morning about road map for obtaining realism in  
22 Fire PRAs, would the outcome of these expert  
23 elicitations be any different?

24 MR. SALLEY: I don't know. I would like  
25 to say no. I would like to say if the industry guys

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will bring some of that knowledge to the PIRT panel  
2 for discussions, you know, some of their priorities or  
3 things they want to discuss among the experts and try  
4 to get some ideas. That's what I'd like to say.

5 MEMBER ABDEL-KHALIK: Well, we're not  
6 really sure.

7 MR. SALLEY: As in what the questions are  
8 as far as --

9 MEMBER ABDEL-KHALIK: With the outcome of  
10 this process.

11 MR. SALLEY: I missed some of this  
12 morning, so I'm speaking from ignorance.

13 MEMBER ABDEL-KHALIK: Okay.

14 MR. SALLEY: So I'll pass on that, if I  
15 could.

16 MEMBER ABDEL-KHALIK: All right. Let's  
17 proceed.

18 MR. SALLEY: Next slide? Currently in the  
19 training, and again it's offered twice a year, we have  
20 the four tracks. We've put the fourth track in, which  
21 is the human reliability analysis. Upon completion of  
22 this year one of the things we looked at was the fire  
23 modeling, that we need to start getting into a  
24 detailed fire modeling program. And we're considering  
25 developing for next year a fifth track, if you will.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The basic fire analysis is more of a hand calculation  
2 fire dynamic-type analysis for the PRA. Let's start  
3 moving into the detailed fire modeling, which this  
4 would be a good forum to do it.

5 And it's interesting talking to the people  
6 who are taking it. We're getting a good mix of both  
7 industry and NRC. I think the people really look  
8 forward to it. Mostly what I've heard has been very  
9 positive on the training. And people are looking at  
10 it that, boy, even if I do just -- if I'm an  
11 electrical engineer and all I do is circuit analysis,  
12 okay, and I know how to take the cables and I know how  
13 to take the PNIDs and I can run the circuits down and  
14 I can run the cables down, they find it very  
15 interesting to look at the PRA piece and learn, you  
16 know, what are the PRA guys doing with this  
17 information once I develop it? Or how are the fire  
18 guys telling me that I get damage? So the word that  
19 used is cross-training. People are seeing a lot of  
20 value in that as to understanding the big picture by  
21 the whole Fire PRA. So I've noticed a number of  
22 positive comments on that. I know the HRA, it was new  
23 this year and it was well-received, and the team did a  
24 very good job. Hopefully we'll have the same success  
25 with fire modeling.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Next slide? Which you get to the fire  
2 modeling slide, and this is one that EPRI has been  
3 doing for about 10 years. And it's kind of gotten  
4 saturated where everybody who is going to do it has  
5 done it and it got a little stagnant. So the  
6 attendance is somewhat down. So I think by kind of  
7 fluffing it up, getting that applications guide out  
8 and then incorporating it into the bigger program we  
9 can get an interest going in fire modeling. Because  
10 quite truthfully, fire modeling is a very powerful  
11 tool. I think if I was back in industry what I would  
12 be doing with fire models -- and I'm really not  
13 seeing, you know -- or when I talk to the NRR guys,  
14 I'm not seeing all these, you know, what I would be  
15 bringing in, a lot of high-powered fire modeling  
16 stuff or things I would be trying to do. So I think  
17 fire modeling is under-utilized and I'd really like to  
18 get it a lot more utilized. So that's something we're  
19 working on.

20           Next slide? Knowledge management is an  
21 area that we picked up on. We had a lot of  
22 information. We've done a lot of things that --  
23 esoteric at the time, like, gee, make sure all the  
24 NUREGs are in ADAMS. Was a program that I used summer  
25 students for three years ago and it was amazing how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 many NUREGS were never in ADAMS, that we had one paper  
2 copy of a document. And it's like, my goodness, after  
3 all this work and time, if you lose that one paper  
4 copy, wow, or who even knows, you know, from 1978 that  
5 this was done? So we've done a lot of work with that.

6 Of course Browns Ferry was the high water mark for us  
7 and, you know, we've captured everything we can. As a  
8 matter of fact, I've even gone and found some more  
9 stuff. We had Jack Lewis come up and give a seminar.

10 Jack was a TVA operator at the time, so beautiful  
11 insights he gave us. You know, he left TVA in '86 and  
12 went to our COC Training Center where he spent the  
13 rest of his career down in COC in Chattanooga  
14 training. That's a TVA term, COC. I'm losing it.

15 PARTICIPANT: PDC?

16 MR. SALLEY: Our PDC. Too many acronyms.

17 Our PDC. And he was an instructor there for a number  
18 of years and he recently retired. But before he  
19 really got to the house, we grabbed him and he kind of  
20 gave us a seminar, which is very interesting and we  
21 want to get that on there as to what he felt and what  
22 he saw that day of the fire.

23 The "History of Fire Research." Wow,  
24 there was a lot more, a lot more than I even realized,  
25 especially things like old generic issues and stuff.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So we've captured that and we've got the history of  
2 where we are, fire research up through 2009.

3 The "Fire Protection Knowledge Management  
4 Digest" is we kind of ripped off the NRC's information  
5 digest and did one for fire protection. And there  
6 we've captured basically every generic letter,  
7 information notice, SECY paper, anything to do with  
8 fire protection. And again, that was built for the  
9 inspectors. And when the inspectors go out and say,  
10 you know, wasn't there something on an information  
11 notice about heat collectors? You know, where's the  
12 list of INs for fire that I can quickly page through  
13 and say, yes, here it is. There was. Or wasn't there  
14 something about hydrogen gas storage on the control  
15 room roof? Or don't I remember reading something? Or  
16 generic letter 8610 is the one that everybody likes to  
17 bring out and beat, because that was the big Q&A. So  
18 we've assembled all that. And again, it's publicly  
19 available to anybody who's interested. We share it  
20 with industry.

21 Next slide? Okay. Looking ahead. You  
22 know, what are we going with? And how are we looking  
23 on time here? We okay?

24 CHAIRMAN STETKAR: Yes, if you can get  
25 through it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SALLEY: Okay. Five Events Data Base.  
2 Very important project. Very, very important  
3 project. On this one, my hands in research are tied.  
4 Okay? I don't see this data. I can't get this data.  
5 If I went to Alex and said, Alex, I'm going to have  
6 you write a generic letter to have every plant turn in  
7 every fire that ever went, you want to talk about a  
8 non-starter. So this one I'm at the mercy of  
9 industry.

10 For years we used the NEIL data base, and  
11 it was good to a point, but I understand that there's  
12 actually -- Ken's told me that there are better things  
13 out there they can do than the NEIL, which was the  
14 insurance data base. This is one we need to pick up,  
15 guys, and really do. I mean, if you look at 6850,  
16 this is where we are a little dated. When 6850 was  
17 done and the team was together, they says, okay, a lot  
18 of times you would have an EPRI piece and you would  
19 have an NRC piece. It's a joint project. Okay. Who  
20 got the better piece? Okay. If it's a better piece  
21 from the NRC, let's use that. If the industry piece  
22 is better, let's use that because we want the best  
23 document at the end of the day.

24 The Fire Events Data Base, clearly the  
25 better one was the EPRI data base. So the NRC, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 stopped. We got out of the data collection business  
2 and we went with the EPRI data base. That was clearly  
3 the better tool at the time. But it was current  
4 through 2000. So the data that you're using now is  
5 good through 2000. There's been 10 more years of  
6 operating experience that we have not picked on that  
7 we need to get in there.

8 And, John, I listened to your question  
9 this morning and I echo many of those same concerns as  
10 to how that older data comes up and in. And I've been  
11 a little bit of a thorn in Rick's side trying to say,  
12 you know, for example, one I got caught cold on was  
13 when we had the new commissioners come in. And the  
14 new commissioners came in and they wanted some  
15 briefings on it. And finally we got the standard  
16 briefing material and I believe it was Commissioner  
17 Magwood, we briefed him on this is what we're doing in  
18 fire research. And he hit with me with a question.  
19 What percentage of the fires were electrical in  
20 nature? Now this is something I should have went bam,  
21 right? And I went let me get back to you on that one  
22 because I don't want to give you a bad number.

23 So I immediately had to scurry over, you  
24 know, back to Church Street and wind my people up and  
25 say, okay, let's start going. And now here's where

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the fun begins, because well, if we look at this data  
2 that's good through 2000, we get, you know, 29  
3 percent. But if we look at the LERs, which are the  
4 official reporting, we get 42 percent. And this  
5 should have been a question that I should have  
6 answered so simply, you know? You know, I'll call you  
7 back in five minutes with the answer. Here's the pie  
8 chart, like NFPA or somebody would do, and we need to  
9 do that.

10 And another problem it presented, J.S. had  
11 an effort where the reactor vendors are doing some  
12 work and they find the data base that's currently on  
13 our Web site, which is an old NRC one from the AEOD  
14 days. It's horribly out of date and I need to sunset  
15 that and get a unified data base. So again, we're  
16 trying to work with EPRI. And at the end of this we  
17 would love to have a data base that we could both work  
18 out of, that we could share as a joint project and  
19 would come from the same numbers. So big project, but  
20 like I say, my hands are kind of tied on that.

21 We do do some metric monitoring. And this  
22 is one the Commission directed NRR and we picked up  
23 and used. And this one we use the LERs. And  
24 basically we're looking at three things from the  
25 Commissions direction. How many fires are we having?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In LER space we're seeing about seven. On average  
2 roughly seven LERs are reported a year for fires.

3 Second question was how about inspection  
4 findings? What are you seeing? I'm sorry I don't  
5 have that number off the top of my head, but we have  
6 the inspection findings. We track, you know, whether  
7 they're green or white or yellow type of findings.

8 And the third one is the long-term  
9 compensatory measures. Again, we're working under the  
10 MOU with EPRI to get that information from NEI.

11 So those are the three that the Commission  
12 has asked us I guess about two or three years ago to  
13 start tracking for them.

14 CHAIRMAN STETKAR: Mark, how do you  
15 respond to what we heard this morning, that if indeed  
16 the PRAs have some fidelity, numerical fidelity, we  
17 should be seeing many more damaging fires per year  
18 than indeed we seem to be seeing as measured from, you  
19 know, some metric. You mentioned metric monitoring  
20 here. Some metric in terms of, you know, a white or  
21 yellow or red finding from the inspection process,  
22 CCPD, however you want to monitor that. Do you agree  
23 with the industry that indeed the numerical results  
24 that seem to be coming out of the Fire PRAs are not  
25 consistent with what we're really seeing, if that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the appropriate way to measure frequency of severity,  
2 if you will?

3 MR. SALLEY: I'm not a PRA expert, so I  
4 hesitate. I mean, my background is more the classical  
5 design experimental fire protection that I come from.

6 And so as a fire protection engineer looking at it,  
7 and you say, you know, for this event the chances of a  
8 core damage from a fire is one times ten to the sixth.

9 Okay. That's one in a million. That's a lot of  
10 operation to get to that. Even if you take it down to  
11 ten to the minus third. Now we start getting itchy,  
12 but we haven't had ten to the third operating  
13 experience.

14 And to do the old Wash 1400, let's take  
15 100 reactors, let's operate them for one year and now  
16 all of a sudden we have 100 reactor years of  
17 operation, that discounts a lot of things like bathtub  
18 curves and start up versus -- you know, stable  
19 operation versus the aging effect. So that's not my  
20 forté. I wouldn't look --

21 CHAIRMAN STETKAR: Sunil will come up at  
22 the end. I'll hit him with that one.

23 MR. SALLEY: Yes. I mean, I personally,  
24 in research I would look to a Nathan Su to help me  
25 with a question like that, because I see it as a much

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 simpler world --

2 CHAIRMAN STETKAR: Okay.

3 MR. SALLEY: -- and where I come from.

4 CHAIRMAN STETKAR: I'm sorry.

5 MR. SALLEY: No problem.

6 CHAIRMAN STETKAR: Hit the wrong guy, but  
7 you had the bullet up there.

8 MR. SALLEY: I'm not the PRA expert.

9 Incipient detection. There's one that  
10 again we want to hopefully work with industry. And I  
11 started laying the groundworks with getting things set  
12 up. I visited NASA and talked with the guys at  
13 Kennedy Space Flight Center and such, and they swear  
14 by incipient detection and they think this is the  
15 greatest thing since sliced bread. And they told me  
16 the stories of the relays getting ready to burn out  
17 before a launch and they caught it and successfully.  
18 So, you know, Kennedy Space Flight thinks that's the  
19 greatest thing since canned beer.

20 Talked with guys from DOE and they tell me  
21 that this is junk and if you want some, they're out  
22 back in the dumpster. So go take them if you want  
23 them because they don't work in our environment.

24 MEMBER ABDEL-KHALIK: You know, you said  
25 that you get roughly seven LERs per year.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SALLEY: Okay.

2 MEMBER ABDEL-KHALIK: These cover  
3 everything from a trash can fire to --

4 MR. SALLEY: Anything. The metric that we  
5 used was what is a fire that meets the threshold to be  
6 reportable to the NRC, like declaring an unusual event  
7 for a fire and filing the LER? That's what we used.  
8 That's the metric that we will get a response from the  
9 industry.

10 MEMBER ABDEL-KHALIK: Okay.

11 MR. SALLEY: And that's what we've used.  
12 And I can share the report I believe with you, and  
13 I'll be happy to do that. We're about at our third  
14 update. We like to do a six-month update is our  
15 agreement with NRR. We'll be happy to share that with  
16 you. Again we're looking for the trend. And the fire  
17 trend tends to want to be pretty flat, that we have  
18 around seven --

19 MEMBER ABDEL-KHALIK: Okay.

20 MR. SALLEY: -- or, you know, some years  
21 there will be four and some years there will be ten.  
22 But, you know, seven is the number from me reviewing  
23 the reports last time. J.S., help me there, but I  
24 believe seven was the LER, or roughly seven LERs.

25 CHAIRMAN STETKAR: Mark, let me interrupt

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you for just a second.

2 MR. SALLEY: Yes.

3 CHAIRMAN STETKAR: Because 33 percent of  
4 our member complement here is going to be leaving and  
5 not returning, and I'd like to ask that 33 percent --  
6 Bill, do you have any particular comments that you'd  
7 like to --

8 MEMBER SHACK: No. No.

9 CHAIRMAN STETKAR: Okay. We usually go  
10 around the room and --

11 MEMBER SHACK: Sitting here absorbing  
12 information all day, but I just sort of sit back and  
13 think.

14 CHAIRMAN STETKAR: I just wanted to check.

15 MEMBER SHACK: Yes.

16 CHAIRMAN STETKAR: We usually do that  
17 right at the end, but wanted to give you the  
18 opportunity. Thank you. Sorry.

19 MR. SALLEY: Okay. So incipient detection  
20 is a program that it was an FAQ. There's been an  
21 answer. And we clearly need to do some follow-on  
22 research and confirmatory research on that.

23 Low-power shutdown is a program that --  
24 this was an interesting one. We originally set out to  
25 do -- this was a joint project. As the project

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 developed, this was one that kind of broke down a  
2 little bit and EPRI said, no, we can't put our  
3 resources on this. We have other things right now.  
4 Tell you what, if you want to go with it, you either  
5 going to go this one alone, however, we can offer a  
6 peer review for you. And we said, fine, that's  
7 understandable. Had to divert some resources. So we  
8 completed this out and they peer reviewed it, and  
9 we're closing up the final comments. And hopefully  
10 this is going to be out before Christmas for public  
11 comment. And again, it's a quantitative method to do  
12 a low-power shutdown risk for fire. So that will be  
13 coming out in a NUREG/CR for comment.

14 The heat release rate, we've talked about  
15 that. Basically, we've got that on hold to see what  
16 EPRI does before we go -- you know, we don't want to  
17 replicate activities. So that one's on hold.

18 Next slide? Kerite. You know, what's it,  
19 you know, I before E except after C, or what's that  
20 rule? There's always an exception to the rule, right?

21 You know, like I said, my world I wanted the cables  
22 to be thermoset and thermoplastic. And from that we  
23 can now say, okay, we can understand failure  
24 temperatures and failure modes and now they start  
25 failing. There's always one cable that ain't going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 play. Cable that ain't going to play is kerite. And  
2 I've had some experience with kerite way back in my  
3 NRR days. I can remember kerite being an interesting  
4 cable in the fact that it was one of the ones that  
5 self-healed itself, where when it was hot, it would  
6 fail, but once it cooled down, like after a hose  
7 stream in a fire barrier test, all of a sudden it  
8 became functional. Okay? So it was doing that self-  
9 healing. You say, wait a minute, it's a thermoset.  
10 Thermosets don't self-heal. Thermoplastic self-heals.  
11 Yes? Well, this one did. I saw it. So it's that  
12 one that always wants to break the rules.

13 The kerite cable tends to be used more I  
14 understand out there in medium-voltage power. The key  
15 for us of course is the control circuits. It is a  
16 control cable though. And when we started down the  
17 little road, we thought that, you know, it was a  
18 handful of plants. There was a couple, three that had  
19 bought it in the control. As we see though, there is  
20 more and more of it out there than we thought.

21 CHAIRMAN STETKAR: That's what we heard  
22 this morning, that it's sort of an issue on -- we  
23 heard numbers, five to ten percent of the plants. So  
24 we're talking round numbers.

25 MR. SALLEY: Right. You know, we had

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it --

2 CHAIRMAN STETKAR: Five to ten units.

3 MR. SALLEY: We had this originally, it  
4 was a couple, three. And the number seems to have  
5 grown. With testing something like kerite, it's hard  
6 because it's not manufactured anymore. So you're  
7 going to have to get it from somebody who's got it.  
8 And this is, you know, somebody who has left overs, if  
9 you will, in their power stores warehouse from when  
10 the plant was built. Again, this was one that it was  
11 good. You know, we want an answer. We want to get  
12 this off the table, that industry was able to go and  
13 some of the utilities donate some material for  
14 testing. So we just want to get an answer.

15 And like I said, Harry Barrett is one of  
16 the guys who really worked out priorities. He wants  
17 to clear that -- you have an FAQ hanging out there.  
18 Well, nobody wants these FAQs. This one you need a  
19 little bit of experimental work on. It's nice in the  
20 fact the experiments are running right now. They're  
21 going to be done here in a few weeks and we're going  
22 to have that data. So the timing is nice for me when  
23 we go to that PIRT panel and say, oh, by the way,  
24 here's the kerite data. Is it a thermoset? Is it a  
25 thermoplastic? Does this one have its own class all

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 by itself? What did the experts deduct from the  
2 tests? So hopefully we can bring a successful closure  
3 to kerite and get it off the table and move onto the  
4 next issue.

5 Smoke damage to electrical circuits and  
6 components is one we want to look at. And this is one  
7 that it's a lower priority. But if we ever get into  
8 the digital INC world, this is one that I think we'll  
9 want to have some information on. So this is one  
10 that's -- it's a medium-type priority that's behind  
11 this cable testing that I would see Gabe looking at.  
12 We've got some ideas and some plans and we're kind of  
13 banging some ideas with some laboratories on how we'd  
14 do this.

15 Gaseous extinguishing agents. This has  
16 always been a little bit of a thorn in the side.  
17 Cable fires tend to be deep-seated fires. Deep-seated  
18 fires tend to take lot higher concentrations than a  
19 surface-type fire. It's very difficult to design  
20 systems that will do that. As the systems age their  
21 concentrations and their hold times if they were  
22 tested today would be lower. There's been some  
23 research on this. We want to do a little bit more  
24 research.

25 Also, another thing, if you remember back

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the '70s and '80s the miracle agent was halon.  
2 And, boy, halon was the Cadillac of agents. And  
3 today, you know, post-Montreal protocol, it's an ozone  
4 eater and you can't buy it. And if you can buy it,  
5 it's grossly expensive. So you're seeing the halons  
6 phase out and you're seeing new agents come in, new  
7 clean agents. So now the question becomes, okay, how  
8 are they going to work for our applications? So we're  
9 looking at doing a little bit of work here again in  
10 the gaseous extinguishing agent.

11 Another things just to tag with that too a  
12 little bit is the water mist, too. You're seeing, you  
13 know, instead of the standard sprinkler that we use to  
14 -- you know, based on the cruise ship fires, you've  
15 seen a lot of the water mist systems coming into  
16 popularity in buildings.

17 Next slide? International, just to touch  
18 on; and I'm just about done here, there is a fire  
19 events data base program internationally and we have  
20 been a member of this. It's an OECD program since its  
21 inception. And this is a nice little metric because  
22 it gives you -- the main thing it gives us is a  
23 conduit to talk with the other fire research  
24 organizations internationally as to what happened. So  
25 if they have a fire, you can kind of call them up and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- you know, you're going to read what the press says,  
2 but when you talk to them at the meeting, they're  
3 going to say, well, here's what really happened. So  
4 it kind of gives us a little bit of an insight like  
5 that.

6 And also it gives us a data point to say,  
7 okay, if we're looking at the fires we're having and  
8 the rest of the world are having, are we having all  
9 electrical fires and they're having all pump fires?  
10 Why are we so different? What are they doing  
11 different than us? We're not seeing that. But it  
12 gives us that metric to watch with.

13 Again, for our reporting here the NRC's  
14 contribution to this is LER fires. So we're tracking  
15 LER fires, because that's what we have. Now,  
16 obviously some countries are putting everything in.  
17 If you're a small country that has four reactors, you  
18 can keep a pretty good eye on things. If you're  
19 larger, that's a weakness of this program is the  
20 reporting criteria. You know, our threshold is very  
21 high, so you're seeing a lower number from the U.S.

22 An interesting program that we've talked  
23 about, and this data base has given us a venue to talk  
24 to people, is the high-energy arcing faults. Like I  
25 say, if you look at what's in 6850 today, no surprise.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It's basically San Onofre. These events have  
2 happened all over the world. Germany's had a number  
3 of them. Belgium, I know talking with them, have had  
4 it. France has had it. And this is a hard one. You  
5 know, we have the best method of putting in the PRA,  
6 which in 6850, if you talk to the other countries,  
7 they'll say that's about the best that you can do for  
8 PRA. How do we refine this? How do we learn some  
9 more? Well, we've got to do some experiments.

10 And this is going to be an interesting  
11 experimental program, because running the experiments  
12 is not going to be the big cost. The big cost is  
13 going to be getting this equipment, to get the  
14 switchgear to blow up and to -- that's where the money  
15 of this is going to be.

16 Now, in the business of doing research, I  
17 can say, you know, Chris, let me have \$X million and,  
18 you know, we'll go buy all kind of switchgears and all  
19 kind of cabinets and we'll go and do this. Or can we  
20 work smarter? And the working smarter piece would be,  
21 okay, the NRC -- we have a laboratory. Sandia has a  
22 nice facility. They're a cross-wind facility for DOE.

23 They have the power supply there. We can do the  
24 testing in Sandia quite nicely. But we need the  
25 equipment. So on the international thing we've talked

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to folks and we've said, you know, price of admission,  
2 like an OECD program, instead of giving us money, what  
3 are you interested in? You're interest in 40-volt  
4 switchgear? Send me one. I'll blow it up for you.  
5 Okay? You know, Japan, what are you interested in?  
6 You're interested in, you know, 4160 breaker cubicles.  
7 Send me them and we'll blow them up for you.

8 So we've put a metric together. And  
9 what's going to be integral about this it's much like,  
10 you know, what I learned with working with EPRI for  
11 that battery bank is what you've got to have is you've  
12 got to have the contacts out there and you've got to  
13 know what's going on to know that there's a plant out  
14 there who just so happens to be recycling their  
15 batteries, so basically you can have them versus going  
16 and spending \$X million buying them. And again, you  
17 know, once I get this rolling and started up I'm going  
18 to go to EPRI and say, okay, here's another program.  
19 How would you like to contribute? And the price of  
20 admission both internationally and nationally is can  
21 you find some old switchgear?

22 It's interesting because J.S. talked it up  
23 at the last meeting in Paris and already I've had  
24 Korea say, okay, hey, I got this switchgear. Where do  
25 I mail it to? And I was like, whoa, whoa, whoa.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Little too quick. So it's good that we are being --  
2 you know, people are receiving our ideas and we can  
3 have a very nice international program here. And I've  
4 asked Gabriel to draw up a matrix as to, you know,  
5 what we're looking for. And hopefully I'll be calling  
6 you, Rick, and saying can you do some shopping here  
7 and see who's got some stuff from abandoned plants or  
8 changing equipment out that we can go here and get a  
9 better understanding of the high-energy arcing faults.

10 And the last one is PRISME. PRISME is a  
11 French program that is very detailed looking into fire  
12 models. They're trying to do a lot of qualitative  
13 work with the fire models. A lot of the work  
14 replicated what we're doing here like the cable trays  
15 and that. So it was hard for us to join it, but we  
16 have finally reached an agreement where we'll do some  
17 in-kind contribution where there won't be a cash  
18 contribution from us, but we'll do some data exchange  
19 from some of our experiments and they'll allow us the  
20 data. But the OEC data brings its own set of  
21 restrictions too in the fact that I can't openly share  
22 the data. So it's very limited to me that I can't  
23 just, you know, openly share the data from the  
24 exchange. But nevertheless it's something nice that  
25 we could stay with the international community.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           And I believe with that, that is the full  
2 research presentation.

3           CHAIRMAN STETKAR: Excellent. Thank you.  
4 Any members have any --

5           MR. SALLEY: Did I lull you to sleep?

6           CHAIRMAN STETKAR: Seeing none, thank you.  
7 Yes?

8           MR. CANAVAN: Can I just have one quick  
9 clarification on the low-power shutdown fires? We  
10 sent you some comments, but we never thought that that  
11 was a peer review. But we look forward to seeing it  
12 on the public --

13           MR. SALLEY: I'm sorry, Ken, I understood  
14 that as -- that was, you know, we had drafted it  
15 early. We had gotten the input from EPRI. We'd  
16 adjusted that and we've talked of course with NRR; got  
17 some input. And we're going to put it out for public  
18 comment.

19           MR. CANAVAN: Well, no. We'll weigh in  
20 during the public comment period.

21           MR. SALLEY: Please do.

22           MR. CANAVAN: The comments that we sent  
23 you were sort of, you know, me and a couple other  
24 people were just taking a quick look at it and giving  
25 you some feedback.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SALLEY: Oh.

2 MR. CANAVAN: I just didn't want to cast  
3 that as a peer review because all the stakeholders  
4 didn't get an opportunity to see it on our side.

5 MR. SALLEY: My misuse of the word.

6 MR. CANAVAN: Oh, and there isn't a lot of  
7 extra 4160-volt switchgear out there.

8 CHAIRMAN STETKAR: You got a big back  
9 yard? You can start stockpiling. I'm sure you can  
10 work a deal out.

11 MR. SALLEY: No, it's interesting though  
12 that -- you know, like I say, the key here on this is  
13 going to be that you'll break the budget.

14 CHAIRMAN STETKAR: I got a bunch of old  
15 relays sitting in my basement if you want them.

16 MR. SALLEY: And you need to just find the  
17 right people at the right time. As a matter of fact,  
18 it was interesting doing the DC testing that we  
19 changed equipment in there. Again, Ken bringing a lot  
20 of the industry experts. There's a place up in New  
21 England that actually refurbishes old switchgear that,  
22 you know, us being researchers or not owning a nuclear  
23 power they really didn't know about, but you know,  
24 that's a contact where we can find things maybe that  
25 aren't going to be refurbished that we can go and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 let's do a cross-phase experiment here and see how big  
2 a bang we can make.

3 CHAIRMAN STETKAR: Sunil, did you run  
4 away?

5 MR. WEERAKKODY: No, I'm here.

6 CHAIRMAN STETKAR: You're on the agenda  
7 for some closing comments, and I'm not going to forget  
8 to ask you the question about the significance of -- I  
9 assume you've had enough time to get an answer  
10 together.

11 MR. WEERAKKODY: After you said that I  
12 told several people in the staff not to leave.

13 CHAIRMAN STETKAR: I know the room  
14 cleared.

15 MR. WEERAKKODY: Thank you. For the  
16 record I'm Sunil Weerakkody. I'm the Deputy Director,  
17 Fire Protection in NRR.

18 I had some concluding remarks that I have  
19 come prepared, but after listening to the subcommittee  
20 chairman's comments and introduction this morning, I  
21 thought I'll share some of the other facts on the NRR  
22 side with the audience.

23 John said that, you know, the Commission  
24 directed that we, you know, the ACRS do the study and  
25 then you're going to get the report out in February.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 For NRR the Commission has directed us to provide them  
2 lessons learned from pilot study in June. So in the  
3 big picture of things what we are planning to do is we  
4 really look forward to getting the ACRS study as an  
5 input as terms of the study that we plan to do, the  
6 lessons learned when we send it to the Commissions. I  
7 mean it in a very complimentary way, John.

8 PARTICIPANT: We took it that way.

9 CHAIRMAN STETKAR: We did.

10 MR. WEERAKKODY: You took it that way?

11 CHAIRMAN STETKAR: We'll issue our report  
12 at the end of February. Do with it what you will.

13 MR. WEERAKKODY: Our due date is June 30th  
14 of 2011, so we have the luxury of waiting for that  
15 report and factoring that into our lessons learned  
16 letter to the Commission.

17 One of the things that -- before I answer  
18 the questions, you know, from the members, I do want  
19 to put some context on the old, old question or the  
20 issue that we are discussing. John, you said that in  
21 terms of what ACRS looks at, you're looking at the;  
22 I'm using my own words, you know, adequacy of methods,  
23 data and that sort of thing as related to Fire PRAs.  
24 And in terms of determining data adequacy, and  
25 obviously you'll have some standards, and against

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those standards you will make certain determination as  
2 to whether it's adequate or not.

3 As a regulator, you know, who's got an  
4 OECD fire safety, when I look at the number of issues  
5 that we discuss here today with respect to Fire PRA, I  
6 do have a very clear standards that we hold in NRR  
7 with respect to is it adequate? In other words, with  
8 all of the things that we talk about, you know,  
9 problems with data or heat release rates and all that,  
10 are the Fire PRA methods adequate? And our standard  
11 is simply this: Are they adequate where when a  
12 licensee determines that I'm not meeting a particular  
13 well-founded deterministic code, such as a separation  
14 issue, are these methods adequate to make a  
15 determination as to whether or not I can live with  
16 that situation? Okay? And even though I can have  
17 multiple opinions with respect to the realism of Fire  
18 PRAs, with respect to that particular question I'm  
19 pretty confident that we are at a stage where we can  
20 say, yes, they are adequate.

21 And then I'm saying this based on some of  
22 the things we learned from Harris. Like for example  
23 Shearon Harris maybe before they even did the Fire  
24 PRA; I don't know the timing for sure, they chose to  
25 replace a number of their cables that were running

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 across different areas with e hour measured cables.  
2 Okay? Now, perhaps hindsight that licensee might find  
3 when they make their Fire PRA very, very realistic  
4 that maybe they didn't need that. Okay? But as a  
5 regulator, when I know that the fundamental fire  
6 safety depends on good separation, okay, I know with  
7 all of the issues with Fire PRAs, if I did an  
8 analysis, conservative or uncertain, I have that tool  
9 adequate to make a judgment on whether or not that  
10 particular mod is necessary or not.

11 So in terms of adequacy, you know, I  
12 really look at this whole issue from the context of  
13 are the methods adequate to support a deviation from a  
14 well-founded deterministic requirements that we are  
15 requiring through Appendix R regulation and that we  
16 are imposed on new reactors?

17 MEMBER ABDEL-KHALIK: No, but the point  
18 was made I think several times this morning; and let  
19 me read exactly the comment, that Fire PRA that is  
20 biased can mask important events and components or can  
21 drive plant changes that do not improve safety. So  
22 from what you just said, are you saying that this is  
23 not a real concern?

24 MR. WEERAKKODY: To me, when I look at a  
25 plant that's transitioning from Appendix R program to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 805 and, you know, uses a Fire PRA to make a  
2 determination as to do or not do mods, I have yet to  
3 see an example where they made a mod that made the  
4 plant unsafe. So, you know, somebody's got to give me  
5 an actual example and say, oh, I made this mod, but  
6 because of Fire PRA conservatism I find that it to be  
7 lessening my safety. You know, I'm very suspicious  
8 about that statement.

9 Did you want to say something, Donnie?

10 MR. HARRISON: This is Donnie Harrison.  
11 In the context of the comment, I think when you're  
12 looking at importance measures, relative importance  
13 measures over conservatism can influence where all of  
14 a sudden you start masking the importance of something  
15 that should be important but it's coming out less  
16 important because you've made something else much more  
17 important than it really is.

18 So if you're in an application that's  
19 using that type of a relative ranking process, that  
20 would probably be a bigger issue. For 805 application  
21 it's not a significant issue. And again, depending on  
22 how you do that delta risk calculation, it can be a  
23 non-issue.

24 MEMBER ABDEL-KHALIK: But this is not a  
25 hypothetical state. This is a statement that's made

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the context of 805.

2 MR. HARRISON: Well, I think actually  
3 that's Doug's comment. I've got a wall blocking me  
4 from seeing that Doug's still here. Or if it's Rick's  
5 comment. I think that he was making a more general  
6 comment.

7 But again, in a relative ranking system  
8 that can be a masking issue.

9 The other thing is I think they're talking  
10 about, in the past the industry has mentioned making  
11 modifications today that if you had refined models  
12 five years from now you may have looked back and said  
13 I don't need that modification, or I didn't need that  
14 modification to be an acceptable 805 application. My  
15 rebuttal to that is I can't predict the future. I can  
16 only deal with where I am today.

17 MR. WACHOWIAK: This is Rick Wachowiak  
18 from EPRI. Just to amplify what was just said, the  
19 statement doesn't say we make a modification that's  
20 unsafe. It's a modification that's unnecessary. So I  
21 think if all you were doing with these PRAs was saying  
22 I have a deviation from some deterministic practice  
23 and do I need to make a modification to make it safe  
24 enough, a conservative or biased high PRA could give  
25 you an upper-bound solution to that and say I don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know whether or not I need to make this mod. But if I  
2 do make the mod, it doesn't make things any worse  
3 other than it used up the resources that we could have  
4 spent on making something else actually better.  
5 Okay? So if that's all you were using the PRA for,  
6 it's a matter of resources at that point.

7 I don't see that happening with these PRAs  
8 that were used for 805 then are now the official fire  
9 PRAs that are going to be used for STPs. And you're  
10 going to get white, yellow, red findings all over the  
11 place because you've got these things in there that  
12 you've used for an application that was just is it a  
13 good idea to make a mod? So we have to be careful  
14 about the application and clear about the statement.  
15 The statement isn't saying we're making unsafe mods.  
16 We're saying we're making mods that may not provide  
17 any benefit and using resources that could have been  
18 used elsewhere to make mods that do have benefit or  
19 other program changes that do have benefit.

20 MEMBER ABDEL-KHALIK: No, but there is  
21 another part of this --

22 MR. WACHOWIAK: Yes.

23 MEMBER ABDEL-KHALIK: -- other than making  
24 modifications that --

25 MR. WACHOWIAK: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: -- may incrementally  
2 improve safety, albeit not cost-effective.

3 The other component, the other part of  
4 this statement is that they can mask important events.

5 MR. WACHOWIAK: They can.

6 MEMBER ABDEL-KHALIK: So how do you  
7 address that?

8 MR. WACHOWIAK: That was the point of our  
9 morning's discussion, was that we need to be able to  
10 address that. In the context here --

11 MR. WEERAKKODY: One of the fundamental  
12 statements that I want to make is that when you look  
13 at the adequacy of Fire PRAs, with all of the issues  
14 you're putting on the table with respect to plant  
15 transitioning to 805, okay, we look at what are the  
16 fundamental good requirements that Appendix R tried to  
17 install, which is separation. Okay? So I think where  
18 I could directly say is if there are situations where  
19 use of Fire PRA could result in modifications that are  
20 unsafe or less safe, I don't think I can agree with  
21 that. But like you said, when you're going to other  
22 applications, or like Donnie said, you know, when you  
23 go to the relative ranking, obviously there could be  
24 certain misunderstandings coming out of that.

25 MEMBER ABDEL-KHALIK: I think you missed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the point that I'm trying to make.

2 MR. WEERAKKODY: Yes?

3 MEMBER ABDEL-KHALIK: Okay? And I fully  
4 understand the point that you make that none of these  
5 modifications would decrease the level of safety.  
6 Right? But the point is there may be changes that you  
7 need to make that you don't see because they're being  
8 masked. And I haven't heard the answer to that.

9 MR. WEERAKKODY: Okay. Yes, I can't see  
10 that happening, but go ahead, Donnie.

11 MR. HARRISON: This is not an 805  
12 transition, but it's one where there's relative  
13 ranking.

14 MEMBER ABDEL-KHALIK: Right.

15 MR. HARRISON: And it's where you've got  
16 10 CFR 50.69, which is special treatment requirements.  
17 And that's a risk-informed application that uses the  
18 importance measures as part of the process. And the  
19 way we dealt with that issue is you don't just look at  
20 everything together. You do what I call a both/and  
21 approach, which is you look at the individual hazards.  
22 So you'd look at the Fire PRA hazards and how things  
23 ranked out, but then you individually look at the  
24 internal hazards, the flooding hazards, all the  
25 different hazard groups and you treat them

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 individually as well as collectively.

2           So I find out what's important for my  
3 internal events model, and that way if there's some  
4 issue in the Fire PRA model that would have masked  
5 that if you looked at it collectively, it will  
6 actually show up on its own in the internal events  
7 ranking. And so then you know what's important for  
8 each of the hazard groups and you can address that.

9           The masking within the hazard group would  
10 still be there, but --

11           PARTICIPANT: That's the point of this.

12           MR. HARRISON: -- that within the total  
13 risk part of it by knowing that the total risk is  
14 acceptable. And it's a matter of conservatism.  
15 Obviously the more conservative, the more drastic that  
16 impact is.

17           CHAIRMAN STETKAR: Rick, do you have --

18           MR. WACHOWIAK: Yes, I was just going to  
19 finish with it all depends on what the use of the tool  
20 is. If you're using the tool for things that involve  
21 relative ranking, then the first part of the statement  
22 applies and you may get the wrong answers if you do  
23 that. And I think Doug mentioned a couple this  
24 morning. If you were to use your Fire PRA for an A4  
25 evaluation, as done with this process, you may not get

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the right answer; his example was in that, or for some  
2 other risk-informed application.

3 CHAIRMAN STETKAR: My sense is what I'm  
4 hearing here is on the part -- and correct me if I'm  
5 wrong; as I said, I'm allowed to be wrong -- on the  
6 part of the staff, and to some extent maybe even on  
7 the part of the industry, is that the degree of  
8 realism, if you will, in the PRA, that bar to justify  
9 the transition to NFPA 805, in other words, to justify  
10 the adoption of a risk-informed fire protection  
11 program, without ever planning to ever do anything  
12 else is different from the level of realism that you  
13 would desire for a variety of particular applications  
14 within that framework. Once you've established the  
15 fact that you're within that framework, whatever those  
16 applications are, whether they're risk-informed  
17 changes to the plant itself, you know, physical  
18 equipment changes or whether they're significant  
19 determination under the ROP process that now, you  
20 know, would take benefit of that risk information.

21 We should think about that, because in  
22 practice -- I'm not an attorney and I don't have  
23 enough brain cells left to go back to school to become  
24 one, but part of the Commission's concern, you know,  
25 in our direction was things that impede the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transition. There's a concern at the Commission level  
2 in terms of why aren't more plants signing on for this  
3 process? Why are plants dropping out? Why are people  
4 saying that indeed the applications, you know, should  
5 be delayed until we have some of these important  
6 issues, whatever they are?

7 And perhaps some of what we're hearing is  
8 kind of a mixture of those two issues. What does it  
9 take to transition? What inherent benefit is there  
10 from simply transitioning and saying I'm never going  
11 to use this thing for anything else versus what do I  
12 need for actual applications? I don't think we'll get  
13 an answer to that, but it might be something worth  
14 discussing in December. I'm not sure that it's as  
15 easy as I've just characterized it to separate those,  
16 because obviously you're developing a --

17 MR. WEERAKKODY: The same model, yes.

18 CHAIRMAN STETKAR: -- the same model --

19 MR. WEERAKKODY: No, I --

20 CHAIRMAN STETKAR: -- you know, that you'd  
21 like to use in the future, but --

22 MR. WEERAKKODY: I deliberately couched my  
23 wording because I knew the Commission was directed to  
24 what are the issues impeding transition to 805? I  
25 don't think Rick said anything that I would disagree

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with. In fact, when I think some of the other  
2 applications that are coming down the line such as; I  
3 don't know whether the members have heard, Tech Spec  
4 4B, which gives the licensees the operational  
5 flexibility to change their allowable outage time  
6 without regulatory intervention, I myself concerned  
7 with, you know, things like that, you know, because  
8 there are conservatisms, un-conservatisms. I'm not  
9 personally concerned with respect to the current  
10 status for 805, but I really do want to be able to  
11 defend to any member of the public that we have a  
12 great tool that I can rely on before I turn over that  
13 flexibility on self-adjusting the AOT to the industry.

14 So I think that is a great point, John.

15 CHAIRMAN STETKAR: I am now officially  
16 starting to get a bit concerned about the time, only  
17 because I have to worry about the rest of you.

18 MR. WEERAKKODY: My rest of my  
19 presentation is simply three statements of what the  
20 staff has saw. It might take me like --

21 CHAIRMAN STETKAR: If you could do that.

22 MR. WEERAKKODY: Yes.

23 CHAIRMAN STETKAR: And again, I'm going to  
24 only interrupt in terms of trying to get --

25 MR. WEERAKKODY: The whole purpose was to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 repeat some of the key messages of the staff. I  
2 wasn't going to add anything that they haven't said.

3 CHAIRMAN STETKAR: If that's the case,  
4 maybe we can --

5 MR. WEERAKKODY: Just go ahead and ask me  
6 questions there.

7 CHAIRMAN STETKAR: I would only like to  
8 ask one question, and you've now had enough time to  
9 think about it, and that is how do you address the  
10 industry's statement, and backed up by their  
11 presentation this morning, that if indeed the methods  
12 and the supporting data are applied we should be  
13 seeing many more damaging fires? And I'm not talking  
14 about core damage frequency, because they've  
15 eliminated that absolute measure of a frequency of  
16 damage, but a frequency of damaging fires, a frequency  
17 of fires that damage equipment such that my  
18 conditional core damage probability is a measurable  
19 event in the same way as we do that sort of  
20 significance determination process for, you know, the  
21 Internal Events PRA? Are we not seeing those fires?  
22 Is there something -- you know, why isn't the staff in  
23 the reactor oversight process issuing more white and  
24 yellow findings for fire events? Because, you know,  
25 it's been stated that indeed fire events in a generic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sense are not events. They're happening out there.  
2 There are countable numbers of events. If they  
3 weren't, we wouldn't worry about counting up many more  
4 events over the last 10 years.

5 So the question is if the fires are  
6 happening, why isn't the agency, the staff identifying  
7 a reasonable countable number of either, you know,  
8 white or yellow? I'm not even going to be up into red  
9 area fires.

10 MR. WEERAKKODY: I have seen that  
11 statement made in a number of industry presentations  
12 and I see that and I go back and ask the staff and  
13 they give me a number of reasons as to why that is not  
14 so. But what I want to do is take a commitment on  
15 that. It is such an important question.

16 CHAIRMAN STETKAR: That's fair. Take it  
17 away.

18 MR. WEERAKKODY: I want to discuss with  
19 the staff and I want to give you written input,  
20 because we should get beyond that. If that is the  
21 case, then there's something wrong.

22 CHAIRMAN STETKAR: Well, that's -- yes.  
23 Okay.

24 MR. WEERAKKODY: And so I'm going to take  
25 a --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: And we'll certainly  
2 bring it up in December, you know, so that's a decent  
3 take-away. But it certainly is --

4 MR. WEERAKKODY: Yes.

5 CHAIRMAN STETKAR: You can't argue with  
6 actual observed operating experience. There can be  
7 differences of opinion over --

8 MR. WEERAKKODY: We should be able --

9 CHAIRMAN STETKAR: -- you know, an  
10 individual event, but not at the level at which we've  
11 heard this morning. You know, we're not talking about  
12 ten to the minus five events per year. We're talking  
13 about countable numbers of events if over nothing  
14 else, a decade.

15 MR. WEERAKKODY: No. Well, Donnie wants -  
16 - go ahead. And I'm going to ask the staff to answer.  
17 But if you don't get a satisfactory answer, I want to  
18 make sure that that point is well addressed.

19 CHAIRMAN STETKAR: Yes.

20 MR. WEERAKKODY: If not today, within a  
21 week or so.

22 MR. HARRISON: And I agree with Sunil.  
23 What we'll need to do though is get with the industry  
24 to actually get their calculation. Because I recall  
25 an ACRS subcommittee meeting many, many months ago;

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 maybe it was the last one or the one before on this  
2 topic, and someone asked a question about the  
3 frequency of fires and how many we should be seeing.  
4 And the question came back of, well, what's that  
5 include? Is it the self-extinguishing ones? And they  
6 said yes. And the person from the ACRS, if I recall  
7 right, said, well, that seems like a reasonable number  
8 then. It all depends on what's in the calculation.

9 CHAIRMAN STETKAR: That's why it's  
10 probably appropriate not to try to answer today  
11 because we want to make sure that we're counting eggs  
12 and eggs and we understand hat those eggs are. But if  
13 indeed you understand what they're counting and indeed  
14 there is a substantive basis for that, that means  
15 there's something wrong, you know, and that we need to  
16 understand what that is in terms of the PRA.

17 MR. WEERAKKODY: No, I fully agree. We  
18 have to get beyond that kind of argument in order  
19 to --

20 CHAIRMAN STETKAR: Because you're never  
21 going to solve that argument.

22 MR. WEERAKKODY: Yes.

23 CHAIRMAN STETKAR: And if there's not  
24 another standard at that level, you'll never be able  
25 to answer the question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WEERAKKODY: You've been very clear  
2 with respect to what you're trying to do. You want to  
3 basically get to a point where we understand the  
4 technical issues and come up with a way to solve them.

5 So I think the only statement that I really want to  
6 make is the last bullet there. We are very glad that  
7 EPRI research, and we have a lot of momentum behind  
8 us, to do research and address these issues. So  
9 that's all. You know, how we got to this point is not  
10 important to me because all of us are supportive of  
11 use of Fire PRA in the regulatory framework.

12 CHAIRMAN STETKAR: Thank you.

13 MR. WEERAKKODY: Any other questions for  
14 me?

15 CHAIRMAN STETKAR: Any of the other  
16 members have any questions?

17 (No audible response.)

18 CHAIRMAN STETKAR: With that, thanks a  
19 lot, Sunil.

20 We do have a presentation from Mardy  
21 Kazarians. While he's getting set up, I think I  
22 mentioned this morning; I don't remember whether Mardy  
23 was here when I talked about it, Mardy is a consultant  
24 to the committee. And his scope of work has been to -  
25 - I would characterize it as flying under the radar a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bit, although the radar picked him up pretty early, to  
2 go out and perform a fact finding first exercise for  
3 us whereby he went out and talked to practitioners  
4 primarily.

5 And I will be the first to admit that if I  
6 were a PRA practitioner and came to an ACRS  
7 subcommittee or an ACRS full committee meeting, what I  
8 said in this public forum with whoever the audience  
9 might be, could be a bit different than if I sat down  
10 over a glass of beer with somebody that I could speak  
11 to on a one to one technical basis in terms of the  
12 problems that I've been finding. So given that  
13 experience, that was one of the reasons why we set  
14 Mardy loose on a variety of stakeholders to see what  
15 information he could gather.

16 And then Mardy, as you're probably all  
17 well aware, is one of the most experienced and well-  
18 respected fire modeling people in the industry, so he  
19 has street credibility to talk to people also, which  
20 is important. And I will now let Mardy tell us what  
21 he's been up to.

22 MR. KAZARIANS: Okay. Well, I'm the  
23 oldest, I can say that. I don't know if I'm the most  
24 experienced one, but definitely I've been around for a  
25 long time. I was just thinking that maybe -- it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 interesting that we're still talking about the same  
2 topics as 30 years ago.

3 All right.

4 CHAIRMAN STETKAR: We haven't redone the  
5 same Fire PRAs three times though.

6 MR. KAZARIANS: Yes, that's true. I guess  
7 my presentation will be very anti-climactic for all  
8 the things we've heard and discussed this morning and  
9 this afternoon.

10 So this is basically my marching orders.  
11 Two questions: Are there limitations in current Fire  
12 PRA methods, models and the data that lead to  
13 inappropriate conclusions during the transition to  
14 NFPA 805? That's one, the key question. And also a  
15 side question which is, are there other issues  
16 impeding or discouraging the transition process? So  
17 those are the things that I'm after.

18 And as John put it, I'm gathering oral  
19 information mostly and some, you know, documents, as  
20 much as I can. So I have to say that this is not a  
21 very scientific process.

22 So I've been contacting a variety of  
23 stakeholders. And if I were to categorize them it  
24 would be people from the NRC staff, utilities  
25 themselves and the consultants; I do recognize the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 difference between the two of them, public  
2 stakeholders, and NIST, NEI and EPRI perhaps. Whoever  
3 would like to talk to me, I'll talk to them for sure.

4 So what I'm doing is I'm collecting information,  
5 organizing it and I will interpret it according to my  
6 understanding of the phenomenons and the models and so  
7 on.

8 This is a short list of some of the topics  
9 that I typically bring up with the people I talk to.  
10 First of all I would like to know their experience  
11 with the Fire PRA. You know, in other words for me to  
12 gauge what part of the Fire PRA they're experienced  
13 with, the type of involvement that they had,  
14 especially NFPA 805 transition- related. And the key  
15 question I ask all of them is the difficulties in  
16 applying the NUREG/CR 6850, including the FAQs  
17 obviously, and have they been forced into taking  
18 deviations from 6850 and FAQs? So those are one of  
19 the key topics that I dwell on and have a long  
20 discussion about it.

21 Then of course some of the things that I  
22 think in my opinion has some bearing on the overall  
23 picture is the information that is available to people  
24 who do the Fire PRA and how much before and after the  
25 start up of the Fire PRA, and especially cable

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information, circuit information. And also I was  
2 curious about the multiple spurious operations and if  
3 that had a huge impact on the level of effort. Then  
4 for me to gain some measure of where they are and  
5 whether the contributors -- and what are the issues  
6 actually is I talk with interviewees about the core  
7 damage frequency and CCDPs and the contributors. That  
8 gives me a good feel for, a relatively good feel for  
9 what the issues are.

10 And of course the peer review process is  
11 an integral part of this whole thing, so sometimes I  
12 go through that with them, especially those people who  
13 have been on the peer review panels and I get the peer  
14 reviewers' viewpoint on what they think of what  
15 they've seen.

16 CHAIRMAN STETKAR: How many, Mardy -- and  
17 I recognize that, you know, everyone that you've  
18 spoken with shall remain completely anonymous.

19 MR. KAZARIANS: Yes.

20 CHAIRMAN STETKAR: Can you give us an idea  
21 of approximately how many folks you've spoken with who  
22 have been on those peer reviews? I mean, is it two or  
23 three? Five?

24 MR. KAZARIANS: It's in that order.

25 CHAIRMAN STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KAZARIANS: Yes.

2 CHAIRMAN STETKAR: Okay.

3 MR. KAZARIANS: It's in that order, yes.

4 CHAIRMAN STETKAR: More than one, less  
5 than 100?

6 MR. KAZARIANS: Yes, actually here it is.

7 CHAIRMAN STETKAR: Oh?

8 MR. KAZARIANS: Okay. People that I've  
9 talked to. Consultants, utility people and NRC staff.

10 CHAIRMAN STETKAR: So out of the 10 from  
11 consultants and utilities there have been --

12 MR. KAZARIANS: Half of them probably were  
13 --

14 CHAIRMAN STETKAR: -- have participated in  
15 peer --

16 MR. KAZARIANS: Yes, because --

17 CHAIRMAN STETKAR: Okay. Good. Good.

18 MR. KAZARIANS: And there is a reason  
19 behind it, is because they're all senior people,  
20 they're well-experienced with Fire PRA, so they've  
21 been drawn into that process.

22 CHAIRMAN STETKAR: So in a sense if  
23 they've participated in peer reviews, they may have  
24 some experience broader than their own particular  
25 PRAs?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KAZARIANS: Yes. Yes.

2 CHAIRMAN STETKAR: Okay. Good.

3 MR. KAZARIANS: And I hear behind the  
4 scenes comments, which is fine for me, you know?

5 CHAIRMAN STETKAR: We all do.

6 MR. KAZARIANS: I'm planning to talk to a  
7 couple more people. There are a couple people I've  
8 missed so far and I need to definitely talk to them.  
9 And I'll be speaking in front of this panel in  
10 December and I'll be presenting my results at that  
11 time. All right?

12 CHAIRMAN STETKAR: Okay. Just for public  
13 disclosure, I've asked Mardy before the meeting; we  
14 haven't set a firm date yet, to at least give us a few  
15 -- you know, like a bullet hit list of some of the  
16 bigger issues that he's identified, you know, before  
17 we have his actual written report. The only reason  
18 for that is if there's anything on his preliminary  
19 list that might affect the content of what we're going  
20 to discuss in that subcommittee meeting in December, I  
21 want to make sure we're aware of it, that our staff is  
22 aware of it and we're able to communicate that to both  
23 NRC staff and the industry so that there aren't any  
24 surprises, at least in terms of, you know, potentially  
25 significant issues that might have been overlooked

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from some of the other discussions that we've had  
2 here.

3 And that's it? Any other questions for  
4 Mardy? Any questions for Mardy?

5 (No audible response.)

6 CHAIRMAN STETKAR: That's one of the  
7 benefits of having to sit up here all day is  
8 everybody's out of gas.

9 With that, I guess what I should do, I  
10 have absolutely no idea whether the bridge line is  
11 still open, so, John, could you find out whether it  
12 is?

13 And if it is, if there's anyone on there  
14 who would like to make any comments or add any  
15 information, I'd really appreciate hearing from you.  
16 And also I admire your stamina if you're out there.

17 We'll wait a couple of minutes until you  
18 confirm what's going on out there.

19 MR. LAI: Mr. Chairman, the line is still  
20 open.

21 CHAIRMAN STETKAR: It is still open?

22 MR. LAI: Yes.

23 CHAIRMAN STETKAR: Has it been unblocked?  
24 Can we get it unblocked?

25 MR. LAI: Yes, you can. You can talk,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 yes.

2 CHAIRMAN STETKAR: Okay. Now, it's the  
3 only way to find this out. If there's anyone out  
4 there listening, could you please just say something  
5 so that (a) we know you're alive; and (b) we know that  
6 indeed there's two-way communications possible? Just  
7 anybody.

8 (No audible response.)

9 CHAIRMAN STETKAR: Don't all speak up at  
10 once.

11 (No audible response.)

12 CHAIRMAN STETKAR: Hearing nothing, I'm  
13 going to assume that either there's people listening  
14 who don't feel necessary to add anything or indeed  
15 everybody has given up. So, we'll close the line back  
16 off again.

17 MR. LAI: From the public?

18 CHAIRMAN STETKAR: Is there any member of  
19 the public here who would like to say anything?

20 (No audible response.)

21 CHAIRMAN STETKAR: Thank you for reminding  
22 me. I always forget that.

23 Before we close what I would like to do  
24 is, I've been trying to keep a short hit list here of  
25 topics that I feel will warrant particular attention

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 during the December subcommittee meeting, because as I  
2 said in December I would like if possible to focus on  
3 the real thorny issues, if there are some. I think  
4 we've had, you know, excellent presentations and I've  
5 tried to distill a little bit of what I've heard from  
6 them. And the reason I'd like to mention this is to  
7 give forewarning to people and also to get feedback  
8 from you. If you think something else should be on  
9 the list, please let us know and we will make sure  
10 that it's on the list so that we can plan for it.

11 The five items that I've sort of listed  
12 here; and they're not necessarily in any prioritized  
13 order, just stream of consciousness, I'll combine the  
14 issue of electrical cabinet fires into a single issue  
15 at the moment, although there are probably several  
16 facets of that issue. One is the frequency of fire  
17 ignition as a function of cabinet type. Another is  
18 the data or models supporting the fire growth rate,  
19 the time to peak heat release rate within those  
20 cabinets. And also the absolute measured maximum heat  
21 release rate on a per cabinet basis.

22 The reason I'll put all of those together  
23 is that when you're thinking risk space, it's the  
24 integration of all of those things that we care about.

25 So however we want to address those, but the cabinet

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fires seem to be an issue and things again that I've  
2 heard peripherally, cabinet fires seem to be an  
3 important topic. If nothing else, you know, we saw  
4 the ridge line there.

5 Second one is; and I think I mentioned  
6 this earlier, there seemed to be some disagreement,  
7 and I'm not going to characterize it any more than  
8 that, over the degree to which the current status of  
9 the FAQs actually resolves technical issues that seem  
10 to be a concern to the industry. And I think I  
11 mentioned it earlier, what I'd like to really  
12 understand, if indeed there is that disagreement,  
13 which particular FAQs are the concern? Why are they  
14 of concern? Now if indeed we can get communications  
15 going; you know, I'd like to hear both sides of the  
16 story, but since the industry primarily raised the  
17 issue, you know, I need to hear from the industry to  
18 elaborate what that list is and what the real concerns  
19 are. Now, I don't know how long your list is. That's  
20 up to you.

21 The next three are less clear in my mind  
22 and that's why I think I'd like some input from all  
23 the participants here. One that I wrote down is are  
24 there still concerns about the methods and models for  
25 incipient fire detection? I don't know. There is an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 FAQ out there that provides a model. We heard that  
2 Shearon Harris used a different model that was deemed  
3 acceptable for the transition but not acceptable for  
4 any post-transition applications essentially. You  
5 know, so this gets into the issue of the fidelity of  
6 the PRA for uses other than simply transitioning to  
7 the risk-informed framework.

8 Is it worth in December to discuss  
9 anything about that issue or is there general  
10 agreement that it's not a very significant technical  
11 problem? I'll let you think about that. You know, I  
12 pretty much know the staff's response, so I'm looking  
13 at the industry to say is it worth addressing?

14 MR. BRADLEY: Yes.

15 CHAIRMAN STETKAR: Okay. I hear a yes.  
16 It's on the table.

17 I hate to say this, but I'll bring it up  
18 because it was mentioned a couple of times. Human  
19 reliability analysis. Is that a topic? And I'm  
20 honestly looking for input. I have my own opinion  
21 here, but --

22 MR. CHAPMAN: Put it on the list. I think  
23 only with regards to underestimating the time  
24 available to take an action with regard to time and  
25 damage.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: That's more of a fire  
2 modeling issue.

3 MR. CHAPMAN: I understand that.

4 CHAIRMAN STETKAR: Okay.

5 MR. CHAPMAN: I just wanted to --

6 CHAIRMAN STETKAR: What I don't want to do  
7 is drag this out into another discussion about how --  
8 you know, where is your unified field theory on human  
9 reliability analysis?

10 MR. CHAPMAN: Right.

11 CHAIRMAN STETKAR: Because that's a non-  
12 productive discussion.

13 MR. CANAVAN: Dennis isn't here, but I'll  
14 reiterate what he had said.

15 CHAIRMAN STETKAR: Yes, Ken, we are indeed  
16 still on the record. I haven't closed this out,  
17 because I want to make sure that all of this  
18 information is available for any other public  
19 stakeholders who might want to --

20 MR. CANAVAN: Ken Canavan, and I'm always  
21 very nervous doing this, because I'm actually speaking  
22 for Dennis Henneke who left, but I believe his issue  
23 was on control room abandonment.

24 CHAIRMAN STETKAR: Yes.

25 MR. CANAVAN: And he had certain concerns

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about the HRA around that.

2 CHAIRMAN STETKAR: If that's an issue. I  
3 mean, what we heard this morning was that to me seemed  
4 to be the only HRA issue, at least what Dennis  
5 highlighted. He seemed to indicate that it may not be  
6 necessarily a very significant across the board issue  
7 for overall risk, certainly not, you know, the ridge  
8 line of the cabinet fire significance, but --

9 MR. CANAVAN: Yes, he said 10 percent  
10 contributor on average.

11 CHAIRMAN STETKAR: Okay. If we want to  
12 discuss it, I'd like to keep it then in that context  
13 of control room abandonment.

14 MEMBER ABDEL-KHALIK: Is it HRA or safety  
15 culture?

16 CHAIRMAN STETKAR: No, it's HRA. It's  
17 HRA.

18 Jim, I think your issue is more toward the  
19 fire modeling and what's the available time versus  
20 required --

21 MR. CHAPMAN: Yes, but I just wanted to  
22 introduce it.

23 CHAIRMAN STETKAR: Yes. Thanks.

24 The last one that I had on my list, and  
25 this one is a bit hazy, is the presentations I heard

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this morning about, or it might have been early this  
2 afternoon about EPRI's research program, and certainly  
3 the presentations we heard this afternoon about the  
4 staff's research program, to me sounds like there's  
5 some communication but that it's not necessarily  
6 directly at the same purpose. The question basically  
7 would be what are EPRI's research priorities? You  
8 know, and we'll know those once we get something that  
9 is legible. I had to get the dig in. It's a small  
10 table.

11 PARTICIPANT: A picture of a small table.

12 CHAIRMAN STETKAR: It's a picture of a  
13 small table.

14 And you know, we have Memoranda of  
15 Understanding set up. If indeed the NRC's research  
16 program is not being responsive to the industry, (a)  
17 is that a problem? And I certainly can't answer that.

18 But if the industry is looking for the NRC, our staff  
19 to do a certain type of -- whether it's fire testing  
20 or fire model validation, or you know, you name it,  
21 and that's viewed as a significant source of  
22 uncertainty or conservatism, the lack of that  
23 information in the PRAs that are being produced today;  
24 not 10 years from now, but today, if the industry  
25 feels that that type of research is important today,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then you know, should it be performed, should it be  
2 given high priority in terms of NRC research? Again,  
3 ACRS does not set research priorities. We can't do  
4 that. And certainly we'll not try to do that. But  
5 it's important for us to understand if there is indeed  
6 a disconnect between things that an industry user says  
7 they need and things that the NRC research program is  
8 producing, I'd like to understand that.

9 So that's sort of a gray area, but it  
10 speaks to this notion of we need better data, we need  
11 better models, we need this, we need this, we need  
12 this. Who's going to supply it and when? You know,  
13 just saying that we want everything all the time from  
14 the other guys is not necessarily conducive to solving  
15 the overall problem. So I'll throw that out there.

16 Mark's got to come up and say something.

17 MR. SALLEY: Yes, I just wanted to touch  
18 on that. NEI at the last fire forum, one of the  
19 things we did, John, was we did a joint presentation  
20 like we do. I kind of asked basically for what you're  
21 saying is customer feedback.

22 CHAIRMAN STETKAR: Yes.

23 MR. SALLEY: And I opened it up to  
24 industry. Could we dig out the feedback forms that --  
25 we had Tom Gorman, if you remember, from PPL put that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 together, Tom? And if we could supply that. Tom  
2 Gorman from PPL came in and we basically asked him to  
3 do kind of a customer survey. You had a mixed  
4 audience of NRC and industry and we asked those  
5 questions. Tom had a form, you know, what are we  
6 doing that's right? What are we doing that's wrong?  
7 What are we doing that you need? What do you wish we  
8 were doing more of? What do you wish we were doing  
9 less of? So I believe we had that at that the last  
10 forum.

11 CHAIRMAN STETKAR: That would be --

12 MR. SALLEY: And that may help you.

13 CHAIRMAN STETKAR: Yes, if there was  
14 reasonable feedback on that, that might be useful.

15 MEMBER ABDEL-KHALIK: Well, I asked  
16 explicitly this morning or this afternoon as to  
17 whether or not you're doing any experiments as a part  
18 of this matrix that you presented, and you indicated  
19 no you're not. You're relying on NRC to produce that  
20 data. And listening to the research program this  
21 afternoon do you think that all the data that you need  
22 will actually be available?

23 PARTICIPANT: That's a good question.

24 MEMBER ABDEL-KHALIK: I didn't see the  
25 answer in the presentation.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: No, and I think it's  
2 something that's worth discussing on the table,  
3 because I have no idea honestly what our conclusions  
4 or recommendations might be. But one thing that I  
5 think might be useful, if indeed there are areas where  
6 the collected wisdom agrees are difficult technical  
7 areas that indeed, because of either individual  
8 sources of conservatism where this accumulated, you  
9 know, two-to-the-fourth-type of factor, they are  
10 driving the unrealism of current PRA results. Then  
11 you know, I think the Commission might appreciate the  
12 ACRS' recommendation about how does that get result,  
13 recognizing that we don't do anything on process. But  
14 I think we could say that we feel more research or  
15 experiments or testing in this particular area seems  
16 to be well-focused. You know, It's up to the  
17 collected world to figure out who does that and when,  
18 but at least saying that it might be an area where a  
19 certain type of testing or a certain type of modeling-  
20 type research might help. Right now, you know, I'm  
21 not sure I can identify that, but that might help.

22 Now with that, does anybody else have any  
23 good items to put on the agenda? Because the reason I  
24 want to go through this exercise obviously is the 13th  
25 and 14th of December are now less than a month away

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and people need time. You know, we have Thanksgiving  
2 and, you know, people have lives. So the more that we  
3 can settle on what should be on that agenda, the  
4 better it is for everyone.

5 MR. TRUE: Okay. This is Doug True. Two  
6 things that I think may deserve some discussion are  
7 manual suppression and control of fires. It kind of  
8 ties in with the growth rate and heat release rates,  
9 but it's an intervention by personnel. To prevent the  
10 growth of the fire is a significant area that we think  
11 needs some enhancement.

12 CHAIRMAN STETKAR: Let me see if I can  
13 understand a little more specificity. Is the issue  
14 more in the area of the fire analyses underestimating  
15 the amount of time that's available to perform those  
16 actions, or is it that the available information for  
17 the performance of those actions is inadequate?  
18 Follow me? In other words, am I looking at a fire  
19 modeling time window issue, time available to perform  
20 whatever it is, put out the fire or de-energize the  
21 circuit or whatever, or is it an issue that the  
22 information for the time required and the  
23 effectiveness of those activities is lacking?

24 MR. TRUE: I think it's the latter, but  
25 it's not that it's lacking. I think it's just we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 still think it's got a fair amount of conservatism.

2 CHAIRMAN STETKAR: Okay.

3 MR. TRUE: Having more realistic growth  
4 rates would give us more time, which would give us  
5 more credit. But for example, the curves are set  
6 based on experience. Well, anecdotally; this is not  
7 fair, but it gets my point across, there's one fire  
8 that lasted 90 minutes that never damaged anything  
9 because the operators or the fire brigade took the  
10 decision to control that fire rather than trying to  
11 extinguish it, for whatever reason.

12 CHAIRMAN STETKAR: Okay.

13 MR. TRUE: That's treated as it took 90  
14 minutes for us to do anything about it.

15 CHAIRMAN STETKAR: So your issue is on  
16 those curves on --

17 MR. TRUE: In fact made some progress on  
18 that, but we think there's more that could be done.  
19 We also think the data base will help us get more  
20 information to able to help support that also.

21 CHAIRMAN STETKAR: Okay.

22 MR. TRUE: The second thing, which is a  
23 segue from that, is the data base. I know you kind of  
24 lumped ignition frequencies and venting for electrical  
25 cabinets into one category. Earlier on I got the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 impression you'd like us to come and specifically talk  
2 about what's going on with the Fire Events Data Base  
3 and how we're going to handle the historical data and  
4 --

5 CHAIRMAN STETKAR: I think that's  
6 important. And I think you're right, I probably  
7 didn't mention that. And in that sense those types of  
8 generic issues I think are important.

9 MR. TRUE: Okay.

10 CHAIRMAN STETKAR: But again, I'm still  
11 trying to focus on if I'm doing a PRA today, what are  
12 the biggest issues that I'm struggling with? You  
13 know, why don't I necessarily believe the numerical  
14 results from my PRA, if that's the assertion? And  
15 what do I need, what tools or what data, what  
16 information do I need in a practical sense to make me  
17 at least believe the numbers better? I'm never going  
18 to believe them perfectly.

19 MR. TRUE: I don't believe internal is  
20 perfectly --

21 CHAIRMAN STETKAR: There you go. So, you  
22 know, when we start talking about data, we can talk  
23 all day about data obviously.

24 MR. TRUE: Right.

25 CHAIRMAN STETKAR: But, yes, I think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you're right there.

2 MR. TRUE: Just trying of give you and  
3 overview of that process.

4 CHAIRMAN STETKAR: Yes. Yes. Yes. Yes.  
5 Yes.

6 MR. TRUE: So, but I know you're looking  
7 for a short list. I know you're looking for a  
8 targeted list, but I --

9 CHAIRMAN STETKAR: No, we have two days  
10 and, you know, on our schedule we can consume the  
11 entire two-day period, or we can decide to quit at the  
12 middle of the morning on the first day. So I want to  
13 make sure that people walk away from the December  
14 subcommittee meeting, at whatever time that ends,  
15 saying that indeed everybody has had their opportunity  
16 to provide technical input to us and don't feel that  
17 there are lingering, you know, trails that need to be  
18 followed up on. Because quite honestly, we as a  
19 committee don't have the time to follow up on those.

20 MR. TRUE: I understand that, but in the  
21 context of your saying that as a PRA analyst, you  
22 know, what things do I need to know, and I just can't  
23 leave this conversation without having said it really  
24 depends which one of those rows in that chart you're  
25 on. Because once you've addressed electrical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cabinets, which I believe we can probably make  
2 progress on, you're going to rapidly run into  
3 something else you don't believe. And the diesel  
4 generator blip on there is one good example of that.

5 And so I realize you can't tackle the  
6 world, but it really is a plant-specific challenge and  
7 we can't just narrowly focus on a couple of things.  
8 They may be symptomatic of other problems, but I don't  
9 think we're going to resolve it with just focusing for  
10 example on electrical cabinets.

11 CHAIRMAN STETKAR: That's a good point and  
12 I think we're all aware that these -- first of all,  
13 regardless of that ridge line there, the most  
14 important contributors and the amount of effort to  
15 address those certainly as you go through this  
16 iterative process do vary from plant to plant.

17 At the first cut I'm obviously trying to  
18 keep us focused on what are the big-ticket issues,  
19 because those are being thrown up as a major  
20 impediment to this whole transition process. And  
21 obviously once you dynamite the biggest boulders, the  
22 next larger rocks show up, you know, and finally get  
23 to the pebbles. On internal events risk assessment,  
24 we tend to say, well fine, if we get to the point  
25 where we have 100 one percent equal contributors, it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not worth blowing up another pebble. You know, if you  
2 have five 20 percent contributors, it might be worth  
3 bring out a little bit of dynamite.

4 We talked about cabinet fires. You  
5 mentioned diesel fires. If there are one or two or  
6 three other ones that in your experience looking at,  
7 you know, what you've seen done so far, that merit  
8 additional discussion, then that's probably a good  
9 idea. I don't want to dredge it out into sort of the  
10 esoteric thing that, yes, eventually we're going to  
11 get to, you know --

12 MR. TRUE: Right.

13 CHAIRMAN STETKAR: -- 15 seven percent  
14 contributors and after that we're going to have, you  
15 know, 40 two-and-a-half percent contributors.

16 MR. TRUE: Okay. We'll try get to you  
17 quickly a list of those other bins.

18 CHAIRMAN STETKAR: Okay.

19 MR. TRUE: And some of the issues related  
20 to that.

21 CHAIRMAN STETKAR: Okay. Good. Good.

22 Anything else?

23 MR. WEERAKKODY: I had just one thing to  
24 say. I took notes on the five issues you mentioned.  
25 We are going to sit down with John Lai either Thursday

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or Friday because what I want to make sure is that we  
2 take these issues, turn them into some actionable  
3 items for the staff and make sure we give you what you  
4 need as soon as possible. Because like you said,  
5 December 14th is the next subcommittee meeting.

6 CHAIRMAN STETKAR: Thirteenth.

7 MR. WEERAKKODY: No, I won't be here  
8 because --

9 CHAIRMAN STETKAR: That's okay. You guys  
10 can work out --

11 MR. WEERAKKODY: Yes, we'll work it out.

12 CHAIRMAN STETKAR: -- who to talk to when  
13 once we're off line.

14 Anything else as far as topics that we  
15 need to think about? I mean, things may come up in  
16 the interim. I just want to make sure that nobody  
17 says, well gee, I was blindsided or surprised by this  
18 issue.

19 (No audible response.)

20 CHAIRMAN STETKAR: As I mentioned, Mardy  
21 Kazarians has indicated that he will give us a  
22 preliminary kind of hit list from his activities. If  
23 something else comes up from his activity that is in  
24 addition to what we just discussed, we'll make sure  
25 through John Lai that that's transmitted to all of you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 interested parties here so again that there isn't any  
2 surprise there.

3 Anything else? Questions?

4 (No audible response.)

5 CHAIRMAN STETKAR: I thank you all very,  
6 very, very much. I think that this was I think a  
7 very, very useful discussion. I appreciate all of the  
8 effort that industry and the staff put into their  
9 presentations. I think I certainly learned a lot and  
10 I think it's very, very helpful. So I thank you all  
11 for your presentations.

12 And with that, we are adjourned.

13 (Whereupon, the meeting was adjourned at  
14 6:07 p.m.)

15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

# **Fire PRA Impacts to NPFA 805 Transitions**

**ACRS Reliability and  
PRA Subcommittee Meeting**

**November 16, 2010**

**Biff Bradley, NEI**

**[reb@nei.org](mailto:reb@nei.org)**



NUCLEAR  
ENERGY  
INSTITUTE

# Overview of Industry Presentations

- **NEI - Fire PRA issues impacting NFPA 805 (Bradley)**
- **EPRI Perspectives (Canavan)**
- **Insights from Industry FPRAs (Chapman/True)**
- **Important Technical Areas (True)**
- **EPRI Fire PRA Action Matrix (Wachowiak)**
- **NEI - non PRA issues impacting NFPA 805 (Basso)**

# Background

- **Industry very supportive of achieving closure of fire protection issues**
  - **Goal: Achieve stable regulatory state**
- **Adoption of 50.48(c) is a major undertaking**
  - **Nearly half of the industry well on their way**
- **A number of important process and technical issues persist**

# Realism of Fire PRAs

- **NEI first identified lack of realism in January 2008**
  - Letter to NRC staff outlining specific technical concerns, requesting collaboration on resolution
- **FAQ process for Fire PRA**
  - Over two years, some technical progress made, but process was slow and ineffective in achieving realism, even for the topics addressed
  - By late 2009, industry stopped submitting FPRA-related FAQs

## **Realism in Fire PRAs (Cont.)**

- **In December 2009, NEI notified the Commission of industry's continued concerns and initiation of EPRI FPRA Action Matrix**
- **Industry committed to improving FPRA methods for use in risk-informed decision-making in NFPA-805 and other risk-informed applications**

# Key FPRA Concerns

- **Major concerns to be illuminated today:**
  - **The manner in which fires are characterized does not appear to conform with operating experience,**
  - **The level of quantified risk using current methods appears to be overstated, as compared to operating experience, and**
  - **Uneven level of conservatism may mask key risk insights and confound decision-making**

# Implications for Submittals

- **The Enforcement Discretion timeline for 50.48(c) submittals does not support resolution of all FPRA technical issues**
  - Large number of licensees submittals due 6 months after 2<sup>nd</sup> pilot SER
  - Current process would require re-submittal of LAR with new information
  - Changing FPRA basis not conducive to stable regulatory condition
- **Industry November 15 letter to NRC requests consideration of staggered submittal schedule; however this alone does not provide sufficient time to address FPRA issues**



**EPRI**

ELECTRIC POWER  
RESEARCH INSTITUTE

## **EPRI Perspectives on Current Fire PRA Methods**

**Ken Canavan**  
Director, Plant Technology

**ACRS PRASC**  
November 16, 2010

# Background on EPRI 1011989-NUREG/CR-6850

- FPRA methodology developed jointly between EPRI and NRC RES
- Landmark study that reset the standards for fire PRA
  - Succeeded in providing a standard framework for FPRA
  - Provided consistency in many inputs, missing in IPEEE-era FPRAs
- Development process included piloting activities
  - Failed to obtain industry support for a full pilot
  - Individual tasks tested instead

# The Fire PRA Challenge

- Fire PRA is a complex analysis
- IPEEE methods were inconsistent, relied on judgment, and were focused on identifying vulnerabilities
- NUREG/CR-6850 aimed to address this by
  - Defining discrete tasks
  - Applying simplifications in boundary conditions, e.g.,:
    - Fire events binned
    - HRRs binned
    - Suppression/control binned
  - Bounding assumptions employed on bins

# EPRI Perspective on FPRA related FAQs

- A total of 15 FPRA-related FAQs processed
- EPRI 1019259/NUREG/CR-6850, Supplement 1 published
- Each FAQ improved the understanding of the technical issues involved in the scope of the FAQ. (Most resulted in risk reductions)
- FAQ process slow and ineffective in establishing realistic FPRA methods

***Published FAQs are interim solutions on a handful of technical issues.***

***Much more work to be done.***

# Implications

- Original method simplifications and conservatisms
  - Expeditious
  - Erode the level of realism in the analysis
- EPRI 1011989/NUREG/CR-6850 methods were not piloted in an integrated manner
- Integrated implications of the simplifications and conservatisms were not known until the NFPA-805 pilots and a few other FPRAs progressed to quantification (late 2007)

# Implications

- Getting realistic risk results and insights will require additional refinement to the methods

***This should not be surprising  
for a fledgling method***

- EPRI committed to supporting methods enhancement



**EPR**I

ELECTRIC POWER  
RESEARCH INSTITUTE



## Insights from Industry Fire PRAs



**Jim Chapman, Scientech**  
**Doug True, ERIN Engineering & Research**



**ACRS PRASC**  
November 16, 2010

# Purpose

- Provide insights from industry PRAs performed using NUREG/CR-6850 with FAQs that support industry's claims that :
  - The manner in which fires are characterized in NUREG/CR-6850 does not appear to conform with operating experience,
  - The level of quantified risk appears to be overstated, as compared to operating experience, and
  - The uneven level of conservatism may mask key risk insights and confound decision-making

# Background

- Basic methodology for constructing a fire scenario:
  - Individual ignition source bins assigned a plant-wide frequency derived from industry operating experience
    - e.g., pumps, electrical cabinets, transient sources, diesel generators, etc.
  - Ignition frequency for a specific source based on an allocation process
  - Fire growth rates are assigned to bin
  - Fire peak heat release rate distributions are assigned to bin
  - Credit for manual suppression based on broad class of fire (i.e., electrical, oil, welding, transients, etc.)
  - Fire modeling defines damage footprint (i.e., zone of influence)
  - Damage translated into PRA model for computation of conditional core damage probability (CCDP)

# Computation of Fire CDF

- In the simplest form, the risk from an individual fire scenario is a function of:
  - The frequency of the fire event ( $F_{\text{fire}}$ )
  - The fire severity characteristics as a function of time ( $S(t)$ )
  - The probability of suppressing the fire event as a function of time ( $\text{NSP}(t)$ )
  - The conditional core damage probability given the damage caused by the postulated fire ( $\text{CCDP}_{\text{damage}}$ )


$$\text{Scenario CDF} = f(F_{\text{fire}}, S(t)_{\text{fire}}, \text{NSP}(t), \text{CCDP}_{\text{damage}})$$

# Computation of Fire CDF (Cont.)

$$\text{Scenario CDF} = f(F_{\text{fire}}, S(t)_{\text{fire}}, \text{NSP}(t), \text{CCDP}_{\text{damage}})$$

- Conservatism exists in each of these components
  - Some fire frequencies overstated
  - Fire severities overstated
  - Suppression under-credited
  - Resulting CCDPs overstated
- No single factor causing the unrealistic results
- Results are very scenario specific, i.e., plant, location, ignition source

# Fire CDF Contribution by Ignition Source



***Electrical cabinets generally important, but other sources can be important on a plant-specific basis***

# Conformance with Operating Experience

- Use of ignition source bins is a useful simplification, but has led to the introduction of conservatisms that lead to
  - Departure from operating experience
  - Overstatement of the consequences for the assigned frequency
- Walkthrough a simple example:
  - Diesel generator fires


# Example: Diesel Generator Fires

- Ignition Source: Bin 8 – Diesel Generator Fires
  - Applies to Diesel Generator Rooms
  - Bin 8 Plant-wide Frequency
    - Original Frequency =  $2.1\text{E-}2/\text{yr}$  (based on 49.5 events)
      - 60 actual events
        - 39 events fully counted
        - 21 events counted as “Indeterminate” with weight of 0.5
    - FAQ-048 Updated =  $5.04\text{E-}3/\text{yr}$  (based on EPRI report)
      - 53 of the 60 fires occurred prior to 1990

# Example: Diesel Generator Fires (Cont.)

- Plant-wide Frequency of  $5E-3$ /yr allocated:
  - Plant with 2 diesels, Frequency  $\sim 2.5E-3$ /diesel-yr
  - Plant with 4 diesels, Frequency  $\sim 1.3E-3$ /diesel-yr
- Characterization of diesel fires based on events:
  - 16% electrical fires
  - 84% oil fires
  - Electrical fires characterized by electrical components identified in inventory
  - Oil fires characterized by distribution
    - 2% of oil fires involve 100% of oil inventory
    - 98% of fires involve 10% of oil inventory
    - HRR computed based on spread of oil

# Operating Experience: Diesel Generator “Oil Fires”



***Assumed HRR  
does not align  
with this  
experience***

# Conformance with Operating Experience: Diesel Generator Fires

- FAQ-048 resulted in significant decrease in ignition frequency
- Allocation of plant-wide frequency can distort results
  - Plant with more diesels has lower per room frequency
- Oil fire HRR not consistent with actual fires
  - Most actual fires very localized, not spills of oil
  - None of the actual fires involve 10% of total oil inventory
  - Assumed HRR likely results in full room damage, unless automatic suppression is available
  - Most fires did not even involve actuation of automatic suppression
- A review of events indicates that plant shutdown was not required in many cases
  - All FPRA fires assumed to lead to plant shutdown

***Severity of assumed fires significantly overstated versus operating experience***

# Conformance with Operating Experience: Spurious Operations

- Addressing spurious operations is an important element of a comprehensive FPRA
  - Essential part of 50.48(c)
- Operating experience has not indicated spurious operations have occurred in real fire events (except Browns Ferry)
- Investigation of FPRA results shows over-prediction of spurious operations
- Sampling of PRAs investigated to compute the predicted frequency of one or more spurious operations

# Conformance with Operating Experience: Spurious Operations (Cont.)

- FPRA focuses on computation of CDF
- However, the FPRA model scenarios include spurious operations (SOs) caused by assumed fires
- Fire scenario damage “vectors” identify those with one or more SOs
- Plant-wide SO frequency (one or more SOs):  
$$\sum \text{Frequency of Scenarios involving one or more SOs}$$
- Results:
  - Plant X: 0.0041/yr
  - Plant Y: 0.0043/yr
- If extrapolated to entire U.S. industry (100 plants):
  - Expect to see a fire involving SO every 2 or 3 years
- None observed since Browns Ferry fire in 1975

***Likelihood of spurious operations significantly overstated in FPRAs versus operating experience***

# Over-Prediction of Fire Risk

- Difficult to use CDF values for comparison with industry performance
- However, it is straightforward to identify scenarios involving a high conditional core damage probability (CCDP) for comparison to industry experience
- CCDPs are routinely assessed by:
  - NRC's Accident Sequence Precursor (ASP) Program
  - Reactor Oversight Process (ROP)
- Approach:
  - Review set of representative FPRAs to identify the frequency of fires involving high CCDPs

# Over-Prediction of Fire Risk: Industry Experience with Fire CCDPs (Cont.)

- ASP Program
  - Maintains a list of “significant precursor” events
    - $CCDP \geq 1E-3$
  - Trends high CCDP events
    - $CCDP \geq 1E-4$
- “Significant precursor” events are relatively rare in recent operating experience:
  - No “significant precursor” events have occurred in the industry since 2002
- Of the 34 “significant precursor” events, only one involves a fire (1975 Browns Ferry)

# FPRA Model Prediction of High CCDP Damage Conditions

FPRA Model	Predicted Frequency of “Significant Precursor” Events (CCDP > 1E-3)	Predicted Frequency of High CCDP Events (CCDP > 1E-4)
Plant A	1.0E-3/yr	1.0E-2/yr
Plant B	9.9E-3/yr	2.0E-2/yr
Plant C	3.3E-3/yr	1.4E-2/yr
Plant D	1.3E-3/yr	3.2E-2/yr
Plant E	4.7E-3/yr	3.2E-2/yr
Range	1.0E-3/yr to 9.9E-3/yr	1.0E-2/yr to 3.2E-2/yr
Industry-wide Recurrence Interval	Every 1 to 10 yrs	1 to 3 <u>per year</u>
Actual Experience	None since Browns Ferry (1975)	None from 2001-2009 based on SECY-10-0125

# SECY 10-0125 Results for CCDP >1E-4




Figure 2. Precursors with High Safety Significance.

- Total of 8 events
- None involved fires
- FPRAs would have predicted ~9 to ~30 fire events, industry-wide for same period

***FPRAs prediction of high CCDP conditions does not comport with actual operating experience***

# ROP Experience

- ROP routinely evaluates CCDP of events and conditions
  - Based on actual plant condition
- ROP Criteria:
  - Green: CDP/CCDP  $< 1E-6$
  - White: CDP/CCDP  $1E-6$  to  $1E-5$
  - Yellow: CDP/CCDP  $1E-5$  to  $1E-4$
  - Red: CDP/CCDP  $>1E-4$
- To date, no actual fire events have been considered Red or Yellow (CCDP  $>1E-5$ )
- Fire PRA models would have predicted many each year across the industry


# Over-Prediction of Fire Risk: Conclusions

- Evidence that FPRA methods are significantly over-predicting the frequency of:
  - Spurious Operations
  - High CCDF conditionsas compared to actual industry experience
- This directly contributes to the over-prediction of computed Fire CDF

# Masking of Risk Insights

- PRA Policy Statement says:
  - PRA evaluations in support of regulatory decisions should be as realistic as practicable and appropriate supporting data should be publicly available for review*
- One of the reasons realism is important is to minimize the potential to mask important insights
  - Realism particularly important for significant contributors
- Likelihood conservatisms have different implications than damage conservatisms

# Baseline Risk from Differing ZOIs



## Plant Baseline Risk


$$CDF_A = \text{Freq}(S_i) * CCDP_A (\text{Sys1, Sys2 failed})$$

$$CDF_B = \text{Freq}(S_i) * CCDP_B (\text{Sys1 Only failed})$$

$$CCDP_A (\text{Sys1, Sys2 failed}) \gg CCDP_B (\text{Sys1 Only failed})$$

$$CDF_A \gg CDF_B$$

# Conditional Risk from Differing ZOIs



## Case with 'System 2' Out of Service

$$CDF_{A2} = CDF_A = \text{Freq}(S_i) * CCDP_A (\text{Sys1, Sys2 failed})$$

$$CDF_{B2} = \text{Freq}(S_i) * CCDP_{B2} (\text{Sys1, Sys2 failed})$$

$$CCDP_A = CCDP_{B2}$$

$$CDF_{A2} = CDF_A = CDF_{B2}$$

**ZOI A = No Change in Risk**

**ZOI B = Potentially Significant  
Change in Risk**

***Conservatism biases the baseline results high, but can lead to understated deltas***

# Summary

- Simplifications/bounding assumptions driving the results
- Problem is compounded conservatisms: No simple fix
- Computed risks don't comport with risk experience (CCDP/ASP)
- Prediction of spurious operations inconsistent with operating experience
- Conservatisms can confound good risk-informed decision-making (805 & beyond)



**EPRI**

ELECTRIC POWER  
RESEARCH INSTITUTE

## Roadmap For Attaining Realism In Fire PRAs

**Doug True, ERIN Engineering & Research**


**ACRS PRASC**

November 16, 2010

# Purpose

- Develop a report that uses insights from industry fire PRAs to identify the important areas of EPRI 1019189/ NUREG/CR-6850 where bounding assumptions/ simplifications are unduly influencing FPRA results
- Report Objectives:
  - Identify key areas needing additional realism
  - Illuminate causes
  - Identify and organize a set of reasonable near-term research activities (next ~3 years)
  - Inform & update the EPRI FPRA Action Matrix

# FPRA Issues Framework



# Category 1: Fire Initiation, Detection, Suppression

## Areas In Need of Additional Realism:

- Fire Event Data Characterization
  - Fire Events Database
  - Fire Ignition Frequency
- Fire Severity Characterization
  - Incipient Fire Growth in Electrical Cabinets
  - Oil Fire Severity
- Incipient Detection
  - Credit for Incipient Detection
- Fire Suppression & Control
  - Credit for Fire Suppression & Control

# Fire Event Data Characterization


- Fire Events Database
  - The events in the current FEDB do not align well with the manner in which they are used.
    - Assumptions are used to make links that could be supported by data
  - The current FEDB only includes data through 2000
  - The current FEDB relies on weak event descriptions and a less than traceable categorization scheme
  - Risk-informed, Performance-based Fire Protection will require a long-term fire event data collection & analysis program

# Fire Event Data Characterization

- Fire Ignition Frequency
  - Current approach to component-based ignition frequencies relies upon an allocation technique rather than component-specific ignition frequencies
  - Current approach to the calculation of ignition frequencies is simplistic, does not comport with current data analysis techniques, and does not account well for plant-to-plant variability
  - Treatment of transient ignition frequencies does not address administrative controls
    - No credit for control of transient combustibles

# Inventory of Electrical Cabinets (Bin 15)

Relative Frequency  
Per Cabinet




\* Draft information (unverified)

© 2010 Electric Power Research Institute, Inc. All rights reserved.

# Inventory of HEAF Sources > 1000V (Bin 16b)

Relative Frequency  
Per Source




\* Draft information (unverified)

© 2010 Electric Power Research Institute, Inc. All rights reserved.

# Plant-wide Inventory of Pumps (Bin 21)


Relative Frequency  
Per Pump



\* Draft information (unverified)

© 2010 Electric Power Research Institute, Inc. All rights reserved.

# Plant-wide Inventory of Air Compressors (Bin 9)



\* Draft information (unverified)

© 2010 Electric Power Research Institute, Inc. All rights reserved.

# Database & Ignition Frequencies

- Implications for FPRA
  - Current FAQ requires reliance on old data
  - Current database has non-negligible frequency contribution from “indeterminate” events
  - All fire events treated as entering the  $t^2$  growth phase
    - Experience does not support this


***Could easily overstate likelihood of true fires by a factor of 2-5 for key bins***

***Insights from enhanced database will provide valuable input to other tasks***

# Fire Severity Characterization

- Incipient Fire Growth in Electrical Cabinets
  - Events from Fire Events Database (FEDB) are treated as in the  $t^2$  growth phase even though vast majority are suppressed or controlled before external damage occurs
- Oil Fire Severity
  - Treatment of oil fires severity is simplistic and over-predicts fire severity vs. events in current FEDB
  - FAQ-44 adjusted treatment for MFW pump oil fires, but other components need a similar update:
    - Pumps
    - Transformers
    - Diesel generators

# FPRA Issues Framework



# Category 2: Fire Damage Assessment

## Areas In Need of Additional Realism :

- Fire Growth Assumptions
  - Fire growth and comparison with data
- Peak Heat Release Rates
  - Electrical cabinet peak heat release rate (HRR)
  - Transient Ignition Source HRR
  - Hot Work HRR
  - Other HRRs
- Damage Assessment
  - Switchgear High Energy Arcing Faults
  - Bus Duct High Energy Arcing Faults
  - Damage to Sensitive Electronic Equipment
- Fire Propagation
  - Electrical cabinet propagation
- Fire Modeling
  - Fire Modeling Guidance

# Fire Growth Assumptions

- Fire growth and comparison with data
  - The treatment of electrical fire growth rates is very coarse and does not address condition-specific factors
    - Ventilation-limited conditions
- Fires in the database do not appear to evolve in the  $t^2$  development phase for some time
- Current assumptions has artificially assigned fire growth rates
  - e.g., 12 minute fire growth timing for electrical cabinets
- Artificially limits benefit of intervention actions
- Improved database should provide better basis for fire growth assumptions

# NUREG/CR-4527

- Primary basis for 12 minute fire growth rate assumption
- To ignite cables, utilized ignition source comprised of a polyethylene bucket containing:
  - 1 quart of acetone
  - 1 lb of kimwipes
- Flame height of ~3ft
- Duration of source burn ~35 min
  
- Source insufficient to sustain burn unless cable bundles were physically separated

# NUREG/CR-4527 – HRR of ignition source only




Figure 6. Heat Release Rate for the Transient Ignition Source; Screening Test #5

# NUREG/CR-4527 – Screening Test Results




Figure 8. Heat Release Rate Plots for Scoping Tests #1 through 5

# NUREG/CR-4527 Scoping Test Results

Test # <sup>a</sup>	Cable Type	Amount of In Situ Fuels (KJ) <sup>b,c</sup>	Cabinet <sup>d</sup> Ventilation Method	Peak HRR (KW)	Intense Burn Duration (min)	Test Result
ST1	Q	117,000	No doors	24	15	Bundle did not burn
ST2	Q	117,000	No doors	27	17	No propagation
ST3	Q	117,000	No doors	77	18	Entire bundle consumed
ST4	Q	117,000	No doors	82	17	Almost entire bundle consumed
ST5	UQ	117,000	No doors	132	17	Entire bundle consumed
ST6	Q	348,500	No doors	82	25	No propagation
ST7	Q	348,500	Doors closed	95	25	No propagation
ST8	Q	582,875	Doors closed	93	30	No propagation
ST9 barriers	Q	234,990	Doors open	74	20	No propagation
ST10	UQ	611,530	Doors closed	280	30	Propagated All burned
ST11	UQ	611,530	Door open	506	20	Propagated All burned

No significant damage

# NUREG/CR-4527 – “Preliminary Cabinet Tests”

Table 4

Matrix of Preliminary Cabinet Tests

TEST #	IGNITION FUEL	CABINET		IN SITU FUEL	
		TYPE	VENTILATION	TYPE	AMOUNT (KJ) [BTU]
PCT 1	Transient	Vertical	Vent Grills on Doors	UQ	$7.283 \times 10^5$ [ $6.90 \times 10^5$ ]
PCT 2	Transient	Vertical	Doors Open	UQ	$1.051 \times 10^6$ [ $1 \times 10^6$ ]
PCT 3	Transient	Vertical	Doors Open	Q	$1.055 \times 10^6$ [ $1 \times 10^6$ ]
PCT 4	Heptane	Vertical	Doors Open	Heptane	$56.78 \text{ l}$ ( $.929 \text{ m}^2 \text{ pan}$ ) [ $15 \text{ gal}$ ( $10 \text{ ft}^2 \text{ pan}$ )]
PCT 5	Electrical	Benchboard	Door Open Front Grill	UQ	$1.519 \times 10^6$ [ $1.44 \times 10^6$ ]
PCT 6	Transient	Benchboard	Door Open Front Grill	Q	$1.551 \times 10^6$ [ $1.47 \times 10^6$ ]

# Fire Growth Rate Data – Electrical Cabinets

Test	Time to Peak	Steady Burning	Time to Decay	Ignition Source	Cable	Ventilation
ST1	7	8	15	Transient	Qualified	Open
ST2	6	11	17	Transient	Qualified	Open
ST3	10	8	18	Transient	Qualified	Open
ST4	14	3	17	Transient	Qualified	Open
ST5	8	9	17	Transient	Unqualified	Open
ST6	8	17	25	Transient	Qualified	Open
ST7	18	7	25	Transient	Qualified	Closed
ST8	10	20	30	Transient	Qualified	Closed
ST9	10	10	20	Transient	Qualified	Open
ST10	10	20	30	Transient	Unqualified	Closed
ST11	18	2	20	Transient	Unqualified	Open
PCT1	11	10	21	Transient	Unqualified	Closed
PCT2	12	2	14	Transient	Unqualified	Open
PCT3	13	14	27	Transient	Qualified	Open
PCT4a	16	0	16	Heptane Pool	Unqualified	Open
PCT4c	16	0	16	Heptane Pool	Unqualified	Open
PCT5	17	0	17	Electrical	Unqualified	Open
PCT6	11	0	11	Transient	Qualified	Open
Test 21	4	14	18	Gas Burner	Unqualified	Open
Test 22	9	2	11	Gas Burner	Unqualified	Open
Test 23	10	0	10	Transient	Qualified	Open
Test 24	12	0	12	Electrical	Qualified	Open
<b>Average</b>	<b>11.4</b>	<b>7.1</b>	<b>19</b>			

# NUREG/CR-4527 – Scoping Test Conclusions

- “A number of conclusions can be made as a result of the Scoping Tasks that give insight into cabinet fire development and input into the Preliminary Cabinet Tests. The conclusions are as follows:
  - There is a “critical” amount of “ignition source fuel” that is necessary to ignite a cable bundle, particularly qualified cable.
  - Qualified cable fires (with the selected cable and ignition source) in vertical cabinets do not spread throughout the cabinet.
  - Unqualified cable in vertical cabinets will easily ignite (with the selected ignition source) and propagate a fire in a single cabinet.
  - Burning rate (as measured by the HRR) is affected by the ventilation method (i.e., closed or open cabinet door) in tests using unqualified cable. Closed cabinet doors appear to result in higher cabinet temperature but also cause oxygen deprivation that appears to limit the burning rate.
  - Smoke obscuration in the test enclosure occurs within eight minutes in unqualified cable cabinet fires in the configurations tested.
  - The thermal environment in the enclosure does not become severe enough to cause melting of components or result in flashover.
- Furthermore, an important observation made during the tests was that when comparing the test cabinets loaded with in situ fuel (loadings are based on survey information) to pictures of actual nuclear power plant cabinets, the fuel load appears to be small. As a result of the Scoping Tests, it appears that cabinet fires with qualified cable do not propagate significantly. However, cabinet fires with unqualified cable may be a real threat to the safety of a nuclear power plant, from the standpoint of fire spread, and control room habitability, given the “critical” conditions and configurations.”

# Ramifications for FPRA

- Simplification in NUREG/CR-6850 leads to potential overstatement of fire growth rate and heat release rate (HRR):
  - Tests designed to cause damage
  - All fires treated as if propagation is possible
  - Fire growth rate set by “transient” ignition source (acetone & kimwipes)
  - Included tests with 10-15 gal of heptane as ignition source
  - Most tests were with open or no doors
  - Many tests were with unqualified cables
  - Benchboard and vertical cabinets treated the same

# Ramifications for FPRA (Cont.)

- Damage rate and damage potential appears overstated
- Short time reduces potential for intervention by plant personnel, e.g., operations or brigade
- Needs to be informed by better experience data & more mechanistic treatment of cabinet parameters, e.g., ventilation limited fires

***Could easily overstate likelihood of fully involved fire by a factor of 2-5***

# Peak Heat Release Rates – Electrical Cabinets

- Electrical cabinet peak heat release rate (HRR)
  - HRRs for electrical cabinets are binned very simply
  - Mix and match of test results to assign peak HRRs
  - Assignment of distribution appears to have little connection to experience
  - Expert judgment inscrutable – does not meet PRA Standard requirements
- Simplified scheme for designating peak HRR
  - Qualified/unqualified & number of bundles
  - Ignores ventilation limited cases
  - Applies test results that may not be applicable

# Peak Heat Release Rates – Electrical Cabinets (Cont.)

- Major contributor to all current FPRAs
- Not aligned with actual operating experience
- Overstates effects of fires
- Has potential to confound risk-informed decision-making:
  - Assumption of damage that may not occur is not always “conservative”
    - Could mask risk increases from plant changes/ conditions, out-of-service equipment, etc.

***Could lead to identification of wrong dominant contributors and misguided decision-making***

# Fixed Ignition Source HRRs

Tests of Cabinets  
with Unqualified Cables

Average of Benchboard  
Tests with Open Doors

Table G-1  
Recommended HRR Values for Electrical Fires

Ignition Source	HRR kW (Btu/s)		Gamma Distribution	
	75th	98th	$\alpha$	$\beta$
Vertical cabinets with <u>qualified cable</u> , fire limited to one cable bundle	69 <sup>1</sup> (65)	211 (200)	0.84 (0.83)	59.3 (56.6)
Vertical cabinets with <u>qualified cable</u> , fire in more than one cable bundle	211 (200)	702 (665)	0.7 (0.7)	216 (204)
Vertical cabinets with unqualified cable, fire limited to one cable bundle	90 <sup>4</sup> (85)	211 <sup>2</sup> (200)	1.6 (1.6)	41.5 (39.5)
Vertical cabinets with unqualified cable, fire in more than one cable bundle closed doors	232 <sup>5</sup> (220)	464 <sup>6</sup> (440)	2.6 (2.6)	67.8 (64.3)
Vertical cabinets with unqualified cable, fire in more than one cable bundle open doors	232 <sup>5</sup> (220)	1002 <sup>7</sup> (950)	0.46 (0.45)	386 (366)

# Peak Heat Release Rates - Transient Ignition Sources

- Transient ignition sources, e.g., Bins 7, 25, 37
- Source peak HRR data from tests performed on trash bags
- FEDB events are primarily events involving transient ignition sources:
  - Space heaters, extension cords, scaffolding, etc.
  - Only one FEDB event involved a trash receptacle

***Overstatement of threat from transient combustibles could skew results and mask important contributors***

***Quantitative impact on PRA is very plant/scenario-specific, but could be significant***

# Peak Heat Release Rates – Hot Work

- Majority of events in FEDB are pre-Appendix R
- New FEDB needs to inform with the type of events that actually occur
- HRR should be tied to the types of hot work that has involved fires, rather than an arbitrary HRR from a transient source

# Peak Heat Release Rates – Other Sources

- As other refinements are made to FPRA methods, it is expected that additional simplifications/assumptions on peak HRRs will be identified for improvement
- One example involves electrical fires from pumps and fans
- NUREG/CR-6850, Table G-1 says that the data used is from electrical cabinet fire tests and it is “considered conservative”

# Fixed Ignition Source HRRs

**Table G-1**  
**Recommended HRR Values for Electrical Fires**

Ignition Source	HRR kW (Btu/s)		Gamma Distribution	
	75th	98th	$\alpha$	$\beta$
Vertical cabinets with qualified cable, fire limited to one cable bundle	69 <sup>1</sup> (65)	211 <sup>2</sup> (200)	0.84 (0.83)	59.3 (56.6)
Vertical cabinets with qualified cable, fire in more than one cable bundle	211 <sup>2</sup> (200)	702 <sup>3</sup> (665)	0.7 (0.7)	216 (204)
Vertical cabinets with unqualified cable, fire limited to one cable bundle	90 <sup>4</sup> (85)	211 <sup>2</sup> (200)	1.6 (1.6)	41.5 (39.5)
Vertical cabinets with unqualified cable, fire in more than one cable bundle closed doors	232 <sup>5</sup> (220)	464 <sup>6</sup> (440)	2.6 (2.6)	67.8 (64.3)
Vertical cabinets with unqualified cable, fire in more than one cable bundle open doors	232 <sup>5</sup> (220)	1002 <sup>7</sup> (950)	0.46 (0.45)	386 (366)
Pumps (electrical fires) <sup>8</sup>	69 (65)	211 <sup>2</sup> (200)	0.84 (0.83)	59.3 (56.6)
Motors <sup>8</sup>	32 (30)	69 (65)	2.0 (2.0)	11.7 (11.1)
Transient Combustibles <sup>9</sup>	142 (135)	317 (300)	1.8 (1.9)	57.4 (53.7)

**See Note 8: No basis**


**Note 2: Vertical Cabinet Test**

# Fixed Ignition Source HRRs (Cont.)

## Notes for Table G-2

1. Ref. G.2: Sandia experiments, average of vertical cabinet fire intensities with qualified cable.
2. Ref. G.3: VTT experiments with control cabinets.
3. Ref. G.2: Sandia experiments, average of two bench-board cabinet experiments with qualified cable.
4. The value is based on expert judgment. The expert panel assumes that the type of cable will only affect the ability of the cable to ignite. Therefore, once ignited, a single cable bundle is assumed to burn with similar intensity regardless of the cable qualification. A value of 85 BTU/s was selected as a conservative estimate for unqualified cables to represent a higher intensity at the 75<sup>th</sup> percentile when compared to qualified cable.
5. Ref. G.2: Sandia experiments, average of two vertical cabinet experiments with unqualified cable and closed doors.
6. Twice the intensity selected for the 75<sup>th</sup> percentile.
7. Ref. G.2: Sandia experiments, the highest heat release rate observed in cabinets with open door and unqualified cable.
8. No experimental evidence is available for assessing fire intensities for electrical fires in equipment other than electrical cabinets (or panels). Recommended values are considered conservative and are based on electrical cabinet (panel) fires experiments.
9. Distribution estimated based on the range of the tested transient fuel packages summarized in table G-7.

# FPRA Issues Framework



# Category 3: Plant Impact, Fire PRA Scenarios & Quantification

## Areas In Need of Additional Realism:

- Treatment of Hot Shorts
  - AC Circuits Hot Short Probability and Duration
  - DC Circuits Hot Short Probability and Duration
- Human Reliability
  - Human Reliability Methods (HRA) methods and performance shaping factors for fire PRAs
- Modeling of Control Room Fires
  - Control Room Modeling and Treatment in the Fire PRA
- PRA Model Advancement
  - Address unrealistic model simplifications

# Summary of Roadmap Conclusions

Conclusion	Primary Bases
Fire characterization does not appear to conform with operating experience	<ul style="list-style-type: none"> <li>• Over-prediction of number of severe fires</li> <li>• Assumed rate of fire growth &amp; severity, e.g., 12 mins in electrical cabinets, oil fire severity</li> <li>• No credit for control of fires</li> </ul>
The level of quantified risk appears to be overstated	<ul style="list-style-type: none"> <li>• FPRAs predict high frequency of fires with high CCDPs, but NRC's ASP &amp; ROP have not observed</li> <li>• Predicted frequency of spurious operations not consistent with operating experience</li> </ul>
Uneven level of conservatism may mask key risk insights and lead to inappropriate decision-making	<ul style="list-style-type: none"> <li>• Simplifications result in bounding treatment of "bin"</li> <li>• Overstated fire damage can lead to underestimation of risk increases from plant changes</li> <li>• Assumes plant challenge for all fires, e.g., plant trip</li> <li>• No credit for administrative controls</li> </ul>

***Many areas of expedited research needed to provide enhanced methods***

# Together...Shaping the Future of Electricity



**EPRI**

ELECTRIC POWER  
RESEARCH INSTITUTE



## **EPRI Fire PRA Action Plan**



**Rick Wachowiak**



**ACRS PRA Subcommittee**

November 16, 2010

# EPRI Fire PRA Action Plan

Initiated in late 2009 as a means to clarify and coordinate industry activities related to fire PRA methods

- Updated as new issues are identified

Includes activities led by EPRI, NEI, PWROG, BWROG

Roadmap used to align and help establish priorities

Reports to NSIAC via an Executive Oversight Group

Technical tasks coordinated within the NEI FPRATF

# Focus of Research Activities


Fire PRA that is biased can mask important events and components or can drive plant changes that do not improve safety

Increase level of realism in fire PRA

- Support risk informed applications
- Reduce large departures from realism where possible
- Compatibility with internal events PRA

Fire PRA Action Matrix outlines and tracks the research activities needed to increase realism

# Fire PRA Industry Organization



# Fire PRA Action Matrix

Provides schedule for resolving key issues through mid-2014

For each activity there are: Owners, Schedules, Products

Categories of fire PRA activities

- Initiation, detection and suppression
- Damage assessment
- Plant impact, PRA scenarios, and quantification
- Ongoing base-load activities

Fire PRA Methods Development - Action Matrix Schedules		Owner	Dec 2010	Mar 2011	Jun 2011	Sep 2011	Dec 2011	Mar 2012	Jun 2012	Sep 2012	Dec 2012	Mar 2013	Jun 2013	Sep 2013	Dec 2013	Mar 2014	Jun 2014
<b>Category 1: Fire Initiation, Detection, Suppression</b>																	
1.1 Fire Events Database	1.1.1	Review the database structure to fit the current uses in Fire PRAs such as ignition frequency, detection and suppression probability, trigger response, and others.	EPR / RES														
	1.1.2	Collection fire event information from industry	PWR/OG BWR/OG														
	1.1.3	Define realistic fire event categorization scheme and apply to events	EPR														
	1.1.4	Collect component events and apply to database	EPR / CGS														
	1.1.5	Review Fire Events Database (FEDB) resolution and report	EPR														
	1.1.6	Transition long-term data collection efforts work	NPO														
1.2 Fire Ignition Frequency	2.1	Improve methods for ignition frequency calculation	EPR														
	2.2	Review fire ignition frequencies	EPR														
	2.3	Update ignition frequencies (accounting for full data & component based)	EPR														
1.3 Incident Fire Growth in Electrical Cabinets	3.1	Obtain information from the PRAs to characterize detection and termination prior to an actual fire event.	EPR/UMD														
1.4 Oil Fire Severity	4.1	Pumps	PWR/OG														
	4.2	Transformers	PWR/OG														
	4.3	Diesel Generators	PWR/OG														
1.5 Credit for Incident Detection	5.1	Refine FAZ-046	EPR														
	5.2	Incipient fire detector testing (NRC lead)	EPR / RES														
1.6 Fire Suppression Phenomena	6.1	Develop recommended approach for non-suppression curves	BWR/OG / GEH														
	6.2	Refine treatment based on current database	GEH														
	6.3	Refine treatment based on updated database	EPR														
<b>Category 2: Fire Damage Assessment</b>																	
1.7 Fire Growth and Non-Propagating Factors	1.1.1	Review of data to determine factors impacting fire growth rate (qualified vs. non-qualified)	EPR														
	1.1.2	Refine treatment based on updated database	EPR														
	1.1.3	Refine treatment based on updated database	EPR														
2.1 Electrical cabinet peak heat release rate (PWR)	2.1.1	Review of available data	EPR														
	2.1.2	Treatment for ventilation limited cabinets	EPR														
	2.1.3	Testing plan, as needed	EPR / RES														
2.2 Transient Ignition Source Work	2.2.1	Review of database and development of revised treatment	EPR														
	2.2.2	Review of database and development of revised treatment	EPR														
2.3 Hot Spots HRR	2.3.1	Review of database and development of revised treatment	EPR														
	2.3.2	Review of database and development of revised treatment	EPR														
2.4 Other HRRs	2.4.1	Review of database and development of revised treatment	EPR														
	2.4.2	Review of data from switchgear events	EPR														
	2.4.3	Formulation of revised treatment for medium voltage switchgear	EPR														
2.5 Switchgear HEAT ZON	2.5.1	Formulation of revised treatment for low voltage switchgear	EPR														
	2.5.2	Review of data from bus duct events and formulation of revised treatment	EPR														
	2.5.3	Formulation of revised treatment to avoid assumption of failure for all factors	EPR														
2.6 Bus Duct HEAT ZON	2.6.1	Review of database and development of revised treatment based on cabinet-specific factors	GEH														
	2.6.2	Formulation of revised treatment to avoid assumption of failure for all factors	GEH														
2.7 Damage to Sensitive Electronic Equipment	2.7.1	Review of database and development of revised treatment based on cabinet-specific factors	EPR / RES														
	2.7.2	Formulation of revised treatment to avoid assumption of failure for all factors	EPR / RES														
2.8 Electrical cabinet propagation	2.8.1	Review of database and development of revised treatment based on cabinet-specific factors	EPR / RES														
	2.8.2	Formulation of revised treatment to avoid assumption of failure for all factors	EPR / RES														
2.9 Fire Modeling Guidance	2.9.1	Completion of Fire Modeling Users Guide	EPR / RES														
	2.9.2	Update FMUG to address propagation of modeling uncertainty in the PRA	EPR														
<b>Category 3: Plant Impact, Fire PRA Scenarios, and Quantification</b>																	
3.1 Fire Impact, Fire PRA Scenarios, and Quantification	3.1.1	Review of data to determine and development of revised treatment to enhance FAZ-051	EPR / RES														
	3.1.2	Review of results and development of revised treatment	EPR / RES														
	3.1.3	Conduct PRT	EPR / RES														
	3.1.4	Peer review of results	EPR / RES														
3.2 Human Reliability Methods	3.2.1	Update of NUREG-1201	EPR / RES														
	3.2.2	Refinement of EPR/HRA, as needed	EPR														
3.3 Control Room Modeling and Treatment in the Fire PRA	3.3.1	Refinement of treatment	EPR														
	3.3.2	Address assumption that there is always a plant following such fire event	EPR														
3.4 Address unrealistic model simplifications	3.4.1	Address assumption that failed ventilation causes immediate failure of equipment	EPR														
	3.4.2	Address assumption that failed ventilation causes immediate failure of equipment	EPR														
<b>Category 4: Other Fire PRA Issues</b>																	
4.1 Update of the Fire PRA Sections of the Standard, given lessons learned from the initial peer review	4.1.1	Initial inquiries submitted, RG 1.200 sections are now reviewed by the ASME, CNRS, and some standard changes are in process.	EPR														
	4.1.2	Additional Peer Review Guidance is needed to ensure lessons learned are quickly fed to the peer review teams.	NEI														
4.2 Results Comparison	4.2.1	Empirical data collection and comparison with PRA results	EPR														
	4.2.2	Provide two year training courses	EPR / RES														
4.3 Support for peer review of new methods	4.3.1	Provide a forum for peer reviewing fire PRA and the modeling methods to support RG 1.200 compliance	EPR / NEI														
	4.3.2	Provide a forum for peer reviewing fire PRA and the modeling methods to support RG 1.200 compliance	EPR / NEI														

Notes: Schedule focuses on key activities expected to occur in the next 14 quarters. Colors are only used to visualize groups of items.

# Action Matrix Example

## Updated Fire Events Database

Fire PRA Methods Development - Action Matrix

Area of Needed Realism	EPRI Research Area	EPRI Research Activity	Priority	Owner	Status
<b>Category 1: Fire Initiation, Detection, Suppression</b>					
Fire event data characterization	1.1 Fire Events Database	1.1.1 Revise the database structure to fit the current uses in Fire PRAs such as ignition frequency, detection and suppression probability, brigade response, and others	High	EPRI / RES	Revision to the database complete. Interim Report 1019198 issued that describes the database specification. Obtained agreement with NRC on the structure of the database.
		1.1.2 Collection fire event information from industry	High	PWROG BWROG	All plants have supplied raw data. PWROG and BWROG are doing the initial screen. PWROG batch is done. BWROG will likely finish in 2010. EPRI will do final screen and data entry
		1.1.3 Define realistic fire event categorization scheme and apply to events	High	EPRI / RES	Categorization scheme has been defined and the NRC concurs. Implementation can start once the owners groups finish the initial data screening.
		1.1.4 Collect component counts and apply to database	High	EPRI / OGS	PWROG and BWROG are developing the component counts. PWROG has had a strong response. Expect to issue a report early in 2011. Currently they have the raw data and explanations of outliers. BWROG is not expecting significant amount of data until late 2010.
		1.1.5 Develop Fire Events Database (FEDB) revision 1 and report	High	EPRI	This will include the description of the classification and the further data collection. A hard copy report of the data will be made public. The database itself is proprietary and will be retained by EPRI. It will be provided to the NRC under the MOU without plant names.
		1.1.6 Transition long-term data collection efforts	High	INPO	Current agreement for INPO to take on data collection effort. INPO evaluating approach to long-term data collection. EPRI will retain responsibility for classification and application to FPRA.

# Conclusions

Many important Fire PRA activities are under way

Focused on increasing the level of realism in Fire PRA

Fire Events Database is a key element to understanding the issues

EPRI is working with NRC RES

- Fire Events Database
- DC Testing
- Fire HRA

Roadmap report, including the full EPRI Action Matrix, will be provided to ACRS in the coming weeks

# Together...Shaping the Future of Electricity

# **Non-FPA Issues Impacting Transition to NPFA 805**

**ACRS Reliability and PRA  
Subcommittee Meeting  
November 16, 2010**



NUCLEAR  
ENERGY  
INSTITUTE

# **Late Emerging Issues with Potential Impact on NFPA 805 Transition**

- **Impractical and evolving expectations to demonstrate “Safe and Stable” for an indefinite period**
- **Resolution of pilot issues being deferred by the issuance of implementation actions or license conditions**
- **Additional technical justification for continued acceptance of Pre-Transitional Licensing Bases**

# Example: Safe and Stable

## Definition of Safe and Stable

- **NFPA 805, 1.6.56:** “For fuel in the reactor vessel, head on and tensioned, safe and stable conditions are defined as the ability to maintain  $K_{eff} < 0.99$ , with a reactor coolant temperature at or below the requirements for hot shutdown for a BWR and hot standby for a PWR.”
  - **1.3.1 Nuclear Safety Goal:** The nuclear goal of NFPA 805 is to provide reasonable assurance that a fire during any operational mode and plant configuration will not prevent the plant from achieving and maintaining the fuel in a “safe and stable condition.”

# Example: Safe and Stable

## Treatment of Safe and Stable

- **HNP SE:** “The licensee stated that the NFPA 805 licensing basis for HNP will be to achieve and maintain safe and stable hot standby conditions. However, ...analyses previously performed ... included actions and equipment to achieve cold shutdown. NRC staff finds this acceptable because these actions are not required to meet the nuclear safety performance criteria...”
- **ONS RAI 3-49:** “Demonstrating the ability to maintain safe and stable conditions for only the first 72 hours following a fire does not, by itself, provide adequate assurance that the nuclear safety goal of NFPA 805 is met. The licensee should be able to demonstrate that safe and stable conditions can be maintained indefinitely, once achieved.”


# Example: Safe and Stable

- **Impact**

- **ONS Re-analysis of All Components and Cables Associated with going to HSD**
- **Non-pilot plants evaluations aligned with pilot/ONS LAR will require significant changes late in the process that will challenge meeting June 2011 submittal**
- **Drive plants to a more restrictive condition than Appendix R**

# Closing Remarks

- **Criteria and Guidance established by Staff and Industry must be consistently applied**
- **Changes in Requirements through the Review Process create instability and will significantly impact non-pilot transitions**
- **Deferral of the resolution of pilot issues by issuing Implementation Actions or License Conditions increases uncertainty in non-pilots applying the guidance consistently**
- **Expedient Resolution and Alignment on treatment of Safe and Stable needs to be reached through FAQ 08-0054**



**Alexander Klein, P.E.**

*Branch Chief, Fire Protection*

*Division of Risk Assessment*

*Office of Nuclear Reactor Regulation*

**Status of Transition to NFPA 805**  
**Methodology and Issues Impacting the Transition**

*Advisory Committee on Reactor Safeguards*

*November 16, 2010*

# Objectives

Provide an Overview of the Status of Licensees Transition to NFPA 805 in Accordance to 10 CFR 50.48(c)

- Pilot plants – Shearon Harris and Oconee
- Other plants transitioning to NFPA 805
- NFPA 805 Infrastructure
- The FAQ process and its impact on the transition process
- Lessons learned

# Shearon Harris and Oconee Transition to NFPA 805

- 6/05 – Progress submits a Letter of Intent to adopt NFPA 805 for Shearon Harris
  - 5/08 – Progress submits the license amendment request
  - 8/09 – 3/10 – Staff issues major rounds of requests for additional information
  - 6/10 – Staff issues the safety evaluation
- 2/05 – Duke submits a Letter of Intent to adopt NFPA 805 for Oconee (3 units)
  - 5/08 – Duke submits the license amendment request
  - 4/10 – Duke submits a revised license amendment request
  - 11/09 – 9/10 – Staff issues major rounds of requests for additional information
  - 12/10 (tentative)– Staff issues the safety evaluation

# Other Plants

## Transitioning to NFPA 805

- 47 Units (non-pilot) have sent a Letter of Intent to adopt NFPA 805
- Most Units plan to submit license amendment requests in 2011
- Some Units plan to submit license amendment requests in 2012
- 1 Unit has not started transition
- 1 Unit has withdrawn

# NFPA 805 Infrastructure Products

- Regulatory Guidance and other documents
  - Regulatory Guide 1.205
    - NEI 04-02, Revision 1 issued September 2005
    - RG 1.205 issued May 2006
    - NEI 04-02, Revision 2 issued April 2008
    - RG 1.205, Revision 1 issued December 2009
  - SRP 9.5.1.2 issued December 2009
- NUREG/CR 6850 issued September 2005
  - Supplement 1 issued September 2010
- Frequently Asked Questions
- NFPA 805 inspection procedure

# NFPA 805 Infrastructure Development Activities

- Pilot Observation Meetings – periodic meetings held throughout NFPA 805 pilot process between pilot plant technical staff and NRC staff
- Pilot Workshops – public meetings held to communicate NFPA 805 pilot lessons learned to industry
- FAQ monthly public meetings – held to communicate technical/regulatory issues addressed through FAQ process

# NFPA 805 Infrastructure Development Activities

- Issues resolved during pilot transition
  - Minimum information required at Acceptance Review
  - Recovery Actions
  - Alternative/Dedicated Shutdown under NFPA 805
  - Fire PRA quality
  - Radioactive Release transition
  - Non-power Operations transition
  - NFPA 805 Monitoring Program

# NFPA 805 Infrastructure Development Activities

- Pilot plant observations and meetings
  - Shearon Harris/Oconee
    - 2005 - 2008
- NFPA 805 workshops
- Frequently Asked Questions monthly meetings
- License Amendment Request and Safety Evaluation template meetings
- Pilot plant site visits

# Frequently Asked Question (FAQ) Process and Impact on Transition

- As lessons were learned through the pilot process, licensees asked for a semi-formal process to address guidance document changes
- FAQ process established to provide interim staff approval of changes to NEI 04-02 guidance
- Process has had substantial impact on transition
  - Facilitated resolution of over 30 significant technical/regulatory issues related to NFPA 805 transition

# Resolved FAQs and their Potential Impact

- FAQ 07-0008 – Fire Protection Engineering Evaluations
- FAQ 07-0040 – Non-Power Operations
- FAQ 09-0046 – Incipient Detection

# Lessons Learned Regarding Non-PRA Implementation Issues

- Licensees still needed a qualitative review process for minor plant changes
- Significant guidance was required to properly establish those recovery actions that require the evaluation of risk
- Implementation of the “safe and stable” concept under NFPA 805 required significant dialog with the pilots
- Monitoring program needs to be more mature at time of submittal to allow the staff to properly review and approve the process



# Fire PRA Related Methodological and Other Issues Impeding the Transition Process

Presentation to ACRS Subcommittee on PRA and Reliability

November 16, 2010

Donnie Harrison, Chief  
PRA Licensing Branch  
Division of Risk Assessment  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission

# General Discussion Topics

- Selected Issues that impact Fire PRA Applications
  - Internal Events PRA/Fire PRA Carry-Over Issues
  - Risk-Informed Applications
  - Fire PRA Peer Reviews
  - Scope of 10 CFR 50.48(c) (NFPA 805) Transition
- Path Forward

# Internal Events/Fire PRA Carry-Over Issues

- Internal events PRA may have been peer reviewed many years prior to application
- Unresolved internal events PRA peer review findings can affect fire PRA application
- Subsequent internal events PRA method changes/upgrades require focus-scope peer reviews
  - Results in subsequent impacts on fire PRA model

# Risk-Informed Applications

- Some licensees have limited experience with risk-informed applications or no experience with applications of this scale
- Though fire PRA methods have been around for about 30 years, most licensees have dated experience in developing fire PRAs
- Impact of nearly simultaneous development of three items:
  - New fire PRA methodology guidance (NUREG/CR-6850)
  - New fire PRA standard (ASME/ANS-RA-Sa-2009)
  - New fire risk-informed application (10 CFR 50.48(c))

# Fire PRA Peer Reviews

- New methods/approaches (beyond NUREG/CR-6850) being implemented impacts peer reviews
- Industry responded to early peer reviews by revising peer review guidance
  - Peer reviews may have initially used NUREG/CR-6850 as the only acceptable methods
  - New peer review guidance impacts the information needed to be provided by an applicant
- Incomplete fire PRAs submitted for peer review to meet scheduling needs may result in follow-on peer reviews of the completed elements

# Fire PRA Peer Reviews

- Industry created Fire PRA methods task force to address new methods
  - Adds another layer of review of fire PRA model
  - Addressing new methods and providing task force feedback to the licensee takes time
  - Task force may modify or reject method resulting in further changes to a licensee's PRA; potentially requiring another peer review

# Scope of 10 CFR 50.48(c) (NFPA 805) Transition

- Licensee decides on level of detail and realism in fire PRA modeling to support their application
- Fire PRA methods use a progressive screening approach
  - Focuses licensee resources on areas of highest fire risk contribution
  - Results in screened areas being conservative

# Scope of 10 CFR 50.48(c) (NFPA 805) Transition

- Licensee may retain conservative screening approach if results are acceptable or implement plant modifications instead of using refined fire PRA models
  - Time, effort, level of justification, and cost considerations
- Plant modifications can reduce risk, not only for fires, but also for other risk contributors
  - Many to be implemented after staff evaluation
  - Ensuring credited performance achieved by actual installation
  - Limitations on the use of the plant change evaluation process until installation completed and confirmed

# Scope of 10 CFR 50.48(c) (NFPA 805) Transition

- Creation of an entirely new licensing basis for fire protection that merges two disciplines
  - Must re-verify feasibility of operator manual actions
  - May need to designate some operator manual actions as recovery actions needing change in risk calculations
- New basis may include variations from deterministic requirements (VFDRs)
  - Results in potentially numerous change in risk calculations
  - Cumulative impact must be acceptable, as well as individual VFDR impacts
  - Fire PRA method simplifications can create conservative change in risk calculations

# Path Forward

- Continue to engage external stakeholders to address Fire PRA concerns
- Identify and address conservatisms in the Fire PRA methods
  - Fire PRA methods or NUREG/CR-6850 FAQs
  - Fire PRA Methods Enhancements issued (Supplement 1 to NUREG/CR-6850)
  - Interact with the Fire PRA Methods Task Force
- Develop and train more industry and NRC staff



**U.S.NRC**  
UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

# ACRS Reliability and PRA Subcommittee Meeting - Fire PRA Research in Support of NFPA 805

Mark Henry Salley P.E., Branch Chief

November 16, 2010

Rockville, Maryland



**Office of Nuclear  
Regulatory Research**



*Fire Research  
Branch* 



## Overview of NRC RES Activities

- Provide a High-Level Overview of NRC RES Fire Research Activities
- NRC's Research Partners
  - Electric Power Research Institute (EPRI)
  - National Institute of Standards and Technology (NIST)
  - Sandia National Laboratories (SNL)
  - Brookhaven National Laboratories (BNL)



## Overview of NRC RES Activities

- Continue to Advance the Science and Understanding
  - Improve the State-of-the-Art
  - Expand the Knowledge Base
- Reduce Uncertainty
  - Continue to refine/improve
    - Methods
    - Data



# How Fire Research Activities Are Determined

- User Need Request
  - Formal Office Request for work
    - Close Interaction with Requesting Office
    - A Number of Different Tasks with NRR
    - Agree on Priority of Task
  - Agency Mandated Programs
  - Long Term Research



# Fire PRA Methodology

- NUREG/CR-6850 EPRI 1011989
- State-of-the-Art
- Initial Issue: September 2005
- NFPA 805
- Frequently Asked Questions (FAQ)
  - Issued Supplement 1 September 2010
- How do we revise/update?



## Fire PRA Methodology Update

- 18 Specific Chapters (Tasks) + Glossary
- 23 Appendix (A – W)
  - State-of-the-Art does not advance uniformly
- NRC Proposal “Modular Update”
  - Revise and Issue Chapters/Appendix as the Research advances State-of-the-Art
- Work closely with EPRI under MOU



## Fire PRA Methodology Update

- Two Examples:
  - Chapter 9 “Circuit Failure Analysis”
    - NRC DESIREE-FIRE Program
      - Electrical PIRT
      - PRA Failure Probabilities
  - Appendix R “Cable Fires”
    - NRC CHRISTIEFIRE Program



# Fire HRA Update

- EPRI/NRC-RES Fire Human Reliability Analysis Guidelines”
  - Draft for Public Comment November 2009
  - Team has addressed major comments
  - Incorporated as a separate class in Fire PRA Training
- To be discussed along with the HRA SRM project Spring 2011



## Fire Modeling

- NUREG-1805 “Fire Dynamic Tools”
  - Initial Issue: December 2004
- New Chapter “THIEF Model”
  - Developed as a part of CAROLFIRE
- New Look to Spreadsheets
  - Update/correct errors
- NUREG-1805 Supplement 1
  - Issue Fall/Winter 2010



## Fire Modeling (cont.)

- NUREG-1824 EPRI-1011999 V&V
  - Initial Issue: May 2007
  - Future Expansion
- NUREG/CR-6978 PIRT
  - Initial Issue: November 2008
- NUREG-1934 EPRI-1019195 Application Guide
  - Draft for Comment January 2010
  - Team working the comments expect a second draft for comment Winter/Spring 2011
  - Discuss with ACRS subcommittee Spring/Summer 2011



## CHRISTIFIRE





## CHRISTIFIRE

- Better Understanding Cable Tray Fires
  - Heat Release Rate (HRR)
  - Ignition
  - Flame Spread
- Multiple Phase Project
  - NIST Performing the Experiments
- Significantly Advances the Science
  - Revise NUREG/CR-6850 Appendix R
- Draft for Comment issued October, 2010
  - Plan to discuss with ACRS Subcommittee after public comment period



## CHRISTIFIRE (continued)

- Next Phases address variables such as:
  - Cable Orientation
  - Fire Retardant Coatings
  - Cable Tray Covers
  - Wind Aided Flame Spread





# CHRISTIFIRE






# CHRISTIFIRE





## DESIREE-FIRE





## Testing for Further Refinements

- To Better Understand the differences between alternating current (ac) and direct current (dc) circuit response
- Supports NFPA 805 and Appendix R Analysis
- Numerous safety related systems commonly powered with dc
- Duke testing in 2006 indicated that dc circuits may react differently than ac circuits to fire-induced failures





## DESIREE-FIRE

- Approach
  - - Similar to CAROL-FIRE Program
    - Industry collaboration through EPRI MOU
    - Test numerous dc circuits
    - Conduct tests and report results
- Objective
  - Provide data to characterize DC circuits
  - Provides additional Data on other issues



- Small-Scale
  - 59 tests
  - 1 circuit type per test



- Intermediate-Scale
  - 16 tests
  - Every circuit per test





## Battery Bank



Nominal 125Vdc  
Batteries from North Anna TSC





## Circuit Evaluated

- dc motor starter (MOV)
- Small pilot dc SOV (ASCO red-hat)
- 15kV & 4.16kV circuit breaker control
- 1" SOV valve assembly
- Large Coil (representative of PORV)



# Key Test Objectives

## Characterize DC

- Realistic circuits and configuration
- Inter-cable shorting
- Interactions with ground plane
- Multiple proper-polarity, coincident hot shorting
- Ground detection circuit

## Follow up testing

- Kerite cable characteristics
- Instrument circuits
- Testing planned Fall/Winter 2010



## Results

- Open Circuits
- Energetic faults

Open Circuit

Copper Slag





## Results





## Results (2)

- Arcing & Cable Ignition
  - Electrical failure are more energetic than in AC testing
  - In most cases arcing appears to act as the pilot for cable ignition
  - Arching and hot short durations are linked to fuse sizing



## Results (3)

- Fuse sizing
  - Larger fuses (15-35A) take longer to clear than small 5-10A fuses
  - In some tests the 25A & 35A fuses did not clear, instead electrical arcing caused an open circuit in cable conductors



## Results (4)

- Grounding
  - DC battery bank is ungrounded
    - Requires both positive & negative circuit conductors to short to ground to clear fuses
    - Several instances where inter-cable shorts through cable raceway



## Follow-on Work

- DESIREE FIRE Draft complete August 2010
  - Draft report to be made Publically Available
- Phenomena Identification and Ranking Table (PIRT) and Expert Elicitation
  - Underway now with two separate Expert Groups
  - Identify and rank electrical fire phenomena
  - Provide best estimate probabilities for use in fire PRA
  - Panel Meetings Beginning Fall 2010 through Summer 2011
  - Final Reports Fall 2011



## Training – Fire PRA

- Fire PRA Training with EPRI
  - Rockville, MD.
    - September 27 thru October 1, 2010
    - October 25 thru 29, 2010
  - Updated Program
    - Added Track for Fire HRA
  - Methods for Applying Risk Analysis to Fire Scenarios (MARIAFIRES-2008)  
NUREG/CP-0194 August 2010



## Training – Topics

- Based on NUREG/CR-6850 (EPRI1011989)
- Currently 4 Separate Classes
  - Fire PRA
  - Fire Analysis
  - Electrical Circuit Analysis
  - Fire HRA
- Fifth Class in Planning Stages
  - Detailed Fire Modeling



## Training – Fire Modeling

- Program currently under development
  - Supported EPRI program past 10+ years
  - Reassessing the users needs
  - NUREG-1934 should form basis for training
  - Expect work to be performed in 2011
  - Currently considering adding it as the 5<sup>th</sup> Class in the Joint RES/EPRI Fire PRA Training



# Fire Research Knowledge Management

- NUREG/BR-0361 Browns Ferry Fire
  - Issued February 2009
  - Plan Revision in 2011
- NUREG/BR-0364 NRC History of Fire Research Activities
  - Issued June 2009
- NUREG/BR-0465 Fire Protection and Research Knowledge Management Digest
  - Issued January 2010



## Other Planned Fire Research

### 2011-2012

- Updating Fire Events Data Base
  - EPRI currently collecting the data
    - Sunset current NRC Data Base
  - Metric Monitoring
    - LER/Inspection Findings/Long Term Compensatory Measures
- Incipient Detection Systems
- Low Power Shutdown Fire PRA
  - Draft Report Public Comment Winter 2010
- Electrical Cabinet HRR
  - Review EPRI project



## Other Planned Fire Research 2011-2012 (Continued)

- Kerite Cable
  - Sandia currently testing
- Smoke Damage to Electrical Circuits/Components
- Effectiveness of Gaseous Fire Extinguishing Agents



## Other Planned Fire Research 2011-2012 (Continued)

- International Projects
  - Fire Event Data Base
  - Proposing High Energy Arc Fault Test Program
    - NRC supply Test Laboratory
    - Foreign Countries supply Electrical Equipment
    - Discuss with EPRI for US Utility Participation
  - PRISME
    - In-Kind Contribution with OECD/IRSN



Current state of licensee efforts to transition to  
10 CFR 50.48(c), NFPA Standard 805  
Concluding Remarks

Presentation to ACRS Subcommittee on PRA and Reliability  
November 16, 2010

Sunil D. Weerakkody, Ph.D  
Deputy Director – Fire Protection  
Division of Risk Assessment  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission

# Closing Remarks

- NFPA 805 is a national consensus standard; NRC incorporated it to NRC regulations via 10 CFR 50.48(c) with limited exceptions.
- NRC's Office of Nuclear Reactor Research (RES) worked with Electrical Power Research Institute (EPRI) using best available data methods at the time to publish NUREG/CR-6850.
- Licensees may deviate from methods provided in NUREG/CR-6850; deviations must be substantiated.
- When licensees identified and proposed new or enhanced methods, NRC staff invested significant resources to review them and develop consensus.

# Closing Remarks (contd.)

- RES is continuing to invest significant resources to enhance the state-of-the-art of fire PRAs.
- Risk-informed licensing processes (e.g., Regulatory Guide 1.174) provides staff capability to make risk-informed decisions with due consideration of fire PRA uncertainties.
- NRC licensing processes provides licensees capability to change commitments if and when new information emerges.
- Staff remains open to collaborating with stakeholders to continue to improve the state-of-the-art of fire PRAs.

# Limitations in Fire PRA Application for NFPA 805 Transition

Presented by

**Mardy Kazarians**

Kazarians & Associates, Inc.

Presented at

**ACRS Subcommittee Meeting**

November 16, 2010

# Purpose / Key Questions

- 1. Could the limitations in current fire PRA analysis methods, models, or data lead to inappropriate conclusions during the transition to NFPA 805?**
- 2. Are there other issues impeding or discouraging the transition process?**

# Overall Approach

**Information is being collected from interested stakeholders.**

- NRC Staff
- Members of Utilities
- Consultants
- Public Stakeholders
- Others (e.g., NIST and NEI)

**Collected information will be organized and interpreted.**

# Overall Approach

## Topics discussed with interviewees:

- Level of experience with Fire PRA
- Type of involvement with Fire PRA and NFPA 805 transition
- Difficulties in applying NUREG/CR 6850
- Deviations from NUREG/CR 6850 and FAQs
- Status of cable information
- Impact of MSO
- Patterns in CDF contributors
- Peer review process

# Progress

**Have interviewed the following entities:**

- Consultants (5)
- Utilities (5)
- NRC Staff (6)

**Will contact additional stakeholders.**

**Results to be summarized and presented during the December Subcommittee meeting.**