#### Gilanshahi, Nikki

From: Sent: To: Subject: Attachments: Gilanshahi, Nikki,  $\mathcal{NRU}$ Tuesday, June 08, 2010 3:03 PM Gilanshahi, Nikki FW: Presentation Crystal River 3.ppt 1-7-2010.pdf; Jan 6 Tech Consistency (1).pdf

From: Gilanshahi, Nikki Sent: Monday, January 11, 2010 2:25 PM To: (b)(6)Subject: FW: Presentation

FYI;

From: Gilanshahi, Nikki
Sent: Monday, January 11, 2010 8:47 AM
To: Hawkins, Kimberly; Riddick, Nicole; Chakrabarti, Samir; Chakravorty, Manas; Gilanshahi, Nikki; Jeng, David; Kazi, Abdul; Xu, Jim; Chuang, Tze-Jer; Jain, Bhagwat; Ma, John; Park, Sunwoo; Patel, Pravin; Tegeler, Bret; Thomas, Brian; Thomas, Vaughn; Valentin, Milton
Subject: Presentation

Good morning All;

Please find attached copy of Jan6 and Jan 7 Crystal River presentation and Please let me know, If you have any questions in this regard.

Thanks,

Nikki Gilanshahi *Structural Engineer* NRVDE/SEB2 Phone: (301) 415-3801

> Information in a second and second in accordance with the Preadoin of Internation Act. Exemptions 6 FOIAIPA 2010-0290



# Crystal River Unit # 3 Containment Delamination



Nikki Gilanshahi Structural Engineer NRO/DE/SEB2 1/7/2010

# USSING OF DESCRIPTION OF DESCRIPTIONOF DESCRIPTION OF DESCRIPTIONO

## Purpose:

To educate the staff and make them aware of the recent discovery, Crystal River 3, Steam Generator Replacement containment delamination.

## Outcome:

Staff can apply the insights from this operating experience to our new reactor reviews after presentation.

## Safety Significance:

Concrete delamination Could compromise the structural integrity of the containment building, which inturn could potentially release radioactivity to the environment.

## Conclusion:

Adequate Containment Design review and good quality of Construction inspection are essential to ensure safety of our future Nuclear Power Plants.







# **Crystal River 3**

- Pressurized Water reactor
- Location: Crystal River Florida
- Commercial Operations Electricity Generation since 1976 for Florida
- Planned Outage
- Routine refueling scope Off line maintenance and fuel once every 2 years
- Extended Power Uprate (EPU)- Phase 2



#### Steam Generator Replacement (SGR) Opening (between Buttresses 3 and 4)



SGR Opening Dimensions @ Liner 23' 6" x 24' 9"

@ Concrete Opening 25' 0" x 27" 0"



The most important role of nuclear containments is to prevent radioactive substances from leaking out, acting as final barrier in nuclear power plants



#### Steam Generator Replacement (SGR) Work Breakdown

- Containment Opening
- Lifting and Rigging
- Cutting and welding





Safe and a constant



Steam Generator Replacement Opening Sequence & Identification of elamination



のなどなったいでは、「ないないない」であっていた。

10,00

#### Location of the Delamination



# Contraction Close-up

#### Actual Delamination Delamination and Cause of Delamination

Common causes of Delamination occurs in reinforced concrete structures subject to reinforcement corrosion, inadequate use of concrete material, and more



They were Approximately 74 Possible failure mode which 1/3 investigation as of Nov, 20,2009 remaining and ongoing



#### **INVESTIGATION APPROACH**









## Root Cause Analysis

- External Events
- Operational Events
- Inadequate Containment
   Cutting
- Inadequate Concrete-tendon
   interactions
- Shrinkage, Creep and Settlement
- Chemically or Environmentally induced aging
- Inadequate use of Concrete Materials
- Inadequate Concrete
   Construction
- Inadequate Concrete Design due to High Local Stress





## **Condition Assessment Activities Completed or Planned**

Determine Extent of Condition

Characterize the extent of delamination at the SGR opening. Determine condition of other portions of structure

• Non Destructive Testing (NDT) of Containment Wall Surfaces

Use of Impulse Response (IR) Method Comprehensive on external exposed surfaces Accessible areas in adjacent buildings

#### Concrete Cores

Used to confirm IR results (over 80 cores) Visual examination of core bore holes with boroscope to identify if delamination present

- ASME Section XI IWL visual inspection (affected areas)
- Containment Dome Inspections

NDT IR scans in segment above the SGR opening Concrete cores with boroscope examination of bore holes Physical survey with established benchmarks



## **Condition Assessment**

#### Condition Assessment Techniques Impulse Response (IR)



- IR Equipment
   Primary test method used in this evaluation
- IR Performed in the Field





# Non Destructive Testing (NDT) Impulse response (IR) method

The Impulse Response method can be applied to a variety of situations that require rapid, accurate, and cost-effective nondestructive condition assessment. Which can be used to test relatively rough concrete surfaces; its fast output, Can detect the delamination of concrete & concrete around steel reinforcement, but, it dose not provide the depth of the delamination.





#### Condition Assessment Techniques Ground Penetrating Radar (GPR)



- Ground Penetrating Radar (GPR) Equipment
  - Locates internal features (rebar, tendon conduits, etc.)



Contraction in the second

GPR Performed in the Field





## **Ground Penetrating Radar**

 Ground Penetrating Radar technology is ground radar that acts as a type of ground sonar and provides critical information regarding anything that could be located below the surface. It is sometimes called ground sonar, Concrete scanning, surface penetrating radar or ground radar





## Concrete Cores

Used to accomplish the results and confirm IR results( Over80 cores) Visual examination of core bore holes with boroscope To identify if delamination present





## Condition Assessment Techniques



IE Equipment
 Ability to determine depth of delamination



IE Performed in the Field







Ú.

Delamination has only been observed in core bore holes (s) boroscopic exams in the buttress 3-4 span, as accurately predicated by IR Red: <u>Core bore with delamination</u> Green :<u>Core bore not delaminated</u> White: <u>To be Core bored</u>







# This Issue is still under Investigation by a team of Industry experts hired by Licensee.

## Possible Repair:

Delamination Removal and Replacement.

## Conclusion:

Adequate Containment Design review for New Reactors and good quality of Construction inspection are essential to ensure safety of our future Nuclear Power Plants.



## Questions



