



- NOTES:
1. EACH STATION CAPABLE OF ACCEPTING 1500ml AND 5000ml SAMPLE VESSELS.
 2. FOR PIPING AND INSTRUMENT SYMBOLS SEE DWGS 9A310F00001 & 9A310F00002.
 3. ALL SAMPLE LINES ON THIS P&ID ARE 1/2 IN. X 0.065 IN. MINIMUM WALL ASME GRADE SA213 TYPE 316 TUBING.
 4. REFER TO WATERS EQUIPMENT DRAWING NO. 562011(S)0001 (L&P) (B) (1/0) FOR EQUIPMENT LIST AND BILL OF MATERIAL FOR VENDOR SUPPLIED COMPONENTS.
 5. THIS DWG SUPERCEDES B&R DWG 120048-H AND 220048-C.
 6. SWAGelok *SS-600-61 BULKHEAD UNIONS ARE FOR ALL SAMPLE LINES ENTERING THE PANEL.
 7. DELETED
 8. HAND SWITCHES FOR THE DEMIN. WATER FLUSH SOLENOID VALVES ARE LOCATED ON THE FRONT OF PANEL ZLP-127.
 9. ALL INSTRUMENTS ON THIS P&ID HAVE SEPARATION GROUP 'N' UNLESS NOTED.
 10. ALL INSTRUMENTS ON THIS P&ID HAVE SYSTEM DESIGNATOR 'PS' UNLESS NOTED.

LR BOUNDARY DRAWING NO. LR-STP-PS-9Z329Z00048#2 REV. 0

NO.	ISSUE DATE	REVISION	BY	CHK	RE	DV	NA	SE	PE	NO.	ISSUE DATE	REVISION	BY	CHK	RE	DV	NA	SE	PE	
9																				
8	12-1-93																			
7	3-31-88																			
6	5-15-87																			



SCALE	DWG. NO.	REV.
NONE	9Z329Z00048 #2	9