



- NOTES:
1. VENT HOLE PROVIDED.
 2. LOCATE CONNECTION AS CLOSE AS POSSIBLE TO PRESS RELIEF TANK.
 3. LOCATE VALVE IN VERTICAL PIPING RUN (MAXIMUM OF 4 FEET FROM 3"RC1035UD7).
 4. DELETED
 5. TEST CONNECTIONS ATTACHED TO BOTTOM ORIPPING TO FACILITATE DRAINAGE.
 6. DRAIN VALVES INSTALLED AS NECESSARY AT LOW POINTS BETWEEN PRESSURE REGULATING VALVE AND P.R.T. VALVES PERIODICALLY OPERATED TO AVOID WATER SEAL.
 7. ALL INSTRUMENTS SHOWN ON THIS P&ID HAVE SYSTEM DESIGNATOR RC.
 8. ALL INSTRUMENTS SHOWN ON THIS P&ID HAVE SEPARATION GROUP "N" UNLESS OTHERWISE NOTED.
 9. LOCATE VALVE AS CLOSE AS POSSIBLE TO 14"RC1014KD7.
- REFERENCES:
1. FOR PIPING & INSTRUMENT SYMBOLS SEE DRAWING 0F0001 & 0F0002.
 2. WESTINGHOUSE DRAWING NO. 12073MB 7 SHT. 2 OF 3. REC L00 14426-0201(1)00002-EWN.

LR BOUNDARY DRAWING NO. REV.
 LR-STP-RC-5R149F05004#1 0A

<p>0-14 06-22-83 REVISED PER CR 00-11098-16 ISSUED FOR CONSTRUCTION.</p>										<p>KS SIGNATURES ON FILE</p>										<p>STP SOUTH TEXAS PROJECT NUCLEAR OPERATING COMPANY</p>										<p>PIPING AND INSTRUMENTATION DIAGRAM RCS PRESSURIZER RELIEF TANK</p>																																																	
<p>REVISION</p>										<p>ORIG CKR RE DV SE</p>										<p>PRIORITY CADD FILE NO. FSUC. NO. STI. NO. SCALE DWG. NO. SHT. REV.</p>										<p>1 FJA156.151 D070928 2 NONE 5R149F05004#1 15</p>																																																	
<p>8</p>										<p>7</p>										<p>6</p>										<p>5</p>										<p>4</p>										<p>3</p>										<p>2</p>										<p>1</p>									