



- NOTES:**
1. INLET OVERFLOW AND INSTRUMENT CONNECTIONS AT BOTTOM OF TANK. DRAIN CONNECTION FROM BOTTOM OF TANK TO SUMP.
  2. DELETED
  3. ALL INSTRUMENTS ON THIS P&ID HAVE SYSTEM DESIGNATOR "RM" UNLESS OTHERWISE NOTED.
  4. LEAK TEST CONNECTIONS AND VENTS LOCATED ON BOTTOM OF PIPE.
  5. LOCATE NEAR CONTAINMENT ISOLATION VALVES.
  6. LOWER LOOP TO EXTEND 12" BELOW OVERFLOW CONNECTION AND UPPER LOOP 6" BELOW DIAPHRAGM FLANGE. LOCATE SIPHON BREAK VENT ON TOP OF UPPER LOOP.
  7. ALL INSTRUMENTS ON THIS P&ID HAVE SEPARATION GROUP "N" UNLESS OTHERWISE NOTED.
  8. FOR PIPING, VALVES, INSTRUMENTS, EQUIPMENT, ETC. REFER TO DWGS. 9A318F00001 AND 9A318F00002 FOR IDENTIFICATION NUMBER DETAILS.
  9. DELETED
  10. "N" SYSTEM DESIGNATOR IS (N2RM01) EXCEPT WHERE SHOWN OTHERWISE.

*D269*

LR BOUNDARY DRAWING NO.	REV.
LR-STP-RM-5R279F05033#2	0

**SOUTH TEXAS PROJECT  
NUCLEAR OPERATING COMPANY**

PIPING & INSTRUMENTATION  
REACTOR MAKEUP WATER SYSTEM

NO.	ISSUE DATE	REVISION	ORIG	CKR	RE	DV	SE	NO.	ISSUE DATE	REVISION	ORIG	CKR	RE	DV	SE	PRIORITY	CADD FILE NO.	FSUG. NO.	STI. NO.	SCALE	DWG. NO.	SHT.	REV.
14	09-28-02	INCORP. DCN 0002877																					
		ISSUED FOR CONSTRUCTION																					
8																							
7																							
6																							
5																							
4																							
3																							
2																							
1																							

ESSECO.DGN