GSI-191 ACRS Slide Presentation – November 19, 2010 (Non-Proprietary)

06581jb.doc

Presentation to ACRS Sub Committee

AP100[™] Long-Term Cooling Debris Issues Resolution Supplemental Information

November 19, 2010 Terry L. Schulz, Consulting Engineer AP1000 Nuclear Systems Engineering



inchouse Non-P

AP1000 is a registered trademark of the Westinghouse Electric Company

Follow–up Information From ACRS Meeting Nov 18, 2010 on GSI-191

- The attached information is expected to resolve questions #69, #68, #71
 - #68 K/A² for AP1000 FA debris tests
 - #68, #69 Additional <u>W</u>C/T plots for cases 6, 8, 9, 10, New1, New2
 - #69 CHF confirmation for cases New1, New2
 - #71 Development of DP vs fiber, including "other" test data



a.c

#68, K/A² For AP1000 FA Debris Tests

- <u>W</u>COBRA/TRAC Case 10
 - Acceptance criterion is 4.1 psid at []^{a,c}
 - <u>W</u>C/T used an input core inlet resistance of k/A² equal to 761.8 ft⁻⁴
- Calculate resistance (k/A²) of FA test tesults



 The K/A^b is calculated with an exponent of "2" and also with a test based exponent



Westinghouse Non-Proprietary Class 3

© 2010 Westinghouse Electric Company LLC. All Rights Reserved.

Tables of k/A² for FA Debris Tests With "b" Exponent



K/A² For AP1000 FA Debris Tests

- Comments on K/A² Information
 - Note that the test based exponent results in a LARGER resistances, which means that the WEC approach is more conservative
 - Test #17 has the highest resistance but maintains margin to the acceptance criteria
 - This test is included even though it is considered an invalid test because the test protocol was not followed
 - Tests #36 & 37 (higher temp tests) have the lowest resistance
 - This shows that more margin is available which may be quantified in the future to allow higher operating fiber limits for AP1000

L'ANDER CONTRACTOR



Additional Plots from WCOBRA/TRAC Debris Sensitivity Cases

- Plots provided for Cases 6, 8, 9, 10, New Case
 1, New Case 2:
 - Hot assembly void fraction in top cell, 2nd to top cell over 100s interval during quasi-steady state period
 - Core inlet flow rate
 - Core inlet pressure drop
 - Downcomer collapsed liquid level







Case 6 – during quasi-steady period restart



Westinghouse Non-Proprietary Class 3

Case 6 – during quasi-steady period restart





10

Case 8 – during quasi-steady period restart



Case 8 – during quasi-steady period restart



Westinghouse Non-Proprietary Class 3

© 2010 Westinghouse Electric Company LLC. All Rights Reserved.

Case 9



13







15











18

Westinghouse Non-Proprietary Class 3

© 2010 Westinghouse Electric Company LLC. All Rights Reserved.

New Case 1



© 2010 Westinghouse Electric Company LLC. All Rights Reserved.

1.50

New Case 1



a,c

New Case 1



New Case 2



a,c

© 2010 Westinghouse Electric Company LLC. All Rights Reserved.

New Case 2



23

© 2010 Westinghouse Electric Company LLC. All Rights Reserved.

New Case 2



Westinghouse Non-Proprietary Class 3

© 2010 Westinghouse Electric Company LLC. All Rights Reserved.

Confirmation of CHF Results in <u>WC/T LTC</u> Results

 CHF check against Chang (1991) correlation for New Case 1, New Case 2



- 1

CHF Comparison – New Case 1, 2





Development of DP vs Fiber Amount

- Information on development of DP vs fiber amount
 - FA debris test data relationship used as input to this evaluation

Approach to using this test data to develop this relationship



فالتعالي المعتدية فتحت والمتحال

Westinghouse Non-Proprietary Class 3

Step 1: PWROG data for cold leg conditions: base-line curve



Comparison with AP1000 data from p:f sensitivity tests

a,c estinghouse

Step 2: extrapolation for 75g of fiber

_		and the second second	· · · · · · · · · · · · · · · · · · ·			10			a,c
		<i>,</i>			· .			÷ .	
							,		
				<i>,</i> .					
								•	
							÷		
				_					
	A STATE OF			A ANNA A ANN					
STATE OF						F 0			
Sur (SCI COLICICICICICICICICICICICICICICICICICICI			تصمد
	Mectinah	AUSE					New Total Cardena and Aller		
				· · ·			•		
							•		30

Step 3: extrapolation of the worst dP curve



Step 4: Comparison whith AP1000 results

