



- NOTES:
1. FOR INSTRUMENT AND PIPING SYMBOLS SEE 9A310F0001 AND 9A310F0002.
  2. ALL INSTRUMENTS ON THIS P&ID HAVE SYSTEM DESIGNATOR SS.
  3. ALL INSTRUMENTS ON THIS P&ID HAVE SEPARATION GROUP N.
  4. SAMPLES ARE TO/FROM CONSTANT TEMP. BATH LOCATED IN ZLP-132.
  5. ALL CONDUCTIVITY ELEMENTS INCLUDE AUTOMATIC TEMPERATURE COMPENSATION.
  6. ALL CATION CONDUCTIVITY ANALYZERS HAVE A HYDROGEN ION EXCHANGE COLUMN UPSTREAM OF THE CELL.
  7. ALL SAMPLE LINES ON THIS P&ID ARE 1/2 IN. O.D. X 0.065 IN. WALL ASME GRADE SA213, TYPE 316 TUBING, UNLESS OTHERWISE NOTED.
  8. DELETED.
  9. DELETED.
  10. SEE DRAWING 9Z329Z00044 FOR ABBREVIATIONS.
  11. ALL ALARMS ARE LOCATED ON SECONDARY SAMPLING AUXILIARY PANEL ZLP-887.
  12. DELETED.

LR BOUNDARY DRAWING NO.	REV.
LR-STP-SS-9Z329Z47521#2	0

NO.	ISSUE DATE	REVISION	BY	CHK	RE	DV	NA	SE	PE	NO.	ISSUE DATE	REVISION	BY	CHK	RE	DV	NA	SE	PE	NO.	ISSUE DATE	REVISION	
10		INCRP. DCN 9504204.																					
9	11-3-95	INCRP. DCN 9502253																					
8	4-3-95	INCRP. DCN 9500077.																					
7	8-17-94	HL&P ASSUMES DESIGN CHANGE CONTROL. INCRP. PCF 181357A & EDITORIAL																					
6	12-3-83	ISSUED FOR CONSTRUCTION																					



PIPING AND INSTRUMENTATION DIAGRAM SECONDARY SAMPLING SYSTEM		
SCALE	DWG. NO.	REV.
NONE	9Z329Z47521 *2	10
PRIORITY		