

	JOB PERFORMANCE MEASURE (JPM)
---	-------------------------------

SITE: MONTICELLO NUCLEAR GENERATING PLANT

JPM TITLE: DEPRESSURIZE THE SCRAM AIR HEADER FROM ASDS PANEL

JPM NUMBER: JPM-C.5-3101-001 **REV.** 4

RELATED PRA INFORMATION: None

TASK NUMBERS / TASK TITLE(S): CR314.105
Perform actions associated with alternate rod insertion

K/A NUMBERS: 295037 EA1.03 **Rating: SRO/RO:** 4.1/4.1

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☒ Perform: ☐

EVALUATION LOCATION: In-Plant: ☒ Control Room: ☐
 Simulator: ☐ Other: ☐
 Lab: ☐

Time for Completion: 10 Minutes Time Critical: No

Alternate Path: No

TASK APPLICABILITY: SRO: ☒ RO: ☒ NLO ☒

Additional site-specific signatures may be added as desired.

Developed by:		
	Developer	Date
Validated by:		
	Validator (See JPM Validation Checklist, Attachment 1)	Date
Approved by:		
	Training Supervisor	Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM-C.5-3101-001 (Depressurize The Scram Air Header From ASDS Panel) Rev. 4

JPM Number: JPM-C.5-3101-001JPM Title: Depressurize The Scram Air Header From ASDS Panel

Examinee: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: ☐UNSAT: ☐**COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

*NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily.
If unsatisfactory performance is demonstrated, the entire JPM should be retained.*

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM BRIEFING/TURNOVER

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- The Reactor was manually scrammed due to loss of both Recirc pumps at 100% power.
- Eight control rods are at position 48 with their associated blue scram lights off.
- All RPS scram bus lights are OFF.
- Annunciator 5-B-22 (Scram Pilot Header Hi/Low Pressure) is not in ALARM.

INITIATING CUES (IF APPLICABLE):

- The CRS directs you to depressurize the scram air header from the ASDS panel using C.5-3101 Part B.
- **ALL OPERATOR ACTIONS ARE TO BE SIMULATED UNLESS OTHERWISE DIRECTED**

JPM-C.5-3101-001 (Depressurize The Scram Air Header From ASDS Panel) Rev. 4

JPM PERFORMANCE INFORMATION

- Required Materials:** • None
- General References:** • C.5-3101
- Task Standards:** • Depressurize the Scram Air Header as per Part B, C.5-3101

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step **SHALL** result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Requalification Program Examinations.

Performance Step: 1	(Equipment)
Critical: N	Locates procedure C.5-3101 (Alternate Rod Insertion) and Key 26 for ASDS Panel C-292.
Standard:	1. Locates appropriate procedure <u>And</u> 2. Locates key 26.
Evaluator Cue:	1. Provide operator with a copy of procedure. 2. Inform operator <u>NOT</u> to open EOP file drawer. 3. Simulate giving operator key 26.
Evaluator Note:	Key 26 is in the EOP file drawer and also the Shift Supv office.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM-C.5-3101-001 (Depressurize The Scram Air Header From ASDS Panel) Rev. 4

Performance Step: 2	(Procedure STEP 1a)
Critical: N	<u>If</u> the scram air header is to be depressurized from the ASDS panel, <u>Then</u> perform the following:
	Verify the following switches in NORMAL on ASDS panel:
	<ul style="list-style-type: none"> • SRV Div II Transfer Switch • RHR B Transfer Switch • Core Spray B Transfer Switch • No. 12 Diesel Gen Transfer Switch
Standard:	<ol style="list-style-type: none"> 1. SRV Div II Transfer Switch in NORMAL, <u>And</u> 2. RHR B Transfer Switch in NORMAL, <u>And</u> 3. Core Spray B Transfer Switch in NORMAL, <u>And</u> 4. No. 12 Diesel Gen Transfer Switch in NORMAL
Evaluator Cue:	<ol style="list-style-type: none"> 1. All switches are as you see them. 2. If asked, inform them the amber light above the Rod Insert Air Header dump valve is not on.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Performance Step: 3	(Procedure STEP 1b)
Critical: Y	Place the Master ASDS Transfer Switch to TRANSFER.
Standard:	Places the Master ASDS Transfer Switch to TRANSFER using key 26.
Evaluator Cue:	Switch is in TRANSFER position.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Performance Step: 4	(Procedure STEP 1c)
Critical: Y	Place the Rod Insertion (Dump Air Header) to INSERT
Standard:	Places the Rod Insertion (Dump Air Header) to INSERT and release.
Evaluator Cue:	Switch in INSERT position, spring return to normal.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM-C.5-3101-001 (Depressurize The Scram Air Header From ASDS Panel) Rev. 4

Performance Step: 5	(Procedure STEP 1d)
Critical: N	Verify amber light above Rod Insertion Dump Air Header switch comes on.
Standard:	Verifies amber light above Rod Insertion Dump Air Header switch comes on.
Evaluator Cue:	Amber light is ON.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Performance Step: 6	(Procedure STEP 1e)
Critical: N	<u>When</u> the control rods no longer move inward, <u>Then</u> place the Master ASDS Transfer Switch to NORMAL.
Standard:	<ol style="list-style-type: none"> 1. Asks if control rods are no longer moving in, <u>And</u> 2. Places the Master ASDS Transfer Switch to NORMAL 3. Removes Key 26
Evaluator Cue:	<ol style="list-style-type: none"> 1. Evaluator reports the eight controls rods fully insert. 2. Master ASDS Transfer Switch is in NOMRAL. 3. Key 26 is removed.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Performance Step: 7	INFORM EVALUATOR THAT THE TASK HAS BEEN COMPLETED.
Critical: N	
Standard:	Operator informs evaluator that the task is completed.
Evaluator Cue:	JPM Complete.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Terminating Cues:

Stop Time: _____

Historical Record:

- Converted from I-leaf and updated for 2010 ILT NRC Exam.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

TURNOVER SHEET

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- The Reactor was manually scrammed due to loss of both Recirc pumps at 100% power.
- Eight control rods are at position 48 with their associated blue scram lights off.
- All RPS scram bus lights are OFF.
- Annunciator 5-B-22 (Scram Pilot Header Hi/Low Pressure) is not in ALARM.

INITIATING CUES:

- The CRS directs you to depressurize the scram air header from the ASDS panel using C.5-3101 Part B.
- **ALL OPERATOR ACTIONS ARE TO BE SIMULATED UNLESS OTHERWISE DIRECTED**

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 1**JOB PERFORMANCE MEASURE VALIDATION CHECKLIST**

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
1. Are all items on the cover page filled in correctly?	<input type="checkbox"/>	<input type="checkbox"/>	
2. Has the JPM been reviewed and validated by SMEs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input type="checkbox"/>	<input type="checkbox"/>	
5. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input type="checkbox"/>	<input type="checkbox"/>	
6. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input type="checkbox"/>	<input type="checkbox"/>	
11. Have all special tools and equipment needed to perform the task been identified?	<input type="checkbox"/>	<input type="checkbox"/>	
12. Are all references identified, current, and accurate?	<input type="checkbox"/>	<input type="checkbox"/>	
13. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written. The individual(s) performing the validation sign and date this form.

Validation Personnel /Date

Validation Personnel/Date

Validation Personnel /Date

Validation Personnel/Date

Validation Personnel /Date

Validation Personnel/Date

Validation Personnel /Date

Validation Personnel/Date



JOB PERFORMANCE MEASURE (JPM)

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

SITE: MONTICELLO NUCLEAR GENERATING PLANT
JPM TITLE: TRANSFER OF RPS BUS A TO ALTERNATE SOURCE

JPM NUMBER: JPM-B.09.12-002 **REV.** 1

RELATED PRA INFORMATION: None

TASK NUMBERS / TASK TITLE(S): CR212.109
 Transfer RPS Bus A(B) to its Alternate Source

K/A NUMBERS: 212000 A2.01 **Rating: SRO/RO:** 3.9/3.7

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☒ Perform: ☐

EVALUATION LOCATION: In-Plant: ☒ Control Room: ☐
 Simulator: ☐ Other: ☐
 Lab: ☐

Time for Completion: 10 Minutes Time Critical: No

Alternate Path: No

TASK APPLICABILITY: SRO: ☒ RO: ☒ NLO ☐

Additional site-specific signatures may be added as desired.

Developed by:		
Developer		Date
Validated by:		
Validator (See JPM Validation Checklist, Attachment 1)		Date
Approved by:		
Training Supervisor		Date

JPM-B.09.12-002 (Transfer Of RPS Bus A To Alternate Source) Rev. 1

JPM Number: JPM-B.09.12-002JPM Title: Transfer Of RPS Bus A To Alternate Source

Examinee: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: ☐UNSAT: ☐**COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM BRIEFING/TURNOVER

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.**INITIAL CONDITIONS:**

- Plant is operating at 100% power.
- "A" RPS MG set has tripped due to an electrical fault.
- ½ scram currently exists on RPS Channel "A".
- No maintenance is in progress that will simulate a Division 2 High Drywell Pressure or a Low Reactor Water Level condition.
- Shift Chemist has been informed as to the reason the Off-gas Pretreatment Radiation Monitor is in Alarm.
- No control rod movement is scheduled.

INITIATING CUES:

- CRS directs you to transfer RPS Bus "A" to the alternate power supply and re-energize RPS Bus "A" by performing **steps 7 – 14** of procedure B.09.12-05, section G.1 (Transfer of RPS Bus A to Alternate Source).
- **INFORM THE EVALUATOR WHEN YOU HAVE COMPLETED THE TASK**
- **ALL OPERATOR ACTIONS ARE TO BE SIMULATED UNLESS OTHERWISE DIRECTED**

JPM-B.09.12-002 (Transfer Of RPS Bus A To Alternate Source) Rev. 1

JPM PERFORMANCE INFORMATION

- Required Materials:**
- Poster sized picture of the inside of Panel Y40/Y50 (Attachment A of this JPM)
 - Section G.1 of procedure B.09.12-05 (current revision) with steps 1 - 3 marked as complete and steps 4 – 6 marked as N/A
- General References:**
- B.09.12-05 (Reactor Protection Power Supplies – System Operation), Rev. 21
- Task Standards:**
- RPS Bus A has been transferred and re-energized via alternate source transformer Y60 in accordance with procedure B.09.12-05, section G.1.

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step **SHALL** result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Qualification Program Examinations.

Performance Step: 1	Identify location of controlled copy and review procedure B.09.12-05, section G.1 (Transfer of RPS Bus A to Alternate Source).
Critical: N	
Standard:	Provides verbal description of where to obtain a controlled copy of procedure.
Evaluator Cue:	When operator provides verbal description, provide operator copy of section G.1 of procedure B.09.12-05 with steps 1 - 3 marked as complete and steps 4 – 6 marked as N/A.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM-B.09.12-002 (Transfer Of RPS Bus A To Alternate Source) Rev. 1

Performance Step: 2	Procedure Step 7:
Critical: N	Verify that alternate supply transformer Y60 is energized by verifying that the Y60 ALT FEED AVAILABLE light on Panel Y40 is LIT.
Standard:	Verifies Y60 Alt Feed Available light is lit.
Evaluator Note:	Use picture provided of inside of this panel for operator to simulate actions. If necessary due to picture quality, confirm that light is on.
Evaluator Cue:	When operator observes light indication, inform operator light is lit.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Performance Step: 3	Procedure Step 8:
Critical: N	Verify EPA-157 power output light is ON.
Standard:	Verifies red Power Out light is lit on EPA-157 (located just below Y40).
Evaluator Cue:	If light is already lit, state panel is as is. Otherwise, when operator observes appropriate light, inform operator light is lit.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Performance Step: 4	Procedure Step 9:
Critical: N	Verify EPA-158 power output light is ON.
Standard:	Verifies red Power Out light is lit on EPA-158 (located to the right of the emergency exit door).
Evaluator Cue:	If light is already lit, state panel is as is. Otherwise, when operator observes appropriate light, inform operator light is lit.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

Performance Step: 5 **NOTE 1:** A half Scram on Channel A will occur after opening CB3A.
Critical: N

NOTE 2: During breaker operations, each APRM and RBM will receive a non-critical self test fault, RBM-A will receive critical and non-critical self test faults, 2-of-4 Voter-1 and 2-of-4 Voter-3 will lose all input power, and annunciators 5-A-5 (APRM DOWNSCALE/TROUBLE), 5-A-43 (TBM DOWNSCALE/TROUBLE), and 5-A-3 (ROD WITHDRAWAL BLOCK), will alarm.

Procedure Step 10:
 Open CB5A, SUPPLY TO PROCESS RAD MONITOR A (Panel Y50).

Standard: Places third circuit breaker from the bottom left in the DOWN position.

Evaluator Cue: Circuit breaker is in DOWN position.

Performance: SATISFACTORY ☐ UNSATISFACTORY ☐

Comments:

Performance Step: 6 Procedure Step 11:
Critical: N

Open CB3A, SUPPLY TO RPS CHANNEL A, PCIS (Panel Y50).

Standard: Places first circuit breaker from the bottom left in the DOWN position.

Evaluator Note: Since RPS Channel "A" is already de-energized, the alarms mentioned in the procedure note will already be in alarm. Therefore, there should be no need to contact Control Room prior to opening this breaker.

Evaluator Cue: Circuit breaker is in DOWN position.

Performance: SATISFACTORY ☐ UNSATISFACTORY ☐

Comments:

JPM-B.09.12-002 (Transfer Of RPS Bus A To Alternate Source) Rev. 1

Performance Step: 7 Procedure Step 12:**Critical: Y**

Open CB1A, Y50 NORMAL FEED FROM MG SET A (Panel Y50).

Standard: Places first circuit breaker from the upper left in the DOWN position.**Evaluator Cue:** Circuit breaker is in DOWN position.**Performance:** SATISFACTORY ☐ UNSATISFACTORY ☐**Comments:****Performance Step: 8** Procedure Step 13:**Critical: Y**

Close CB2A, Y50 ALTERNATE FEED FROM Y60 (Panel Y50).

Standard: Places second circuit breaker from the upper left in the UP position moving mechanical interlock bar out of the way as necessary.**Evaluator Cue:** Circuit breaker is in UP position.**Performance:** SATISFACTORY ☐ UNSATISFACTORY ☐**Comments:****Performance Step: 9** Procedure Step 14:**Critical: Y**

Close CB3A (Panel Y50).

Standard: Places first circuit breaker from the bottom left in the UP position.**Evaluator Note:** This performance step is a critical step only if the breaker was opened in performance step 6.**Evaluator Cue:** Circuit breaker is in UP position.**Performance:** SATISFACTORY ☐ UNSATISFACTORY ☐**Comments:**

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM-B.09.12-002 (Transfer Of RPS Bus A To Alternate Source) Rev. 1

Performance Step: 10	Inform Control Room that steps 7 – 14 of procedure B.09.12-05, section G.1 have been completed.
Critical: N	
Standard:	<ul style="list-style-type: none"> • Contacts Control Room and reports RPS Bus “A” has been transferred to the alternate power supply and re-energized. • Informs evaluator task is complete.
Evaluator Cue:	Inform the operator that the JPM is complete.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Terminating Cues: RPS Bus “A” has been re-energized from alternate power supply transformer Y60.

Stop Time: _____

Historical Record:

- Revised for 2010 NRC ILT Exam
- Provided a picture of the inside of the Y40/Y50 panel as Attachment A of this JPM
- Eliminated the option of obtaining permission and opening the panel with a flathead screwdriver

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

TURNOVER SHEET

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- Plant is operating at 100% power.
- "A" RPS MG set has tripped due to an electrical fault.
- ½ scram currently exists on RPS Channel "A".
- No maintenance is in progress that will simulate a Division 2 High Drywell Pressure or a Low Reactor Water Level condition.
- Shift Chemist has been informed as to the reason the Off-gas Pretreatment Radiation Monitor is in Alarm.
- No control rod movement is scheduled.

INITIATING CUES:

- CRS directs you to transfer RPS Bus "A" to the alternate power supply and re-energize RPS Bus "A" by performing **steps 7 – 14** of procedure B.09.12-05, section G.1 (Transfer of RPS Bus A to Alternate Source).
- **INFORM THE EVALUATOR WHEN YOU HAVE COMPLETED THE TASK**
- **ALL OPERATOR ACTIONS ARE TO BE SIMULATED UNLESS OTHERWISE DIRECTED**

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM-B.09.12-002 (Transfer Of RPS Bus A To Alternate Source) Rev. 1

ATTACHMENT A

ATTACHMENT 1

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
14. Are all items on the cover page filled in correctly?	<input type="checkbox"/>	<input type="checkbox"/>	
15. Has the JPM been reviewed and validated by SMEs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input type="checkbox"/>	<input type="checkbox"/>	
18. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input type="checkbox"/>	<input type="checkbox"/>	
19. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
21. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
23. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input type="checkbox"/>	<input type="checkbox"/>	
24. Have all special tools and equipment needed to perform the task been identified?	<input type="checkbox"/>	<input type="checkbox"/>	
25. Are all references identified, current, and accurate?	<input type="checkbox"/>	<input type="checkbox"/>	
26. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written. The individual(s) performing the validation sign and date this form.

 Validation Personnel /Date

 Validation Personnel/Date

 Validation Personnel /Date

 Validation Personnel/Date

 Validation Personnel /Date

 Validation Personnel/Date

 Validation Personnel /Date

 Validation Personnel/Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM-B.09.12-002 (Transfer Of RPS Bus A To Alternate Source) Rev. 1

ATTACHMENT A



JOB PERFORMANCE MEASURE (JPM)

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

SITE: MONTICELLO NUCLEAR GENERATING PLANT

JPM TITLE: USE OF ALTERNATE INJECTION FOR RPV MAKEUP

JPM NUMBER: JPM-C.5-3203-002 **REV.** 9

RELATED PRA INFORMATION: WWHINXTIEY

TASK NUMBERS / TASK TITLE(S): CR314.110
Use Alternate injections systems for RPV makeup

K/A NUMBERS: 295031 **Rating: SRO/RO:** 3.9/3.8
EA1.08

APPLICABLE METHOD OF TESTING:

Discussion: ☐ Simulate/walkthrough: ☒ Perform: ☐

EVALUATION LOCATION: In-Plant: ☒ Control Room: ☐
Simulator: ☐ Other: ☐
Lab: ☐

Time for Completion: 10 Minutes Time Critical: No

Alternate Path: No

TASK APPLICABILITY: SRO: ☒ RO: ☒ NLO ☒

Additional site-specific signatures may be added as desired.

Developed by:		
Developer		Date
Validated by:		
Validator (See JPM Validation Checklist, Attachment 1)		Date
Approved by:		
Training Supervisor		Date

JPM-C.5-3203-002 (Use Of Alternate Injection For RPV Makeup) Rev.9

JPM Number: JPM-C.5-3203-002JPM Title: Use Of Alternate Injection For RPV Makeup

Examinee: _____

Evaluator: _____

Job Title: _____

Date: _____

Start Time _____

Finish Time _____

PERFORMANCE RESULTS:

SAT: ☐UNSAT: ☐**COMMENTS/FEEDBACK: (Make written comments for any steps graded unsatisfactory).****EVALUATOR'S SIGNATURE:** _____

NOTE: Only this page needs to be retained in examinee's record if completed satisfactorily. If unsatisfactory performance is demonstrated, the entire JPM should be retained.

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

JPM-C.5-3203-002 (Use Of Alternate Injection For RPV Makeup) Rev.9

JPM BRIEFING/TURNOVER

You may use any approved reference materials normally available including logs. Make all written reports, oral reports, and log entries as if the evolution is actually being performed.

EOP Immediate Actions are required to be performed from memory. After completing immediate action steps without using the procedure, you may then use any approved reference materials.

If this JPM is performed on the simulator, the JPM administrator should only give cues that are not indicated on the simulator. If simulator indication is sufficient to indicate the completion of a step, the JPM administrator should not have to give a cue to the trainee to continue the evolution.

I will explain the initial conditions, which step(s) to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- The plant is in an emergency condition requiring the use of Alternate Injection Systems for RPV Makeup.
- No. 11 & No. 13 RHRSW pumps are running and the Fire System is not supplying RHR.

INITIATING CUES (IF APPLICABLE):

- The CRS directs you to perform the IN-PLANT steps to CROSS-TIE A RHRSW WITH LPCI using Procedure C.5-3203.
- **ALL OPERATOR ACTIONS ARE TO BE SIMULATED UNLESS OTHERWISE DIRECTED**

EVALUATOR NOTE: Some steps in this procedure require the use of a ladder. To prevent the inadvertent bumping of plant equipment, use of the ladder **MUST BE SIMULATED.**

JPM PERFORMANCE INFORMATION

- Required Materials:** • Ladder (Simulated)
- General References:** • C.5-3203
- Task Standards:** • Crosstie RHRSW to LPCI

Start Time: _____

NOTE: When providing “Evaluator Cues” to the examinee, care must be exercised to avoid prompting the examinee. Typically cues are only provided when the examinee’s actions warrant receiving the information (i.e., the examinee looks or asks for the indication).

IMPORTANT: Critical steps are marked with a “Y” below the performance step number. Failure to meet the standard for any critical step **SHALL** result in failure of this JPM, per FP-T-SAT-73, Licensed Operator Qualification Program Examinations.

Performance Step: 1 Obtain Procedure C.5-3203, PART A, RHR SW CROSS-TIE LPCI.
Critical: N

Standard: None

Evaluator Cue: Provide operator with a copy of procedure.

Performance: SATISFACTORY ☐ UNSATISFACTORY ☐

Comments:

Performance Step: 2 Procedure STEP 1
Critical: Y

CLOSE RHRSW-13, EMERGENCY INJECTION LEAKAGE TELLTALE.

Standard: Closes RHRSW-13 by turning the handwheel CW.

Evaluator Cue: Valve handwheel moves clockwise, stem moves in, meets resistance and is tight.

Performance: SATISFACTORY ☐ UNSATISFACTORY ☐

Comments:

JPM-C.5-3203-002 (Use Of Alternate Injection For RPV Makeup) Rev.9

Performance Step: 3	Procedure STEP 2
Critical: N	Verify CLOSED RHRSW-46, EMERGENCY INJECTION VIA DIESEL FIRE PUMP.
Standard:	Verifies RHRSW-46 Closed by attempting to move handwheel in CW direction <u>Or</u> uses the valve stem position to determine the valve is close.
Evaluator Cue:	Valve handwheel meets resistance, and is tight, or valve stem position indicates valve is closed.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Performance Step: 4	Procedure STEP 3
Critical: Y	OPEN the following valves: <ul style="list-style-type: none"> • RHRSW-12, EMERGENCY INJECTION VIA A RHRSW LOOP • RHRSW-14, EMERGENCY INJECTION VIA A RHRSW LOOP
Standard:	Opens RHRSW-12. Opens RHRSW-14.
Evaluator Cue:	Both valve handwheels move CCW, both valve stems rise, meet resistance and are tight.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Performance Step: 5	INFORM EVALUATOR THAT THE TASK HAS BEEN COMPLETED.
Critical: N	
Standard:	Operator informs evaluator that the task is completed.
Evaluator Note:	The remaining steps of the procedure are performed in the control room.
Performance:	SATISFACTORY <input type="checkbox"/> UNSATISFACTORY <input type="checkbox"/>
Comments:	

Terminating Cues:

Stop Time: _____

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

Historical Record:

- Procedure updates for the 2010 ILT NRC Exam.

TURNOVER SHEET

DURING THE JPM, ENSURE PROPER SAFETY PRECAUTIONS, FME, AND/OR RADIOLOGICAL CONCERNS AS APPLICABLE ARE FOLLOWED.

INITIAL CONDITIONS:

- The plant is in an emergency condition requiring the use of Alternate Injection Systems for RPV Makeup.
- No. 11 & No. 13 RHRSW pumps are running and the Fire System is not supplying RHR.

INITIATING CUES (IF APPLICABLE):

- The CRS directs you to perform the IN-PLANT steps to CROSS-TIE A RHRSW WITH LPCI using Procedure C.5-3203.
- **ALL OPERATOR ACTIONS ARE TO BE SIMULATED UNLESS OTHERWISE DIRECTED**

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.

ATTACHMENT 1

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

ALL STEPS IN THIS CHECKLIST ARE TO BE PERFORMED UPON INITIAL VALIDATION AND PRIOR TO USE.

REVIEW STATEMENTS	YES	NO	N/A
27. Are all items on the cover page filled in correctly?	<input type="checkbox"/>	<input type="checkbox"/>	
28. Has the JPM been reviewed and validated by SMEs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
29. Can the required conditions for the JPM be appropriately established in the simulator if required?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
30. Do the performance steps accurately reflect trainee's actions in accordance with plant procedures?	<input type="checkbox"/>	<input type="checkbox"/>	
31. Is the standard for each performance item specific as to what controls, indications and ranges are required to evaluate if the trainee properly performed the step?	<input type="checkbox"/>	<input type="checkbox"/>	
32. If the task is NOT time critical, has the completion time been established based on validation data or incumbent experience?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
33. If the task is time critical, is the time critical portion based upon actual task performance requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
34. Is the Licensee level appropriate for the task being evaluated if required? Not applicable to Non-Licensed Operators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
35. Is the K/A appropriate to the task and to the licensee level if required? Not applicable to Non-Licensed Operators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
36. Have the performance steps been identified and typed (Critical / Sequence / Time Critical) appropriately?	<input type="checkbox"/>	<input type="checkbox"/>	
37. Have all special tools and equipment needed to perform the task been identified?	<input type="checkbox"/>	<input type="checkbox"/>	
38. Are all references identified, current, and accurate?	<input type="checkbox"/>	<input type="checkbox"/>	
39. Have all required cues (as anticipated) been identified for the evaluator to assist task completion?	<input type="checkbox"/>	<input type="checkbox"/>	

All applicable questions must be answered "YES" or the JPM is not valid for use. If all applicable questions are answered "YES" then the JPM is considered valid and can be performed as written. The individual(s) performing the validation sign and date this form.

Validation Personnel /Date

Validation Personnel/Date

Validation Personnel /Date

Validation Personnel/Date

Validation Personnel /Date

Validation Personnel/Date

Validation Personnel /Date

Validation Personnel/Date

Retention: Life of Plant

Retain in: Training Record

Form retained in accordance with record retention schedule identified in FP-G-RM-01.