



DEC 02 2010

L-PI-10-114
10 CFR 50.73

U S Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Prairie Island Nuclear Generating Plant Units 1 and 2
Dockets 50-282 and 50-306
License Nos. DPR-42 and DPR-60

Cancellation of Licensee Event Reports Associated with Flooding Scenarios

- References:
1. Northern States Power Company, a Minnesota corporation (NSPM), doing business as Xcel Energy, letter to NRC, "LER 1-09-06, Unanalyzed Condition Due to Potential Safety System Susceptibility to Turbine Building Flooding Due to a Postulated High Energy Line Break, Supplement 1", dated April 8, 2010 (ADAMS Accession ML100980611).
 2. NSPM letter to NRC, "LER 50-282/2010-003-00, Postulated Flooding of Battery Rooms Due To Inadequate Battery Room Door Threshold Seals", dated August 9, 2010 (ADAMS Accession ML102220147).

This letter constitutes notification to the NRC of the cancellation of Prairie Island Nuclear Generating Plant (PINGP) Licensee Event Report (LER) 1-09-06 (Reference 1) and LER 50-282/2010-003-00 (Reference 2). The cancellations are consistent with the guidance in NUREG-1022, Rev. 2, "Event Reporting Guidelines 10 CFR 50.72 and 50.73."

Further review of the flooding scenario reported in these LERs has identified that the scenario is not required to be analyzed per the PINGP licensing basis. Licensing documentation related to this issue was discussed at the Regulatory Conference conducted at the NRC Region III on July 13, 2010. Review of licensing documentation has not identified any noncompliance with plant design. Thus, there was no unanalyzed condition or Safety System Functional Failure (SSFF).

Based on the determination that no unanalyzed condition or SSFF existed, NSPM is cancelling LER 1-09-06 and LER 50-282/2010-003-00.

If you have questions regarding this submittal, please contact Jon Anderson at 651-388-1121.

Summary of Commitments

This letter contains no new commitments and no revisions to existing commitments.

A handwritten signature in black ink, appearing to read "Mark A. Schimmel". The signature is fluid and cursive, with a large initial "M" and "S".

Mark A. Schimmel
Site Vice President, Prairie Island Nuclear Generating Plant
Northern States Power Company - Minnesota

cc: Administrator, Region III, USNRC
Project Manager, PINGP, USNRC
Resident Inspector, PINGP, USNRC
Department of Commerce, State of Minnesota