



Entergy Nuclear Northeast
Indian Point Energy Center
450 Broadway, GSB
P.O. Box 249
Buchanan, NY 10511-0249
Tel 914 734 6700

Robert Walpole
Licensing Manager
Tel (914) 734-6710

November 17, 2010

NL-10-112

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

SUBJECT: Withdrawal of Proposed License Amendment Regarding One Time Extension of the Auxiliary Boiler Feedwater Pump Allowed Outage Time Indian Point Unit Number 3
Docket No. 50-286
License No. DPR-64

- REFERENCE:**
1. Entergy Letter NL-09-167 to NRC, "Proposed Exigent License Amendment Regarding One Time Extension of the Auxiliary Boiler Feedwater Pump Allowed Outage Time," dated December 15, 2009.
 2. Entergy Letter NL-09-172 to NRC, "Supplement to Proposed Exigent License Amendment Regarding One Time Extension of the Auxiliary Boiler Feedwater Pump Allowed Outage Time," dated December 22, 2009.
 3. Entergy Letter NL-10-001 to NRC, "Supplement to Proposed Exigent License Amendment Regarding One Time Extension of the Auxiliary Boiler Feedwater Pump Allowed Outage Time," dated January 4, 2010.
 4. NRC Letter to Entergy, "Indian Point generating Unit No. 3 – Determination on Exigent Circumstances For Licensing Amendment Request (TAC No. ME2910)," dated January 5, 2010.
 5. Entergy Letter NL-10-010 to NRC, "Proposed License Amendment Regarding One Time Extension of the Auxiliary Boiler Feedwater Pump Allowed Outage Time," dated January 11, 2010.

Dear Sir or Madam:


Entergy Nuclear Operations, Inc, (Entergy) requested an exigent License Amendment to Operating License DPR-64, Docket No. 50-286 for Indian Point Nuclear Generating Unit No. 3 (IP3) in Reference 1. This was supplemented in References 2 and 3 based on discussions with the NRC. As a result of the NRC request in Reference 4, Entergy changed the request to a

A001
NR

non exigent License amendment request in Reference 5. The proposed amendment was to allow a one time extension of the 72 hour completion time of Technical Specification (TS) 3.7.5, Condition B, Action B.1 "Restore AFW train to OPERABLE status." Entergy was able to complete the necessary repairs within the allowed completion time and the pump has performed well the since then, therefore Entergy would like to withdraw the requested amendment.

If you have any questions or require additional information, please contact Mr. Robert Walpole, Manager, Licensing at (914) 734-6710.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Walpole", written in a cursive style.

RW/sp

cc: Mr. John P. Boska, Senior Project Manager, NRC NRR DORL
Mr. William M. Dean, Regional Administrator, NRC Region 1
NRC Resident Inspectors
Mr. Francis J. Murray, Jr., President and CEO, NYSERDA
Mr. Paul Eddy, New York State Dept. of Public Service