

DiabloCanyonNPEm Resource

From: Ferrer, Nathaniel
Sent: Tuesday, December 07, 2010 3:17 PM
To: Grebel, Terence
Cc: DiabloCanyonNPEm Resource
Subject: Draft Teleconference Summary for November 10, 2010
Attachments: Telecon Summary 11-10-10 AMP.doc

Terry,

Attached is a draft of the Teleconference Summary for November 10, 2010, conference calls. Please review and let me know if there are any corrections/changes needed.

Please let me know if you have any questions.

Nathaniel Ferrer
Project Manager
Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
(301)415-1045

Hearing Identifier: DiabloCanyon_LicenseRenewal_NonPublic
Email Number: 2223

Mail Envelope Properties (26E42474DB238C408C94990815A02F09143A1FDBDD)

Subject: Draft Teleconference Summary for November 10, 2010
Sent Date: 12/7/2010 3:17:03 PM
Received Date: 12/7/2010 3:17:04 PM
From: Ferrer, Nathaniel

Created By: Nathaniel.Ferrer@nrc.gov

Recipients:

"DiabloCanyonNPEm Resource" <DiabloCanyonNPEm.Resource@nrc.gov>
Tracking Status: None
"Grebel, Terence" <TLG1@pge.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	412	12/7/2010 3:17:04 PM
Telecon Summary 11-10-10 AMP.doc		92154

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
NOVEMBER 10, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND PACIFIC GAS AND ELECTRIC COMPANY, CONCERNING
REQUESTS FOR ADDITIONAL INFORMATION RELATED TO THE DIABLO
CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2, LICENSE RENEWAL
APPLICATION (TAC NOS. ME2896 AND ME2897)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Pacific Gas and Electric Company (PG&E or the applicant) held a telephone conference call on November 10, 2010, to obtain clarification on PG&E's response to the staff's requests for additional information (RAIs) regarding the Diablo Canyon Nuclear Power Plant, Units 1 and 2, license renewal application.

By letter dated September 30, 2010, the PG&E sent a response to the staff's RAIs regarding aging management programs. The staff reviewed the information contained therein, and requested a telephone conference call. The telephone conference call was useful in clarifying the intent of the PG&E's response. Enclosure 1 provides a listing of the participants. Enclosure 2 provides discussions on RAI responses for which the staff requested clarification. PG&E will submit supplemental responses, as necessary, within 30 days of the issuance of this summary.

The applicant had an opportunity to comment on this summary.

Nathaniel B. Ferrer, Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosures:
As stated

cc w/encls: Distribution via Listserv

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
NOVEMBER 9, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND PACIFIC GAS AND ELECTRIC COMPANY, CONCERNING
REQUESTS FOR ADDITIONAL INFORMATION RELATED TO THE DIABLO
CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2, LICENSE RENEWAL
APPLICATION (TAC NOS. ME2896 AND ME2897)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Pacific Gas and Electric Company (PG&E or the applicant) held a telephone conference call on November 9, 2010, to obtain clarification on PG&E's response to the staff's requests for additional information (RAIs) regarding the Diablo Canyon Nuclear Power Plant, Units 1 and 2, license renewal application.

By letter dated September 30, 2010, the PG&E sent a response to the staff's RAIs regarding aging management programs. The staff reviewed the information contained therein, and requested a telephone conference call. The telephone conference call was useful in clarifying the intent of the PG&E's response. Enclosure 1 provides a listing of the participants. Enclosure 2 provides discussions on RAI responses for which the staff requested clarification. PG&E will submit supplemental responses, as necessary, within 30 days of the issuance of this summary.

The applicant had an opportunity to comment on this summary.

Nathaniel B. Ferrer, Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosures:
As stated

cc w/encls: Distribution via Listserv

DISTRIBUTION:
See next page

ADAMS Accession No.: **ML103190602**

OFFICE	LA:RPOB:DLR	PM:RPB2:DLR	BC:RPB2:DLR	PM:RPB2:DLR
NAME	SFigueroa	NFerrer	DWrona	NFerrer (Signature)
DATE	11/16/10	11/ /10	11/ /10	11/ /10

OFFICIAL RECORD COPY

Memorandum to Pacific Gas and Electric Company from Nathaniel B. Ferrer dated November XX, 2010

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON NOVEMBER 9, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND PACIFIC GAS AND ELECTRIC COMPANY, CONCERNING REQUESTS FOR ADDITIONAL INFORMATION RELATED TO THE DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION (TAC NOS. ME2896 AND ME2897)

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDlr Resource

RidsNrrDlrRpb1 Resource

RidsNrrDlrRpb2 Resource

RidsNrrDlrRarb Resource

RidsNrrDlrRapb Resource

RidsNrrDlrRasb Resource

RidsNrrDlrRerb Resource

RidsNrrDlrRpob Resource

RidsOgcMailCenter Resource

NFerrer

KGreen

AStuyvenberg

DWrona

AWang

MPeck, RIV

TBrown, RI

GMiller, RIV

NO'Keefe, RIV

ICouret, OPA

VDricks, OPA

WMaier, RIV

JWeil, OCA

EWilliamson, OGC

SUttal, OGC

RRihm, EDO

**TELEPHONE CONFERENCE CALL
DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
NOVEMBER 10, 2010**

PARTICIPANTS

Nathaniel Ferrer

Bart Fu

Terry Grebel

Chris Beard

Justin Whitely

Dan Gibbons

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)

NRC

Pacific Gas and Electric Company (PG&E)

PG&E

PG&E

PG&E

Diablo Canyon Nuclear Power Plant, Units 1 and 2
License Renewal Application
Request for Additional Information
Aging Management Programs

Request for Additional Information (RAI) B2.1.19-2 (follow-up)

In its September 30, 2010, response to RAI B2.1.19-2 (follow-up), the applicant described its sample size for the One-Time Inspection of American Society of Mechanical Engineers (ASME) Code Class 1 Small-Bore Piping Program. However, the staff was unclear about the total population of Class 1 small-bore welds at Diablo Canyon Nuclear Power Plant, Units 1 and 2, and the statistical significance of the sampling size.

Discussion

Pacific Gas and Electric Company agreed to supplement its response to RAI B2.1.19-2 (follow-up) to update its sampling size description for the One-Time Inspection of ASME Code Class 1 Small-Bore Piping Program.