



December 6, 2010

12/06/2010  
75 FR 75704 (1)

Cindy Bladey  
Chief, Rules, Announcements, and Directives Branch (RADB)  
Div. of Administrative Services  
Office of Administration  
Mail Stop: TWB5-B01M  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

RECEIVED

2010 DEC -9 AM 10:06

RULES AND DIRECTIVES  
BRANCH  
USNRC

RE: **Docket ID NRC 2010-0374**  
Docket No. 30-36974  
"Draft Supplement to the Final Environmental Assessment Related to the  
Proposed Pa'ina Hawaii, LLC Underwater Irradiator in Honolulu, Hawaii,  
December 2010."

Dear Ms Bladey:

Overall, I believe that the NRC has done an excellent job in preparing this supplement per the direction of the ASLB.

The following are my comments on significant and pertinent issues of the Draft EA. I do not believe that my comments will effect your overall conclusions. However, I believe these will help the NRC provide an even more precise Final EA.

1) Section 1.3 Proposed Action:

In the first paragraph, the Draft EA states that the License allows for the irradiation "...of other materials as specifically approved by the NRC on a case-by case basis." This is not technically correct. License number 53-29296-01 states for the authorized use: "For use in a Gray\*Star Model Genesis II irradiator for the irradiation of material except explosives, and flammable or corrosive material..."

Other than the restriction of "explosives, and flammable or corrosive material" there are no restrictions in the current license requiring Pa'ina to obtain approval from the NRC on a "case by case basis".



SUDSI Review complete  
Template = ADM-013

FRIDS = ADM-03  
Cell = J. Moore (JAM T)

2) Section 3.2 Description of Electron-Beam Irradiation Facility:

A) In this section the Draft EA states:

*"Ozone is generated as radiation passes through air before reaching the product. Ozone is one of six criteria pollutants identified in the U.S. Environmental Protection Agency's National Ambient Air Quality Standards codified in 40 CFR Part 50. The limit for ozone in air is 0.075 parts per million (ppm). For the x-rays produced by an e-beam, ozone levels of up to 0.7 ppm can be expected (Miller, 2005). Thus, ozone must be removed from the irradiation chamber using a ventilation system. "*

However, the Draft EA does not explain the concentrations of ozone released into the atmosphere and does not justify the statement that the "Air Quality" for an Electron-Beam Irradiator as "Small". Nor does the Draft EA provide comparison to the "Cobalt-60 Irradiator".

I believe ozone production from an e-beam irradiator is much greater than that for a comparable production cobalt-60 irradiator. And, that the ozone generated by an underwater irradiator is far less than a panoramic irradiator. I do not believe that the Draft EA has significantly addressed this point. Especially since the Draft EA brought up the subject and specifically say that the concentrations of ozone for an e-beam unit are approximately 10 times over the allowable limit with no discussion of dilution via ventilation and allowable release limits. As an illustration of this point, the Draft EA's e-beam/x-ray unit requires a ventilation system. The Genesis underwater irradiator does not require a ventilation system to maintain legal ozone concentrations per OSHA and EPA.

B) Figure 6 depicts an electron beam accelerator without any indication of its wattage (production output). I believe that this particular accelerator (in x-ray mode) has only a fraction of the production capabilities of a Genesis Irradiator loaded to its licensed capacity. Therefore, this picture might not be a good illustration for comparison. Production output is certainly an important point for comparison.

3) Section 3.3 Environmental Impacts of the E-Beam Irradiator Facility:

The Draft EA states that "an e-beam irradiator would occupy a small percentage of existing industrial space adjacent to Honolulu International Airport." However, the real question is a comparison between the proposed irradiator and an alternate. If one goes by the rough sketch, and assuming the main shielding walls are 10' thick of normal concrete with a density of 2.3 g/cc, there would be some problems with the analysis. [Please note that I am going by major assumptions and do not have detailed drawings of an e-beam/x-ray unit of comparable output to the proposed underwater irradiator. Therefore, I am only speculating on the following issues and am not providing detailed analysis.]

A) The unit, as sketched, would be approximately 70' x 80'. This is much larger than the proposed underwater irradiator. Further, as sketched, there are more space requirements for product handling and support facilities. The licensed property is 119' x 124' with a 4' set back. It would be difficult, if not impossible, to lay out an e-beam/x-ray irradiator (as sketched) within the proposed lot. Even if it is not important to the analysis to determine if the unit could be used at that site, at the very least, from an environmental perspective, the e-beam/x-ray unit would have a much larger "foot print" for the same production capabilities.


B) A very quick analysis indicates that the concrete shielding alone for the e-beam/x-ray unit (as sketched) would weigh around 10,000,000 pounds. Assuming that the area the irradiator occupies is approximately 5,000 square feet, this would lead to a floor loading of around 2,000 pounds per square foot. I am not sure that the existing soil conditions at that site can bear that amount of weight per area. In other words, there might have to be significant modifications (foundations) to the site to support an e-beam/x-ray unit. The Draft EA has not included any analysis of the environment that might be affected assuming significant foundations need to be made to support the unit.

C) The Draft EA basically states that an e-beam unit in x-ray mode "can have a more significant impact with respect to energy consumption than pool-type irradiators that use sealed sources, assuming the same product volume throughput." However, the Draft EA does not identify this factor (electricity consumption) in Table-2.

D) The Draft EA states that during decommissioning of an e-beam irradiator that there is an "...absence of any radioactive or hazardous materials." I am not sure that this is true. Earlier the Draft EA states that the maximum energy for an e-beam unit is 7.5 MeV. This is not true. There are no regulatory limits that I am aware of for an electron beam accelerator. The "7.5 MeV" reference is the maximum energy allowed by the FDA for energy level of electrons prior to being converted to x-rays. This is only specific to food production. It is typical for accelerators to operate at electron energies well above 7.5 MeV. The Draft EA has not addressed what the actual energy levels are for all the products allowed for under Pa'ina's current license assuming that they were to use e-beam or x-ray. More importantly, it has not analyzed any induced activation of accelerator components due to the high energies used in an e-beam/x-ray unit. Therefore it is not clear that there is an "absence of any radioactive" material with respect to an e-beam/x-ray unit.

Please accept the above comments on the Draft EA as constructive. I thank the Commission for the opportunity to make these comments.

Sincerely,



Russell N. Stein  
Vice President  
GRAY\*STAR, Inc.