

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: ACRS AP1000 Subcommittee

Docket Number: N/A

Location: Rockville, MD

Date: November 17, 2010

Work Order No.: NRC-558

Pages 1-110

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2 DISCLAIMER

3
4
5 UNITED STATES NUCLEAR REGULATORY
6 COMMISSION'S ADVISORY COMMITTEE ON REACTOR
7 SAFEGUARDS

8
9
10 The contents of this transcript of the
11 proceeding of the United States Nuclear Regulatory
12 Commission Advisory Committee on Reactor Safeguards,
13 as reported herein, is a record of the discussions
14 recorded at the meeting.

15
16 This transcript has not been reviewed,
17 corrected, and edited, and it may contain
18 inaccuracies.

19
20
21
22
23
NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
+ + + + +
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)
AP1000 REACTOR SUBCOMMITTEE MEETING

OPEN SESSION

+ + + + +

WEDNESDAY

NOVEMBER 17, 2010

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met, at the
Nuclear Regulatory Commission, Two White Flint North,
Room T2B1, 11545 Rockville Pike, at 8:30 a.m., Harold
B. Ray, Chairman, presiding.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 COMMITTEE MEMBERS:

2 HAROLD B. RAY, Chairman

3 SAID ABDEL-KHALIK, Member

4 J. SAM ARMIJO, Member

5 SANJOY BANERJEE, Member

6 DENNIS C. BLEY, Member

7 MARIO V. BONACA, Member

8 JOY REMPE, Member

9 MICHAEL T. RYAN, Member

10 WILLIAM J. SHACK, Member

11 JOHN D. SIEBER, Member

12 JOHN W. STETKAR, Member

13
14 NRC STAFF PRESENT:

15 PEI-YING CHEN

16 PHYLLIS CLARK

17 LAURA DUDES

18 BILLY GLEAVES

19 JOHN HONCHARIK

20 ROBERT HSU

21 JOHN S. MA

22 EILEEN MCKENNA

23 PRAVIN PATEL

24 JOSE PIRES

25 BRET TEGELER

26 **NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 NRC STAFF PRESENT: (CONTINUED)

2 BRIAN THOMAS

3 JOHN WU

4 WEIDONG WANG, Designated Federal Official

5

6 PRESENT FROM WESTINGHOUSE:

7 MIKE CORLETTI

8 ED CUMMINS

9 WILLIAM LEPAY

10 DON LINDGREN

11 DON MOORE

12 RICHARD ORR

13 ROB SISK

14 DOUG TRIMBLE*

15 LEE TUNON-SANJUR

16 AMIT VARMA

17 RON WESSEL

18

19 ALSO PRESENT:

20 THOMAS S. KRESS, ACRS Consultant

21 BOZIDAR STOJADINOVIC*, ACRS Consultant

22 GRAHAM B. WALLIS, ACRS Consultant

23

24 *Present via telephone

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

C-O-N-T-E-N-T-S

1		
2		
3	Call to Order and Opening Remarks	5
4	Harold Ray	
5	Chairman	
6	Westinghouse Presentation	14
7	Sections 3.7 and 3.8	
8	Don Lindgren	14, 22
9	Lee Tunon-Sanjur	
10	Richard Orr	
11	Questions	19, 31
12	Staff Presentation	35, 42
13	Billy Gleaves	35, 42
14	Senior Project Manager	
15	Office of New Reactors	
16	Pravin Patel	36, 42
17	John Ma	43, 45
18	Joe Braverman	
19	Questions	40, 45, 50
20		
21		
22		

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

C-O-N-T-E-N-T-S (CONTINUED)

1		
2		
3		
4	Westinghouse Presentation	55
5	Balance of Chapter 3	
6	ACRS Action Items 4 and 46	
7	Don Lindgren	55, 58, 62, 63, 75
8	Ron Wessel	
9	Dale Wiseman	
10	Gerry Riegel	
11	Questions	58, 61, 63, 67
12		
13	Staff Presentation	91
14	Balance of Chapter 3	
15	Phyllis Clark	91
16	Robert Hsu	
17	John Wu	91
18	Pei-Ying Chen	97
19	Questions	103
20		
21		
22		
23		

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:31 a.m.

CHAIRMAN RAY: (Presiding) The meeting will now come to order.

This is a meeting of the AP1000 Reactor Subcommittee, a standing subcommittee of the Advisory Committee on Reactor Safeguards. I'm Harold Ray, the Chairman of the Subcommittee.

ACRS members in attendance today are Mike Ryan, Mario Bonaca, Dennis Bley, Bill Shack, John Stetkar, Joy Rempe, and Sam Armijo.

ACRS Consultant Tom Kress is also present. ACRS Consultant Bozidar Stojadinovic is on the telephone from overseas and will participate with us.

CONSULTANT STOJADINOVIC: Yes, I am on the phone.

CHAIRMAN RAY: Thank you, Bozidar.

Weidong Wang is the Designated Federal Official for this meeting.

This meeting is part of the ongoing review of a proposed amendment to the AP1000 Pressurized Water Reactor Design Control Document. In the past, we have had 10 of these AP1000 Subcommittee meetings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 This AP1000 Subcommittee meeting will
2 continue to review the Safety Evaluation Reports on
3 Revision 17 to the AP1000 DCD. During this three-day
4 meeting, we will review Chapters 3, 15, 23, and
5 action items from the past AP1000 Subcommittee
6 meetings.

7 We will hear presentations from the DCD
8 applicant, Westinghouse, and from the NRC staff. We
9 have received no written comments or requests for
10 time to make oral statements from members of the
11 public regarding today's meeting.

12 As shown on the agenda, some
13 presentations will be closed in order to discuss
14 information that is proprietary to the applicant and
15 its contractors, pursuant to 5 USC 552bc(3) and (4).

16 Attendance at these portions of the meeting dealing
17 with such information will be limited to Westinghouse
18 representatives, the NRC staff and its consultants,
19 and those individuals and organizations who have
20 entered into an appropriate confidentiality agreement
21 with them.

22 MEMBER RYAN: Excuse me, Harold.

23 Could whoever is on the phone line put
24 your line on mute?

25 CHAIRMAN RAY: That is on the bridge

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 line.

2 MEMBER RYAN: The bridge line, please.

3 CHAIRMAN RAY: I was going to get to that
4 in a minute.

5 MEMBER RYAN: Sorry.

6 CHAIRMAN RAY: But that's fine.

7 Consequently, we will need to confirm
8 that we have only eligible observers and participants
9 in the room for the closed portions.

10 Now let me digress here briefly and say
11 that the agenda that was provided and is available
12 here in the room would have us go back and forth
13 between open and closed in each of the three
14 presentations this morning. So, we would be making
15 that transition a total of six times. I don't think
16 that's practical for us or for those who would be
17 involved in going in and out of the room and doing
18 the necessary verification.

19 Therefore, we are going to amend the
20 agenda as shown. This portion of the meeting, of
21 course, is open. But when we begin the applicant
22 presentation, it will then be a closed meeting and
23 will remain so through the staff discussions until we
24 get to item 6 on the agenda, at which time we will
25 then have it open except for discussion in that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 section that needs to be closed.

2 This is the only practical way I can see
3 for us to go forward here, since, like I say, going
4 back and forth and having people come in and out of
5 the room at times that it is very difficult for us to
6 know that we are in the open sessions not encroaching
7 on the proprietary information, is the way we will
8 have to do it.

9 So, when I am done here and anything in
10 the other business is concluded, we will close the
11 meeting until item 6 on the agenda.

12 The Subcommittee will gather information,
13 analyze relevant issues and facts, and formulate
14 proposed positions and actions as appropriate for
15 deliberation by the full Committee.

16 The rules for participation in today's
17 meeting have been announced as part of the notice of
18 this meeting previously published in The Federal
19 Register.

20 A transcript of the meeting is being kept
21 and will be available, as stated in The Federal
22 Register notice. Therefore, we request that
23 participants in the meeting use the microphones
24 located throughout the meeting room when addressing
25 the Subcommittee. The participants should first

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 identify themselves and speak with sufficient clarity
2 and volume so that they may be readily heard.

3 And we will now proceed with the meeting.

4 Now I believe, as it is set up now, we
5 basically have two telephone connections: one, the
6 bridge line that Member Ryan spoke about a minute
7 ago, and the other one is on another -- "frisbee" I
8 call it -- here in the room.

9 So, we will close the bridge line for the
10 closed portion of the meeting, unless there is a
11 Westinghouse proprietary line established, but the
12 line with the ACRS consultant on it -- and he's the
13 only one on that line -- will remain open during that
14 time, during the entire meeting. And from time to
15 time, he will make input, a comment to us, ask
16 questions, and so on, just as if he were here.

17 Okay. With that now having been said,
18 Eileen, are you here this morning? And do you have
19 anything you would like to say?

20 MS. MCKENNA: Yes, sir. This is Eileen
21 McKenna from the NRO staff.

22 I just wanted to say, as you said, we
23 were trying to make as much material available as we
24 could. And I will comment that the staff slides are
25 material that can be made public, and the first few

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 slides of Westinghouse's presentation are also non-
2 proprietary. So, that material can be shared in the
3 public domain.

4 But I appreciate the logistical
5 challenges, and we were trying to balance those
6 interests.

7 CHAIRMAN RAY: Yes. Can we do that with
8 the publication of the minutes that are made
9 available to the public, include all the slides that
10 you mentioned?

11 MS. MCKENNA: The ones that I have
12 mentioned as being -- you'll see in the Westinghouse
13 pile there's a few in the front that are non-
14 proprietary and then a larger stack that is
15 proprietary.

16 CHAIRMAN RAY: Yes.

17 MS. MCKENNA: The staff slides are all
18 non-proprietary.

19 CHAIRMAN RAY: But, I mean, when we issue
20 the transcript -- I said the minutes; I was mistaken.

21 Anyway, what's the vehicle by which we will make
22 them available to the public?

23 MS. MCKENNA: I'm not sure what that
24 might be. Maybe your staff has an idea on that, but
25 I'm just making the comment that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Yes.

2 MS. MCKENNA: -- from our perspective,
3 that is material that can be open.

4 CHAIRMAN RAY: All right. Well, I
5 appreciate your saying that, and it is certainly our
6 goal to try to make it available. I'm simply trying
7 to find a path by which members of the public can
8 have access to the slides. Well, we will leave it as
9 something we need to do. But, as you say,
10 logistically, it just doesn't seem practical for us
11 to go back and forth that many times here.

12 Okay. Do you guys have anything you want
13 to say?

14 MR. TUNON-SANJUR: No, thank you.

15 CHAIRMAN RAY: All right. Okay. With
16 that, then, we will take a moment to -- well, let me
17 say this: do you guys, Westinghouse, are you
18 prepared to do your non-proprietary portion and then
19 say, "We're at the proprietary section."?

20 MR. CORLETTI: It's about our first four
21 or five slides.

22 CHAIRMAN RAY: All right. Well, we'll do
23 that then.

24 MR. WANG: The line is already closed.

25 CHAIRMAN RAY: It is already closed?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Okay. Well, so be it. We'll check the room and do
2 that step. Has that been done also?

3 MR. WANG: We are not through yet. We
4 have to make sure.

5 CHAIRMAN RAY: Because if there's anybody
6 here, there's certainly no objection to them
7 remaining.

8 MR. WANG: We'll check it out.

9 (Whereupon, at 8:39 a.m., the proceedings
10 went from open to closed session.)

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

(Whereupon, at 2:55 p.m., the proceedings resumed in open session.)

CHAIRMAN RAY: Back on the record now.

We're in open session finally.

(Laughter.)

We will remain there for as long as I can keep people here and we have something to talk about because we have a big hill to climb; we can't afford to waste any of the available daylight hours.

(Laughter.)

Or the early nighttime hours, either.

So, let's get underway here. The gym is open until midnight, Sanjoy.

MR. LINDGREN: My name is Don Lindgren, Westinghouse Electric. With me is Dr. William LePay, Lee Tunon-Sanjur, and Richard Orr.

We are going to be discussing Section 3-7 and 3-8 in the DCD and the SER. Towards the end of 3-8, I believe we have some additional information that may address Mr. Ray's questions about what are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we putting in the DCD to make sure we build the
2 shield building like we say we do.

3 CHAIRMAN RAY: Please do.

4 MR. LINDGREN: I thought you would want
5 to see that.

6 Okay. And I've got the wrong file here.
7 Sorry about that.

8 CHAIRMAN RAY: It happens to the best of
9 us.

10 MR. LINDGREN: Okay. There we go. Okay.

11 The first thing we are going to talk
12 about is 3-7, which is seismic design.

13 Just to remind you what's in 3-7, 3-7.1
14 is about seismic input. That is the design, and the
15 response, and the supporting media.

16 3-7.2 is titled, "Seismic System
17 Analysis", which means structures in this Chapter.

18 The 3-7.3 is seismic systems analysis,
19 which is really mechanical systems and components,
20 particularly piping.

21 3-7.4 is seismic instrumentations, and we
22 made no changes in that.

23 And then, finally, there is a section on
24 combined license information items. And we did
25 include a timing clarification on that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The changes in 3-7 were the extension
2 from just hard rock sites to soil sites, utilization
3 of 3D finite element shell models, instead of --

4 MEMBER SHACK: Isn't the extension to two
5 hard rock sites --

6 MR. LINDGREN: Yes. We included hard
7 rock, yes. Previously, we only had hard rock sites.

8 Now we have six soil cases all together, including
9 hard rock.

10 We addressed the effect of high-frequency
11 ground motion, use of the coherency function, and
12 classification of adjacent buildings. Those were the
13 changes.

14 And it was primarily the changes that
15 drove the NRC questions and open items. There were
16 15 open items all together in the 3.7 SER. As I
17 said, these items were primarily as a result of NRC
18 staff questions about the changes in the DCD, and the
19 largest number of them were due to questions about
20 the addition of the soil changes and things that fell
21 out of that. These open items have all been
22 resolved.

23 I selected a few of the more interesting
24 ones to discuss. I am not going to go through all of
25 them, but just the ones that typically were the most

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 difficult to come to agreement on. So, we can do
2 more if you have questions, but these were what we
3 think were the critical ones.

4 There were two of them that were closely
5 aligned. They were related to justifying the
6 concrete cracking and the damping values we used in
7 the analysis and justifying the .8 stiffness
8 reduction factor for concrete cracking used in the
9 shield building analysis.

10 This is resolved. We did this by doing
11 an additional nonlinear time history analysis that
12 supported the original analysis assumptions. That
13 is, the .8 stiffness factor reduction.

14 Oh, and we have two more that were
15 closely aligned to each other. We requested to
16 provide a description of a proposed method of using a
17 more detailed NI05 model to evaluate the flexible
18 regions, and then addressed some issues related to
19 the NI20 model for flexible regions up to 50 hertz.

20 As a reminder, NI stands for nuclear
21 island; 05 is the approximate size in feet of the
22 elements that are in the model. We have an NI05,
23 NI10, and NI20, and we had questions coming about
24 some of the modeling of these.

25 Once again, these are resolved. The NI05

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 model was reviewed to find the flexible regions where
2 the out-of-plane response is considered flexible.
3 The floor response spectra for the flexible nodes are
4 included in the design floor response spectra
5 document as a separate table for area-specific
6 spectra to use in local analysis.

7 The next item we want to discuss was a
8 question to justify the treatment of missing mass in
9 mode superposition. The resolution was a
10 determination that the mode superposition time
11 history analysis provides a sufficient solution
12 accuracy because the modes which respond beyond the
13 cutoff frequency have no significant contribution to
14 the structure amplified response spectra.

15 The way this was determined was we did a
16 time history analysis of the cutoff frequency, which
17 was compared to an identical time history analysis
18 with significantly more modes, and the results were
19 comparable.

20 The next item was a request to include
21 the methodology for structure/soil, structure
22 interaction analysis of buildings adjacent to the
23 nuclear island. To resolve this, we included the
24 methodology we used in the DCD. The seismic analysis
25 that is performed for the adjacent seismic Category

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 II structures is a simulated 3D analysis, and the
2 seismic Category II buildings are designed using
3 envelope foundation input response spectra.

4 And the next one, because of the changes
5 in the shield building dimensions, we are asked to
6 update the sloshing analysis of the PCS tank. That
7 is the tank on the roof of the shield building.

8 The actual change from the Rev. 18 design
9 to the enhanced shield building was that the roof was
10 basically dropped about 5 feet. Rev. 15, okay, that
11 was in Rev. 15.

12 And the actual configurations of the tank
13 stayed the same. It was just dropped down 5 feet.
14 NRC did audit our calculations and agreed with the
15 conclusions.

16 MEMBER ARMIJO: Could I ask a question on
17 that?

18 MR. LINDGREN: Yes.

19 MEMBER ARMIJO: In the SER, you dropped
20 that rise in the roof by 5 feet.

21 MR. LINDGREN: It wasn't actually the
22 rise. The whole roof was dropped 5 feet.

23 MEMBER ARMIJO: Okay.

24 CHAIRMAN RAY: Including the ring, and so
25 on, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LINDGREN: Yes, it's just the whole,
2 from the roof up, was just translated down 5 feet.

3 MEMBER ARMIJO: I thought it was just the
4 slope of the roof was flattened?

5 MR. LINDGREN: No.

6 MEMBER ARMIJO: Okay. Everything was
7 lowered?

8 MR. LINDGREN: Everything. So, the
9 dimensions from the intersection of the shell of the
10 cylinder with the roof up, those dimensions did not
11 change.

12 MEMBER ABDEL-KHALIK: We had used the
13 cylindrical wall.

14 MEMBER ARMIJO: Okay. Okay, and you
15 dropped that 5 feet, but it says that you got a 20
16 percent reduction in wind loads. How is that
17 possible with such a small -- you know, I don't know
18 how that could be.

19 MR. LINDGREN: You're reading from the
20 SER?

21 MEMBER ARMIJO: Yes. Yes, I'm reading
22 from the SER. It's Section 3.3.3, the evaluation in
23 the SER.

24 MR. LINDGREN: Well, yes, the wind
25 doesn't actually impact the sloshing analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: No.

2 MR. LINDGREN: Okay.

3 MEMBER ARMIJO: It just said, it just
4 stated -- I don't know why they even said it, but it
5 didn't make any sense to me, but maybe --

6 MR. LINDGREN: Okay.

7 MEMBER ARMIJO: Bill Shack and I
8 discussed it, and he had an explanation, but I was
9 hoping that you might have.

10 (Laughter.)

11 MR. LINDGREN: It's not that much of a
12 change. So, I don't know.

13 MEMBER ARMIJO: So, you don't know?
14 Could you find out?

15 CHAIRMAN RAY: Well, we will ask the
16 staff.

17 MR. TUNON-SANJUR: We must have had
18 something we said that led them to it. So, we'll
19 find the right --

20 MEMBER ARMIJO: Okay.

21 MEMBER SHACK: He's got a vivid
22 imagination.

23 (Laughter.)

24 MR. LINDGREN: Okay. Okay, you were
25 looking in the 3.7 SER for that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: 3.3.3 is the check.

2 MR. LINDGREN: Okay. We are actually
3 going to talk about that 3.3 section later.

4 MEMBER ARMIJO: Okay.

5 MR. LINDGREN: Okay? Okay, that's all we
6 have in 3.7.

7 We will now talk about 3.8. Okay, 3.8 is
8 the design of Category I structures. Everything that
9 we have talked about in the morning fits in this
10 section. But we won't be talking about most of what
11 we talked about this morning.

12 Okay. What is included in 3.8 is steel
13 containment. That is in 3.8.2. And a reminder that
14 we have a self-standing shield building which stands
15 inside the containment, inside the shield building,
16 but it supports itself.

17 We have concrete and steel internal
18 structures. These are primarily the structural
19 modules that are inside containment and hold the
20 reactor vessel in place, and those items.

21 We have a section on other Category I
22 structures. That includes the aux building as well
23 as the shield building.

24 And then, finally, we have a section on
25 foundations or the basemat, as we call it, under the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 nuclear island.

2 The changes from Rev. 15, which was the
3 Certified Design, we did introduce the enhanced
4 shield building, which was discussed this morning.
5 We extended the AP1000 structure design to sites
6 ranging from soft soils to hard rock. In some cases,
7 that changed our design. In all cases, it changed
8 our analysis.

9 Critical section design was updated.
10 There are 12 critical sections all together, plus
11 three in the basemat. These were updated. These
12 were updated because of the addition of the soil
13 cases and, also, for design finalization changes. We
14 also did a settlement evaluation for settlement
15 during construction to include the construction
16 sequence limits.

17 Items have been resolved with the NRC,
18 and the DCD changes are included in DCD Rev. 18.
19 There were 20 open items that were identified in the
20 SER. Since that was issued, there was one additional
21 RAI that we addressed, and two of those items were
22 actually placeholder items for NRC action.

23 Once again, I have picked up a selection
24 of open items to address here. We had an open item
25 and an RAI that were related asking about details

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 regarding the temperature and external pressure loads
2 of the containment and explaining the assumptions we
3 used to evaluate the containment external pressure.

4 We met with the NRC to explain the
5 analysis. There are several NRC groups involved in
6 this, both structures and thermal hydraulic type of
7 people.

8 We provided an analysis for audit. In
9 some respects, this is less important than it was
10 because we included a design change to include a
11 vacuum relief system on the containment. So, the
12 external pressure maximum becomes what the relief
13 system is set to, open for.

14 CHAIRMAN RAY: Are you going to discuss
15 that any other time than now?

16 MR. LINDGREN: The vacuum relief system
17 is scheduled to be discussed on Friday as part of the
18 Chapter 3 items.

19 CHAIRMAN RAY: Okay.

20 MR. LINDGREN: Okay? We did update a
21 load combination table in the DCD, also, to address
22 this.

23 The structural part of this question is
24 probably the easiest, once you know what the pressure
25 is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 3.8.3, which is internal structures
2 again. We had an open item that described how the
3 loads in the module can be properly transferred from
4 the module to the embedded bars in the base concrete.

5 The end result of this was we made a design change
6 to include the use of mechanical connectors.
7 Previously, we had what was referred to as the lap
8 splice approach, which were dowel rods coming from
9 the base concrete through the structural modules. We
10 have changed the design so that there is a mechanical
11 connection or a weld to a base plate, to accomplish
12 this load transfer.

13 Other Category I structures, there was a
14 question about explaining and justifying the AP1000
15 implementation of the 100/40/40 method for a
16 combination of the three-directional seismic loading.

17 We provided a comparison of the calculated
18 reinforcement demand with the 100/40/40 combination
19 we were using to the technique that is identified in
20 the ASCE 4-98 combination, and the Westinghouse
21 method, the Westinghouse design was deemed to be
22 acceptable.

23 Okay. Moving on to the basemat, there
24 was a request to make several of our technical
25 reports Tier 2* information or provide an acceptable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 alternative. The resolution of this was to add
2 information from TR-09, TR-85, TR-15. These mean
3 nothing to you. That is the Containment Design
4 Report, the Basemat Report, and the High-Frequency
5 Motion Report, and include those in Rev. 18.

6 We also included information from the
7 Shield Building Report as part of our response. And
8 TR-57, which was a TR about critical sections, was
9 withdrawn because essentially all the information in
10 TR-57 was in the DCD. So, it really served no
11 purpose anymore.

12 Now, at this time, this is a good time
13 for me to go into -- this is where we addressed the
14 Tier 2* information at the same time. So, we can
15 show you what we did.

16 Now this is a review copy. So, it's a
17 little busy.

18 CHAIRMAN RAY: What are you talking
19 about?

20 (Laughter.)

21 MR. LINDGREN: Anyway, this shows that in
22 the shield building, this is just to give you an idea
23 of what we have done. I don't expect any real review
24 here.

25 CHAIRMAN RAY: That's good.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MR. LINDGREN: So, we have identified in
3 3.8 the information about the shield building, and
4 this includes assumptions and what the features are.

5 Okay. And as you can see, we have added a page and
6 a half of material.

7 I will tell you that this agreement was
8 reached in the last two months. Both we and the NRC
9 staff realized that we did not have time to come to a
10 final resolution on what ought to be Tier 2*. So,
11 they are treating that information as confirmatory.
12 So, we have another chance to discuss what ought to
13 be Tier 2*.

14 So, that is the kind of information we
15 have added in 3.8 on the shield building. Just to
16 remind you that in 3.8 there is a list of the
17 critical sections, and that is this list is, in fact,
18 Tier 2*.

19 There is additional information that has
20 been added on testing and in-service inspection
21 requirements. This is all 3.8, which is other
22 structures.

23 So, we have identified places that need
24 -- in this case we looked for leaks when we fill up
25 the shield building, and this identifies where we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looked for it.

2 And then, we also have -- I skipped a
3 page. Instruction inspection, we've got information
4 inspection and we have added a couple of paragraphs
5 on the shield building markup program and process
6 control, that sort of thing.

7 Then, to top it all out, we have added a
8 couple of COL information items on the structures
9 inspection program and the construction procedures
10 program. So, these are both COL information items
11 that have been added.

12 Okay. Now we also put information about
13 the shield building into 3h. So, we have added
14 information about the tie bars here. This is all
15 Tier 2* information.

16 The summary of in this case the shield
17 building roof, this will be in Rev. 18. We have
18 added information about the shield building
19 cylindrical wall, the air inlets, the tension ring,
20 the shield building roof, the compression ring, the
21 knuckle region --

22 CHAIRMAN RAY: Is there ever any drawings
23 in this?

24 (Laughter.)

25 MR. LINDGREN: Well, first of all, let me

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do tables first. Tables come before.

2 So, what we have here, a reinforcement
3 summary, and you see that what we have done is we
4 have made the steel area provided as reinforcement as
5 Tier 2*. So, you can't go below that without NRC
6 approval. So, these tables are different, but they
7 are pretty much all the same.

8 This is the air inlet and tension ring
9 area that we have here. And, yes, we have drawings.

10 CHAIRMAN RAY: Good.

11 MR. LINDGREN: You can't see this one,
12 but we do have a drawing. This happens to be for the
13 shield building roof, and we have some dimensions
14 here. So, when Rev. 18 comes out, you can --

15 MR. TUNON-SANJUR: And this is meant for
16 the roof. It's got to capture the geometry of the
17 roof, so that we won't change it again. So, we will
18 have to do sloshing analysis all over again in the
19 future.

20 MR. LINDGREN: We have a smaller scale on
21 the intersection of the roof, the tension ring, and
22 the vents.

23 MR. TUNON-SANJUR: And these are the
24 drawings that Tod was going over in detail this
25 morning.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LINDGREN: And you will notice that
2 here we do identify the tie bars and the spacing on
3 the tie bars for both horizontal and vertical.

4 CHAIRMAN RAY: So, if I can read that,
5 say the weld detail, which is one of the questions
6 that was asked --

7 MR. LINDGREN: I don't believe the weld
8 details are on here.

9 CHAIRMAN RAY: Okay.

10 MR. TUNON-SANJUR: But the way we are
11 going to inspect it, it's in the DCD.

12 MR. LINDGREN: Yes. Well, the welds are
13 really more standard-driven.

14 Let me get down and see what else I've
15 got here to show you.

16 We have the vertical slice. This is the
17 horizontal slice that also shows the tie bars, and I
18 guess these are pockets.

19 And we have one that shows the interface
20 of the -- and this is all the rebar that is required
21 for the interface of the roof and the exterior wall
22 of the tank. This is referred to as the knuckle
23 region, if you see that reference.

24 Okay. Finally, we also have, in Tier 1,
25 there is information that is in Tier 1. In this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 case, it's mostly about the concrete, but it does
2 include a little bit about the liner.

3 And then, there is an ITAAC that was
4 already in there that talks about inspection of the
5 structures. A report exists that reconciles
6 deviations during construction, including the
7 critical sections. So, this was already in here.
8 That is not anything new, and there are figures in
9 Tier 1 that identify the overall configuration of the
10 shield building.

11 And then, finally --

12 CHAIRMAN RAY: Well, some of that stuff
13 you're looking at, Don, would go to the issue that
14 -- I mean, for example, one of the things you just
15 flashed across there was be analyzed to design basis
16 loads. Well, obviously, of course, they will be.

17 But to the extent that somebody around
18 here is looking to margins, I mean I would think it
19 would be irresponsible for you to specify all the
20 margins as belonging to somebody other than yourself.

21 And therefore, the margins I'm talking about would
22 be margins that are taken credit for in the safety
23 findings. In my mind, those would go well beyond
24 making sure that design basis requirements are met.
25 But that is where the uncertainty lies in my mind.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You've got a lot of detail in there that
2 creates margins. I understand that. In other words,
3 you've got information about reinforcing and many,
4 many, many things that, when you put them all
5 together, they create margin and you can't take that
6 away. So, that's good.

7 MR. LINDGREN: We have included in the
8 critical sections what, here, like the maximum
9 required reinforcement.

10 CHAIRMAN RAY: Yes, absolutely.

11 MR. LINDGREN: And this is subject to the
12 50.59 kind of rules for any changes to the DCD.

13 CHAIRMAN RAY: Yes, and I've done a few
14 50.59's in my lifetime. So, if I was going to
15 change, I would have to take a look and say, is it
16 making any significant reduction in margin? Not
17 just, can I still meet the code?

18 MR. LINDGREN: Right. Well, speaking of
19 codes, because this question was asked, we do
20 identify both ACI-349 and AISC N690 as codes we live
21 to. And you will notice it says, "For design
22 materials, fabrication, construction, inspection, and
23 testing". So, these are in the DCD for these
24 structures and they impact Tier 2*.

25 CHAIRMAN RAY: Well, is that in conflict,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for example, with the idea that -- does it refute
2 anybody who would argue that the ultimate failure
3 mode for any part of the structure was a brittle
4 failure, for example? Brittle being something that
5 is a term that is used. Whether it is accurate or
6 not, we know what we mean.

7 I read that up there. It says, "The
8 following standards are applicable to the design."
9 Well, you can read that two ways. You can say
10 they're applicable to the design to the extent that
11 they apply to the design. Fine. But here's where it
12 doesn't apply, you know.

13 MR. LINDGREN: I believe the question
14 was, do the ACI-349 requirements for construction
15 apply?

16 MR. CUMMINS: So, this is Ed Cummins.

17 I think earlier you were saying, what
18 makes you make a construction joint the right way?

19 CHAIRMAN RAY: Yes.

20 MR. CUMMINS: Well, we have to meet the
21 ACI-349 code for construction joints. I mean, so --

22 CHAIRMAN RAY: Yes. Let me stop you
23 right there.

24 That really wasn't what I said. The
25 question wasn't doing it the right way. It was doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it the way you presented and was accepted as okay.
2 That's different than doing it the right way.

3 (Laughter.)

4 In some people's minds at least.

5 MR. CUMMINS: Yes.

6 CHAIRMAN RAY: Okay.

7 MR. CUMMINS: But I mean a reference was
8 made to the ASME code. If you follow the ACI-349 and
9 N690, you get a whole bunch of requirements on
10 welding and all kinds of other things which those
11 sentences say that, when we have a conflict with some
12 inspector, that's where we're going to go to settle
13 the conflict because we are committed to the codes.

14 CHAIRMAN RAY: Yes, well, it is where the
15 codes don't apply that -- anyway, let's not argue.

16 MR. LINDGREN: Okay. So, I hope I have
17 given you a little more information about what we are
18 doing.

19 CHAIRMAN RAY: Yes.

20 MR. LINDGREN: Okay. Also, on the
21 basemat, we were asked to justify the assumption of
22 uniform soil spring beneath the basemat. The
23 resolution included a comparison of the maximum
24 reactions of the nuke island for various soil and
25 analysis methods. The comparison was completed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We also completed a comparison between
2 equivalent static and dynamic time history analyses,
3 and both linear and nonlinear models were compared.
4 The comparison demonstrated that the assumption was
5 acceptable.

6 And that's all we have.

7 CHAIRMAN RAY: All right. Any questions?
8 Any more questions?

9 (No response.)

10 Whoever is on the phone line, would you
11 put it on mute, please? I guess we used to put them
12 on listen-only, and we can do that also.

13 All right, moving right along then, we
14 will go to item 8 on our agenda, Tegeler and company.

15 Anytime you're ready, Billy.

16 MR. GLEAVES: Yes, sir.

17 This presentation will be on Section 3.7
18 of the AP1000, the DCD seismic design review.

19 I'm Billy Gleaves, Senior Project Manager
20 in NRC's Office of New Reactors and also the Project
21 Manager for Section 3.7 and 3.8.

22 This entire presentation has been
23 prepared in a non-proprietary manner.

24 At this point, all of the open items from
25 the July meeting have been either closed or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 considered by the staff to be confirmatory, which, of
2 course, confirmatory awaiting the Revision 18 to the
3 DCD, which is expected in the beginning of December.

4 The items in 3.7, one above, we plan to
5 discuss one. For Section 3.7.2, we just plan to
6 discuss five of those items.

7 But I would like to note that
8 Westinghouse has already addressed all of the items
9 that we had planned to address except for one, which
10 is TR-0301.

11 CHAIRMAN RAY: Graham, could you move
12 your microphone back away?

13 CONSULTANT WALLIS: Oh, I'm sorry.

14 MR. GLEAVES: So, hopefully, that will
15 speed things up.

16 Missing from this slide is the
17 contribution of Terri Spicher in DNRL, who helped to
18 prepare the 3.7 and 3.8 phase 2 evaluation.

19 Pravin Patel will now discuss the open
20 items as they have been changed or closed or
21 converted to confirmatory that we believe are of
22 greatest interest to you all.

23 Thank you.

24 MR. PATEL: Thank you, Billy.

25 My name is Pravin Patel, structural

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 engineer in NRO SED1.

2 Most of the items that we have identified
3 that was a little bit of interest to the ACRS
4 Committee were already addressed by Westinghouse, but
5 I will go into some of them in a little bit more
6 detail, if you like.

7 But, starting with the open items that
8 were left out from the phase 2 presentation, one of
9 them is an interesting item is SRP3.7.1-SEB1-19. It
10 has to do with justification of the concrete model
11 reduction to 80 percent.

12 To demonstrate, Westinghouse assumed a
13 damping value for these composite steel construction
14 of .5 percent damping value and then for concrete 7
15 percent.

16 The applicant performed a nonlinear time
17 history analysis using the finite element code, which
18 the concrete is allowed to crack intentionally, and,
19 also, applicant provided plots to test what's the
20 time in SC concrete.

21 Ensured that the predictors either were
22 close to or at least to the cracking limit of 43 ksf.

23 So, basically, we looked at calculations
24 and found that the cracking was uniform on the SC
25 structure. So, appropriately, they considered the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 value of piping on damping and a 7 percent damping
2 reinforced concrete is appropriate.

3 Regarding justification of .8 modulus
4 reduction, applicant, I mean Westinghouse also
5 provided the plot of stress versus strain for the
6 highly-stressed element in the shell building, which
7 this morning was presented.

8 Based on the review of the staff, we
9 found that this is also acceptable.

10 Next slide, please.

11 These two areas are similar, except the
12 PRP-032 is related to CRDS, which is a 35 design
13 response spectra, is up to 33 hertz. The staff had a
14 concern that the flexible region of the wall and
15 floor and roof are -- when we looked at the analysis
16 of the model which is NI20, we found that they might
17 not predict the flexible region in the structure's
18 wall and floor and roof in the southern part of the
19 building.

20 So, staff had a concern. So,
21 Westinghouse performed a little detailed analysis
22 with reducing the element size to NI05, which they
23 mentioned. And the analysis showed that there are
24 some flexible regions in the structure.

25 So, it created requirements in the DCD

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 how those regions will be evaluated by providing a
2 table in a technical report as well as in the DCD to
3 address those areas.

4 So, staff is satisfied with those
5 requirements, that if there is any SSE test to floor
6 or wall or roof, they will be addressed by using the
7 specific response spectra for those locations.

8 Regarding the 3.7.1-SEB1-06, it is the
9 same thing, except that is the high-frequency of
10 input. It is up to 50 hertz. Those are the same way
11 of analyzing except they have different input for the
12 high-frequency.

13 Next slide, please.

14 This is the one that when they changed
15 the design of the turbine building they wanted to
16 carry the building as a Category II structure, the
17 first bay, which is closer to the nuclear island.
18 They changed the classification and, also, the rest
19 of the turbine building was, according to Revision
20 15, that was non-acceptability.

21 So, staff is concerned, how are you going
22 to implement this change with respect to between the
23 southern building and nuclear island. So, applicant
24 did the soil/structure intersection analysis and
25 showed that there is very little effect on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 nuclear island with respect to this. And also, they
2 provided a requirement that we follow, if they have
3 site-specific requirements for the soil.

4 Next slide, please.

5 This is TR-3001. That is the open item
6 was there on phase 2. Now it is confirmatory. This
7 is related to the description and to the technical
8 report that did not address any detailed modeling
9 analysis for the shield building. Technical Report 3
10 was related to seismic analysis of the nuclear island
11 structure, which is certified design requirements
12 that are addressed in TR-3 related to all soil cases
13 and hard rock analysis.

14 So, applicant added to, revised the
15 Technical Report 3. So, staff is satisfied with that
16 the description they have included in the TR-3 as
17 well as that same carried forward to the DCD. Some
18 of the information that is required are essential
19 requirements.

20 Next open item, SRP3.7.1-SEB1-17. This
21 RAI was related to the residual response of missing
22 mass.

23 MEMBER SHACK: What is missing mass?

24 MR. PATEL: When you have an analysis
25 that goes beyond certain frequency level, cutoff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency, which is 33 hertz, then the analysis is a
2 little bit unpredictable. So, then, you started to
3 lose much in calculations. So, that was Dr.
4 Kennedy's people that helped me address those missing
5 mass, according to that justification.

6 DR. LePAY: Just to clarify a little bit,
7 when you do a relative position time history
8 analysis, one of the parameters that you select is
9 the number of modes to retain in the solution. To
10 retain 100 percent of the mass, you would need a mode
11 for every degree of freedom in the system, which is
12 impractical.

13 So, typically, depending on the frequency
14 content of the input, a cutoff frequency is defined.

15 But these are the important structural modes.

16 Of course, when you add up the mass
17 participation of those modes, it is less than 100
18 percent. So, the question is, well, what effect did
19 the, quote, "missing mass" have on the overall
20 response? So, there are mathematical procedures to
21 incorporate the effect of that missing mass as a
22 pseudo-mode which accelerated at the level of the
23 input motion, and it gets added into the modal
24 responses for the modes that you included in the mode
25 position time history.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In the case of Westinghouse's
2 implementation of mode position time history, they
3 did not directly implement a missing mass correction
4 methodology. Instead, they just added more modes
5 beyond the cutoff frequency in the solution. So, we
6 just asked them to confirm that their approach gave
7 results that were comparable numerically to results
8 that would be obtained if they had included a missing
9 mass correction.

10 Their approach to doing that, as Don
11 Lindgren discussed, was to compare the solution
12 results for all the modes up to the cutoff frequency
13 and then to include maybe another 20 or 30 modes
14 beyond that and show that the results didn't change.

15 MR. PATEL: Next slide, please.

16 So, at this point, all the items in
17 Section 3.7 are resolved or confirmatory pending the
18 DCD revision, which is really already mentioned that
19 is coming in December. And, also, technical reports
20 belong to these sections, which is TR-3 and TR-115,
21 will come also in December, at the same time.

22 So, this concludes my presentation.

23 CHAIRMAN RAY: Any questions?

24 (No response.)

25 Very good. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 All right. Now, Eileen, it looks like
2 we're back to Westinghouse again for open items.

3 MS. MCKENNA: Well, actually, we have the
4 staff's 3.8 presentation --

5 CHAIRMAN RAY: Oh, oh, oh.

6 MS. MCKENNA: -- and a couple of
7 different players to come up.

8 CHAIRMAN RAY: Yes. Of course. Sorry.
9 I was reading the wrong column.

10 Okay, it's a familiar face.

11 (Laughter.)

12 Who's in charge? Billy?

13 MR. GLEAVES: All right. This is the 3.8
14 shortened version presentation. Again, this
15 presentation has been prepared in a non-proprietary
16 manner.

17 As you can see from this slide, all the
18 open items are either resolved or are considered to
19 be confirmatory, waiting for the Rev. 18 of the DCD.

20 We have selected some of the items for
21 the presentation that we believe may be of the most
22 interest to the Committee.

23 For 3.8.2, we have selected two items,
24 one item each from 3.8.3 and .4 and five items from
25 3.8.5. And unlike the 3.7 presentation, Westinghouse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 has only addressed two of those.

2 So, the technical presentation today will
3 be made by Mr. John Ma, who is the lead structural
4 reviewer in Structural Engineering.

5 DR. MA: I have help from Joe Braverman
6 and Professor Carl Constantino.

7 This steel containment issue, applicant
8 was requested to explain whether the design and
9 construction and inspection of the plan are in
10 accordance with current Regulatory Guides. And the
11 resolution is information they provided to
12 demonstrate that design and construction of
13 containment is in accordance with Reg Guide 1.57,
14 Revision 1, for load combinations and design limit,
15 Reg Guide 1.7, Revision 3, for hydrogen-generated
16 pressure loads, and Reg Guide 1.199, Revision 0, for
17 anchorage.

18 Inspection of other plant structures, the
19 DCD will be revised to indicate that the COL
20 applicant is responsible for establishing a
21 structural inspection program consistent with the
22 Maintenance Rule 10 CFR 50.65 and Reg Guide 1.160.

23 So, based on that, we believe they have
24 complied with the Regulatory Guides.

25 Next one, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The next issue is additional information
2 needed to describe the 3-D finite element model of
3 containment used for local evaluation near
4 penetrations and axisymmetric model used for analysis
5 away from penetrations.

6 They used those two models. Both are
7 three-dimensional finite elements. So, we want more
8 information.

9 The information provided to describe both
10 models with specific reference to TR-09 for more
11 detailed information, and DCD markup provided to
12 incorporate the additional description presented in
13 the RAI response because at the time they did not
14 describe clearly. So, in our RAI, we asked them to
15 describe clearly how the model was generated and was
16 done.

17 And based on what they gave to us, the
18 information, we believe that is complete.

19 The next one, please.

20 The next one is the connection detail.

21 CHAIRMAN RAY: That information, though,
22 would still need to be in Rev. 18? Is that the way I
23 understand it?

24 MR. BRAVERMAN: Some of it is already in
25 the prior DCD Rev. 17, but there was some additional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information missing. They gave us an RAI response
2 which had proposed markups. So, we have to wait
3 until that is placed into the official DCD. I
4 believe DCD Rev. 18 markup version has that.

5 MR. GLEAVES: Yes, and that is why we
6 call it confirmatory, because we are waiting just for
7 that final confirmation. It is the response from
8 Westinghouse gives commitments to make these changes
9 to Rev. 18, but we actually haven't seen the hard
10 final copy yet.

11 DR. MA: And the next issue is, when we
12 reviewed their connection details from SC module to
13 the concrete basemat, at that time we found some
14 connection; the force transfer was not at the same
15 plane. And we did not believe those connection
16 details were good enough, and they did not provide
17 any test data at that time.

18 So, the resolution is to revise their
19 connection detail to utilize the direct load paths
20 from steel faceplate to reinforced concrete basemat.

21 So, it is a direct-force transfer by welding. So,
22 we have no problem.

23 And the next one is they revised a
24 detailed utilized steel dowels, which at one end
25 dowel is welded to the steel faceplate, then use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mechanical connectors, and at the other end, embed
2 into reinforced concrete base.

3 This connection is also acceptable to us.

4 So, the connection problem has been resolved.

5 The next one, please.

6 This issue is the revisions made in DCD
7 Rev. 16 regarding critical sections. That means the
8 number of critical sections they reduced, and there
9 is also incomplete information, and they also removed
10 some of the Tier 2* information. So, we have an RAI
11 to them.

12 The resolution is the markups for the
13 additional critical sections provided to be
14 consistent with the Certified Design in DCD Rev. 15.

15 And the markups for tabulated results
16 that were removed from DCD Rev. 15 were provided. It
17 was, in fact, the load combinations and member forces
18 for critical sections. All those are put back

19 The next markups provided to include
20 additional design information, like required
21 reinforcement for concrete members and required plate
22 thicknesses for modules.

23 The next markups provided to restore Tier
24 2* information, which we believe should be Tier 2,
25 and they agreed to it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And this issue has been resolved.

2 The next one, please.

3 The next issue is there is an inadequate
4 description of the soil-bearing pressure evaluation
5 and foundation stability evaluation.

6 And this problem has been resolved by
7 they provided information to describe the methodology
8 for soil-bearing pressure and the foundation
9 stability evaluation.

10 And we reviewed that information, and the
11 staff considers it acceptable.

12 And the markups for DCD provide these
13 evaluations.

14 And this issue has been resolved.

15 Next, please.

16 Difficulties were encountered in
17 demonstrating adequate factor of safety for the
18 seismic sliding stability evaluation. They used the
19 equivalent static method.

20 This problem was resolved by using a more
21 realistic nonlinear time history analysis, and they
22 used a revised 2-D ANSYS surface-mounted model. It
23 means the model just rests on top of the soil, and
24 they did not assume the soil provides the resistance
25 to the sliding of the nuclear island.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And they also increased the seismic input
2 by 10 percent, as a demonstration that provided a
3 factor of safety of 1.1. This is the requirement in
4 our SRP 3.8.5.

5 And the staff ordered this analysis, and
6 we consider the analysis acceptable. So, this issue
7 has been resolved.

8 The next one, please.

9 The other issue is the foundation seismic
10 design was based on the assumption of uniform soil
11 spring beneath the basemat, which is not consistent
12 with the known soil pressure distributions. Usually,
13 the higher stress will be around the periphery
14 foundation than within.

15 So, what Westinghouse did was they
16 performed a study, utilized the soil finite element
17 representation and compared the results to the
18 uniform soil spring model. Based on this model, the
19 member forces in the foundation did go up in some
20 locations. However, they performed a re-analysis for
21 these higher forces, and the results indicates the
22 basemat still meets the ACI-349 code design.

23 So, based on that, the staff considered
24 this issue resolved.

25 The next one, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The next issue is talking about
2 settlement. The staff believes additional
3 information is needed to describe the development of
4 the settlement criteria consistent with the
5 evaluation of the effect of settlement on the
6 structural integrity of the nuclear island.

7 So, Westinghouse provided a description
8 on how the settlement criteria were developed by
9 using a nonlinear analysis of the foundation during
10 construction and over time after construction.

11 Settlement criteria were updated and
12 markups for the DCD were provided to give guidance on
13 the settlement criteria for the COL applicants.

14 And the staff reviewed this information
15 and considers it acceptable, and this issue has been
16 resolved.

17 The next one, please.

18 Requirement for soil angle of internal
19 friction needs to be defined in the DCD for the COL
20 applicants because this plant would be built at a
21 different site. So, we want different site, whoever
22 builds this plant to give us the minimum soil angle
23 internal friction. So, in that way, the analysis
24 they performed for the sliding will be covered.

25 Markups provided for revision of DCD Tier

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 1 and Tier 2 to define minimum soil angle of internal
2 friction. So, that is included.

3 If minimum soil angle of internal
4 friction cannot be met, then site-specifics
5 evaluation is required.

6 And with this, the staff considers this
7 issue resolved.

8 And that's it.

9 CHAIRMAN RAY: All right.

10 DR. MA: Any questions?

11 CHAIRMAN RAY: Yes.

12 MEMBER ARMIJO: I have a general
13 question.

14 CHAIRMAN RAY: Yes.

15 MEMBER ARMIJO: Will we finish with
16 Chapter 3 open items in this meeting or will that be
17 some other later meeting?

18 CHAIRMAN RAY: We finish here, don't we?

19 MEMBER ARMIJO: Well, you know, I wanted
20 to get back to that Section 3.3 of the SER.

21 CHAIRMAN RAY: About the wind loadings.

22 MEMBER ARMIJO: About the wind loadings.

23 Because there seems to be a difference of opinion of
24 what the geometry changes between the staff and
25 Westinghouse.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The SER says Revision 17 proposes changes
2 to the geometry of the shield building roof by
3 reducing the roof rise from 25 feet 6 inches down to
4 20 feet 6 inches. It sounds to me that the SER says
5 the roof is getting a little bit flatter.
6 Westinghouse told us that the whole cylinder was
7 shorter by 5 feet. So, that should be clarified.

8 MR. CUMMINS: This is Ed Cummins.

9 When we went from AP600 to AP1000, we
10 needed more containment volume. So, we added 25 feet
11 to the height of the plant.

12 MEMBER ARMIJO: You mean 5 feet?

13 MR. CUMMINS: Twenty-five.

14 MEMBER ARMIJO: Twenty-five? Oh, okay.

15 MR. CUMMINS: And then, when we had to
16 make the airplane crash changes, we were trying to
17 keep the same seismic response spectra, and we were
18 worried that the additional weight from a thicker
19 roof would change it. So, we tried to minimize that
20 change by reducing the height by 5 feet.

21 So, if 5 out of 25, it could be that the
22 increase from AP600 is somewhere near 20 percent
23 less, but the 5 out of -- I don't know what the
24 height is -- 180 is nowhere near 20 percent.

25 MEMBER ARMIJO: Yes. Well, there's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 something very confusing the way it is written
2 because, to me, roof rise means --

3 MR. CUMMINS: The roof rise didn't
4 change.

5 CHAIRMAN RAY: Okay. Hold on a second.

6 Let's just turn to the staff. The
7 discussion with Westinghouse I think is interesting,
8 but not going to solve the problem.

9 MR. THOMAS: Right, right, right.

10 Brian Thomas, the Branch Chief.

11 It was my understanding -- and perhaps
12 there is a need for some clarification in the wording
13 in the SER -- but it was my understanding that the
14 overall height of the structure was lowered.

15 MEMBER ARMIJO: The height of the
16 structure would be lowered either if you flattened
17 the roof a little bit, so it's not so steep -- you
18 will get the same effect as if you reduce the
19 cylinder, but --

20 MR. THOMAS: Right. Yes.

21 MEMBER ARMIJO: So, I don't know what
22 actually is the design.

23 MR. THOMAS: No, it was my understanding
24 that this was not a roof rise type of a change in the
25 design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: But the language in the
2 SER says --

3 MR. THOMAS: So, I think the language in
4 the SER probably needs some --

5 MEMBER ARMIJO: All right. Okay.

6 CHAIRMAN RAY: Just give the citation,
7 Sam.

8 MEMBER ARMIJO: It's --

9 MEMBER SHACK: Page 312.

10 MEMBER ARMIJO: Page 312, Section 3.3.1.

11 So, the question is, what is the actual geometry
12 change? And then, how can such a small change
13 affect, get a 20 percent reduction in wind loading?

14 MR. THOMAS: Yes, and that's the other
15 part of this issue, and I --

16 CHAIRMAN RAY: Wait a minute. I would
17 rather you not speculate now.

18 MR. THOMAS: Okay.

19 CHAIRMAN RAY: Can you just come back and
20 tell us tomorrow? Thank you.

21 Do you have anything else?

22 MEMBER ARMIJO: That's it.

23 CHAIRMAN RAY: All right. Anybody else
24 have anything else?

25 (No response.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 All right. Eileen, did you want to say
2 something?

3 MS. MCKENNA: Well, I was just going to
4 say, to answer the first question, the next agenda
5 item is the rest of Chapter 3 for today.

6 CHAIRMAN RAY: Okay.

7 MS. MCKENNA: But we may or may not be
8 able to answer this particular question today. We
9 might have to wait until tomorrow.

10 MEMBER ARMIJO: Sure.

11 CHAIRMAN RAY: Yes. The next agenda
12 item, just to keep me straight, is nine. That's what
13 we're talking about here?

14 MS. MCKENNA: Correct.

15 CHAIRMAN RAY: Yes. I always think of
16 that as an open item. It's both an open item and the
17 last thing on Chapter 3, I guess.

18 But we will hear from the applicant first
19 on open item No. 46, and then, as item 10 on the
20 agenda, OI closure on Chapter --

21 MS. MCKENNA: Yes, maybe I'm confusing
22 you with my agenda. What I'm trying to indicate is
23 that this was our Chapter 3 closure of open items for
24 all the things other 3.7 and 3.8. Within that set of
25 information is an ACRS action item 46. That is what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I designated with the hash marks, is that specific
2 numbered items.

3 CHAIRMAN RAY: Okay.

4 MS. MCKENNA: You can let me know if we
5 are going to cover that topic in this session.

6 CHAIRMAN RAY: We are going to hear from
7 the applicant and then the staff.

8 MS. MCKENNA: Correct, correct.

9 CHAIRMAN RAY: All right. And when we
10 are done with that, we are done with 10, we are done
11 with 3, I think.

12 Okay, No. 46.

13 MR. LINDGREN: Are you ready?

14 CHAIRMAN RAY: Yes.

15 MR. LINDGREN: Okay. My name, again, is
16 Don Lindgren. I'm here to talk about the balance of
17 3. That is everything that is not in 3.7 or 3.8.

18 Ron Wessel is here to support me if we
19 have any questions on equipment qualification and
20 high-frequency screening. Dale Wiseman knows all
21 things components. Gerry Riegel is here to talk
22 about valves and in-service testing.

23 One thing you will discover in the
24 handout I just gave you includes the ACRS action
25 items 46, 55, and 4. I understand that you want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 defer talking about 55 until Mr. Brown is here.

2 CHAIRMAN RAY: Yes, I believe that would
3 be wise. I think item 4, the Reactor coolant
4 flywheel, we have the interested member here. We can
5 do that.

6 MR. LINDGREN: Okay. Then, we can figure
7 out when we do 55 later.

8 CHAIRMAN RAY: Yes.

9 MR. LINDGREN: Okay. Tier 2, Chapter 3,
10 which is design and structure components, equipment
11 and systems. It is a very wide-ranging chapter. It
12 includes a lot of different items.

13 The items that are included are the
14 general design criteria; classifications of
15 structures, components, and systems; wind and tornado
16 loadings; water level and flood design; missile
17 protection; postulated pipe rupture dynamic effects;
18 seismic design; design of Category I -- we have
19 already discussed. Mechanical systems and
20 components, seismic and dynamic qualification, and
21 environmental qualification.

22 In 3.2, the classifications of structures
23 components and systems, the classification approach
24 is not changed in the Design Cert amendment. The
25 classification, some of the details were changed to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reflect design finalization.

2 The open items were a result of NRC audit
3 and review of design documents, design specs and
4 design reports. These items are resolved. There are
5 the details, if you care to look. I wasn't planning
6 on going over them in detail. They are all resolved,
7 and some of them were quite detailed.

8 We combined 3.3 and 3.5 here because the
9 most interesting items are tornado missiles. We did
10 change our evaluation of the impact of tornado-borne
11 missiles. We included it at a higher elevation to
12 support the COL applicants.

13 It turns out that you have to analyze the
14 automobile 30 feet from above where it starts, not 30
15 feet above grade. So, if you have an elevated
16 parking lot within a half a mile, you have to start
17 from 30 feet up to that. So, we have included an
18 evaluation that includes all the sites that have
19 expressed an interest in the AP1000.

20 CONSULTANT WALLIS: So, why is there one
21 automobile?

22 MR. LINDGREN: What's that?

23 CONSULTANT WALLIS: There are a bunch of
24 automobiles in the parking lot.

25 MR. LINDGREN: That is true, but the Reg

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Guides and Standard Review Plan, you do them one at a
2 time.

3 CONSULTANT WALLIS: One at a time?

4 (Laughter.)

5 MR. LINDGREN: I think you can probably
6 safely guess that you are not going to hit the same
7 spot repeatedly, but I don't know.

8 CONSULTANT WALLIS: But a global failure
9 you're talking about.

10 MR. LINDGREN: Well, that also is one at
11 a time. They won't hit simultaneously. That would
12 have to be a very smart tornado.

13 The open items were either a result of
14 design changes, such as the radwaste tank, addition
15 of radwaste tanks in the radwaste building, or came
16 out of NRC review, in particular, the automobile and
17 the siting missile. I will discuss these a little.

18 We had an open item on the impact of
19 steel siding from either the annex building or the
20 turbine building impacting on the modular wall of the
21 shield building. We have addressed those issues,
22 provided that calculation for NRC audit, and that is
23 now resolved.

24 We had an open item that came about
25 asking us to look at the effect of three added

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 radwaste tanks inside the radwaste building. The
2 radwaste building is a lightweight steel frame
3 structure that we presume is blown away in a tornado.

4 So, we looked at, we resolved this by
5 determining that the tanks are anchored to the ground
6 sufficiently that they will not become missiles.

7 And also, we did end up with an RAI on
8 our elevated automobile. In addition to looking at
9 the effects of a local impact, we looked at, does an
10 automobile striking the shield building, is it going
11 to stop at the shield building, and determined that
12 that is not the case.

13 3.4 is water level or flood design.
14 These open items resulted from design changes. We
15 changed the roof design of the seismic category to
16 structures. They were not previously. They were
17 strictly flat and had no parapets or anything at the
18 edges.

19 The fire tank volume was also increased,
20 and these same radwaste tanks, we also looked at the
21 possibility of them tipping over or rupturing and
22 causing a flood up against that end of the aux
23 building.

24 In all three cases, the roof design we
25 determined that we had sufficient drainage capability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to drain the water off of these seismic Category II
2 structures. So, there was not an issue with water
3 buildup and the weight due to that.

4 The fire tank is on the opposite end of
5 the turbine building and the ground is sloped away,
6 and the radwaste tanks cause a very short-term 6-inch
7 flood against the aux building that doesn't have any
8 openings in it.

9 These items are all resolved.

10 Once again, there's more details, if you
11 care to investigate further.

12 3.6 is about postulated pipe rupture
13 dynamic effects, and I am including the SRP Section
14 3.12 here. There is no DCD Section 3.12.

15 So, this is a case where we ended up
16 doing -- anyway, we will go over the individual
17 items.

18 We added a COL information item to
19 address the completion and the review of the piping
20 design. You will see some people referring to this
21 as a piping DAC, but in the Design Certification we
22 did not actually add an ITAAC for this item. But
23 there will be an ITAAC added on a plant-specific
24 basis.

25 We added a COL information item to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 address the completion of the pipe rupture hazard
2 report. Okay.

3 Then, finally, the other question that
4 came about was an issue on the computer code that we
5 used for piping fatigue analysis, known as WESTEMS.
6 We decided to withdraw it from review in the Design
7 Certification amendment. The staff will evaluate
8 piping design fatigue analysis at the time of the COL
9 item closure, and there is a requirement that
10 benchmark programs are required by the DCD if a
11 piping analysis program other than those included in
12 the design certification are used. So, those are how
13 this piping fatigue analysis will ultimately be
14 closed.

15 CHAIRMAN RAY: Why? Why did that occur?

16 MR. LINDGREN: Why did we add all of
17 these or? Which one are you talking about?

18 CHAIRMAN RAY: Why did you withdraw from
19 review in the Design Certification amendment the
20 computer code and go down the path of putting it at
21 COL item closure?

22 MR. LINDGREN: We could not come to
23 agreement with the staff on the WESTEMS code in a
24 time that was acceptable for closing out the Design
25 Certification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Okay.

2 MR. LINDGREN: I have included in your
3 package the COL information items on both the pipe
4 break hazard here -- so, we have identified what
5 needs to be done to finish that out -- and the as-
6 designed piping analysis.

7 We expect that Westinghouse will actually
8 do this work to complete it, but it will show up as
9 the responsibility of the COL applicants.

10 And once again, I have included the open
11 items, if you care to investigate further. We had
12 about five open items on WESTEMS that were closed by
13 withdrawing WESTEMS from the review.

14 3.9, which is mechanical systems and
15 components, is the next subject. The NRC generated
16 some open items as a result of their review of design
17 documents. In particular, the open items addressed
18 the vortices coming off the flow skirt in the reactor
19 vessel. The flow skirt is an item that was added to
20 the design. It sits underneath the internals, and it
21 is intended to smooth out the flow that is going into
22 the bottom of the core.

23 The staff had some questions about
24 vortices. We resolved those.

25 CONSULTANT WALLIS: It's resolved by a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CFD or something? How did you resolve that? It
2 simply says they will be small, but how do you know
3 they will be small?

4 MR. LINDGREN: Dale, can you answer that?

5 MR. WISEMAN: I think the evaluation was
6 based on the size of the holes in the flow skirt
7 relative to the question of --

8 CONSULTANT WALLIS: Well, these are
9 simply the vortices from the holes. They are not
10 global vortices or a donut-type vortex in the hole,
11 lower plenum.

12 MR. WISEMAN: Right.

13 MR. LINDGREN: The question was just
14 putting this flow skirt in caused you new vortices
15 that you have to worry about.

16 We had a question on the attachment of
17 the CRDM nozzle to reactor vessel head. It is
18 attached with a weld, what's called a J-groove weld.

19 We ultimately resolved this by doing a
20 plastic analysis of that weld and including that in
21 our design report document. So, the NRC audited that
22 and is now satisfied with what we did.

23 We also had a question about
24 recirculation screen loads. That was also addressed.
25 So, staff is satisfied.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Finally, there was an issue that came up
2 on international CRDM classification questions. This
3 came about after the SER with open items was issued.

4 We have resolved this question to the staff's
5 satisfaction, and they say so in the SER.

6 Once again, the open items are included
7 here for your information, as well as the RAIs on the
8 CRDM classification.

9 We had questions on valve testing. These
10 came about, once again, from an NRC audit. We had a
11 rather detailed audit, in part, because we are the
12 first ones to come through with a design after the
13 JOB MOV programs and the like. So, we are
14 implementing these things on the front end instead of
15 backfitting information. So, that provided a lot of
16 interest from the staff. As a result, we came up
17 with a few questions.

18 Westinghouse is implementing the testing.

19 This is operability testing required by the Joint
20 Owners' Group MOV Program and, in fact, are applying
21 those principles to all power-operated valves.

22 We have additional information that is
23 provided in our response to ACRS action item 46,
24 which we will be talking about shortly.

25 Once again, I have included the open

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 items, if you want to look at it in more detail.

2 3.10 and 3.11 are very similar. One is
3 seismic and dynamic qualification. One is
4 environmental qualification. We have added a
5 discussion about the screening of equipment for
6 sensitivity to high-frequency motions, and we
7 describe in Appendix 3I of the DCD.

8 We had RAIs on screening for equipment
9 sensitive to high-frequency motion in conformance
10 with Interim Staff Guidance 1. These RAIs have been
11 resolved.

12 And the open item on equipment
13 qualification requirements in design documents is
14 also resolved.

15 Two of these were RAIs. The one is an
16 open item, and it addresses the valves, the Standard
17 QME-1-2000.

18 Okay. That's what we have for the
19 balance of Chapter. Now I'll start answering at
20 least two of these RAI responses. Oh, ACRS actions.

21 CHAIRMAN RAY: Yes.

22 MR. LINDGREN: Okay. ACRS action 46
23 talks about valve testing and risk ranking. The
24 first two lines were the action as we got it.
25 Components, MOV, POV testing. How is the risk-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 informed rank. PRA is not sufficient and needs to
2 review other criteria.

3 Strictly speaking, the risk ranking of
4 valves to determine the frequency for valve
5 operability testing is a COL responsibility mostly.
6 The DCD includes a COL information item that the COL
7 applicant must complete an evaluation to determine
8 the frequency of valve operability testing. This
9 evaluation includes risk ranking, and the DCD also
10 includes a description of the evaluation to be
11 completed to determine the frequency.

12 This risk ranking is not completed as
13 part of the Design Certification.

14 The determination of operability test
15 frequency uses a combination of functional margin and
16 risk ranking. So, if you have high risk/low margin,
17 you test more frequently; if you have low risk/high
18 margin, you test less frequently.

19 And valve margin evaluates the load on
20 the actuator versus the capability of the actuator.
21 That is what they mean when they talk about margin.

22 In response to Generic Letter GL 96-05,
23 the Westinghouse Owners' Group prepared a report on
24 the risk ranking approach for the existing fleet. We
25 would expect we would follow the same process.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The approach identified in the report
2 includes six steps:

3 Identify the valves to be considered.

4 Calculate the valve at-power risk
5 importance.

6 Assess PRA completion issues.

7 Evaluate other considerations.

8 Develop component ranking worksheets.

9 And conduct an expert panel for ranking.

10 And in fact, we have already identified
11 in the DCD the valves that are subject to operability
12 testing in Table 3.9-16.

13 Risk importance is in the case of AP1000
14 considered based on both core damage frequency and
15 large release frequency.

16 For AP1000, we have quantified the
17 shutdown risk, which one of the kind of open items
18 they talked about in the report.

19 And both Westinghouse and the AP1000
20 utility personnel have participated in risk ranking
21 expert panels for the Generic Letter 96-05 responses.

22 CHAIRMAN RAY: Bill, you are going to
23 have to handle this for you and John.

24 MEMBER SHACK: On this particular one,
25 for the test that you have done in 3.9-16, was that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 done with the whole process or is this done on just
2 the risk ranking?

3 MR. LINDGREN: Okay. What you will find,
4 3.9-16 is mostly an in-service test table. It tells
5 you what has to be done for in-service testing for
6 all the valves that are subject to safety. What you
7 will find is that we have, in the notes there's a
8 note that says this valve is subject to operability
9 testing.

10 So, what we have done so far is
11 identified the valves that need to be, that are
12 subject to the operability testing. We have not
13 completed the risk ranking process of how much risk
14 is there to this valve or what the margin is on this
15 valve.

16 In some cases, for instance, the margin,
17 until you have selected both a valve manufacturer and
18 an actuator manufacturer, you won't necessarily know
19 what the margin is.

20 MEMBER SIEBER: But the standard testing
21 is MOV ATS testing at shutoff heads.

22 MR. LINDGREN: Did that help at all?

23 MEMBER SHACK: How do you choose the ones
24 that are subject to operability testing? What are
25 the criteria for that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LINDGREN: Can you help, Gerry?
2 Sorry. No, you can?

3 MR. WESSEL: That would be all the active
4 valves that have a safety-related function for safe
5 shutdown that you would have to do operability
6 testing on.

7 MEMBER SHACK: Okay. I mean that sounds
8 like a minimum set.

9 MR. WESSEL: Yes.

10 MEMBER SHACK: And so, what we have in
11 3.9-16 is the minimum set, and you will have to look
12 at others later?

13 MR. LINDGREN: I believe that the ones
14 that we are looking at are identified in the DCD. We
15 believe we have done --

16 MR. WESSEL: At this time, the list is
17 complete from our perspective, but the ranking hasn't
18 been done yet, as Don has stated, because we have not
19 necessarily got the vendors. We haven't done all the
20 sizing calculations for the actuators and done those
21 evaluations to determine exactly where we are at.
22 Now we are in the process of doing that.

23 MEMBER SHACK: Okay. Is the scope, then,
24 for GL 96-05 essentially all the operable valves?
25 That is how the scope is defined in the Generic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Letter?

2 MR. WESSEL: That's correct.

3 MEMBER SIEBER: Class 1 valve, I think.

4 MEMBER SHACK: Okay.

5 MEMBER SIEBER: And then, in the
6 AP1000 --

7 MEMBER SHACK: Okay. So, once you have
8 done that, then you do the risk ranking to determine
9 the frequency of the testing and --

10 MR. LINDGREN: Well, the risk ranking and
11 the margin.

12 MEMBER SHACK: And the margin, right.

13 MR. LINDGREN: Yes.

14 MR. WESSEL: And that's done after you
15 select a vendor and do all the sizing calculations,
16 all the weak point analysis, and all the work that is
17 done to show the margin that is contained in the
18 valve design.

19 MR. LINDGREN: Okay?

20 CHAIRMAN RAY: Just a second.

21 MEMBER SHACK: But is there a COL item,
22 then, to do the risk ranking?

23 MR. LINDGREN: Yes.

24 MEMBER SHACK: Okay.

25 MR. LINDGREN: Yes, we do have a COL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information item that says it has to be done and what
2 the evaluation leads to.

3 MEMBER SHACK: And that, essentially,
4 outlines the approach that you have given here for
5 the --

6 MR. LINDGREN: I believe this approach is
7 more detailed than what is in there.

8 MEMBER SHACK: What is in there then?

9 MR. LINDGREN: It says you have to do a
10 risk ranking, okay, and that the evaluation -- well,
11 the evaluation has to include risk ranking and to
12 include the frequency. I focused on risk ranking
13 because that's what the question was about.

14 MEMBER SHACK: Okay.

15 MR. LINDGREN: It does not specifically
16 say that you will use the process in the report that
17 was in response to --

18 MEMBER SHACK: 96-05?

19 MR. LINDGREN: -- 96-05, but, frankly, I
20 can't imagine what else we would do. And it is far
21 more than just coming up with numbers out of the PRA.

22 MEMBER SHACK: No, but I suspect that
23 John won't be happy with a process that somehow just
24 leaves it at risk ranking, which sounds awfully PRA-
25 ish.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LINDGREN: Risk ranking is a lot more
2 than PRA.

3 CHAIRMAN RAY: As opposed to what, Bill?

4 MEMBER SHACK: As opposed to a process
5 including the six steps that I see here for 96-05.

6 MR. LINDGREN: Well, those are the
7 process that is used in risk ranking.

8 MEMBER SHACK: Okay.

9 MR. LINDGREN: Although we haven't
10 committed to that.

11 MEMBER SHACK: You haven't committed to
12 it is the problem.

13 MR. LINDGREN: Granted, we have not
14 committed to that, but that is the industry method,
15 and the same people are involved for the operating
16 fleet as are involved for AP1000.

17 MEMBER SHACK: Well, I can't see why the
18 risk ranking approach isn't specified closer to the
19 six steps. It is what it is.

20 MR. LINDGREN: It is what it is.

21 CHAIRMAN RAY: Well, we'll not close this
22 until we decide, then, if we have a comment.

23 MR. LINDGREN: Okay. Okay, then we have
24 55, which we want to defer to another time?

25 CHAIRMAN RAY: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LINDGREN: Okay.

2 CHAIRMAN RAY: Another time, hopefully,
3 meaning --

4 MR. LINDGREN: Tomorrow morning, I hope?

5 MS. McKENNA: Later this week.

6 CHAIRMAN RAY: Yes, I do, too.

7 (Laughter.)

8 MR. CUMMINS: This is Ed Cummins.

9 We see the six steps as a decision by the
10 COLs rather than a decision by us. So, they get to
11 commit to what they needed.

12 MEMBER SHACK: Oh, I see. We're going to
13 put them up --

14 MR. CUMMINS: So, it is really not our
15 scope. Once you take it out of our scope, then --

16 MEMBER ARMIJO: Then you don't want to
17 answer.

18 MR. CUMMINS: -- we don't really want to
19 answer, right.

20 (Laughter.)

21 CHAIRMAN RAY: Well, all right.

22 Bill, do you think we can move it off of
23 this list and put it on a COL list? Are you
24 comfortable doing that?

25 MEMBER SHACK: Why not?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 CHAIRMAN RAY: Well --

3 MEMBER SHACK: Just so it gets done.

4 (Laughter.)

5 CHAIRMAN RAY: The "why not", you know,
6 there's a number of answers I can think of. But, in
7 any event --

8 MEMBER SHACK: But, no, my concern is
9 that it gets done, and if Westinghouse wants to pass
10 it to the COL, I guess that is up to Westinghouse and
11 their customers.

12 CHAIRMAN RAY: As long as we don't see a
13 problem with that.

14 MEMBER SHACK: Yes, I don't see a problem
15 with it because, until you actually have to do it --

16 MEMBER ARMIJO: It's pretty hard to test
17 something one time --

18 MEMBER SHACK: -- this process doesn't
19 have to be in place.

20 CHAIRMAN RAY: All right. Just make a
21 note of that, Weidong.

22 All right, let's go to 4.

23 MEMBER ARMIJO: It's 55 that's being --

24 CHAIRMAN RAY: No.

25 MEMBER ARMIJO: What happened to 55?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Charlie's not here.

2 MEMBER ARMIJO: Oh, okay.

3 MR. LINDGREN: Okay. Action item 4 was a
4 question about the reactor coolant flywheel design.
5 This is really a Chapter 5 question, but since I
6 have Mr. Wiseman here, I have decided to do this now.
7 We're not doing Chapter 5 otherwise this session.

8 This is the action item as we got it. We
9 have determined that the potential for corrosion and
10 consequences of a failure of the 18 Cr 18 Mn retainer
11 ring material is not a safety issue.

12 Westinghouse has reviewed and analyzed
13 industry testing. It is not planning on any more
14 testing of the retainer ring material in support of
15 DCD Rev. 18.

16 The flywheel, including the retainer
17 ring, is sealed in an enclosure to prevent exposure
18 to the reactor coolant. The pressure boundary
19 criteria and requirements that are applied to the
20 welding and the helium leak test for the enclosure
21 are similar to pressure boundary criteria for the
22 design and the fabrication.

23 Industry stress corrosion environments
24 more severe than reactor coolant water has shown
25 satisfactory resistance to stress corrosion cracking.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: But that's for the can,
2 not the ring.

3 MR. LINDGREN: No, this is testing of the
4 ring material.

5 MEMBER SHACK: Oh, this is the ring?

6 MEMBER ARMIJO: No, I asked for whatever
7 stress corrosion test reports that you or your pump
8 supplier, which I guess was Curtiss-Wright, had
9 performed on the retainer ring material. I never got
10 anything.

11 Our ACRS staff member went into the
12 technical literature to look for some information,
13 whatever might be available, and it is incredibly
14 sparse, and I didn't find any environment that even
15 came close to the PWR coolant environment.

16 Since this is super-high-strength
17 material, that is always suspect to being susceptible
18 to stress corrosion cracking. So, I haven't seen any
19 information that you've got that says this stuff
20 would reasonably in the coolant environment, if this
21 can leaked -- there's a lot of welds in lots of cans,
22 and it's not inspectible. So, I don't understand the
23 reluctance to do some stress corrosion cracking tests
24 to make sure that this thing isn't going to --

25 MR. LINDGREN: I have some more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information to --

2 MEMBER ARMIJO: Well, you know, I had
3 asked for this material long ago.

4 MR. LINDGREN: Okay. Testing includes
5 test specimens under constant load for deionized
6 water, 1 percent ammonium nitrate, and 1 percent
7 sodium chloride at ambient temperature.

8 MEMBER ARMIJO: That has nothing to do
9 with PWR water chemistry and temperatures. So, I
10 don't know why you're even presenting that, but, you
11 know, if that's the best you've got, that's the best
12 you've got.

13 MR. LINDGREN: Okay.

14 MEMBER ARMIJO: But it's not at all
15 representative of what would happen if those cans
16 leaked.

17 And, you know, I did ask, and I may have
18 misunderstood it, but I believed that you had told us
19 that these were not inspectible, that the cans were
20 not going to be inspected periodically during their
21 service life because the pump has to be disassembled,
22 and I don't know if that's really true, but that was
23 my assumption when I wrote this.

24 MR. LINDGREN: That's correct.

25 MEMBER ARMIJO: So, you've got a 60-year

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 life of two cans spinning around at high speed,
2 welded around very high-energy components, and you're
3 presuming, assuming that in all that time that the
4 alloy 625 can will not leak. And you are then
5 presuming that, if the water gets in there, that this
6 material that hasn't been tested in PWR water
7 chemistry will not crack. And if it does crack,
8 you've got these massive tungsten things that are
9 going to fly apart, and that pump will come to a
10 screeching halt. And, yes, I think you have
11 demonstrated that the pump won't come apart, but why
12 you let it get -- you even leave that in doubt, it's
13 hard to believe.

14 You know, we get involved with worrying
15 about leaks in 2-inch socket welds, and here this
16 super-high-energy primary pump could come to a
17 screeching halt with a lot of energy being dissipated
18 in a very short time. And I just can't see how you
19 just don't go the extra mile to protect yourself in
20 case your containers leak.

21 And I can tell you, if you're relying on
22 this so-called industry ammonia/sodium chloride test
23 to give you comfort, then I think you're making a
24 huge mistake because stress corrosion cracking
25 doesn't work that way. You can't translate stress

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 corrosion cracking resistance in one environment to
2 another environment. So, that information is pretty
3 much useless.

4 But, you know, I'm not going to preach.
5 My biggest question will be why the staff accepts
6 this. I'll let it go at that.

7 CHAIRMAN RAY: All right. Anybody else
8 have any questions on this point?

9 (No response.)

10 I understand your starting position on
11 this is that it is not a safety issue if it does
12 fail.

13 MR. LINDGREN: Yes.

14 CHAIRMAN RAY: Okay. And so, it doesn't
15 sound to me like we're disagreeing about that, are
16 we, Sam?

17 MEMBER ARMIJO: Yes, I think it is. I
18 think it is an extremely narrow interpretation of
19 what is a safety issue. The GDCs require that we
20 build things and test things so that they will
21 perform in the environment that is likely to occur.
22 And unless you can show that the alloy 625 can is
23 either inspectible or has been demonstrated to be
24 immune to failure, either by fatigue or by a weld
25 defect or by stress corrosion cracking itself, then I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think you haven't done your job.

2 So, I think it is. It is a safety issue.

3 CHAIRMAN RAY: Okay. Is there anything
4 about the safety issue aspect that you want to pursue
5 further now, just so there's no --

6 MEMBER ARMIJO: No. I'm going to have to
7 do some more, look it up and put my arguments
8 together for you, but --

9 CHAIRMAN RAY: Well, no, I mean I think
10 that the likelihood of a cracking failure certainly
11 under these circumstances can't be excluded. The
12 real question is, do we have any disagreement about
13 the consequences when that happens? That's all.
14 This is the last time we have a chance to pursue
15 that. That's all I'm --

16 MEMBER ARMIJO: I did read the Curtiss-
17 Wright report, and I think that they showed they had
18 a lot of margin about the casing and everything else
19 hanging together. And I think, Harold, you asked the
20 question of, you know, if this thing comes to a
21 screeching halt, will it torque the bolts off --

22 CHAIRMAN RAY: Right.

23 MEMBER ARMIJO: -- and the thing come
24 apart that way? And those are just two things that
25 we came up with.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 But it just seems to me that this is the
2 highest-energy moving component to have -- it should
3 be -- just the fact that it doesn't leak in the event
4 of this kind of an accident, to me, it's just not
5 sufficient.

6 MR. CUMMINS: This is Ed Cummins.

7 We hear clearly that this open item is
8 still open, and we will see if we can do better.

9 CHAIRMAN RAY: Well, I'm not asking for
10 anything more, Ed. I mean I think you have answered
11 all that you can. If you can provide Sam any
12 material information, I would do that at the earliest
13 opportunity.

14 MEMBER ARMIJO: Well, I've been an
15 engineering manager long before I did this. And I'll
16 tell you, I would never let a component that my
17 company supplied be run without having tested the
18 material in an environment that is reasonably likely
19 to exist, particularly if I can never inspect the
20 seal can. If I could inspect the seal can, I might
21 cross my fingers and take a look every once in a
22 while and say, "Yup, it's still hanging together."

23 But, otherwise, I think you're sailing
24 into harm's way.

25 CHAIRMAN RAY: Okay, but you're right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 For now, it's open, and right now we'll get it
2 translated into comments one way or another, in all
3 likelihood, unless we resolve it ourselves.

4 All right. Well, with that, then --

5 MEMBER SHACK: Can I just ask for --

6 CHAIRMAN RAY: Yes, sure.

7 MEMBER SHACK: -- an interpretation from
8 the staff of this final sentence?

9 When it says, "This material", are we
10 referring to alloy 625 or to 18 Manganese 18 Chrome?

11 MR. LINDGREN: 18/18.

12 MEMBER SHACK: Well, this is the staff's
13 SER, right?

14 MR. LINDGREN: Yes.

15 CHAIRMAN RAY: Well, they're going to
16 come up next. But you can get an answer right behind
17 you, Bill.

18 MR. HONCHARIK: Yes, this is John
19 Honcharik from the staff.

20 Yes, that was my part. I basically was
21 talking about the 18/18 material that was basically
22 tested, like they were talking about, for retainer
23 rings for steam turbine generators which are
24 basically in oxygenated water and, also, in hydrogen
25 environments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And basically, they came up with that
2 material in `85, and they basically replaced all of
3 their -- I guess, before, it used to be 5 Chrome 18
4 Manganese alloy steel. They changed it to this 18/18
5 in `85. And so far, they have had no problems with
6 stress corrosion cracking.

7 MEMBER SHACK: Okay. So, your address of
8 stress corrosion environment is different than his?

9 MR. HONCHARIK: Right, but this is based
10 on analysis for --

11 MEMBER ARMIJO: Well, you know --

12 MR. HONCHARIK: But it's similar.

13 MEMBER ARMIJO: Well, you know what's
14 troubling is I asked for this, whatever test reports
15 and information you had to demonstrate stress
16 corrosion cracking resistance months and months ago,
17 and all I get is, the only thing I actually got was
18 what Michael Benson of our staff looked up. And we
19 transferred that information to the staff, and it was
20 very little. And I received nothing from the staff
21 about the stress corrosion cracking data that you are
22 relying on.

23 So, I would really appreciate your report
24 or your data that says, hey, this environment that
25 this stuff has been tested in is close enough to a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PWR coolant environment that maybe it is applicable.

2 I don't know. I have never seen it.

3 MR. HONCHARIK: Right.

4 CHAIRMAN RAY: Yes, I thought you were
5 relying upon the alloy 625 enclosure when I read
6 that.

7 MR. HONCHARIK: Well, yes. I mean, well,
8 this is just part of an excerpt. I mean I talked
9 about the 625 earlier, that also 625 has better
10 properties than alloy 600, okay, for stress corrosion
11 cracking.

12 But, also, I think, you know, as
13 Westinghouse has stated, the safety consequence for a
14 LOCA or missile has been analyzed.

15 CHAIRMAN RAY: Yes, and that's why I
16 asked the question. We are not quibbling about that,
17 at least not to the point of saying the analysis is
18 wrong. But I think the point is, is that a
19 sufficient reason to not insist that we address the
20 other issue, which is, well, we have good reason to
21 believe it won't fail?

22 Now you can say, well, we also think it
23 won't fail because it's enclosed in this enclosure.
24 But, then, if you can never inspect it or not often
25 enough inspect it anyway, that really doesn't do the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 job, for the reasons that Sam said.

2 All right.

3 MR. HONCHARIK: I guess one other point
4 is, actually, the pump itself doesn't see the full
5 reactor temperature because basically it's cooling.
6 So, it runs at a much lower temperature than reactor
7 coolant water.

8 CHAIRMAN RAY: Is that a significant
9 factor?

10 MEMBER ARMIJO: It could be. It could
11 be. But, you know --

12 MR. HONCHARIK: Yes. I mean, typically,
13 they try to keep it -- because, actually, I went down
14 to Curtiss-Wright while they were doing a test for
15 the pump, and you could actually touch the pump while
16 it was pushing reactor coolant pressure and water
17 temperature.

18 And the flywheel and everything is
19 basically cool. So, the operating temperature --

20 CHAIRMAN RAY: Aren't there two
21 flywheels?

22 MEMBER ARMIJO: There's two flywheels.

23 CHAIRMAN RAY: Aren't there two
24 flywheels, Dale?

25 MEMBER ARMIJO: On each pump, there's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bigger one --

2 MR. HONCHARIK: Yes.

3 MEMBER ARMIJO: -- on top and then the
4 smaller one.

5 MR. HONCHARIK: That's correct.

6 MEMBER ARMIJO: But the cooling to the
7 flywheel assembly, is that separate from the reactor
8 coolant system? Is that a separate cooling --

9 MR. WISEMAN: It's cooling the motor,
10 basically.

11 MEMBER ARMIJO: Totally separate?

12 MR. WISEMAN: It's a closed cooling -- it
13 is reactor coolant, but it is in a closed system
14 loop.

15 MEMBER ARMIJO: With its own cooling --

16 MR. WISEMAN: With its own coolant and
17 external heat exchanger which dumps the heat to the
18 component cooling water.

19 MEMBER ARMIJO: And the temperatures are
20 real, real low? I would sure like to see that.

21 MR. WISEMAN: The temperatures of the
22 cooling water are, I think, 150 max or somewhere in
23 that range.

24 MEMBER ARMIJO: F?

25 MR. WISEMAN: F, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: So, you really do cool
2 that. That's much cooler than what I thought you
3 had. That wasn't clear in the Curtiss-Wright report.

4 MR. WISEMAN: Right.

5 CHAIRMAN RAY: Well, this is pretty close
6 to the motor windings and everything, isn't it? I
7 mean --

8 MR. LINDGREN: Yes, and you've got to
9 keep those cool.

10 CHAIRMAN RAY: You've got to keep those
11 cool.

12 MR. WISEMAN: Right. The flywheels are
13 on both ends of the motor winding. The flywheel
14 itself is at a higher temperature than that.

15 MEMBER ARMIJO: Sure. Yes.

16 MR. WISEMAN: It's in the 300 range, 300-
17 degree F range is where it's operating.

18 MEMBER ARMIJO: And the water chemistry
19 is intended to be the same as the water chemistry of
20 the primary coolant?

21 MR. WISEMAN: Yes.

22 MEMBER ARMIJO: So, 300 is still --

23 CHAIRMAN RAY: Yes.

24 MEMBER ARMIJO: 150 would be a lot
25 better.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 CHAIRMAN RAY: You can't get it to 150.

3 MEMBER ARMIJO: I just really would like
4 to see the staff's data, whatever data you've got.

5 CHAIRMAN RAY: Yes, well, it's a way to
6 avoid having to deal with a comment.

7 (Laughter.)

8 So, it should be motivating to want to do
9 that.

10 MR. LINDGREN: I do have some information
11 to provide you.

12 MEMBER ARMIJO: Well, I would be happy to
13 receive it.

14 MR. LINDGREN: I have a little more
15 information on the details of the testing. I can
16 pass that along. And I'll also make sure that the
17 staff knows what we're telling them.

18 (Laughter.)

19 CHAIRMAN RAY: All right. We'll
20 certainly take that into account, but I don't want to
21 hold things up while we read it.

22 Is there anything more that you have to
23 say?

24 MR. LINDGREN: I'm done.

25 CHAIRMAN RAY: Okay. Are there any more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions for Westinghouse?

2 We still have the staff to go, and then
3 we have got an important additional open item that we
4 would like to get to today because God knows we can't
5 afford to carry things over.

6 MR. LINDGREN: Okay, but when will we
7 discuss when we are going to talk about 55?

8 CHAIRMAN RAY: Well, you said tomorrow
9 morning, and I agreed with you. Let's hope that we
10 can do it then.

11 MR. LINDGREN: Well, we'll show up first
12 thing tomorrow morning.

13 MEMBER ABDEL-KHALIK: Five o'clock?

14 (Laughter.)

15 MR. LINDGREN: Whatever time you want.
16 Before you kick everybody out for the AIA stuff, we
17 will try to sneak it in there.

18 CHAIRMAN RAY: Yes, well, actually, let's
19 see, aren't we starting off with --

20 MS. MCKENNA: We were going to start with
21 the AIA. Because of the security aspect --

22 CHAIRMAN RAY: Yes.

23 MS. MCKENNA: -- we thought it would be
24 better to do that at the beginning, so we could get
25 --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Does that make sense to
2 you, Eileen, to do 55 before we secure things for
3 AIA? Is that possible?

4 MS. MCKENNA: That's fine. I think, you
5 know, we just --

6 CHAIRMAN RAY: Is Charlie coming in the
7 morning?

8 MR. WANG: Yes.

9 MS. MCKENNA: Okay.

10 CHAIRMAN RAY: All right. We've got to
11 cross things off the list here.

12 MR. LINDGREN: I know, and my support is
13 staying here for the night, but they won't stay here
14 through Friday.

15 (Laughter.)

16 CHAIRMAN RAY: Yes. I understand.

17 Well, we've got a very busy day tomorrow.

18 So, with that in mind, can we proceed on, then, to
19 the staff's closure of Chapter 3?

20 MS. MCKENNA: Sure. Let's start coming
21 up.

22 CHAIRMAN RAY: I foresee that we will go
23 until 5:50 at this point anyway. Make sure I read
24 the clock right. Yes.

25 And I guess let me say one other thing to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 my colleagues. After this is done, I want to go off
2 the record and, before you scatter, discuss -- we
3 can't afford to wait until Friday to try and make
4 sure we identify any open items.

5 I am thinking particularly now of the
6 first part of today's discussion. So, we need to
7 have a few minutes on that subject, but it doesn't
8 need to be on the record. Everything that we have
9 talked about is on the record already.

10 But because it could involve proprietary
11 discussion, we will make it after we can close the
12 room, off the record, and just make sure we've got
13 any open items nailed down.

14 Okay, let's go.

15 MS. CLARK: Okay. For this section of
16 the ACRS meeting, we are going to discuss three items
17 for the balance of Chapter 3: the 3.9.1, which is
18 special topics for mechanical components; 3.12,
19 piping design, and Appendix I.

20 For the first two, the project engineers,
21 well, the project engineer, me, Phyllis Clark, and
22 the technical people will be Robert Hsu and John Wu.
23 They are going to discuss 3.9.1.

24 CHAIRMAN RAY: Okay. In the context of
25 3.9.1, would you say anything more that you want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 say about the issue we just discussed, which is the
2 flywheel?

3 MR. WU: No, actually, because we just
4 heard the Westinghouse presentation.

5 3.9.1, we will try to discuss these
6 WESTEMS computer codes.

7 CHAIRMAN RAY: Well, now you guys did
8 some review of this subject, didn't you, that we
9 talked about, the flywheel and all of that?

10 MR. WU: Not the flywheel.

11 CHAIRMAN RAY: Huh?

12 MR. WU: We did not review the flywheel.

13 MS. McKENNA: It's a different section.

14 MR. WU: That's a different section.

15 CHAIRMAN RAY: All right. That's why I
16 asked, is it in 3.9.1? The answer is no.

17 MS. McKENNA: No.

18 MR. SISK: Mr. Ray, it's in Chapter 5,
19 actually.

20 MS. McKENNA: Yes.

21 CHAIRMAN RAY: Okay.

22 MS. McKENNA: But if you want any --

23 CHAIRMAN RAY: Yes, you're right. I'm
24 sorry. I forgot.

25 MS. McKENNA: -- any discussion from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 staff about what they did, just let us know and we'll
2 schedule that, but it's not --

3 CHAIRMAN RAY: All right. No, I forgot
4 that it was stuck on Chapter 3 when Westinghouse did
5 it, for matters, reasons of convenience. Okay, I
6 apologize.

7 Go ahead.

8 MR. WU: Well, I'm going to present
9 Section 3.9.1. It is related to WESTEMS computer
10 codes.

11 CHAIRMAN RAY: Good. It's on my list to
12 ask you about.

13 MR. CUMMINS: This is Ed Cummins.

14 This isn't part of the review scope.

15 CHAIRMAN RAY: Why?

16 MR. CUMMINS: Because we went through it.
17 I mean I don't know why we're talking about it. It
18 doesn't make any sense whatsoever.

19 CHAIRMAN RAY: All right. We're talking
20 about it, Ed, because I would like to know why you
21 went through it.

22 (Laughter.)

23 MR. CUMMINS: Okay.

24 CHAIRMAN RAY: And since ultimately it
25 will have to be addressed, I think it is reasonable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for the Subcommittee to understand how it will be
2 done later and, as part of that, to understand what
3 we are about to be told.

4 So, proceed.

5 MR. WU: For WESTEMS computer codes, five
6 items were identified, five open items was identified
7 addressing concerns. There was quality assurance,
8 methodology used in the WESTEMS code.

9 As the staff completes the audit and
10 identified the continuing concerns with the quality
11 assurance and the methodology resulting in two
12 remaining open items. Three open items were closed.
13 The staff documented the audit results in the WESTEMS
14 audit summary reports.

15 Recently, we received a letter by date of
16 September 29th that Westinghouse determined to remove
17 WESTEMS from the DCD markup because it was identified
18 during the review of the Revision 17. That put the
19 WESTEMS in the markup Table 3.9-15.

20 Now, on the basis that Westinghouse will
21 show that the current version of WESTEMS for AP1000
22 design analysis, we, the staff, closed all open items
23 because all open items are not assessed anymore.
24 It's closed. So, no more review.

25 Any questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CUMMINS: So, just to put in context
2 -- Ed Cummins again -- we were trying to close the
3 piping DAC. So, we were working on all piping
4 things. This is a small element of all piping
5 things. It is how we do fatigue analysis.

6 Once we decided between us and the staff
7 that we were not going to close the piping DAC, that
8 is, we didn't have sufficient completion levels of
9 all of our analysis, then this was not important to
10 us in the current schedule to have our fatigue code
11 approved or not approved because that's a futures
12 action now.

13 CHAIRMAN RAY: Okay. Thank you.

14 MR. WU: Okay. 3.12 now, piping design.

15 By letters dated April 1st, 2010 and
16 August 23rd, 2010, the applicant stated that
17 Westinghouse would not remove the piping DAC and
18 provide a DAC and ITAAC closure process.

19 On the basis that the piping DAC was
20 approved in Revision 15 and additional clarification
21 being provided with the DAC and ITAAC closure
22 process, the staff finds this is acceptable.

23 So, probably you don't have a problem
24 with this?

25 CHAIRMAN RAY: No, I don't.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WU: Okay. The next topic is talking
2 about hard rock high frequency ground motion response
3 spectra exceedance seismic input.

4 Seismic input was identified in Section
5 3.7.3 as inadequate due to a mathematical model
6 error. So, on that basis, Westinghouse revised
7 TR-115, "Effects of High Frequency Seismic Content on
8 SSCs", with adequate seismic input.

9 So, staff reviewed the TR-115 and staff
10 identified the applicant's screening criteria
11 selection for the piping package did not address the
12 response spectra exceedance because, for the
13 mechanical components, the response spectra, which is
14 the input for all the mechanical components and
15 piping design analysis and the qualification. And
16 Westinghouse's screening criteria was based on ground
17 motion high frequency response spectra exceedance.

18 So, by letter dated August 17th, 2010,
19 the applicant revised the DCD Appendix 3I to evaluate
20 a hard rock high frequency ground motion response
21 spectra for all the ASME Class 1, 2, and 3 piping
22 systems instead of a two-sample. So, previously,
23 they only used two-sample. Now they put back 100
24 percent. They are to address 100 percent as their
25 screen criteria.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, on this basis, the staff finds this
2 is acceptable. It will address the GDC2 concern.

3 CHAIRMAN RAY: Okay. I would think so,
4 yes.

5 (Laughter.)

6 MS. CLARK: Okay. Next, Pei-Ying Chen is
7 going to speak to the seismic and dynamic
8 qualifications of mechanical and electrical
9 equipment.

10 MR. CHEN: Okay. Basically, for the
11 seismic and dynamic qualification of equipment, we
12 looked at the major changes from Revision 15 to the
13 Revision 17.

14 The changes, basically, they decided not
15 to use the experience-based approach. Originally,
16 they thought they wanted to use the experience-based
17 approach to qualify all the AP1000 mechanical and
18 electrical equipment. So, they take that one off.

19 The other significant issue is talking
20 about the high frequency exceedance, the spectra
21 exceedance. So, we had to address that.

22 Next slide.

23 So, the only one significant issue is the
24 qualification for mechanical and electrical equipment
25 which the spectra indicates exceeds the CSDRS. That

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is the certified seismic design response spectra.

2 The hard rock high frequency issue is --
3 I mean the spectra indicates that that exceeds the
4 CSDRS quite a bit. So, from the ground motion, it
5 generates up to the floor response spectra. They
6 have exceedance also. So, they have to qualify the
7 equipment for those exceedance spectra.

8 Now, basically, we used SRP Section 3.10,
9 ISG-1, SECY Paper 93-087, to address these issues.

10 CHAIRMAN RAY: I didn't follow that last
11 thing you said because I was trying to figure out
12 what happened to the screen.

13 MR. CHEN: Yes. Okay. All right.

14 Initially, Westinghouse submitted a
15 topical report, TR-115, addressing the high frequency
16 issues. So, we generated quite a bit of RAI, and
17 then that is under the review of Topical Report 115.

18 All right.

19 CHAIRMAN RAY: Just leave it alone.

20 (Laughter.)

21 Yes, it's getting too hard to follow what
22 you're doing and what he's saying. It's becoming
23 impossible.

24 MR. CHEN: I will wait.

25 MEMBER SHACK: I think you're out of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 luck. Don't try to do anything at this point. Just
2 get to the right slide.

3 CHAIRMAN RAY: Just leave it there.

4 MEMBER SHACK: Leave it there. Don't
5 touch it.

6 (Laughter.)

7 MR. CHEN: All right. Then, I have to
8 look at my slide instead of looking at the screen.

9 Okay. Anyway, the RAI that we asked
10 under the review of TR-115 is directly applicable to
11 the DCD Appendix 3I which addressed the same high
12 frequency issues. So, all the response that we
13 reviewed for TR-115 is applicable to the review of
14 DCD Appendix 3I.

15 Now when we looked at the Westinghouse
16 response to all those RAIs, there is one significant
17 RAI issue which, based on Westinghouse's submittal,
18 for those equipment subject to high frequency
19 exceedance spectra, they only do the screening test,
20 which is doing one SSE response spectra, achieving
21 the response spectra, while, according to the
22 regulation and the guidance that we have for seismic
23 qualification of equipment, it is supposed to be
24 qualified for five OBEs and one SSE.

25 Now screening test is one SSE. They did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not perform the five OBE for the hard rock high
2 frequency spectra. So, we raised that issue through
3 the RAI and discussed with Westinghouse how to
4 resolve it.

5 Later on, they came back saying, since
6 all the equipment is going to be qualified for the
7 CSDRS spectra, that means they already have some
8 testing done for those standard spectra. They can
9 use that one to account for the five OBEs.

10 Well, the question will be -- I mean in
11 our question we asked Westinghouse to demonstrate and
12 through the calculation that the testing done using
13 CSDRS spectra can be shown to be equivalent or
14 greater than the five OBEs using the hard rock high
15 frequency exceedance spectra.

16 So, Westinghouse did go back, and then
17 they provide the calculation and demonstrate, yes,
18 it's equivalent or greater than five OBE for the hard
19 rock high frequency. So, this issue, at that time,
20 it was resolved.

21 However, recently -- well, recently means
22 they submit the TR-115, Revision 2, which calls all
23 the spectra changes for the equipment. So, we said,
24 well, by looking at the spectra, I will show you in
25 an example that the issue becomes not only for high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency area, but the increase is in the mid and
2 low frequency.

3 Well, that impacted the CSDRS testing
4 because that exceeded the original CSDRS response
5 spectra. So, we raised that issue, and then, of
6 course, our regulatory basis is GDC2, SECY Paper
7 93-087, and the Interim Staff Guidance 1.

8 The Westinghouse response to that RAI,
9 basically, they indicate that in the Appendix 3I of
10 DCD Revision 17 they categorized all the AP1000
11 equipment into two categories. One is potential high
12 frequency sensitivity equipment. The other table is
13 not sensitive to high frequency equipment.

14 Well, for the Category 1 equipment, they
15 already have a program for hard rock high frequency
16 screening tests. But for the Category 2 equipment,
17 which initially was qualified for CSDRS spectra, but
18 not addressed in the high frequency program, and in
19 that situation it was not clear how Westinghouse is
20 going to qualify for the Category 2 equipment, which
21 is the equipment not sensitive to the hard rock high
22 frequency spectra.

23 So, in the ISG, there is an item which
24 clearly stated that in the evaluation of all the
25 components other than high frequency sensitive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 equipment, for those cases where the ground motion
2 response spectra-based in structural response spectra
3 exceeds the standard in structural response spectra
4 below 50 hertz, then the structural integrity and
5 functionality evaluations are required.

6 So, they have to go back to going through
7 all their qualification data or records to see which
8 equipment needs to be further evaluated. This is
9 through one of the RAIs, EMB-11.

10 At this point, Westinghouse agrees that
11 they are going to go back and then look at all the
12 equipment qualification data and then to see whether
13 all the equipment is properly qualified.

14 Now I am going to give you the next
15 slide. That is an example of the floor spectra
16 exceedance. If you look at it, the dotted line is
17 the floor spectra for equipment generated through the
18 hard rock high frequency ground spectra. And if you
19 look at it, the exceedance for this spectra is not in
20 the high frequency area. It is in the mid frequency
21 and low frequency, which will affect the equipment.

22 So, they have to go back and then to see
23 each equipment location's required response spectra
24 and their qualification data, and then to see if the
25 qualification is properly done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, in conclusion, the changes from
2 Revision 17 of TR-115, Revision 2, are acceptable,
3 subject to two confirmatory items. Confirmatory Item
4 10, which is they have this calculation to
5 demonstrate that the CSDRS qualification can be
6 counted as equal or greater than five OBEs for the
7 hard rock high frequency. So, they have to put that
8 information into the DCD Appendix 3I. That is one of
9 their agreements.

10 The second agreement is to resolve this
11 RAI 11. What they are going to do is they go back to
12 revise the response to the RAI 11, revise the
13 Appendix 3I, to account for the increase or revised
14 response spectra as a result of TR-115, Revision 2.

15 So, that's it.

16 CHAIRMAN RAY: Okay.

17 MR. CHEN: I think they already are going
18 to do that.

19 CHAIRMAN RAY: Well, lots of things to do
20 still, huh?

21 MR. CHEN: I don't know how far they have
22 qualified all the equipment, and the other thing is
23 the original qualification may be still good.

24 CHAIRMAN RAY: Yes.

25 MR. CHEN: So, it is depending on how the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 results come out.

2 CHAIRMAN RAY: I understand.

3 Okay. Any questions?

4 MEMBER SHACK: I sort of hesitate to ask,
5 but I am going to do it anyway.

6 If I go back to 14, slide 14, the floor
7 motion is now higher, as you note, down in the low
8 frequencies, too. You get an exceedance. Is that
9 low frequency exceedance, you didn't get that before
10 they added the high frequency part to the ground
11 motion?

12 MR. CHEN: Yes, if you look at it, the
13 black line is the CSDRS RRS for the equipment.

14 MEMBER SHACK: Right.

15 MR. CHEN: Okay. Now, as a result of
16 high frequency ground motion, the spectra changed for
17 that particular location. So, the original
18 qualification to the black line is not good anymore
19 because --

20 CHAIRMAN RAY: Yes. But I understand it
21 is kind of amazing that the high frequency ground
22 motion would result in the change that you see there,
23 is the point.

24 MR. CHEN: Well, it goes through the
25 filtering effect of the structural --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: I understand, but it is
2 still kind of amazing.

3 (Laughter.)

4 MR. CHEN: Sure.

5 MEMBER SHACK: Okay, your reaction is
6 like mine.

7 CHAIRMAN RAY: Yes, yes. I've looked at
8 that stuff a lot, and it's kind of amazing.

9 MEMBER SHACK: Okay.

10 CHAIRMAN RAY: But, anyway, all right
11 now, Sanjoy, we're going to try to resolve one of
12 your issues. I'm glad you're here.

13 Well, I've first got to make sure
14 everybody is satisfied with these guys, but it is the
15 coding one. It is the last item on our agenda.

16 MS. MCKENNA: Well, okay, I think that
17 was a placeholder. What I thought we had left on the
18 general category of coding was this issue about
19 wetting and whether the distribution and the --

20 CHAIRMAN RAY: There were two items.
21 That was one of them, you're correct.

22 MS. MCKENNA: And this was a placeholder
23 that, if there were questions about that, but I don't
24 know that there has been sufficient time to get the
25 WCAPS to you to see if there were any questions. So,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I don't think we have anything prepared to discuss on
2 that.

3 And what was the other one remaining?

4 CHAIRMAN RAY: The other one is Professor
5 Banerjee's point here about the coding analysis, the
6 micrographs. I thought this --

7 MS. McKENNA: Okay. We provided the
8 references to Weidong.

9 MR. WANG: No, I haven't seen those.

10 MS. McKENNA: I don't know if they have
11 been --

12 MR. WANG: We haven't seen them. At
13 least I'm sure you have, but we haven't seen them.

14 CHAIRMAN RAY: This was something that --

15 MS. McKENNA: Micrographs?

16 CHAIRMAN RAY: -- Westinghouse was going
17 to give us. It said, "Tim of Westinghouse will send
18 the reference."

19 MS. McKENNA: I forwarded the references
20 to your staff.

21 CHAIRMAN RAY: Okay.

22 MS. McKENNA: There were two reports that
23 NRC had prepared, and I found them in ADAMS and --

24 CHAIRMAN RAY: You haven't seen them?

25 MR. WANG: No. There are three -- okay,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I don't recall three of them.

2 CHAIRMAN RAY: All right, stop it.

3 (Laughter.)

4 MS. McKENNA: Okay.

5 CHAIRMAN RAY: When we're done, you two
6 guys talk and get him what he needs. All right?

7 MS. McKENNA: Okay.

8 CHAIRMAN RAY: Because I don't want to
9 fool with this anymore.

10 And as far as the wetting is concerned,
11 you're saying --

12 MS. McKENNA: My understanding was that
13 there were a couple of WCAPS from like AP600 time
14 that some of the Committee members had requested, and
15 we had asked those of Westinghouse. With everything
16 else going on, I haven't had a chance to find out
17 whether they have been delivered to us and/or to --

18 CHAIRMAN RAY: You've been busy?

19 MS. McKENNA: Okay, they've been
20 delivered to us.

21 Weidong, have you received them?

22 MR. WANG: That particular WCAPS things,
23 I think Bill, he requested, and I sent out last
24 Friday by FedEx.

25 MS. McKENNA: Okay. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WANG: And I don't know if any of the
2 members --

3 CHAIRMAN RAY: All right, listen. This
4 sounds like staff needs to continue to working.
5 We're not going to do 50, is what it turns out to be.

6 MS. MCKENNA: Right. Yes.

7 MEMBER RYAN: Weidong, you sent it out as
8 a DVD?

9 MR. WANG: Yes. Not a DVD; a CD,
10 basically.

11 MEMBER RYAN: A CD, yes. Yes. That's
12 all right. Close enough.

13 (Laughter.)

14 MEMBER SHACK: Westinghouse was going to
15 come back with some work on the surface tension, too
16 though, right?

17 MEMBER ARMIJO: That was new.

18 CHAIRMAN RAY: I've got lots of CDs.

19 (Laughter.)

20 Listen, let's end this, so we can get off
21 the record here and do one other thing, and then call
22 it a day.

23 Anything more for these folks here?

24 (No response.)

25 Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 All right, Eileen, aside from this little
2 confusion here about 50, is there anything else you
3 want to tell us today?

4 MS. McKENNA: No.

5 CHAIRMAN RAY: All right. Except be here
6 on time in the morning?

7 How about Westinghouse? Ed, do you have
8 anything more you want to say?

9 MR. CUMMINS: No, thanks.

10 CHAIRMAN RAY: Okay. All right.

11 We will start tomorrow in open session to
12 -- I'm so confused now, I can't remember -- to do
13 something. Squib valves with Charlie. Charlie will
14 not be here until just 8:30, I'll bet you. So, we
15 will try to get that out of the way.

16 Then, we will do AIA, and then we will
17 give the day to Sanjoy.

18 MEMBER BANERJEE: I'm sorry?

19 CHAIRMAN RAY: I said we will do AIA and
20 then we'll give the day to you.

21 MEMBER BANERJEE: Why?

22 CHAIRMAN RAY: Because GSI-191.

23 MEMBER BANERJEE: All right. Fine.

24 MS. McKENNA: And some of the Chapter 15
25 LOCA issues --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SISK: Mr. Chairman, just one quick
2 point, if I may, sir?

3 CHAIRMAN RAY: Yes, Rob, go ahead.

4 MR. SISK: I just wanted to check. With
5 the action items that were addressed during the
6 shield building meeting, did they close out the
7 action items for --

8 CHAIRMAN RAY: We're going to talk about
9 that.

10 MR. SISK: Okay. I was just wondering.

11 CHAIRMAN RAY: But I am not going to
12 attempt to resolve here now. That is a longer
13 discussion, and I don't have everybody here because
14 we had two meetings going on simultaneously today.
15 People were going back and forth.

16 And I know we would all like the answer
17 to that question, but right now I am just going to
18 try to make sure we understand what the state of play
19 is and what we need to do. Then, I'm going to quit.

20 MR. SISK: Thank you.

21 CHAIRMAN RAY: But we will give you that
22 answer as soon as we can have it.

23 Well, with that, we are going to recess
24 for the day and resume at 8:30 in the morning. I
25 will ask the members to stay just a moment, so we can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 make sure our head is clear about the question Rob
2 asked, and then we'll go do something else for the
3 rest of the evening.

4 With that, we're done.

5 (Whereupon, at 5:17 p.m., the proceedings
6 in the above-entitled matter were recessed for the
7 day, to reconvene the following day, Thursday,
8 November 19, 2010, at 8:30 a.m.)

9
10
11
12
13

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

AP1000 Shield Building


Advisory Committee on Reactor Safeguards

November 17, 2010




AP1000 Shield Building

- Shields the containment vessel and systems within the containment from external events during normal operations, such as tornados and tornado-driven objects
- Supports the passive containment cooling water storage tank (PCSWST)
- Provides for natural air circulation cooling of the containment vessel
- Provides an additional radiological barrier for radioactive systems and components inside the containment vessel




SC Construction Provides Superior Performance against Missiles

RC Wall




SC Wall




Shield Building Design Features

- Revised the air inlet/ tension ring design for constructability and strength
- Reinforced cylindrical wall with tie bars between steel plates
- Increased SC plate thickness to improve strength and ductility
- RC/SC connection redesigned to improve ductility



Integrated Design Process



AP1000 Shield Building Design – All Open Issues Resolved

- The SC was adopted for the Shield Building because of its superior performance in resisting aircraft crash
- The adequacy of the Shield Building to meet regulatory requirements with large margin has been demonstrated through testing and benchmarked nonlinear analyses
- Design has undergone substantial improvements. Features have been implemented into the Shield Building design that increase the safety margin and make the SC Shield Building act more as a unit
- The design changes have been implemented through an integrated design approach that has considered all aspects of design, including durability, construction, and safety
- The out-of-plane shear capacity is much larger than the force demands in all regions of the Shield Building
- Pushover analyses demonstrate that the Shield Building has large margin and can withstand SSE and beyond RLE level earthquakes and system failure occurs by ductile membrane action and not by out-of-plane shear brittle failure.

AP1000 Design Control Document Amended Design

Section 3.7 Seismic Design

Section 3.7 Overview

- 3.7.1 Seismic Input
 - Design Response Spectra
 - Supporting media
- 3.7.2 Seismic System Analysis (Structures)
 - Seismic analysis methods
 - Soil-Structure interaction
 - Floor response spectra
 - Combination of modal responses
 - Seismic interactions

Section 3.7 Overview

- 3.7.3 Seismic Subsystem Analysis (Mechanical Systems and Components)
 - Seismic analysis methods
 - Combination of modal responses
 - Analytical procedure for piping
- 3.7.4 Seismic Instrumentation – No Changes
- Combined License Information
 - Timing clarification

Section 3.7 Changes

- Extension of hard-rock sites to soil sites
- Utilization of 3D finite element shell models
- Effect of High Frequency Ground Motion
- Use of the coherency function
- Classification of adjacent buildings

Open Items

- 15 Open Items in 3.7 SER
 - These open items are a result of NRC staff questions about changes to the DCD
 - Most of the questions are due to the addition of soil cases
- These open items have all been resolved

3.7 Open Items

- OI-SRP3.7.1-SEB1-19 – Justify the concrete cracking and damping value used in the analysis
- OI-TR03-005 – Justify 0.8 stiffness reduction factor for concrete cracking used for the SB analysis
- Resolution:
 - Additional nonlinear time history analysis supported the original analysis assumptions

3.7 Open Items

- OI-TR03-032 – Description of the proposed method using more detailed NI05 model to evaluate flexible regions.
- OI-SRP3.7.1-SEB1-06 – NI20 model for flexible regions up to 50 Hz
- Resolution:
 - The NI05 model has been reviewed for flexible regions where the out-of-plane response is considered flexible
 - The FRS for all “flexible nodes” is included in the design floor response spectra document as a separate table for area-specific spectra for use in local analyses.

3.7 Open Items

- OI-SRP3.7.1-SEB1-17 – Justify the treatment of missing mass in mode superposition
- Resolution:
 - The superposition time history analysis provides sufficient solution accuracy because the modes, which respond beyond cutoff frequency, have no significant contribution to the in-structure amplified response spectra.
 - A time history analysis at cutoff frequency was compared to an identical time history analysis with significantly more modes and the results were comparable.

3.7 Open Items

- OI-SRP3.7.1-SEB1-15 – Include methodology for structure-soil-structure interaction analyses of buildings adjacent to the NI
- Resolution:
 - Methodology included in the DCD
 - The seismic analysis performed for the adjacent Seismic Category II structures is a simulated 3D analysis.
 - Seismic Category II buildings are designed using envelope foundation input response spectra

3.7 Open Items

- OI-TR03-007 – Changes in the Shield Building dimensions required WEC to update sloshing analysis of the PCS tank
- Resolution:
 - NRC Audited WEC calculations and agreed with the conclusions

Questions?

AP1000 Design Control Document Amended Design

Section 3.8 Design of Category I Structures

Section 3.8 Overview

- Steel Containment
- Concrete and Steel Internal Structures
- Other Category I Structures
- Foundations

Section 3.8 Changes from DCD Rev. 15

- Enhanced Shield Building
 - Discussed separately
- Extended the AP1000 structure design to sites ranging from soft soils to hard rock
- Critical Section Design Updated
 - Soil cases
 - Design finalization
- Settlement evaluation during construction
 - Include construction sequence limits

Section 3.8 Open Items

- Items have been resolved with the NRC and the DCD changes included in the DCD Revision 18
 - 20 Open Items have been identified in SER for DCD Chapter 3.8
 - 1 additional RAI
 - 2 placeholder items for NRC action

Section 3.8.2 – Steel Containment

Open Items

- OI-RAI-TR09-08 – Provide details regarding temperature and external pressure loads of containment
- RAI-SRP3.8.2-SPCV-01 – Explain assumptions used in evaluation to determine containment external pressure
- Resolution:
 - Met with NRC to explain analysis
 - Provided analysis for audit
 - Design change to include vacuum relief system
 - Load combination table in the DCD is updated

Section 3.8.3 – Concrete and Steel Internal Structures Open Items

- OI-SRP3.8.3-SEB1-04 – Describe how the loads from the module can be properly transferred from the module to the embedded bars in the base concrete
- Resolution:
 - Design change has been made to use mechanical connectors

Section 3.8.4 – Other Category I Structures Open Items

- OI-TR85-SEB1-27 – Explain and justify the AP1000 implementation of 100/40/40 method for combination of the three direction seismic loading
- Resolution:
 - Provided a comparison of the calculated reinforcement demand with the 100/40/40 combination technique to the ASCE 4-98 100/40/40 combination technique
 - Westinghouse design deemed acceptable

Section 3.8.5 – Basemat Open Items

- OI-TR85-SEB1-10 – Request to make TR-09, TR-57, and TR-85 Tier 2* or provide acceptable alternative
- Resolution:
 - Information has been added to TR-09, TR-85, and TR-115 and is included in DCD Rev. 18
 - TR-57 was withdrawn because the information is included in DCD Section 3.8 and appendices

Section 3.8.5 – Basemat Open Items

- OI-TR85-SEB1-32 – Justify the assumption of uniform soil spring beneath the basemat
- Resolution:
 - Comparison of the maximum reactions of the Nuclear Island for various soil and analysis methods was completed
 - Comparison between equivalent static and dynamic time history analyses was completed
 - Both linear and nonlinear models compared
 - Comparison demonstrates that the assumption is acceptable

Questions?



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Subcommittee

**Advanced Final SER
Section 3.7 – Seismic Design**

**Westinghouse AP1000 Design Certification Amendment
Application Review**

November 17, 2010

Overview

- Staff summarized its safety evaluation for DCD Section 3.7 at ACRS Subcommittee Meeting on July 21-22, 2010.
- At that time, seven Open Items needed resolution and there were eleven confirmatory items.
- All Open Items are now either resolved or confirmatory pending formal submittal of DCD and TR revisions.

Phase 4 Status of 3.7

SRP Section/Application Section		July 21, 2010 Status Phase 2	November 17, 2010 Status Phase 4
3.7.1	Seismic Design Parameters	1 Open Item 2 Confirmatory Items	1 Confirmatory Item
3.7.2	Seismic System Analysis	6 Open Items 8 Confirmatory Items	12 Confirmatory Items
3.7.3	Seismic Subsystem Analysis	1 Confirmatory Item	-----

Staff Review Team

- Technical Staff
 - Brian Thomas, Chief, SEB1
 - Pravin Patel, Structural Engineer
 - Bret Tegeler, Sr. Structural Engineer
- Project Management
 - Billy Gleaves, Sr. Project Manager
- Contractor Support
 - Brookhaven National Laboratory
(C. Costantino, R. Morante)

Section 3.7.1 – Seismic Design Parameters

OI-SRP3.7.1-SEB1-19 (now Resolved)

- Justification for concrete modulus reduction to 80%
- Justification for damping values used in the building seismic analyses
 - Shield Building SC Walls - 5%
 - Reinforced Concrete structures - 7%.

[80% reduction in concrete modulus issue is also addressed in the OI-SRP3.8.3-SEB1-03 resolution; resolution also closes OI-TR03-05]

Section 3.7.2 – Seismic System Analysis

OI-TR03-032 (now Confirmatory)

- Demonstration that additional local amplification in flexible regions (walls, floors, roof) is adequately considered in developing ISRS for the ground motion up to 33 Hz.

OI-SRP3.7.1-SEB1-06 (now Confirmatory)

- Demonstration that additional local amplification in flexible regions (walls, floors, roof) is adequately considered in developing ISRS for the HRHF ground motion up to 50 Hz.

Section 3.7.2 – Seismic System Analysis

OI-SPR 3.7.1-SEB1-15 (now confirmatory)

- Applicant changed classification of Turbine Building (TB). TB first bay is now Seismic Cat II and rest of the TB is Non Safety.
- Applicant addressed the effect of the non seismic portion of the TB on the Cat II section of the TB.
- Applicant addressed structure-soil-structure interaction between the NI and adjacent Seismic Category II building structures.

Section 3.7.2 – Seismic System Analysis

OI-TR03-001 (now confirmatory)

- Applicant will include the dynamic modeling details for the enhanced shield building design in TR-03.

OI-SRP3.7.1-SEB1-17 (now resolved)

- Applicant provided details on how residual rigid response (i.e., missing mass) is addressed. The staff accepted the applicant justification.

Conclusion

- All open items in Section 3.7 are resolved or confirmatory pending formal DCD or TR revisions.



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS Subcommittee

**Advanced Final SER
Section 3.8 – Design of Category I Structures**

**Westinghouse AP1000 Design Certification Amendment
Application Review**

November 17, 2010

Overview

- All Open Items are now Resolved or Confirmatory pending DCD/TR revision
- Remaining slides highlight resolution of Some Key Open Items that are currently identified as Confirmatory
- This presentation excludes discussion of Shield Building
- Next slide presents the current status of the review of SRP Section 3.8

Phase 4 Status of 3.8 (Rev. 17)

SRP Section/Application Section		July 21, 2010 Status	November 17, 2010 Status
3.8.1	Concrete Containment	Not Applicable	Not Applicable
3.8.2	Steel Containment	4 Open Items 2 Confirmatory Items	6 Confirmatory Items
3.8.3	Concrete & Steel Internal Structures of Containment	4 Open Items 2 Confirmatory Items	5 Confirmatory Items
3.8.4	Other Seismic Category I Structures (excluding SB review)	1 Open Item	1 Confirmatory Item
3.8.5	Foundations	8 Open Items 2 Confirmatory Items	9 Confirmatory Items
3.8.6	Combined License Information	2 Open Items	2 Confirmatory Items

Staff Review Team

- Technical Staff
 - Brian Thomas, Chief, SEB1
 - John Ma, Sr. Structural Engineer
- Project Management
 - Billy Gleaves, Sr. Project Manager
 - Terri Spicher, Project Manager
- Contractor Support
 - Brookhaven National Laboratory
(J. Braverman, C. Costantino, & X. Wei)

Section 3.8.2 – Steel Containment

- CI-SRP3.8.2-SEB1-02

Issue(s)

- Applicant was requested to explain whether the design, construction, and inspection of the plant are in accordance with current regulatory guides

Resolution

- Information provided to demonstrate that design and construction of containment is in accordance with RG 1.57 Rev. 1 for load combinations and design limits, RG 1.7 Rev. 3 for hydrogen generated pressure loads, and RG 1.199 Rev. 0 for anchorage
- For inspection of other plant structures, the DCD will be revised to indicate that the COL applicant is responsible for establishing a structures inspection program consistent with the Maintenance Rule 10CFR50.65 and RG 1.160.

Section 3.8.2 – Steel Containment

- CI-SRP3.8.2-SEB1-04

Issue(s)

- Additional information needed to describe the 3-D finite element model of containment used for local evaluation near penetrations and axisymmetric model used for analysis away from penetrations

Resolution

- Information provided to describe both models with specific reference to TR-09 for more detailed information
- DCD markups provided to incorporate the additional descriptions presented in the RAI response.

Section 3.8.3 – Concrete and Steel Internal Structures of Containment

- CI-SRP3.8.3-SEB1-04

Issue(s)

- Connection detail of containment internal structures using concrete-filled steel modules does not rely on a direct load path from module steel faceplates to reinforced concrete base

Resolution

- Revised connection detail to utilize a direct load path from steel face plates to reinforced concrete base
- Revised detail utilizes steel dowels which at one end are welded to face plates using mechanical connectors and at other end embedded in reinforced concrete base.

Section 3.8.4 – Other Seismic Category I Structures

- CI-SRP3.8.4-SEB1-03

Issue(s)

- Revisions made in DCD Rev. 16 regarding “critical sections” - e.g., number of critical sections reduced, incomplete information, removal of some Tier 2* information

Resolution

- Markups for additional critical sections provided to be consistent with the certified design in DCD Rev. 15
- Markups for tabulated results that were removed from DCD Rev. 15 were provided – e.g., load combinations & member forces for critical sections
- Markups provided to include additional design information – e.g., required reinforcement for concrete members and required plate thicknesses for modules
- Markups provided to restore Tier 2* information.

Section 3.8.5 – Foundations

- CI-TR85-SEB1-04

Issue(s)

- Inadequate description of the soil bearing pressure evaluation and foundation stability evaluation

Resolution

- Information provided to describe the methodology for soil bearing pressure and foundation stability evaluation
- Markups for DCD provided for these evaluations.

Section 3.8.5 – Foundations

- CI-TR85-SEB1-10

Issue(s)

- Difficulties were encountered in demonstrating adequate factor of safety for the seismic sliding stability evaluation using the equivalent static method

Resolution

- A more realistic non-linear time history analysis was performed
- Utilized a revised 2-D ANSYS surface mounted model (conservative because no benefit of embedment considered)
- At interface with soil, utilized finite elements with sliding friction and uplift capabilities
- Seismic input was increased by 10% to demonstrate that the factor of safety requirement of 1.10 per SRP 3.8.5 was met.

Section 3.8.5 – Foundations

- CI-TR85-SEB1-32

Issue(s)

- Foundation seismic design was based on the assumption of uniform soil springs beneath basemat which is not consistent with known soil pressure distributions (i.e., higher around periphery of foundation than within)

Resolution

- Study performed which utilized soil finite element representation and compared results to the uniform soil spring model
- Based on this study, some member forces in the foundation became higher
- Basemat re-evaluated for higher forces, and the results indicate that the basemat still meets the ACI 349 Code

Section 3.8.5 – Foundations

- CI-TR85-SEB1-36

Issue(s)

- Additional information needed to describe the development of the settlement criteria consistent with the evaluation of the effects of settlement on the structural integrity of the NI

Resolution

- A description was provided on how the settlement criteria were developed using a non-linear analysis of the foundation during construction and over time
- Settlement criteria were updated and markups for the DCD were provided to give guidance on the settlement criteria for the COL applicants.

Section 3.8.5 – Foundations

- CI-TR85-SEB1-37

Issue(s)

- Requirement for soil angle of internal friction needs to be defined in the DCD for the COL applicants

Resolution

- Markups provided for revision of DCD Tier 1 and Tier 2 to define minimum soil angle of internal friction
- If minimum soil angle of internal friction cannot be met, then site-specific evaluation is required.

AP1000 Design Control Document

Tier 2 Chapter 3

Design of Structures, Components, Equipment, and Systems



Tier 2 Chapter 3

- Chapter Overview
 - General Design Criteria
 - Classification of Structures, Components, and Systems
 - Wind and Tornado Loadings
 - Water Level (Flood) Design
 - Missile Protection

Tier 2 Chapter 3

- Chapter Overview (continued)
 - Postulated Pipe Rupture Dynamic Effects
 - Seismic Design
 - Design of Category I Structures
 - Mechanical Systems and Components
 - Seismic and Dynamic Qualification
 - Environmental Qualification

3.2 Classification of Structures, Components, and Systems



- The classification approach is not changed in the DC amendment
- The classification details are changed to reflect design finalization
- Open Items were a result of NRC audit and review of design documents - These open items are resolved.

3.2 Classification of Structures, Components, and Systems - Open Items



Item	Subject	Status/Comments
OI-SRP3.2.1-EMB2-01	Seismic Requirements for Class D Systems	Closed - Use of seismic anchorage is consistent with SECY-96-128
OI-SRP3.2.1-EMB2-02	Seismic Classification for Electrical and other Equipment not in Table 3.2-3	Closed - Table 3.11-1 provide seismic classification of electric and instrumentation equipment
OI-SRP3.2.1-EMB2-03	Augmented QA for SC II SSCs	Closed – DCD revised to reference DCD 17.3 for augmented quality requirements for seismic Category II SSCs and pertinent portions of 10 CFR 50 Appendix B.
OI-SRP3.2.1-EMB2-06	SSCs Required for continued operation	Closed - DCD Subsection 3.2.1.1 revised to reference Appendix S. Regulatory Guide is not applicable to the design certification
OI-SRP3.2.2-EMB2-01	Supplemental Requirements for risk significant RTNSS Systems	Closed - AP1000 RTNSS SSCs apply quality standards commensurate with the importance of their safety functions
Correction of Table 3.2-3	From extent of condition	FPS Classification corrected.



3.3.Wind and Tornado Loadings

3.5 Missiles

- Impact of tornado borne automobile missile at higher elevations is included to support COL applicants
- Open Items were the result of design changes (radwaste tanks) and NRC review (automobile and siding missiles) –
These items resolved

3.3.Wind and Tornado Loadings – 3.5 Missiles

Open Items



Item	Subject	Status/Comments
OI-SRP3.3.2-SEB1-01	Impact of steel siding missile on the modular wall of the shield building	Closed - Structural integrity of the Seismic Category I structures will not be compromised from the siding missile strikes
OI-SRP3.7.2-SEB1-02	Effect of 3 added radwaste tanks on collapse of Radwaste Building	Closed - Tanks will not become a tornado born missile
RAI COL03.05.01.04-1	Elevated automobile	Closed – NI Structure demonstrated to be not subject to global failure due to sliding and overturning at the base by impact of an automobile.



3.4 Water Level (Flood) Design

- Open items resulted from design changes
 - Roof design of seismic Category II structures altered,
 - Fire tank volume increased,
 - Radwaste tanks added to Radwaste Building.
- These items resolved

3.4 Water Level (Flood) Design – Open Items



Item	Subject	Status/Comments
OI-SRP3.4.1-RHEB-01	Analysis of Parapet roof design for Probable Maximum Precipitation	Closed – Parapet Roof not on Seismic Cat. 1 Structures. The roof drain design includes no weirs.
OI-SRP3.4.1-RHEB-02	Analysis of increase in fire tank volume	Closed – Site is graded away from Nuclear Island.
OI-SRP3.4.2-SEB1-01	Hydrodynamic load of tanks in Radwaste Building	Closed – Flood level of 6 inches is insignificant load on NI walls.



3.6 Postulated Pipe Rupture Dynamic Effects – 3.12 Piping



- COL Information Item added to address completion and review of piping design
- COL Information Items added to address completion and pipe rupture hazard report.
- The computer code used for piping fatigue analysis (WESTEMS) is withdrawn from review in the design certification amendment.
 - NRC Staff will evaluate piping design fatigue analysis at the time of COL item closure
 - Benchmark program is required by DCD if a piping analysis program other than those for design certification is used



3.6 Postulated Pipe Rupture Dynamic Effects

COL Information item



3.6.4.1 Pipe Break Hazard Analysis

The following activity-will be completed by the COL applicant:

Combined License applicants referencing the AP1000 certified design will complete the as-designed pipe rupture hazards evaluation and make design information available for NRC review. The completed as-designed pipe rupture hazards evaluation will be in accordance with the criteria outlined in subsections 3.6.1.3.2 and 3.6.2.5. Systems, structures, and components identified to be essential targets protected by associated mitigation features (reference is Table 3.6-3) will be confirmed as part of the evaluation, and updated information will be provided as appropriate.



3.9 Mechanical Systems and Components

Piping COL Information Item



3.9.8.7 As-Designed Piping Analysis

The following activity will be completed by the COL applicant:

Combined License applicants referencing the AP1000 design will complete the as-designed piping analysis (DAC) for the piping lines chosen to demonstrate all aspects of the piping design. A design report referencing the as-designed piping calculation packages – including ASME Section III piping analysis, support evaluations, and piping component fatigue analysis for Class 1 piping using the methods and criteria outlined in Table 3.9-19 – will be made available for NRC review. The availability of the piping design information and design reports will be identified to the NRC. Combined License applicants may address this item in accordance with the process options for DAC/ITAAC closure outlined in Appendix 14A.



Westinghouse

3.6 Postulated Pipe Rupture Dynamic Effects – Open Items



Item	Subject	Status/Comments
OI-SRP3.6.2-EMB2-01	<ul style="list-style-type: none"> • Evaluation of leakage and through wall cracks, • Complete as-designed pipe break hazards analysis report 	Closed - COL information item - COL applicants referencing the AP1000 design will complete the as-designed pipe rupture hazards analysis report
OI-SRP3.6.3-CIB1-01	Review as-designed LBB analyses for other-than-hard-rock seismic input	Closed - NRC staff will review the final as-built LBB analyses results



3.9 Mechanical Systems and Components – Open Items



Item	Subject	Status/Comments
OI-SRP3.9.1-EMB1-03	Follow up WESTEMS audit	WESTEMS is withdrawn from Design Certification Review
OI-SRP3.9.1-EMB1-04	Provide guideline or criteria for developing or benchmarking transfer function stress database	WESTEMS is withdrawn from Design Certification Review
OI-SRP3.9.1-EMB1-05	Provide technical justification for this option in selecting peak and valley times for the fatigue evaluation	WESTEMS is withdrawn from Design Certification Review
OI-SRP3.9.1-EMB1-06	Provide benchmark acceptance criteria to validate the computer code calculation (WESTEMS)	WESTEMS is withdrawn from Design Certification Review
OI-SRP3.9.1-EMB1-07	Provide the configuration control and limitations of WESTEMS for an option to eliminate peak/valley points	WESTEMS is withdrawn from Design Certification Review



3.9 Mechanical Systems and Components

3.9.2, 3.9.3, and 3.9.4



- NRC Open items generated by the review of design documents are resolved.
 - Flow Skirt Vortices
 - CRDM Nozzle J-Groove weld
 - Recirculation Screen loads
- International CRDM classification questions resolved.



3.9 Mechanical Systems and Components – Open Items



Item	Subject	Status/Comments
OI-SRP3.9.2-EMB1-07	Potential for generation of vortices in the region of the flow skirt	Closed - Any vortices generated will therefore be too small
OI-SRP3.9.3-EMB2-05	ASME Code Requirements for reactor vessel J-Groove weld	Closed - Westinghouse completed a plastic analysis and revised design documents
OI-SRP3.9.3-EMB2-08	Address issues with Containment Recirculation Screens design specifications	Closed - Updated design documents to include loads on screens

3.9 Mechanical Systems and Components – Open Items



Item	Subject	Status/Comments
RAI-SRP3.9.4-EMB1-01	Seismic classifications of the CRDM latch mechanism and coil stack assembly	Safety analyses do not rely on latch assembly function during an earthquake.
RAI-SRP3.9.4-EMB1-02	International standards for CRDM components	Design, fabrication and quality assurance requirements for the CRDM latch assemblies are the same for U. S. and international applications.

3.9 Mechanical Systems and Components

Valve Testing



- Open items for valve in-service testing and functional testing are resolved.
 - Resulted from NRC Audit
 - AP1000 is implementing testing required by Joint Owners' Group MOV program
 - Additional information provided in response to ACRS Action Item 46

3.9 Mechanical Systems and Components – Open Items – 3.9.6



Item	Subject	Status/Comments
OI-SRP3.9.6-CIB1-01	Resolve issues from onsite review of design and procurement specifications for pumps, valves, and dynamic restraints	Closed – Follow up review verified changes to design documents.
OI-SRP3.9.6-CIB1-02	Reference to static testing needs to be consistent with the JOG MOV Program, which might require dynamic testing	Closed – DCD revised to remove reference to valves outside JOG Program.
OI-SRP3.9.6-CIB1-03	Specify the edition of the ASME Standard QME-1 referenced in Section 3.9	Closed – DCD to reference ASME QME-1-2007
OI-SRP3.9.6-CIB1-04	Application of ASME OM Code Case OMN-1 as part of the AP1000 IST Program	Closed DCD specifies use of ASME OM Code Cases must be consistent with RG 1.192.



3.9 Mechanical Systems and Components – Open Items – 3.9.6



Item	Subject	Status/Comments
OI-SRP3.9.6-CIB1-05	Technical Specifications and Technical Specification Bases need to be revised to be consistent with the ASME OM Code	Closed - Technical Specifications and Technical Specification Bases to be revised to be consistent with the ASME OM Code
OI-SRP3.9.6-CIB1-06	Include Acceptance Criteria for Check Valve and clarify response to RAI-SRP3.9.6-CIB1-12	Closed – Revise DCD to include check valve test acceptance criteria
OI-SRP3.9.6-CIB1-07	Clarify Table 3.9-16 Note 31 be consistent with the JOG MOV periodic verification program	Closed – Revise Note 31 in Table 3.9-16 to be consistent with the JOG MOV periodic verification program
OI-SRP3.9.6-CIB1-08	Clarify the reference to ASME OM Code, Subsection ISTC-3700 to confirm that the exercise test frequency requirements specified in the ASME OM Code will be satisfied	Closed - Revised DCD Table 3.9-16 to indicate a separate Fail Safe test for the applicable valves with fail safe functions



3.9 Mechanical Systems and Components – Open Items – 3.9.6



Item	Subject	Status/Comments
OI-SRP3.9.6-CIB1-09	Address issues about testing for CVS valves	Closed - Revised DCD table as requested.

3.10 Seismic and Dynamic Qualification

3.11 Environmental Qualification



- Screening of equipment for sensitivity to high frequency motion is discussed in DCD Appendix 3I
- RAIs on screening for equipment sensitive to high frequency motion and conformance with COL/DC-ISG-1 have been resolved.
- The open item on equipment qualification requirements in design documents is resolved.

3.11 Environmental Qualification – Open items



Item	Subject	Status/Comments
OI-SRP3.11-CIB1-01	Revise design and procurement specifications to address NRC audit comments on equipment qualification	Closed - Valve design specifications require that active valves will be qualified in accordance with ASME Standard QME-1-2007



ACRS Questions

ACRS Actions 4, 46, and 55

ACRS Action 46

Valve Testing Risk Ranking



Components MOV, POV testing, how is the risk informed and ranked. PRA is not sufficient and need to review other criteria.

- The risk ranking of valves to determine the frequency for valve operability testing is a COL responsibility
- The DCD includes a COL information item that the COL applicant must complete an evaluation to determine the frequency of valve operability testing.
 - This evaluation will include risk ranking.
 - The DCD also includes a description of the evaluation to be completed to determine the frequency.
- Risk ranking is not completed as part of the design certification.



ACRS Action 46

Valve Testing Risk Ranking



- The determination of valve operability test frequency uses a combination of functional margin and risk ranking.
 - High risk, low margin → more frequent
 - Low risk, high margin → less frequent
- Valve margin evaluates load on actuator and capability of actuator.



ACRS Action 46

Valve Testing Risk Ranking



- In response to NRC Generic Letter GL 96-05, the Westinghouse Owners Group prepared a report on the risk ranking approach for the existing fleet.
- The approach identified in the report includes six steps
 1. Identify valves to be considered
 2. Calculate valve at-power risk importance
 3. Assess PRA completion issues
 4. Evaluate other considerations
 5. Develop component ranking worksheets
 6. Conduct expert panel session for ranking.



ACRS Action 46

Valve Testing Risk Ranking



- Valves subject to operability testing are identified in DCD Table 3.9-16
- Risk importance is considered based on both core damage frequency and large release frequency.
- Shutdown risk has been quantified for AP1000
- Westinghouse and AP1000 utility personnel have participated in risk ranking expert panels for the GL 96-05 responses.



ACRS Action Item 55

Squib Valve Functional Testing



Testing of Squib Valves - Verification/qualification program, IST program. - Banerjee

Details on how many tests, what's the configuration, what are the upstream pressures, and etc, aside from how do you test them once they are in service. – Brown

- The squib valve design includes functional testing, lot acceptance testing, equipment qualification testing and in-service testing.



ACRS Action Item 55

Functional Testing



- The design and development program includes functional testing of the design at the extreme conditions. Variables include propellant loads, material properties, environmental conditions, and machining tolerances.
- 17 tests have been completed with prototype valves with all valves opening
- Propellant loads included 80% of nominal, 120 % of nominal, and higher
- Tests were done with air at ambient and water at ambient and at pressures up to 450 PSI.
- Shear cap thicknesses include nominal, minimum, and maximum.
- Tension bolts at minimum and maximum break strength were included.



ACRS Action Item 55

Squib Valve Functional Testing



- Lot acceptance testing (LAT) is required of the production lots of critical one time use valve internal parts (shear caps and tension bolts).
 - For the current production orders there are 22 full scale tests.
 - Fourteen (14) – 14” ADS Valves
 - Six (6) – 8” HP Valves
 - Two (2) – 8” LP Valves
 - These will be done with the actuator loaded at 80% of nominal.
- The actuators (charges) also have a sample size of 10% of the entire lot, including deliverables, assurance, and LAT units tested.

ACRS Action Item 55

Squib Valve In-Service Testing (IST)



- The IST Table in the DCD requires a Charge Test Fire of 20% in 2 Years
 - The squib valve charge is removed and test fired outside of valve.
 - Squib valves are not exercised for in-service testing.
 - Consistent with ASME OM requirements
- Westinghouse will provide additional in-service inspection and testing recommendations to the utilities as appropriate.
 - Recommendations are a result of the design and development activities.

ACRS Action Item 55

Squib Valve Equipment Qualification



- The squib valve is qualified based on the guidance provided in IEEE Std 323-1974, IEEE Std 344-1987, IEEE Std 382-1996 and ASME QME-1 2007 with referencing to the power operated valve process. This includes actuator environmental seismic and Design Basis Accident simulation, qualification of the safety-related non metallic components, valve assembly functional testing, and flow testing.
- The NRC Component Integrity Branch has audited Westinghouse general equipment qualification methodology documents and the squib valve design specification.
- NRC personnel have observed the squib valve design reviews where equipment qualification has been discussed in detail.



ACRS Action 4

RCP Flywheel Design



I would like to receive stress corrosion test reports performed by W or pump supplier on the 18Cr 18Mn retainer ring material. I suspect that they have not tested this material sufficiently (if at all) to demonstrate SCC resistance in the coolant environment. Even though the ring is sealed in a Alloy 625 can, the assembly will not be inspected in service, and there will be no way of knowing whether the can will remain leak tight during service. If SCC of the retainer ring occurs, a serious accident would be likely. –Armijo



ACRS Action 4

RCP Flywheel Design



- The potential for corrosion and consequences of the 18Cr 18Mn retainer ring material is not a safety issue.
- Westinghouse has reviewed industry testing and is not planning any more testing of the retainer ring material in support of DCD Rev. 18
 - The flywheel including the retainer ring is sealed in an enclosure to prevent exposure to reactor coolant
 - Pressure boundary criteria and requirements are applied for welding and helium leak test for the enclosure design and fabrication
 - Industry stress corrosion testing in environments more severe than reactor coolant have shown satisfactory resistance to stress corrosion cracking

ACRS Action 4

RCP Flywheel Design



- If the enclosure would leak, the worst case is a flywheel failure which would not be a safety issue
 - Flywheel missile analysis has shown tungsten inserts would be contained within the pressure boundary and would not create a LOCA
 - If the rotor would lock due to the flywheel failure, analyses have shown the integrity of the reactor coolant pump to steam generator weld and reactor coolant pump to cold leg weld would be maintained and would not create a LOCA
 - The Chapter 15 safety analysis has shown the acceptability of core cooling during a locked rotor event

ACRS Action 4

RCP Flywheel Design



- We understand that the position of the NRC staff, as documented in the Chapter 5 SER, is that the material is acceptable for the application.
 - “Since this alloy steel is not a nickel based alloy, such as Alloy 600, primary water stress corrosion cracking is not a concern. The NRC also notes that the 18Mn-18Cr alloy steel outer hub will be enclosed in a Alloy 625 flywheel enclosure to prevent the outer hub from contacting the reactor coolant. Therefore, the staff finds the use of the 18Mn-18Cr alloy steel acceptable based on the current operating experience of this material in an aggressive stress corrosion environment,”



Westinghouse

Questions



**Presentation to the ACRS
Subcommittee**

**Westinghouse AP1000 Design Certification Beyond
Amendment (Revision 17) Application Review**

Advanced Final SER

Section 3.9.1 – Special Topics for Mechanical Components

Section 3.12 – Piping Design

Appendix 3I – Evaluation for High Frequency Seismic Input

Staff Review Team

- Technical Staff
 - Robert Hsu
 - John Wu
- Project Management
 - Phyllis Clark

Overview of AP1000 DCD

DCD SECTION - SUMMARY OF CHANGES

DCD SECTION		SUMMARY OF CHANGES
3.9.1	Special Topics for Mechanical Components	<ul style="list-style-type: none">• Remove WESTEMS Computer Program
3.12	Piping Design	<ul style="list-style-type: none">• Add piping DAC and DAC/ITAAC closure process
Appendix 3I	Evaluation for High Frequency Seismic Input	<ul style="list-style-type: none">• Revise the sample to be evaluated for the piping systems

Technical Topics of Interest, AP1000 DCA

3.9.1 Special Topics for Mechanical Components

- **WESTEMS Computer Code**
 - **Five Open Items addressing concerns with the quality assurance and methodology used in the WESTEMS Code**
 - **Staff completed audits and identified continuing concerns with quality assurance and methodology resulting in two remaining open items. The staff documented its audit results in the WESTEMS audit summary report.**
 - **By letter dated September 29, 2010 (ML1027703290), Westinghouse determined to remove WESTEMS from DCD markup that adds WESTEMS to DCD Table 3.9-15.**
 - **On the basis that the applicant will not apply the current version WESTEMS for AP1000 design analysis, the staff closed OIs.**

Technical Topics of Interest, AP1000 DCA

3.12 Piping Design

- **By letters dated April 1, 2010 (ML100970364) and August 23, 2010 (ML102380040), , the applicant stated that Westinghouse would not remove piping DAC and provide a DAC/ITAAC closure process.**
- **On the basis that the piping DAC was approved in Rev. 15 and the additional clarification provided with the DAC/ITAAC closure process, the staff finds this acceptable.**

Technical Topics of Interest, AP1000 DCA

3.12 Piping Design

- **Hard Rock High Frequency (HRHF) Ground Motion Response Spectra (GMRS) Exceedance Seismic Input**
 - Seismic input was identified in Section 3.7.3 as inadequate due to a mathematical model error.
 - The applicant revised TR-115, “Effects of High Frequency Seismic Content on SSCs”, with adequate seismic input.
 - The staff reviewed TR-115 and noted that the applicant’s screening criteria selection did not address response spectra exceedance due to in structure response spectra (ISRS), which is the input for mechanical components and piping design analysis and qualification.
 - By letter dated August 17, 2010 (ML 102350447), the applicant revised DCD Appendix 3I to evaluate HRHF GMRS for all ASME Class 1, 2, and 3 piping systems instead of 2 sample piping systems. This evaluation is within the scope of the piping DAC.
 - On the basis that the applicant will address seismic evaluations for all Class 1, 2, and 3 piping systems, the staff finds this acceptable.



Presentation to the ACRS Subcommittee

**Westinghouse AP1000 Design Certification Beyond
Amendment (Revision 17) Application Review**

Advanced Final SER Section 3.10

**Seismic and Dynamic Qualification of Mechanical and
Electrical Equipment**

Staff Review Team

- Technical Staff
 - Pei-Ying Chen
- Project Management
 - Phyllis Clark

ACRS Subcommittee Presentation

AP1000 Design Certification Review

Section 3.10 – Seismic and Dynamic Qualification of Equipment

Summary of Major Changes from DCD Revision 15 to DCD Revision 17

- Westinghouse decided not to use Experience – Based Qualification Method for Seismic Qualification of AP1000 mechanical and electrical equipment
- Appendix 3I.6.4 of AP1000 DCD Revision 17 addresses the Certified Seismic Design Response Spectra (CSDRS) exceedance in high frequency spectrum region at some Central and Eastern United States rock sites.

CSDRS High Frequency Exceedance

- Staff Guidance: SRP Section 3.10, COL/DC – ISG-1, and SECY – 93-087
- Resolution of RAIs on the Review of APP-GW-GLR-115 (TR-115) is directly applicable to DCD Appendix 3I for high frequency issues
- One significant RAI issue – Westinghouse did not perform, in addition to the HRHF SSE screening test, low level testing (5 OBEs) for equipment identified as potentially sensitive to HRHF excitation.

CSDR High Frequency Exceedance (continued)

- Westinghouse provided the calculations to justify that equipment testing for AP1000 CSD ISRS is equivalent to or envelops the five one-half SSE events using the AP1000 HRHF ISRS, that resolves the 5-OBE issue (to be incorporated into the future DCD revision – CI-SRP3.10-EMB-10).
- **RAI-SRP3.10-EMB-11 (On TR115, Revision 2)**
Some equipment GMRS-based (HRHF) ISRS is higher than previously evaluated for the exceedance over the CSDRS-based ISRS. Westinghouse was requested to demonstrate the seismic adequacy of all AP1000 mechanical and electrical equipment.
- Regulatory Basis: GDC 2, SECY-93-087 and ISG-1

CSDR High Frequency Exceedance (continued)

- **Westinghouse Response**

Appendix 3I of AP1000 DCD, Revision 17

- Category 1 equipment (potential HF sensitive) – In addition to CSDRS seismic qualification testing, HRHF screening test will be performed.
- Category 2 equipment (not HF sensitive) – Only CSDRS seismic qualification testing is performed.
- Not clear how Westinghouse is going to qualify Category 2 equipment if the GMRS-based ISRS exceeds the CSDRS-based ISRS to satisfy ISG-1 and requirements of GDC 2.

CSDR High Frequency Exceedance (continued)

- **Regulatory Guidance (Section 3.2.2 of ISG-1)**


In the evaluation of SSCs other than HF sensitive equipment, for those cases where the GMRS-based ISRS exceed the CSDRS-based ISRS below 50 Hz, further structural integrity and functionality evaluations are required.

- **Path to Resolution**

Westinghouse agreed to revise its RAI response, Appendix 3I, and TR115 Revision 2, to verify the adequacy of the equipment seismic qualification for all AP1000 equipment for entire frequency range of interest, including mid and low frequency range exceedance. (CI-SRP3.10-EMB-11). Example:

CSDR High Frequency Exceedance (continued)

APP-RNS-PLR-010 Floor Response Spectra X-Direction 5% Damping



ACRS Subcommittee Presentation AP1000 Design Certification Review

Section 3.10 – Seismic and Dynamic Qualification of Equipment

Conclusions

- Changes from DCD Revision 17 and TR115 Revision 2 are acceptable subject to Confirmatory Items CI-SRP3.10-EMB-10 and CI-SRP3.10-EMB-11, because the AP1000 mechanical and electrical equipment are seismically qualified for the entire frequency range of interest.