

**APPENDIX 15B****REMOVAL OF AIRBORNE ACTIVITY FROM THE CONTAINMENT ATMOSPHERE FOLLOWING A LOCA**

The AP1000 design does not depend on active systems to remove airborne particulates or elemental iodine from the containment atmosphere following a postulated loss-of-coolant accident (LOCA) with core melt. Naturally occurring passive removal processes provide significant removal capability such that airborne elemental iodine is reduced to very low levels within a few hours and the airborne particulates are reduced to extremely low levels within 12 hours.

**15B.1 Elemental Iodine Removal**

Elemental iodine is removed by deposition onto the structural surfaces inside the containment. The removal of elemental iodine is modeled using the equation from the Standard Review Plan (Reference 1):

$$\lambda_d = \frac{K_w A}{V}$$

where:

$\lambda_d$  = first order removal coefficient by surface deposition

$K_w$  = mass transfer coefficient (specified in Reference 1 as 4.9 m/hr)

$A$  = surface area available for deposition

$V$  = containment building volume

The available deposition surface is 219,000 ft<sup>2</sup>, and the containment building net free volume is 2.06 x 10<sup>6</sup> ft<sup>3</sup>. From these inputs, the elemental iodine removal coefficient is 1.7 hr<sup>-1</sup>.

Consistent with the guidance of Reference 1, credit for elemental iodine removal is assumed to continue until a decontamination factor (DF) of 200 is reached in the containment atmosphere. Because the source term for the LOCA (defined in subsection 15.6.5.3) is modeled as a gradual release of activity into the containment, the determination of the time at which the DF of 200 is reached needs to be based on the amount of elemental iodine that enters the containment atmosphere over the duration of core activity release.

**15B.2 Aerosol Removal**

The deposition removal of aerosols from the containment atmosphere is accomplished by a number of processes including sedimentation, diffusiophoresis, and thermophoresis. All three of the deposition processes are significant contributors to the overall removal process in the AP1000. The large contributions from diffusiophoresis and thermophoresis to the total removal are a direct

consequence of the high heat transfer rates from the containment atmosphere to the containment wall that characterize the passive containment cooling system.

Because of the AP1000 passive containment cooling system design, there are high sensible heat transfer rates (resulting in higher thermophoretic removal of aerosols) when condensational heat transfer is low (and the aerosol removal by diffusiophoresis is also low). The reverse is also true. Thus, there is an appreciable deposition removal throughout the accident from either diffusiophoresis or thermophoresis, in addition to the removal by sedimentation.

### 15B.2.1 Mathematical Models

The models used for the three aerosol removal processes are discussed as follows.

#### 15B.2.1.1 Sedimentation

Gravitational sedimentation is a major mechanism of aerosol removal in a containment. A standard model (Stokes equation with the Cunningham slip correction factor) for this process is used. The Stokes equation (Reference 2) is:

$$v_s = \frac{2\rho_p g r^2 C_n}{9\mu}$$

where:

$v_s$  = settling velocity of an aerosol particle

$\rho_p$  = material density of the particle

$g$  = gravitational acceleration

$r$  = particle radius

$\mu$  = gas viscosity

$C_n$  = Cunningham slip correction factor, a function of the Knudsen number ( $Kn$ ) which is the gas molecular mean free path divided by the particle radius

However, the Stokes equation makes the simplifying assumption that the particles are spherical. The particles are expected to be nonspherical, and it is conventional to address this by introducing a "dynamic shape factor" (Reference 2) in the denominator of the Stokes equation, such that the settling velocity for the nonspherical particle is the same as for a spherical particle of equal volume. The value of the dynamic shape factor ( $\phi$ ) thus depends on the shape of the particle and, in general, must be experimentally determined.

The concept of dynamic shape factor can also be applied to a spherical particle consisting of two components, one of which has the density of the particle material, while the other component has a different density (Reference 9). In this manner, the impact of the void fraction in the particle can be modeled. Thus, the revised Stokes equation is:

$$u_s = \frac{2\rho_p g r^2 C_n}{9\mu\phi}$$

The derivation of  $\phi$  follows.

The two-component particle is considered to have a density  $\rho_{av}$  and an effective radius of  $r_e$ . Assuming that the second component of the particle is the void volume and letting the void fraction be  $\varepsilon$ , then the average density of the particle is:

$$\rho_{av} = \text{the average density of the particle} = \rho_p (1-\varepsilon) + \rho_v \varepsilon$$

where:

- $\rho_v$  = density of the void material (0.0 for gas filled, 1.0 for water filled)
- $\varepsilon$  = void fraction
- $\rho_p$  = material density (solid particle with no voids)

The definition of  $\phi$  is obtained from the Stokes equation and the equation for mass of a sphere:

$$\frac{2\rho_p g r^2 C_n}{9\mu\phi} = \frac{2\rho_{av} g r_e^2 C_n}{9\mu}$$

which reduces to:

$$\rho_p r^2 = \phi \rho_{av} r_e^2$$

and

$$\frac{4\rho_p \pi r_0^3}{3} = \frac{4\rho_{av} \pi r_e^3}{3}$$

which reduces to:

$$\rho_p r_0^3 = \rho_{av} r_e^3$$

Then:

$$\phi = \frac{\rho_p r^2}{\rho_{av} r_e^2}$$

and

$$r_e = r \left( \frac{\rho_{av}}{\rho_p} \right)^{-1/3}$$

From these two relationships, the dynamic shape factor is given by:

$$\phi = \left( \frac{\rho_{av}}{\rho_p} \right)^{-1/3}$$

### 15B.2.1.2 Diffusiophoresis

Diffusiophoresis is the process whereby particles are swept to a surface (for example, containment wall) by the flow set up by a condensing vapor (Stefan flow). The deposition rate is independent of the particle size and is proportional to the steam condensation rate on the surface. The standard equation for this phenomenon is due to Waldmann and Schmitt (Reference 3):

$$v_d = \frac{\sqrt{M_v}}{\sqrt{M_v} + \chi_{a/v} \sqrt{M_a}} \frac{W}{\rho_v}$$

where:

$v_d$  = diffusiophoretic deposition velocity

$\chi_{a/v}$  = ratio of mole fraction of air to mole fraction of steam in the containment atmosphere

$M_v$  = molecular weight of steam

$M_a$  = molecular weight of air

$W$  = steam condensation rate on the wall

$\rho_v$  = mass density of steam in the containment atmosphere

Because of the design of the passive containment cooling system, steam condensation rates are high at certain times in the design basis LOCA; thus at these times, diffusiophoretic deposition rates are significant.

### 15B.2.1.3 Thermophoresis

Thermophoresis is the process whereby particles drift toward a surface (for example, the containment wall) under the influence of a temperature gradient in the containment atmosphere at the surface. The effect arises because the gas molecules on the hot side of the particles undergo more collisions with the particle than do those on the cold side. Therefore, there is a net momentum transfer to the particle in the hot-to-cold direction. There are several models in the literature for this effect; the one used is the Brock equation in a form due to Talbot et al. (Reference 4). As indicated below, this model is in agreement with experimental data. The thermophoretic deposition rate is somewhat dependent on particle size and is proportional to the temperature gradient at the wall, or equivalently, the sensible heat transfer rate to the wall. The Talbot equation is:

$$v_{th} = \frac{2 C_s C_n (\mu_g / \rho_g) [\alpha + C_T Kn] dT}{[1 + 2(\alpha + C_T Kn)][1 + 3 C_M Kn]} \left( \frac{1}{T} \right) \frac{dT}{dy}$$

where:

- $v_{th}$  = thermophoretic deposition velocity
- $\alpha$  =  $k_g/k_p$  which is the ratio of the thermal conductivities of the gas (evaluated at the gas temperature at each time step) and the aerosol particle ( $k_p$  is set equal to the thermal conductivity of water – the results are not sensitive to  $k_p$  or  $\alpha$ .)
- $Kn$  = Knudsen number (equal to the gas molecular mean free path divided by the particle radius)
- $C_n$  = Cunningham slip correction factor, a function of the Knudsen number
- $\mu_g$  = gas viscosity
- $\rho_g$  = gas density
- $C_s$  = slip accommodation coefficient (Reference 4 gives the best value as 1.17.)
- $C_T$  = thermal accommodation coefficient (Reference 4 gives the best value as 2.18.)
- $C_M$  = momentum accommodation coefficient (Reference 4 gives the best value as 1.14.)

The temperature gradient at the wall,  $dT/dy$ , can be evaluated as

$$\frac{dT}{dy} = \frac{\phi_s}{k_g}$$

where  $\phi_s$  is the sensible heat flux to the wall, and  $k_g$  is the thermal conductivity of the gas. The sensible heat flux used in the analysis is the convective heat transfer calculated as discussed in subsection 15B.2.4.7.

### 15B.2.2 Other Removal Mechanisms

In addition to the above mechanisms, there are others that were not considered, including turbulent diffusion and turbulent agglomeration. The neglect of these mechanisms adds further conservatism to the calculation.

### 15B.2.3 Validation of Removal Mechanisms

The aerosol processes are well established and have been confirmed in many separate effects experiments, which are discussed in standard references (References 2 through 4). The Stokes formula for sedimentation velocity has been well confirmed for particles whose diameters are less than about 50  $\mu\text{m}$ . In the present calculations, these make up basically all of the aerosol.

There are some separate effects validations of the diffusio-phoretic effect, but the best confirmation comes from integral experiments such as the LACE tests (Reference 5). Calculations of these and other integral tests accurately predict the integrated mass of plated aerosol material only if diffusio-phoresis is taken into account. If it is neglected, the predicted plated mass is about two orders of magnitude too small, compared to the observed plated mass.

The Talbot equation for the thermophoretic effect has been experimentally confirmed to within about 20 to 50 percent over a wide range of particle sizes (Reference 4). The temperature gradient at the wall, which drives this phenomenon, can be approximated by the temperature difference between the bulk gas and the wall divided by an appropriate length scale obtained from heat transfer correlations. Alternatively, because sensible heat transfer rates to the wall are available, it is easier and more accurate to use these rates directly to infer the temperature gradient.

### 15B.2.4 Parameters and Assumptions for Calculating Aerosol Removal Coefficients

The parameters and assumptions were selected to conservatively model the environment that would be expected to exist as a result of a LOCA with concurrent core melt.

#### 15B.2.4.1 Containment Geometry

The containment is assumed to be a cylinder with a volume of 55,481  $\text{m}^3$  ( $1.959 \times 10^6 \text{ ft}^3$ ). This volume includes those portions of the containment volume that would be participating in the aerosol transport and mixing; this excludes dead-ended volumes and flooded compartments. The horizontal surface area available for aerosol deposition by sedimentation is 2900  $\text{m}^2$  (31,200  $\text{ft}^2$ ). This includes projecting areas such as decks in addition to the floor area and excludes areas in dead-ended volumes and areas that would be flooded post-LOCA. The surface area for Brownian diffusive plateout of aerosols is 8008  $\text{m}^2$  (86,166  $\text{ft}^2$ ).

#### 15B.2.4.2 Source Size Distribution

The aerosol source size distribution is assumed to be lognormal, with a geometric mean radius of 0.22  $\mu\text{m}$  and a geometric standard deviation equal to 1.81. These values are derived from an evaluation of a large number of aerosol distributions measured in a variety of degraded-fuel tests and experiments. The sensitivity of aerosol removal coefficient calculations to these values is small.

#### 15B.2.4.3 Aerosol Void Fraction

Review of scanning electron microscope photographs of deposited aerosol particles from actual core melt and fission product vaporization and aerosolization experiments (the Argonne STEP-4 test and the INEL Power Burst Facility SFD 1-4 test) indicates that the deposited particles are relatively dense, supporting a void fraction of 0.2.

The above-mentioned test results indicate that a void fraction of 0.2 is appropriate for modeling the aerosols resulting from a core melt. As part of the sensitivity study that was performed for the AP600 project, a case was run with a void fraction of 0.9. That analysis showed that the high void fraction resulted in an integrated release of aerosols over a 24-hour period that was less than 14 percent greater than that calculated when using the void fraction of 0.2. Thus, it is clear that the removal of aerosols from the containment atmosphere is not highly sensitive to the value selected for the void fraction. This is largely due to the fact that, while the selected value for void fraction has a significant impact on the calculated sedimentation removal, the impact on thermophoresis and diffusio-phoresis removal is slight or none. The impact for AP1000 of using the higher value for void fraction would be less than was determined for the AP600 since sedimentation removal comprises a smaller fraction of the total removal calculated for the AP1000.

For additional conservatism, the AP1000 aerosol removal analysis uses a void fraction of 0.4 and assumes the voids are filled with air.

#### 15B.2.4.4 Fission Product Release Fractions

Core inventories of fission products are from ORIGEN calculations for the AP1000 at end of the fuel cycle. Fractional releases to the containment of the fission products are those specified in subsection 15.6.5.3.

#### 15B.2.4.5 Inert Aerosol Species

The inert species include SnO<sub>2</sub>, UO<sub>2</sub>, Cd, Ag, and Zr. These act as surrogates for all inert materials forming aerosols. The ratio of the total mass of inert species to fission product species was assumed to be 1.5:1. This value and the partitioning of the total inert mass among its constituents are consistent with results from degraded fuel experiments (Reference 6).

#### 15B.2.4.6 Aerosol Release Timing and Rates

Aerosol release timing is in accordance with the source term defined in subsection 15.6.5.3. Aerosol release takes place in two main phases: a gap release lasting for 0.5 hour, followed by an early in-vessel release of 1.3 hours duration. During each phase, the aerosols are assumed to be released at a constant rate. These rates were obtained for each species by combining its core inventory, release fraction, and times of release.

Only cesium and iodine are released during the gap release phase. During the in-vessel release phase, the other fission product and inert species are released as well.

#### 15B.2.4.7 Containment Thermal-Hydraulic Data

The thermal-hydraulic parameters used in the aerosol removal calculation are the containment gas temperature, the containment pressure, the steam condensation rate on the wall, the steam mole fraction, and the convective heat transfer rate, all as functions of time. The AP1000-specific parameters were obtained using MAAP4 (Reference 7) for the 3BE-1 severe accident sequence (medium LOCA with failure to inject water from the refueling water storage tank into the reactor vessel). The thermal-hydraulic data are thus consistent with a core melt sequence.

#### 15B.2.5 Aerosol Removal Coefficients

The aerosol removal coefficients are provided in Table 15B-1 starting at the onset of core damage through 24 hours. The removal coefficients for times beyond 24 hours are not of concern because there would be so little aerosol remaining airborne at that time. The values range between  $0.29 \text{ hr}^{-1}$  and  $1.1 \text{ hr}^{-1}$  during the time between the onset of core damage (0.167 hour) and 24 hours.

These removal coefficients conservatively neglect steam condensation on the airborne particles, turbulent diffusion, and turbulent agglomeration. Additionally, the assumed source aerosol size is conservatively small being at the low end of the mass mean aerosol size range of  $1.5$  to  $5.5 \mu\text{m}$  used in NUREG/CR-5966 (Reference 8). Selection of smaller aerosol size would underestimate sedimentation.

Unlike the case for the elemental iodine removal, there is no limit assumed on the removal of aerosols from the containment atmosphere.

#### 15B.3 References

1. NUREG-0800, Section 6.5.2, Revision 2, "Containment Spray as a Fission Product Cleanup System."
2. Fuchs, N. A., The Mechanics of Aerosols, Pergamon Press, Oxford, 1964.
3. Waldmann, L., and Schmitt, K. H., "Thermophoresis and Diffusiophoresis of Aerosols," Aerosol Science, C. N. Davies, ed., Academic Press, 1966.
4. Talbot, L., Chang, R. K., Schefer, R. W., and Willis, D. R., "Thermophoresis of Particles in a Heated Boundary Layer," J. Fluid Mech. 101, 737-758 (1980).
5. Rahn, F. J., "The LWR Aerosol Containment Experiments (LACE) Project," Summary Report, EPRI-NP-6094D, Electric Power Research Institute, Palo Alto, Nov. 1988.
6. Petti, D. A., Hobbins, R. R., and Hagrman, D. L., "The Composition of Aerosols Generated during a Severe Reactor Accident: Experimental Results from the Power Burst Facility Severe Fuel Damage Test 1-4," Nucl. Tech. 105, p.334 (1994).
7. MAAP4 - Modular Accident Analysis Program for LWR Power Plants, Computer Code Manual, May 1994.

8. Powers D. A., and Burson, S. B., "A Simplified Model of Aerosol Removal by Containment Sprays," NUREG/CR-5966, June 1993.
9. Powers, D. A., "Monte Carlo Uncertainty Analysis of Aerosol Behavior in the AP600 Reactor Containment under Conditions of a Specific Design-Basis Accident, Part 1," Technical Evaluation Report, Sandia National Laboratories, June 1995.

Table 15B-1 (Sheet 1 of 3)

<b>AEROSOL REMOVAL COEFFICIENTS IN THE AP1000 CONTAINMENT FOLLOWING A DESIGN BASIS LOCA WITH CORE MELT</b>			
<b>Time Interval (hours)</b>		<b>Removal Coefficient (hr<sup>-1</sup>)</b>	
0.167	-	0.179	1.141
0.179	-	0.200	1.013
0.200	-	0.251	0.944
0.251	-	0.292	0.882
0.292	-	0.433	0.842
0.433	-	0.631	0.901
0.631	-	0.684	0.821
0.684	-	0.801	0.781
0.801	-	0.893	0.735
0.893	-	1.033	0.699
1.033	-	1.171	0.662
1.171	-	1.233	0.627
1.233	-	1.331	0.594
1.331	-	1.395	0.562
1.395	-	1.429	0.551
1.429	-	1.475	0.576
1.475	-	1.519	0.537
1.519	-	1.579	0.510
1.579	-	1.653	0.483
1.653	-	1.776	0.458
1.776	-	1.903	0.430
1.903	-	1.991	0.462
1.991	-	2.067	0.429
2.067	-	2.176	0.396
2.176	-	2.371	0.380
2.371	-	2.621	0.337

Table 15B-1 (Sheet 2 of 3)

<b>AEROSOL REMOVAL COEFFICIENTS IN THE AP1000 CONTAINMENT FOLLOWING A DESIGN BASIS LOCA WITH CORE MELT</b>		
<b>Time Interval (hours)</b>		<b>Removal Coefficient (hr<sup>-1</sup>)</b>
2.621	- 2.822	0.320
2.822	- 2.872	0.357
2.872	- 2.973	0.327
2.973	- 3.176	0.302
3.176	- 3.684	0.287
3.684	- 3.737	0.328
3.737	- 3.839	0.304
3.839	- 3.990	0.298
3.990	- 4.090	0.317
4.090	- 4.438	0.346
4.438	- 4.684	0.369
4.684	- 4.880	0.396
4.880	- 4.928	0.449
4.928	- 5.362	0.435
5.362	- 5.460	0.459
5.460	- 5.511	0.518
5.511	- 5.608	0.487
5.608	- 6.040	0.479
6.040	- 6.090	0.537
6.090	- 6.615	0.506
6.615	- 6.753	0.567
6.753	- 7.194	0.513
7.194	- 7.285	0.594
7.285	- 7.814	0.518
7.814	- 7.904	0.581

Table 15B-1 (Sheet 3 of 3)

<b>AEROSOL REMOVAL COEFFICIENTS IN THE AP1000 CONTAINMENT FOLLOWING A DESIGN BASIS LOCA WITH CORE MELT</b>	
<b>Time Interval (hours)</b>	<b>Removal Coefficient (hr<sup>-1</sup>)</b>
7.904 - 8.431	0.528
8.431 - 8.521	0.589
8.521 - 9.387	0.529
9.387 - 9.553	0.568
9.553 - 11.189	0.530
11.189 - 14.937	0.516
14.937 - 17.610	0.506
17.610 - 24	0.492