



**Pacific Gas and
Electric Company®**

James R. Becker
Site Vice President

Diablo Canyon Power Plant
Mail Code 104/5/601
P. O. Box 56
Avila Beach, CA 93424

805.545.3462
Internal: 691.3462
Fax: 805.545.6445

December 13, 2010

PG&E Letter DCL-10-163

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20852

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2

Response to Telephone Conference Call Held on November 18, 2010, Between the
U.S. Nuclear Regulatory Commission and Pacific Gas and Electric Company
Concerning Responses to Requests for Additional Information Related to the Diablo
Canyon Nuclear Power Plant, Units 1 and 2, License Renewal Application

Dear Commissioners and Staff:

By letter dated November 23, 2009, Pacific Gas and Electric Company (PG&E) submitted an application to the U.S. Nuclear Regulatory Commission (NRC) for the renewal of Facility Operating Licenses DPR-80 and DPR-82, for Diablo Canyon Power Plant (DCPP) Units 1 and 2, respectively. The application included the license renewal application (LRA), and Applicant's Environmental Report – Operating License Renewal Stage.

On November 18, 2010, a telephone conference call between the NRC and representatives of PG&E was held to obtain clarification on PG&E's response to a request for additional information (RAI), which was submitted to the NRC in PG&E Letter DCL-10-126, dated September 30, 2010, regarding the Structures Monitoring Aging Management Program.

PG&E's supplemental information to the RAI response for which the staff requested information is provided in Enclosure 1. PG&E revises a commitment in LRA Table A4-1, License Renewal Commitments, provided in Enclosure 2. LRA Amendment 29 is included in Enclosure 2 showing the changed pages with line-in/line-out annotations. Enclosures 1 and 2 supersede previously submitted information regarding the Structures Monitoring Aging Management Program.

If you have any questions regarding this response, please contact Mr. Terence L. Grebel, License Renewal Project Manager, at (805) 545-4160.



I declare under penalty of perjury that the foregoing is true and correct.

Executed on December 13, 2010.

Sincerely,

James R. Becker
Site Vice President

TLG/50340356

Enclosures

cc: Diablo Distribution

cc/enc: Elmo E. Collins, NRC Region IV Regional Administrator
Nathanial B. Ferrer, NRC Project Manager, License Renewal
Kimberly J. Green, NRC Project Manager, License Renewal
Michael S. Peck, NRC Senior Resident Inspector
Alan B. Wang, NRR Project Manager

Pacific Gas and Electric (PG&E) Supplement to Telephone Conference Call Held on November 18, 2010, Concerning Response to Request for Additional Information (RAI) Submitted to the NRC in a Letter Dated September 30, 2010, Regarding the Structures Monitoring Aging Management Program

By PG&E Letter DCL-10-126, dated September 30, 2010, PG&E committed to revising procedure NDE VT 3C-1 and Calculation No. 2305C acceptance criteria to be consistent with American Concrete Institute (ACI) 349.3R Chapter 5 detailed quantitative acceptance criteria with the exception that the First Tier, the allowable crack width of 0.015 inches (per ACI 349.3, Section 5.1) is increased to 0.025 inches for areas not around penetrations and embedments. PG&E provided technical justifications for the exception of the First Tier acceptance criteria for the increased allowable crack size.

PG&E will amend its previous commitment by removing the exception of the First Tier acceptance criteria for the increased allowable crack size. See amended LRA Table A4-1 in Enclosure 2.

LRA Amendment 29

LRA Section
Table A4-1

Table A4-1 License Renewal Commitments

Item #	Commitment	LRA Section	Implementation Schedule
42	Procedure NDE VT 3C-1 and Calculation No. 2305C acceptance criteria will be revised to be consistent with ACI 349.3R Chapter 5 detailed quantitative acceptance criteria. with the exception that the First Tier, the allowable crack width of 0.015" (per ACI 349.3, Section 5.1) is increased to 0.025" for areas not around penetrations and embeddings.	B2.1.28	Prior to the period of extended operation