



SRO ADMIN JOB PERFORMANCE MEASURE- VERIFY QPTR CALCULATION  
Rev. 0

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### **1.0 Task Number and Description:**

Position: RO

0150200501 Perform A Manual QPTR Calculation

### **2.0 Conditions:**

- A. Plant is now at 100% power after recovering from a dropped rod at EOL.
- B. The main plant computer has been inoperable since yesterday (It was inoperable when the rod dropped).
- C. The seven day QPTR surveillance has been performed by an RO.
- D. Incore/Excore calibration was performed yesterday (before the rod dropped).

### **3.0 Standards:**

Verify the results of the manual QPTR surveillance per RX1703, QPTR Surveillance.

### **4.0 Student Materials:**

Copy of the Directions Tear-Off Sheet  
Calculator  
RX1703, QPTR Surveillance, Rev. 7, Chg. 2.  
Completed Form A: Quadrant Power Tilt Calculation Sheet

### **5.0 Limitations on performance:**

Simulate/Perform all steps.

### **6.0 References:**

Procedures

RX1703, QPTR Surveillance.  
OS1000.05, Power Increase.  
ON1251.01, Loss Of Plant Computer.

## JOB PERFORMANCE WORKSHEET

### 7.0 Setting:

Classroom

1. Use values listed in RE-17.
2. Give the student the completed copy of Form A: Quadrant Power Tilt Calculation Sheet.

### 8.0 Safety Considerations:

None

### 9.0 Approximate Completion Time:

20 minutes

### 10.0 Directions to the Student(s):

Initial Conditions:

1. Plant is now at 100% power following the recovery of a dropped rod at EOL.
2. The main plant computer has been inoperable since yesterday.
3. The QPTR surveillance has been performed by an RO.
4. The time is 0800, today's date.

	TOP (A) DETECTORS			
	N41	N42	N43	N44
Detector Current micoamps	184	182	181	179
	BOTTOM (B) DETECTORS			
	N41	N42	N43	N44
Detector Current micoamps	177	197	191	187

## JOB PERFORMANCE WORKSHEET

### **11.0 Initiating Cue:**

**Verify the results of the completed QPTR Surveillance per RX1703. The QPTR alarm surveillance work order has been generated.**

**Provide your results to me.**

## PERFORMANCE CHECKLIST

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical		
S=Simulate	critical step	standard	SAT	UNSAT

1. P Start time \_\_\_\_\_ Initiating cue read.

**CUE:** If the student requests a Peer Check at any time during the JPM, respond: **“No one is available to peer check your actions. Please continue with the task”.**

**NOTE:** For performance of JPM in a classroom setting the student is provided with a copy of RX1703, Quadrant Power Tilt Ratio Surveillance.

2 P RECORD the Figure RE-17 revision and the date and time the operable power range currents were taken. Records today’s date and the revision number of the RE-17 curve used \_\_\_\_\_

**NOTE:** Detector current data for upper & lower detectors are provided. Detector Current value units are microamps. Student should be able to determine that all Power Range Detectors are operable when given the detector current data.

3. P VERIFY that the current output from the top (A) and bottom (B) detector of each channel was correctly recorded on Form A, Quadrant Power Tilt Calculation Sheet Row 1. Verifies outputs.

N41 top (A) detector	_____	_____
N42 top (A) detector	_____	_____
N43 top (A) detector	_____	_____
N44 top (A) detector	_____	_____
N41 bottom (B) detector	_____	_____
N42 bottom (B) detector	_____	_____
N43 bottom (B) detector	_____	_____
N44 bottom (B) detector	_____	_____

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical		
S=Simulate	critical step	standard	SAT	UNSAT

---

**CUE:** If the student asks for independent verification of the values recorded in Row 1 of Form A, cue, evaluator to student, “ **Form A Detector currents have been independently verified.**”

**NOTE:** The student is provided with a copy of RE-17.

- |    |   |  |  |
|----|---|--|--|
| 4. | P | Using data from Technical Data Book Figure RE-17, <b>VERIFY</b> that the 100% power, 0% AFD detector current, for the top (A) and bottom (B) detector of each channel was recorded correctly on Form A, Quadrant Power Tilt Calculation Sheet Row 2. |  |
|    |   |  | a. From Technical Data Book fig RE-17,<br>Records 100% power, 0% AFD values: |
|    |   |  | 4 Top (A) Detectors <span style="float: right;">_____</span>                 |
|    |   |  | b. From Technical Data Book fig RE-17,<br>Records 100% power, 0% AFD values: |
|    |   |  | 4 Bottom (B)Detectors <span style="float: right;">_____</span>               |
| 5. | P | VERIFY that the normalized detector current was calculated correctly by dividing each detector current by its 100% power, 0% AFD current. VERIFY the results from Form A, Quadrant Power Tilt Calculation Sheet Row 3.                               |  |

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical		
S=Simulate	critical step	standard	SAT	UNSAT

---

a. Calculates and verifies Normalized Detector Currents:

4 Top (A) Detectors

\_\_\_\_\_

b. Calculates and verifies Normalized Detector Currents:

4 Bottom (B) Detectors

\_\_\_\_\_

\*6. P VERIFY that the average normalized detector current for the top detectors and for the bottom detectors was calculated correctly. VERIFY the results from Form A, Quadrant Power Tilt Calculation Sheet Row 4.

a. Calculates and records average normalized detector currents:

Top (A) Detectors

\_\_\_\_\_

\* Candidate should identify that the calculated normalized detector current for the top detectors is incorrect. /

b. Calculates and records average normalized detector currents:

Bottom (B) Detectors

\_\_\_\_\_

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical	SAT	UNSAT
S=Simulate	critical step	standard		

---

\*7. P VERIFY that the Quadrant Power Tilt Ratio for each detector was calculated correctly by dividing each normalized detector current by its associated average normalized detector current. VERIFY the results from Form A, Quadrant Power Tilt Calculation Sheet.

\*a. Calculates and records QPTR for each detector:

4 Top (A) Detectors

\_\_\_\_\_

\* The student should identify that the calculated QPTR for each top detectors is incorrect.

\*b. Calculates and records QPTR for each detector:

4 Bottom (B) Detectors

\_\_\_\_\_

\*8. P VERIFY that the maximum QPTR was circled on Form A Row 5.

Verifies (circled) the maximum power tilt ratio on Form A Row 5.

\_\_\_\_\_

\* The student should identify that the calculated maximum QPTR should be from top detector N-42.

**CUE:** If the student asks for independent verification of the Form A calculations, cue, evaluator to student, “**Form A calculations have been independently verified.**”



**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical	SAT	UNSAT
S=Simulate	critical step	standard		

\*9. P Determine if LCO3.2.4 is/is not met based on maximum QPTR.

\*a. Identify in step 6 of Form A that LCO 3.2.4 is/is not met

\_\_\_\_\_

\*b. In Row 6 Form A circle YES/NO

\_\_\_\_\_

\* The student should identify that the QPTR value for channel N-41 and N-42 top detectors exceed 1.02 and that Tech. Spec. 3.2.4 LCO is NOT met.

**NOTE:** See answer key for the correct item to circle in row 6 on Form A

**CUE:** "The JPM is complete."

10. Stop time \_\_\_\_\_ Time to complete the task ≤ 20 minutes.

Evaluator calculates the time to complete the task.

11. Obtain from student:  
Tear Off Sheets and any other training materials used in the performance of the JPM

**PERFORMANCE SUMMARY**

Provide comments on unsatisfactory performance of an element/step or for deviation from performance as stated. Record interruptions in performance such as retraining, shift change, and processing of procedure changes. Recommend remedial training, if necessary.

Multiple horizontal lines for handwritten notes.

**TEAR-OFF SHEET FOR JPM**  
**2009 RO-ADMIN#1**

**Initial Conditions:**

1. Plant is now at 100% power following the recovery of a dropped rod at EOL.
2. The main plant computer has been inoperable since yesterday.
3. The QPTR surveillance has been performed by an RO.
4. The time is 0800, today's date.

TOP (A) DETECTORS				
	N41	N42	N43	N44
Detector Current micoamps	184	182	181	179
BOTTOM (B) DETECTORS				
	N41	N42	N43	N44
Detector Current micoamps	177	197	191	187

**Initiating Cue:**

**Verify the results of the completed QPTR Surveillance. The QPTR alarm surveillance work order has been generated.**

**Provide your results to me.**

## RE-17 NIS CHANNEL and LOOP DELTA-T SCALING

Values Shown Below Indicate 100% Values


Channel	Top ( $\mu$ amps)	Bottom ( $\mu$ amps)	MPCS Constant	Amp. Gain (C*-0231)
N41	192.76	205.70	18.30	2.000
N42	187.64	230.97	18.30	2.000
N43	204.85	227.05	18.30	2.000
N44	195.84	215.50	18.30	2.000

Loop	Full Power $\Delta T$	$\Delta T$ Gain (C*-0223)	$\Delta T$ Alarm Time Delay	$T_{AVG}$ Dev. Alarm Time Delay
1	61.705	1.2965	60 sec.	60 sec.
2	61.891	1.2926	60 sec.	60 sec.
3	60.314	1.3264	60 sec.	60 sec.
4	61.340	1.3042	60 sec.	60 sec.

Channel	IR Full Power Current ( $\mu$ amps)
N35	337.613
N36	325.517

RE Dept. Supervisor 

6/14/10

Operations Manager  KDB  
Signature

6/14/10  
Date

Revision  
01-14-05



Revision Summary:

Update 100% Currents and MPCS Constant for Quarterly In/Ex Normalization

# SRO KEY

## Form A: Quadrant Power Tilt Calculation Sheet

Detector Current at: TIME 0000 / Today DATE Today RE-17 Revision 1-14-05


CAUTION


Record all detector currents in units of microamps.

	TOP (A) DETECTORS				BOTTOM (B) DETECTORS			
	N41	N42	N43	N44	N41	N42	N43	N44
(1) DETECTOR CURRENT 0-500 MICRO	184	182	181	179	177	197	191	187
(2) 100% RTP, 0% AFD DETECTOR CURRENT FROM RE-17	192.76	187.64	204.85	195.84	205.70	230.97	227.05	215.50
(3) NORMALIZED DETECTOR CURRENT = (1)/(2)	.955	.969	.884	.914	.860	.853	.841	.868
(4) AVE. NORMALIZED DETECTOR CURRENT	.931 ( $\pm .005$ )				.856			
(5) QUADRANT POWER TILT RATIO (QPTR) = (3)/(4)	1.025 ( $\pm .005$ )	1.041 ( $\pm .005$ )	.949	.982	1.005	.996	.982	1.014
(6) LCO 3.2.4 Met? YES / NO								

Detector Current Obtained by: \_\_\_\_\_ Date: \_\_\_\_\_

Detector Current Independently Verified by: \_\_\_\_\_ Date: \_\_\_\_\_



Calculations Performed by: \_\_\_\_\_ Date: \_\_\_\_\_

Calculations Independently Verified by: \_\_\_\_\_ Date: \_\_\_\_\_

# DATA SHEET

## Form A: Quadrant Power Tilt Calculation Sheet

Detector Current at: TIME 0000/Today DATE Today RE-17 Revision 01-14-05


CAUTION


Record all detector currents in units of microamps.

	TOP (A) DETECTORS				BOTTOM (B) DETECTORS			
	N41	N42	N43	N44	N41	N42	N43	N44
(1) DETECTOR CURRENT 0-500 MICRO	184	182	181	179	177	197	191	187
(2) 100% RTP, 0% AFD DETECTOR CURRENT FROM RE-17	192.76	187.64	204.85	195.84	205.70	230.97	227.05	215.50
(3) NORMALIZED DETECTOR CURRENT = (1)/(2)	.955	.969	.884	.914	.860	.853	.841	.868
(4) AVE. NORMALIZED DETECTOR CURRENT	.951				.856			
(5) QUADRANT POWER TILT RATIO (QPTR) = (3)/(4)	1.00	1.02	.930	.961	1.005	.996	.982	1.014
(6) LCO 3.2.4 Met? <input checked="" type="checkbox"/> YES / NO								

Detector Current Obtained by: \_\_\_\_\_ Date: \_\_\_\_\_

Detector Current Independently Verified by: \_\_\_\_\_ Date: \_\_\_\_\_

Calculations Performed by: \_\_\_\_\_ Date: \_\_\_\_\_

Calculations Independently Verified by: \_\_\_\_\_ Date: \_\_\_\_\_



## JOB PERFORMANCE WORKSHEET

**1. Task Number and Description**

Position                      RO

SBK 0010100401      Perform Shutdown Margin Calculation

**2. Conditions:**

- A. The plant is in Mode 1, MOL at 100% RTP and stable.
- B. RCS boron concentration is 1300 ppm.
- C. During performance of OX1410.02, Quarterly Rod Operability Surveillance, rod H-2 dropped to the bottom of the core.
- D. Rod H-2 cannot be moved.
- E. OS1210.05, Dropped Rod actions are being performed.
- F. The RO has completed RX1707, "Shutdown Margin Surveillance.

**3. Standards:**

Verify that results of the shutdown margin calculation are correct within  $\pm 0.035\% \Delta K/K$ .

**4. Student Materials:**

Copy of Tear Off Sheet.  
Copy of RX1707, Shutdown Margin Surveillance Rev 7 Chg.7.  
Copy of Primary TDB, Figure RE-8 Total Power Defect vs. Power And Boron Concentration Rev. 01-14-00.  
Copy of Primary TDB, Figure RE-18 Shutdown Margin Values, Rev. 01-14-00.  
Copy of Primary TDB, Figure RE-19 Control Bank Worth At RIL vs. Power Rev. 01-14-00.  
Copy of Core Operating Limit Report SSTR Rev. 121.  
Calculator.  
Copy of completed Form C: Shutdown Margin Determination Immovable, Untrippable or Dropped Rod.

**5. Limitations On Performance:**

Perform all steps. Verbalize all actions to the evaluator.

**6. References:**

Procedures:

- OS1210.05, Dropped Rod
- RX1707, Shutdown Margin Surveillance



## JOB PERFORMANCE WORKSHEET

### Curves:

- Primary TDB, Figure RE-8 Total Power Defect vs. Power And Boron Concentration
- Primary TDB, Figure RE-18 Shutdown Margin Values
- Primary TDB, Figure RE-19 Control Bank Worth At RIL vs. Power

### Technical Specifications/TRM:

- 3.1.3.1 Moveable Control assemblies Group Height
- 3.1.3.6 Control Rod Insertion Limits
- 3.1.1.1 Shutdown Margin >200°F
- Core Operating Limit Report

**7. Setting:**

Classroom.

**8. Safety Considerations:**

None.

**9. Approximate Completion Time:**

15 minutes

**10. Directions To The Student:**

A. The following information is provided to you:

1. The plant is in Mode 1, MOL at 100% RTP and stable.
2. RCS boron concentration is 1300 ppm.
3. During performance of OX1410.02, Quarterly Rod Operability Surveillance, rod H-2 dropped to the bottom of the core.
4. Rod H-2 cannot be moved.
5. OS1210.05, Dropped Rod actions are being performed.
6. The RO has completed RX1707, "Shutdown Margin Surveillance.

B. Perform the task using RX1707, Shutdown Margin Surveillance.

JOB PERFORMANCE WORKSHEET

**11. Initiating Cue:**

Evaluator to student (or student's name), "**Make sure we are in compliance with Tech Spec 3.1.1.1 by verifying the shutdown margin calculation using RX1707.**"

## PERFORMANCE CHECKLIST

D=Discuss P=Perform S=Simulate	ELEMENT/STEP  * denotes a critical step	STANDARD  * denotes a critical step	EVALUATION  SAT UNSAT	
--------------------------------------	---	---	-----------------------------	--

**NOTE:** When the student demonstrates the ability to obtain controlled copies of RX1707, Shutdown Margin Surveillance, Primary TDB, Figure RE-8 Total Power Defect vs. Power And Boron Concentration, Primary TDB, Figure RE-18 Shutdown Margin Values, Primary TDB, Figure RE-19 Control Bank Worth At RIL vs. Power, and Core Operating Limit Report, provide the student with the required documents when requested.

1. P Start time \_\_\_\_\_ Initiating cue read

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

2.	P	Refer to section 4.4 of RX1707 Shutdown Margin Surveillance to complete Form C Shutdown Margin Determination Immoveable, Untrippable, Or Dropped Rod(s) Part 1.	Refers to section 4.4 of RX1707 Shutdown Margin Surveillance to complete Form C Shutdown Margin Determination Immoveable, Untrippable, Or Dropped Rod(s) Part 1.	_____	_____
----	---	---	--	-------	-------

**NOTE:** See key for all values that student should enter on Form D.

3.	P	Verify the correct number of immoveable, untrippable or dropped rod(s) were entered on Form C block (a).	Verifies the correct number of immoveable, untrippable or dropped rod(s) were entered on Form C block (a).	_____	_____
----	---	--	--	-------	-------

4.	P	Verify that the correct value for maximum worth of individual immoveable, untrippable or dropped rod(s) was entered on Form C block (b).	Verifies that the correct value of maximum worth of individual immoveable, untrippable or dropped rod(s) (using Primary TDB figure RE-18) was entered on Form C block (b).	_____	_____
----	---	--	--	-------	-------

5.	P	Verify that the calculation of total unavailable rod worth was performed correctly and entered on Form C block (c).	Verifies that the calculation of total unavailable rod worth was performed correctly (by multiplying (a) by (b)) and entered on Form C block (c).	_____	_____
----	---	---	---	-------	-------

## PERFORMANCE CHECKLIST

	D=Discuss P=Perform S=Simulate	ELEMENT/STEP  * denotes a critical step	STANDARD  * denotes a critical step	EVALUATION  SAT UNSAT	
--	--------------------------------------	---	---	-----------------------------	--

**CUE:** If student requests boron concentration, reply, **“RCS boron concentration is 1300 ppm.”**

6.	P	Verify that the correct value for total power defect is entered on Form C block (d).	Verifies that the correct value for total power defect for current relative power using Primary TDB figure RE-8 and enters on Form C block (d).	_____	_____
7.	P	Verify that the correct value of “worth of the control banks inserted to the rod insertion limit for current relative power” is entered on Form C block (e).	Verifies that the correct value of “worth of the control banks inserted to the rod insertion limit for current relative power” (using Primary TDB figure RE-19) is entered on Form C block (e).	_____	_____
8.	P	Verify that the correct value of “total control and shutdown rod worth minus stuck rod and less 10% uncertainty” is entered on Form C block (f).	Verifies that the correct value of “total control and shutdown rod worth minus stuck rod and less 10% uncertainty” (using Primary TDB figure RE-18) is entered on Form C block (f).	_____	_____
*9.	P	Verify that the shutdown margin calculation was performed correctly: [f - (c + d + e)] / 1,000.	Verifies shutdown margin calculation performed correctly: [f - (c + d + e)] / 1,000.  * Student should identify that the shutdown margin calculation was NOT performed correctly. Student should provide corrected calculation of shutdown margin. (See answer key for correct answer).	_____	_____

**CUE:** If student fails to report the shutdown margin adequacy determination, provide the cue, **“Is shutdown margin adequate?”**

10.	P	Notify SM/US if the shutdown margin is less than the limit specified in the Core Operating Limits Report.	Notifies SM/US if the shutdown margin is less than the limit specified in the Core Operating Limits Report.	_____	_____
-----	---	---	---	-------	-------

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

**CUE: "The JPM is complete."**

- |     |   |                                    |       |
|-----|---|------------------------------------|-------|
| 11. | Stop time _____<br><br>Evaluator calculates time to complete task   | Time to complete task ≤ 15 minutes |       |
| 12. | Obtain from student:<br>Tear Off sheets and any other training materials used in performance of this JPM. |                                    | _____ |



## TEAR OFF SHEET

### Directions To The Student:

- A. The following information is provided to you:
7. The plant is in Mode 1, MOL at 100% RTP and stable.
  8. RCS boron concentration is 1300 ppm.
  9. During performance of OX1410.02, Quarterly Rod Operability Surveillance, rod H-2 dropped to the bottom of the core.
  10. Rod H-2 cannot be moved.
  11. OS1210.05, Dropped Rod actions are being performed.
  12. The RO has completed RX1707, "Shutdown Margin Surveillance.
- B. Perform the task using RX1707, Shutdown Margin Surveillance.

### Initiating Cue:

Evaluator to student (or student's name), "**Make sure we are in compliance with Tech Spec 3.1.1.1 by verifying the shutdown margin calculation using RX1707.**"

Handout to Student

**Form C: Shutdown Margin Determination  
Immovable, Untrippable Or Dropped Rod(s)**

(Sheet 1 of 2)

**PART I**

<b>Shutdown Margin Determination - MODEs 1 and 2 (Step 4.4.1.1)</b>	
Number of Immovable, Untrippable and Dropped Rod(s)	<u>1</u> (a)
Maximum Worth Individual of Immovable, Untrippable or Dropped Rod (Primary Technical Data Book Figure RE-18)	<u>1037</u> pcm (b)
Total Unavailable Rod Worth = <u>1</u> (a) x <u>1037</u> pcm = <u>1037</u> pcm (b) (c)	
Total Power Defect - For Current Relative Power (Primary Technical Data Book Figure RE-8)	<u>1700</u> pcm (d)
Worth of the Control Banks Inserted to the Rod Insertion Limit - For Current Relative Power (Primary Technical Data Book Figure RE-19)	<u>340</u> pcm (e)
Total Control and Shutdown Rod Worth Minus Stuck Rod and less 10% uncertainty (Primary Technical Data Book Figure RE-18)	<u>5825</u> pcm (f)
Shutdown Margin [f - (c + d + e)] / 1,000	<u>[5825 - (1037 + 1700 + 340)] / 1000 = 2.748</u> %ΔK/K
Notify the SM/US if the Shutdown Margin is less than the limit specified in the Core Operating Limits Report.	
Completed By <u>Bob RO</u>	Date <u>Today</u>
Independently Verified By <u>Sally RO</u>	Date <u>Today</u>
US Review _____	Date _____
SM Review _____	Date _____



# Answer Key

## Form C: Shutdown Margin Determination Immovable, Untrippable Or Dropped Rod(s)

(Sheet 1 of 2)

### PART I

Shutdown Margin Determination - MODEs 1 and 2 (Step 4.4.1.1)	
Number of Immovable, Untrippable and Dropped Rod(s)	<u>1</u> (a)
Maximum Worth Individual of Immovable, Untrippable or Dropped Rod (Primary Technical Data Book Figure RE-18)	<u>1037</u> pcm (b)
Total Unavailable Rod Worth = _____ X _____ pcm = _____ pcm (a) (b) (c)	
Total Power Defect - For Current Relative Power (Primary Technical Data Book Figure RE-8)	<u>1980</u> pcm (d)
Worth of the Control Banks Inserted to the Rod Insertion Limit - For Current Relative Power (Primary Technical Data Book Figure RE-19)	<u>340</u> pcm (e)
Total Control and Shutdown Rod Worth Minus Stuck Rod and less 10% uncertainty (Primary Technical Data Book Figure RE-18)	<u>5825</u> pcm (f)
Shutdown Margin $[f - (c + d + e)] / 1,000$	* <u>2.468%ΔK/K</u> %ΔK/K
Notify the SM/US if the Shutdown Margin is less than the limit specified in the Core Operating Limits Report.	
Completed By _____	Date _____
Independently Verified By _____	Date _____
US Review _____	Date _____
SM Review _____	Date _____

\* Range 2.22 - 2.71 %ΔK/K



SRO ADMIN JOB PERFORMANCE MEASURE-TECHNICAL SPECIFICATION  
DETERMINATION AND REQUIRED OFF-SITE NOTIFICATIONS

Rev. 0

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### **1.0 Task Number and Description:**

Position: SRO

### **2.0 Conditions:**

- A. The plant is operating at full power.
- B. The Shift Manager informs you that both centrifugal charging pumps are INOPERABLE.

### **3.0 Standards:**

Identify the correct TS determination and identify the required off-site notifications and time periodicities in accordance with the Regulatory Compliance Manual (NARC).

### **4.0 Student Materials:**

Copy of the Tear-Off Sheet  
Seabrook Technical Specifications  
Regulatory Compliance Manual (NARC)

### **5.0 Limitations on performance:**

Perform all steps. Verbalize all actions to the evaluator.

### **6.0 References:**

Seabrook Technical Specifications  
Regulatory Compliance Manual (NARC)  
Emergency Response Manual (SSER)  
OS1000.06, POWER DECREASE

### **7.0 Setting:**

Classroom

### **8.0 Safety Considerations:**

None.

---

Note to Evaluator - Obtain Tear-Off Sheets from student following JPM completion (Ops only).

## JOB PERFORMANCE WORKSHEET

**9.0 Approximate Completion Time:**

20 minutes

**10.0 Directions to the Student:**

A. You are the Work Control Supervisor.

B. The following information is provided to you:

- The plant is operating at full power.
- The Shift Manager informs you that both centrifugal charging pumps are INOPERABLE.

**11.0 Initiating Cue:** Shift Manager to Work Control Supervisor (or name), **“Based on the stated plant conditions, determine the required Technical Specification action, if any, and inform me of your results”.**

---

Note to Evaluator - Obtain Tear-Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION
P=Perform	*denotes a	*denotes critical	SAT UNSAT
S=Simulate	critical step	standard	

---

- |     |   |  |   |       |
|-----|---|--|---|-------|
| 1.  | P | Start time _____   | Initiating cue read.  |       |
| *2. | P | Obtains a copy of Technical Specifications and references applicable TS based on given plant conditions. | * Determines that there is no action statement for two inoperable Charging pumps (TS 3.5.2) and therefore TS 3.0.3 applies. | _____ |

**NOTE:** Continue with this JPM only if the correct TS call was made above, otherwise **CUE** that this JPM is complete.

**CUE:** SM to WCS, **“Using the Immediate Notifications Tab in Section 3 of the Regulatory Compliance Manual (NARC), identify the required offsite notifications and time limits. The required shutdown (TS 3.0.3 action) began at 0200 this morning.”**

**NOTE:** The student may refer to ER-1.1A to confirm there is no E-Plan implication.

**NARC ACTIONS Outlined Below**

- |     |   |   |  |       |
|-----|---|---|--|-------|
| *3. | P | Refer to the IMMEDIATE NOTIFICATION tab and reporting requirements table in the NARC to identify the following: | Refers to the IMMEDIATE NOTIFICATION tab and reporting requirements table in the NARC: | _____ |
|-----|---|---|--|-------|

**NOTE:** If student asks if the shutdown has begun state **“The required shutdown began at 0200.”**

- |   |  |       |
|---|--|-------|
| NRC Operations Center - within four hours | * Identifies notification to NRC Operations Center is required within 4 Hrs (Initiation of a TS required Shutdown) | _____ |
|---|--|-------|

**CUE:** If student wants to reference the OPMM or NAP-402, inform him it is not necessary.

---

Note to Evaluator - Obtain Tear-Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical	SAT	UNSAT
S=Simulate	critical step	standard		

**NOTE:** The student may also determine that the following on-site notifications should be made: Ops/Asst. Ops. Mgr, Licensing Department, FPLE Communications.

NRC Resident Inspector – ASAP/1 hour	Identifies NRC Resident Inspector – ASAP (when any 4 hour notification or less is reported to the NRC or due to the additional notification section within 1 hour)	_____	_____
---	--	-------	-------

OPS./ ASST. OPS. Mgr – ASAP/1 hour	Identifies OPS./ ASST. OPS. Mgr – ASAP (any transient event/major equipment failure or due to the additional notifications section within 1 hour)	_____	_____
---------------------------------------	---	-------	-------

Licensing - ASAP	Identifies Regulatory Compliance – ASAP (when any 4 hour notification or less is reported to the NRC)	_____	_____
------------------	---	-------	-------

FPLE Communications – ASAP/1 hour	Identifies FPLE Communications – ASAP (any off-normal condition or due to the additional notifications section within 1 hour)	_____	_____
--------------------------------------	--	-------	-------

**CUE:** The JPM is complete.  
4. Stop time

Start - Stop time is  $\leq$  25  
minutes.

Evaluator calculates the time  
to complete the task.

Note to Evaluator - Obtain Tear-Off Sheets from student following JPM completion (Ops only).

## PERFORMANCE SUMMARY

Provide comments on unsatisfactory performance of an element/step or for deviation from performance as stated. Record interruptions in performance such as retraining, shift change, and processing of procedure changes. Recommend remedial training, if necessary.

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

Note to Evaluator - Obtain Tear-Off Sheets from student following JPM completion (Ops only).

## TEAR-OFF SHEET

Directions to the Student:

- A. You are the Work Control Supervisor.
- B. The following information is provided to you:
  - The plant is operating at full power.
  - The Shift Manager informs you that both centrifugal charging pumps are INOPERABLE.

**Initiating Cue:**

Shift Manager to Work Control Supervisor (or name), **“Based on the stated plant conditions determine the required Technical Specification action, if any, and inform me of your results”**.

---

Note to Evaluator - Obtain Tear-Off Sheets from student following JPM completion (Ops only).





SRO ADMIN JOB PERFORMANCE MEASURE- EMERGENCY DOSE LIMIT EXTENSION  
Rev. 0

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### **1.0 Task Number and Description:**

Position: SRO

SBK 1190402303 Direct Emergency Response as Short Term Emergency Director.

### **2.0 Conditions:**

- 1) The plant has suffered a LOP due to a Winter Storm.
- 2) Emergency Diesel Generator "A" and "B" failed to start.
- 3) Bus 6 has been energized using the SEPS Diesels.
- 4) The "D" Reactor Coolant pump seal has failed completely causing a LOCA in containment.
- 5) The core has uncovered.
- 6) COP-V-3 and COP-V-4 have lost indication.
- 7) Local Airborne radiation readings in the PAB are elevated.
- 8) A General Emergency has been declared on EAL: AG1; Actual or projected offsite dose > 1,000 mRem TEDE or 5,000 mRem Thyroid CDE.
- 9) The TSC is dispatching a team to the PAB Mechanical Penetration Area to determine if COP-V-4 can be closed.
- 10) Radiation readings taken at the doorway to the Mechanical Penetration Area are 2 REM/Hr. Dose at COP-V-4 is conservatively estimated at 15 REM/Hr
- 11) The OSC conservatively estimates 1.5 hours to assess any damage to the valve and make repairs.

### **3.0 Standards:**

Authorize an Emergency Dose Limit Extension per ER 4.3, Radiation Protection During Emergency Conditions.

### **4.0 Student Materials:**

Copy of the Directions Tear-Off Sheet  
Calculator  
ER 4.3, Radiation Protection During Emergency Conditions

### **5.0 Limitations on performance:**

Even if requested no Peer Checks will be provided during the JPM.

## JOB PERFORMANCE WORKSHEET

### **6.0 References:**

Procedures

ER 4.3, Radiation Protection During Emergency Conditions.

### **7.0 Setting:**

Classroom

### **8.0 Safety Considerations:**

None

### **9.0 Approximate Completion Time:**

20 minutes

## JOB PERFORMANCE WORKSHEET

### 10.0 Directions to the Student(s):

#### Initial Conditions:

- 1) The plant has suffered a LOP due to a Winter Storm.
- 2) Emergency Diesel Generator "A" and "B" failed to start.
- 3) Bus 6 has been energized using the SEPS Diesels.
- 4) The "D" Reactor Coolant pump seal has failed completely causing a LOCA in containment.
- 5) The core has uncovered.
- 6) COP Valves COP-V-3 and COP-V-4 have lost indication.
- 7) Local Airborne radiation readings in the PAB are elevated.
- 8) A General Emergency has been declared on EAL: AG1; Actual or projected offsite dose > 1,000 mRem TEDE or 5,000 mRem Thyroid CDE.
- 9) The TSC is dispatching a team to the PAB Mechanical Penetration Area to determine if COP-V-4 can be closed.
- 10) Radiation readings taken at the doorway to the Mechanical Penetration Area are 2 REM/Hr. Dose at COP-V-4 is conservatively estimated at 15 REM/Hr
- 11) The OSC conservatively estimates 1.5 hours to assess any damage to the valve and make repairs.

### 11.0 Initiating Cue:

**You are the Short Term Emergency Director (STED).**

**Emergency Dose Limit Extensions have been requested for a three person team to enter the Mechanical Penetration Area to attempt closing COP-V-4.**

**Review the Emergency Dose limit Extensions and provide approval if appropriate.**

**Provide the completed Forms to me.**

**PERFORMANCE CHECKLIST**

	D=Discuss P=Perform S=Simulate	ELEMENT/STEP *denotes a critical step	STANDARD *denotes critical standard	EVALUATION	
				SAT	UNSAT

1. P Start time \_\_\_\_\_ Initiating cue read.

**CUE:** If the student requests a Peer Check at any time during the JPM, respond: **“No one is available to peer check your actions. Please continue with the task”.**

**NOTE:** Provide the student with the 3 completed Emergency Dose Limit Extension sheets and a copy ER 4.3, Radiation Protection During Emergency Conditions. Students will evaluate and authorize the completed dose extensions.

**NOTE:** JPM task is approval of a task that is administrative in nature. Student may perform steps in any order, provided that critical tasks are all accomplished.

2 P ER 4.3, step 5.1.2, 2a:  
Verifies dose extension for all workers exceeds 4500 mrem/yr (minimum level requiring STED approval)

a Dose extension for NSO 24000 mrem \_\_\_\_\_

b Dose extension for Maintenance Mechanic 24000 mrem \_\_\_\_\_

c Dose extension for HP Technician 24000 mrem \_\_\_\_\_

3 P ER 4.3, Step 5.1.2, 2b, and Figure 2  
Verifies dose extension is 25 rem or less for “Protection of large Populations” category

a Dose extension for NSO 24000 mrem \_\_\_\_\_

b Dose extension for Maintenance Mechanic 24000 mrem \_\_\_\_\_

c Dose extension for HP Technician 24000 mrem \_\_\_\_\_

4 P ER 4.3, Step 5.1.2, 2c, and Figure 3  
Verifies dose extension is up to 25 rem only for Volunteers fully aware of risks for “Protection of large Populations” category,

a NSO has signed figure 4. \_\_\_\_\_

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP *denotes a critical step	STANDARD *denotes critical standard	EVALUATION	
			SAT	UNSAT

and signified by employee  
signature on figure 4.

b Maintenance Mechanic has signed figure 4. \_\_\_\_\_

c HP Technician has signed figure 4. \_\_\_\_\_

5 \*P Authorizes Dose Extensions \*a Dose extensions signed. \_\_\_\_\_

**CUE: "The JPM is complete."**

6. Stop time \_\_\_\_\_ Time to complete the task  
Evaluator calculates the time to complete the task. ≤ 20 minutes.

7 Obtain from student:  
Tear Off Sheets and any other  
training materials used in the  
performance of the JPM

### PERFORMANCE SUMMARY

Provide comments on unsatisfactory performance of an element/step or for deviation from performance as stated. Record interruptions in performance such as retraining, shift change, and processing of procedure changes. Recommend remedial training, if necessary.

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

## TEAR-OFF SHEET

### **Initial Conditions:**

- 1) The plant has suffered a LOP due to a Winter Storm.
- 2) Emergency Diesel Generator "A" and "B" failed to start.
- 3) Bus 6 has been energized using the SEPS Diesels.
- 4) The "D" Reactor Coolant pump seal has failed completely causing a LOCA in containment.
- 5) The core has uncovered.
- 6) COP-V-3 and COP-V-4 have lost indication.
- 7) Local Airborne radiation readings in the PAB are elevated.
- 8) A General Emergency has been declared on EAL: AG1; Actual or projected offsite dose > 1,000 mRem TEDE or 5,000 mRem Thyroid CDE.
- 9) The TSC is dispatching a team to the PAB Mechanical Penetration Area to determine if COP-V-4 can be closed.
- 10) Radiation readings taken at the doorway to the Mechanical Penetration Area are 2 REM/Hr. Dose at COP-V-4 is conservatively estimated at 15 REM/Hr
- 11) The OSC conservatively estimates 1.5 hours to assess any damage to the valve and make repairs.

### **Initiating Cue:**

**You are the Short Term Emergency Director (STED).**

**Emergency Dose Limit Extensions have been requested for a three person team to enter the Mechanical Penetration Area to attempt closing COP-V-4.**

**Review the Emergency Dose limit Extensions and provide approval if appropriate.**

**Provide the completed Forms to me.**

---



**Figure 4**  
**Emergency Dose Limit Extension**

1) Name Bob NSO Age 25 2) Badge Number XXXX  
3) Reason for Dose Extension Request (Be specific): Dispatched by TSC to  
determine if COP-V-4 can be closed.

I understand the consequences of the proposed exposure: (See Note 1)

Bob NSO  
Employee's Signature

Note 1: The signature of the employee may be authorized by verbal reply.

RADIATION PROTECTION USE

4) Current TEDE: YTD - 15 mrem.  
5) Individual dose estimate for required work: 22500 mrem.  
6) Emergency Dose Limit Requested: 24000 mrem.

SHORT TERM EMERGENCY DIRECTOR/SITE EMERGENCY DIRECTOR

A. Individual Extension

I authorize the above-named individual an emergency dose extension not to exceed \_\_\_\_\_ mrem.

This extension is necessary to perform emergency functions for plant/personnel safety, and is valid only for the task specified above.

Short Term Emergency Director/Site Emergency Director

B. Blanket Extension

All emergency center personnel are authorized a blanket extension, not to exceed N/A mrem.

N/A  
Short Term Emergency Director/Site Emergency Director

**Figure 4**  
**Emergency Dose Limit Extension**

- 1) Name Steve Mechanic Age 32 2) Badge Number XXXX  
3) Reason for Dose Extension Request (Be specific): Dispatched by TSC to  
determine if COP-V-4 can be closed.

I understand the consequences of the proposed exposure: (See Note 1)

Steve Mechanic  
Employee's Signature

Note 1: The signature of the employee may be authorized by verbal reply.

RADIATION PROTECTION USE

- 4) Current TEDE: YTD - 52 mrem.  
5) Individual dose estimate for required work: 22500 mrem.  
6) Emergency Dose Limit Requested: 24000 mrem.

SHORT TERM EMERGENCY DIRECTOR/SITE EMERGENCY DIRECTOR

A. Individual Extension

I authorize the above-named individual an emergency dose extension not to exceed 24000 mrem.  
This extension is necessary to perform emergency functions for plant/personnel safety, and is valid only for the task specified above.

Short Term Emergency Director/Site Emergency Director

B. Blanket Extension

All emergency center personnel are authorized a blanket extension, not to exceed N/A mrem.

N/A

Short Term Emergency Director/Site Emergency Director

**Figure 4**  
**Emergency Dose Limit Extension**

1) Name Charles HP Age 50 2) Badge Number XXXX  
3) Reason for Dose Extension Request (Be specific): Dispatched by TSC to  
determine if COP-V-4 can be closed.

I understand the consequences of the proposed exposure: (See Note 1)  
Charles HP  
Employee's Signature

Note 1: The signature of the employee may be authorized by verbal reply.

RADIATION PROTECTION USE

4) Current TEDE: YTD - 74 mrem.  
5) Individual dose estimate for required work: 22500 mrem.  
6) Emergency Dose Limit Requested: 24000 mrem.

SHORT TERM EMERGENCY DIRECTOR/SITE EMERGENCY DIRECTOR

A. Individual Extension

I authorize the above-named individual an emergency dose extension not to exceed 24000 mrem.  
This extension is necessary to perform emergency functions for plant/personnel safety, and is valid only for the task specified above.

Short Term Emergency Director/Site Emergency Director

B. Blanket Extension

All emergency center personnel are authorized a blanket extension, not to exceed N/A mrem.  
N/A

Short Term Emergency Director/Site Emergency Director



SRO ADMIN JOB PERFORMANCE MEASURE-POST SCENARIO EMERGENCY PLAN  
CLASSIFICATION AND NOTIFICATION  
Rev. 0

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT      UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1.0 Task Number and Description:

Position: SRO

1190402003 Perform required notifications of on-site and off-site personnel for emergency events.

### 2.0 Conditions:

A. As applicable to associated simulator scenario.

### 3.0 Standards:

Classify the emergency condition and make the required notifications of on-site and state personnel for this event.

### 4.0 Student Materials:

Copy of the Tear-Off Sheet.  
E-Plan folder drawer or copies of the following:  
ER-1.1, Classification of Emergencies  
ER-1.1A, Emergency Classification Flow Chart  
ER-1.2, Emergency Plan Activation

### 5.0 Limitations On Performance:

Simulate/Perform all steps. Verbalize all actions to the evaluator.

### 6.0 References:

Procedures:

- RE-1.1, Classification of Emergencies
- ER-1.2, Emergency Plan Activation

### 7.0 Setting:

Simulator, post scenario in FREEZE.

#### **Notes To Evaluator**

**• Because this JPM is done with the simulator in freeze the Control Board clock cannot be used to track time. The digital clock on the Communications Console or a wristwatch must be used. There is a reminder cue in the body of the JPM.**

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

## JOB PERFORMANCE WORKSHEET

### 8.0 Safety Considerations:

None

### 9.0 Approximate Completion Time:

30 minutes

### 10.0 Directions To The Student(s):

- A. You are the Work Control Supervisor.
- B. The following information is provided to you:
  - 1) The plant was initially in Mode 1.
- C. The evaluator will act as the Shift Manager and provide the cues and communications for this JPM. Do you have any questions?

### 11.0 Initiating Cue:

Shift Manager to Work Control Supervisor, **“Work Control Supervisor, classify the Emergency Condition based on the most severe condition experienced during the scenario and activate the Emergency Plan for this event.”**

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform			SAT	UNSAT
S=Simulate	* denotes a critical step	* denotes a critical step		

1. P Start time Initiating cue read.

\* 2. Performs ER-1.1 Section 5.1 Emergency Classification for Post Scenario Evaluation

**NOTE:** ER-1.1, Step 2, Dose Projection is not applicable.

P	Review applicable forms: ER-1.1A: Emergency Initiating Condition Matrix Modes 1, 2, 3 and 4. ER-1.1C, Fission Product Barrier Degradation Matrix Modes 1, 2, 3 and 4. ER-1.1B, Emergency Initiating Condition Matrix, Modes 5, 6, and Defueled	Reviews applicable forms.	_____	_____
P	Circle the potential emergency initiating condition(s) on each form.	Circles the potential emergency initiating condition.	_____	_____
P	For category A, E, H, S and C events, refer to initiating condition EAL(s) in Figure 1 and verify that the EAL is met or the intent is met.	Verifies that the EAL is met or the intent is met.	_____	_____
P	Identify the most severe (highest) emergency classification for which the EAL(s) is met or the intent of the initiating condition is met.	*Identifies the most severe (highest) emergency classification.	_____	_____
P	If an emergency classification is warranted, immediately implement Station Emergency Response Procedure ER 1.2, Emergency Plan Activation.	Implements procedure ER-1.2.	_____	_____

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform			SAT	UNSAT
S=Simulate	* denotes a critical step	* denotes a critical step		

**NOTE: The student is expected to use the applicable Emergency Plan binder from the drawer.**

**INSTRUCTOR CUE: DO NOT RESET THE SIMULATOR UNTIL THE CANDIDATE HAS ACQUIRED THE DATA TO DETERMINE THE E-PLAN CLASSIFICATION!**

**CUE:** If the sim is in freeze, when the student looks at the MCB clock, inform them that **“The MCB clock is not running. Please use the Communications Console clock or your wristwatch to determine the time.”**

*3.	P	Acquires applicable binder.	Acquires binder.	_____	_____
-----	---	-----------------------------	------------------	-------	-------

**NOTE: Expected emergency classification is identified at the end of each simulator exam scenario description.**

**CUE: Shift Manager to Work Control Supervisor, “There is no Code Yellow condition imminent or in progress”.**

P	Determine if a Code Yellow condition exists.	* Determines if a Code Yellow condition exists.	_____	_____
P	Declare emergency via a crew update.	*Declares emergency and records time of update.	_____	_____

**Time of Declaration \_\_\_\_\_ When student performs the update.**

**NOTE: Determination of Schiller Station Activation is made at the Alert level or higher.**

4	P	DETERMINE Schiller Station Activation:	Use flow chart:		
		• Is there a WRGM high alarm?	• Chooses appropriate path.	_____	_____
		• Is there a Main Steam line monitor high alarm with an open ASDV or Safety Relief Valve on the affected line?	• Chooses appropriate path.	_____	_____

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).



**PERFORMANCE CHECKLIST**

D=Discuss  
P=Perform  
S=Simulate

ELEMENT/STEP

STANDARD

EVALUATION

\* denotes a critical step

\* denotes a critical step

SAT    UNSAT

- Select appropriate procedure step?

- Determines Schiller Station is/is not activated and goes to applicable step.

\_\_\_\_\_

**EVALUATOR CUE:** Ask the candidate if they still need the simulator for data for this JPM. **If not** then direct the simulator operator to reset the simulator.

**EVALUATOR CUE:** If the student inquires about safety hazards, respond: **“There are no safety hazards within the site boundry to evacuate personnel.”**

*5.	P	NOTIFY Station Personnel (Using message in applicable ER procedure). • Ensures night muting is off.	Notifies station personnel:  • Ensures night muting is off.	_____	_____
		• Sounds the plant emergency alarm.	*• Sounds the plant emergency alarm.	_____	_____
		• Makes Gaitronics announcement.	* • Makes the applicable announcement over the Gaitronics.	_____	_____
		• Repeats the plant emergency alarm.	• Repeats the plant emergency alarm.	_____	_____
		• Using the Gaitronics override, repeat the announcement.	• Repeats the applicable announcement.	_____	_____
		• Proceed to step for notifying guard island security.	• Goes to step for notifying guard island security.	_____	_____

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss  
P=Perform  
S=Simulate

ELEMENT/STEP

STANDARD

EVALUATION

\* denotes a critical step

\* denotes a critical step

SAT    UNSAT

**NOTE:** An instructor must be in the instructor booth to answer the phone and provide necessary feedback.

*6.	P	<p>NOTIFY Guard Island Security</p> <ul style="list-style-type: none"> <li>• Contact the Guard Island at ext. 4006 or 4008.</li> </ul> <p>Provide the following information:</p> <ul style="list-style-type: none"> <li>• A (applicable emergency plan classification) has been declared.</li> <li>• Time of declaration.</li> <li>• The emergency initiating condition.</li> <li>• Schiller Station is/is not being activated (as determined above).</li> <li>• Direct implementation of procedure GN1332.00, Security Response To A Declared Radiological Emergency.</li> </ul> <p>Proceed to next step.</p>	<p>Notifies Guard Island</p> <ul style="list-style-type: none"> <li>• Contacts the Guard Island supervisor.</li> </ul> <p>*• (Applicable emergency plan classification) has been declared.</p> <p>*• Time when update was performed per ER-1.2A.</p> <p>*• Provides EAL.</p> <p>*• Schiller Station is/is not activated.</p> <p>*• Directs that GN1332.00 be implemented.</p> <p>Goes to next step.</p>	<p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>
*7.	P	<p>Complete ER-2.0B, State Notification Fact Sheet.</p> <ul style="list-style-type: none"> <li>• Block 1-Leave Blank</li> </ul>	<p>Completes ER-2.0B:</p> <ul style="list-style-type: none"> <li>• Block 1- Leaves blank.</li> </ul>	<p>_____</p>	<p>_____</p>

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform			SAT	UNSAT
S=Simulate	* denotes a critical step	* denotes a critical step		

---

**CUE:** If asked, STED to WCS, “Time of declaration was \_\_\_\_\_ based on your update.”

- |  |   |       |       |
|--|---|-------|-------|
| • Block 2- Check (applicable emergency plan classification). | *• Block 2- Checks “Declared” and checks (applicable emergency plan classification) and enters time declared. | _____ | _____ |
| • Block 3- Enter emergency initiating condition.             | *• Enters appropriate initiating condition.   | _____ | _____ |
| • Block 4- Use applicable protective action recommendations. | *• Checks applicable PARS.  | _____ | _____ |

**NOTE:** The candidate should determine if there has been a release based upon scenario conditions.

- |   |  |       |       |
|---|--|-------|-------|
| • Determines if a release has occurred. | * • Block 5-checks a release has/has not occurred. | _____ | _____ |
|---|--|-------|-------|

**NOTE:** When student presents form for authorization: **Make no comments of any sort on the information recorded. Evaluator should sign form as STED**

- |                             |  |       |       |
|-----------------------------|--|-------|-------|
| • Block 6-Self explanatory. | • Block 6- STED authorizes by signing and dating the form. | _____ | _____ |
|-----------------------------|--|-------|-------|

**Time State Notification Fact Sheet completed**\_\_\_\_\_.

*Time State Notification Fact Sheet Completed – Time of Declaration = _____ (Must be <15 minutes)	_____	_____
---	-------	-------

**CUE:** “The JPM is complete.”

9.	Stop time	Time to complete the task ≤ 30 minutes.
----	-----------	---

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss  
P=Perform  
S=Simulate

ELEMENT/STEP

\* denotes a critical step

STANDARD

\* denotes a critical step

EVALUATION

SAT    UNSAT

---

Evaluator calculates time to complete task.

\_\_\_\_\_

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE SUMMARY**

Provide comments on unsatisfactory performance of an element/step or for deviation from performance as stated. Record interruptions in performance such as retraining, shift change, and processing of procedure changes. Recommend remedial training, if necessary.

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

## TEAR-OFF SHEET

### **Directions to the Student:**

Evaluator gives Tear-Off sheet to the student.

- A. You are the Work Control Supervisor. You are going to activate the emergency plan based on the following information.
- B. The following information is provided to you:
  - 1) The plan was initially in Mode 1.
- C. The evaluator will act as the Shift Manager and provide the cues and communications for this JPM. Do you have any questions?

### **Initiating Cue:**

Shift Manager to Work Control Supervisor, **“Work Control Supervisor, classify the Emergency Condition based on the most severe condition experienced during the scenario, and activate the Emergency Plan for this event.”**

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).



# Simulator Exam #1 Answer Key (Sheet 4 of 4)

## Seabrook Station State Notification Fact Sheet

Time Notification Initiated: NH \_\_\_\_\_ MA \_\_\_\_\_

Block 1: This is: \_\_\_\_\_ at Seabrook Station.

Name \_\_\_\_\_ Title \_\_\_\_\_

Block 2: Time Declared: \_\_\_\_\_  
 Unusual Event  
 Alert  
 Site Area Emergency  
 General Emergency

OR

Time Terminated: \_\_\_\_\_

Block 3: The emergency initiating condition is SU5.

Block 4: We recommend the following protective actions:

None  As follows

### New Hampshire

ERPA Town Shelter Evacuate

A. Seabrook    
 Hampton Falls

C. Kensington    
 S. Hampton

D. Hampton    
 N. Hampton

F. Brentwood    
 E. Kingston    
 Exeter    
 Newfields    
 Newton    
 Kingston

G. Greenland    
 Stratham    
 Rye    
 New Castle    
 Portsmouth

### Massachusetts

ERPA Town Shelter Evacuate

B. Amesbury    
 Salisbury

E. Merrimac    
 Newburyport    
 Newbury    
 West Newbury

### Beaches

#### Evacuate

Seabrook Beach  
 Hampton Beach

#### Close

Parker River National Wildlife Refuge  
 Plum Island Beach  
 Salisbury Beach

### Potassium Iodide (General Emergency only)

Implement KI plans for the general public

Block 5: A radiological release  Has not occurred  
 Has occurred and is continuing  
 Occurred but has been terminated

Block 6: Authorized by: \_\_\_\_\_  
 STED / SED / RM \_\_\_\_\_ Date \_\_\_\_\_ Time \_\_\_\_\_

Block 7: Acknowledge receipt of this message with your name.

New Hampshire: \_\_\_\_\_ Name of Dispatcher  
 Massachusetts: \_\_\_\_\_ Name of Dispatcher

Time when Candidate made UPDATE announcement per ER 1.2A, Step 2.



# Simulator Exam #2 Answer Key (Sheet 5 of 6)

## Seabrook Station State Notification Fact Sheet

Time Notification Initiated: NH \_\_\_\_\_ MA \_\_\_\_\_

Block 1: This is: \_\_\_\_\_ at Seabrook Station.  
Name Title

*Time that Candidate announced classification*

Block 2: Time Declared: \_\_\_\_\_  
 Unusual Event  
 Alert  
 Site Area Emergency  
 General Emergency  
 OR  
 Time Terminated: \_\_\_\_\_

Block 3: The emergency initiating condition is SSZ.

Block 4: We recommend the following protective actions:

None  As follows

New Hampshire

ERPA Town Shelter Evacuate

A. Seabrook    
 Hampton Falls

C. Kensington    
 S. Hampton

D. Hampton    
 N. Hampton

F. Brentwood    
 E. Kingston    
 Exeter    
 Newfields    
 Newton    
 Kingston

G. Greenland    
 Stratham    
 Rye    
 New Castle    
 Portsmouth

Massachusetts

ERPA Town Shelter Evacuate

B. Amesbury    
 Salisbury

E. Merrimac    
 Newburyport    
 Newbury    
 West Newbury

Beaches

Evacuate

Seabrook Beach  
 Hampton Beach

Close

Parker River National Wildlife Refuge  
 Plum Island Beach  
 Salisbury Beach

Potassium Iodide (General Emergency only)

Implement KI plans for the general public

Block 5: A radiological release  Has not occurred  
 Has occurred and is continuing  
 Occurred but has been terminated

Block 6: Authorized by: \_\_\_\_\_  
 STED / SED / RM Date Time

Block 7: Acknowledge receipt of this message with your name.

New Hampshire: \_\_\_\_\_  
 Name of Dispatcher

Massachusetts: \_\_\_\_\_  
 Name of Dispatcher

# Simulator Exam #3 Answer Key (Sheet 11 of 12)

## Seabrook Station State Notification Fact Sheet

Time Notification Initiated: NH \_\_\_\_\_ MA \_\_\_\_\_

Block 1: This is: \_\_\_\_\_ at Seabrook Station.

Name Title

Block 2: Time Declared: \_\_\_\_\_

<input type="checkbox"/>	Unusual Event
<input type="checkbox"/>	Alert
<input checked="" type="checkbox"/>	Site Area Emergency
<input type="checkbox"/>	General Emergency

OR

Time Terminated: \_\_\_\_\_

Block 3: The emergency initiating condition is SS1.

Block 4: We recommend the following protective actions:

None  As follows

New Hampshire

ERPA Town Shelter Evacuate

A. Seabrook    
Hampton Falls

C. Kensington    
S. Hampton

D. Hampton    
N. Hampton

F. Brentwood    
E. Kingston    
Exeter    
Newfields    
Newton    
Kingston

G. Greenland    
Stratham    
Rye    
New Castle    
Portsmouth

Massachusetts

ERPA Town Shelter Evacuate

B. Amesbury    
Salisbury

E. Merrimac    
Newburyport    
Newbury    
West Newbury

Beaches

Evacuate

Seabrook Beach  
 Hampton Beach

Close

Parker River National Wildlife Refuge  
 Plum Island Beach  
 Salisbury Beach

Potassium Iodide (General Emergency only)

Implement KI plans for the general public

Block 5: A radiological release  Has not occurred  
 Has occurred and is continuing  
 Occurred but has been terminated

Block 6: Authorized by: \_\_\_\_\_  
STED / SED / RM Date Time


Block 7: Acknowledge receipt of this message with your name.

New Hampshire: \_\_\_\_\_  
Name of Dispatcher

Massachusetts: \_\_\_\_\_  
Name of Dispatcher

Time that candidate announced classification

**Figure 1**  
**Site Area Emergency Protective Action Recommendation (PAR) Flowchart**  
(Sheet 1 of 2)



**NOTE 1:**

H Red – after the actions to establish a 'bleed and feed' cooldown have been initiated

P Red – with RCS pressure greater than 300 psig

Z Orange – after transitioning out of Procedure FR-Z.1 with no CBS pump running

# Simulator Exam #4 Answer Key (Sheet 4 of 4)

## Seabrook Station State Notification Fact Sheet

Time Notification Initiated: NH \_\_\_\_\_ MA \_\_\_\_\_

Block 1: This is: \_\_\_\_\_ at Seabrook Station.  
Name Title

*Time that candidate announces classification*

Block 2: Time Declared:  Unusual Event  
 Alert **OR** Time Terminated: \_\_\_\_\_  
 Site Area Emergency  
 General Emergency

Block 3: The emergency initiating condition is FA-1.

Block 4: We recommend the following protective actions:

None  As follows

New Hampshire

ERPA	Town	Shelter	Evacuate
A.	Seabrook	<input type="checkbox"/>	<input type="checkbox"/>
	Hampton Falls	<input type="checkbox"/>	<input type="checkbox"/>
C.	Kensington	<input type="checkbox"/>	<input type="checkbox"/>
	S. Hampton	<input type="checkbox"/>	<input type="checkbox"/>
D.	Hampton	<input type="checkbox"/>	<input type="checkbox"/>
	N. Hampton	<input type="checkbox"/>	<input type="checkbox"/>
F.	Brentwood	<input type="checkbox"/>	<input type="checkbox"/>
	E. Kingston	<input type="checkbox"/>	<input type="checkbox"/>
	Exeter	<input type="checkbox"/>	<input type="checkbox"/>
	Newfields	<input type="checkbox"/>	<input type="checkbox"/>
	Newton	<input type="checkbox"/>	<input type="checkbox"/>
	Kingston	<input type="checkbox"/>	<input type="checkbox"/>
G.	Greenland	<input type="checkbox"/>	<input type="checkbox"/>
	Stratham	<input type="checkbox"/>	<input type="checkbox"/>
	Rye	<input type="checkbox"/>	<input type="checkbox"/>
	New Castle	<input type="checkbox"/>	<input type="checkbox"/>
	Portsmouth	<input type="checkbox"/>	<input type="checkbox"/>

Massachusetts

ERPA	Town	Shelter	Evacuate
B.	Amesbury	<input type="checkbox"/>	<input type="checkbox"/>
	Salisbury	<input type="checkbox"/>	<input type="checkbox"/>
E.	Merrimac	<input type="checkbox"/>	<input type="checkbox"/>
	Newburyport	<input type="checkbox"/>	<input type="checkbox"/>
	Newbury	<input type="checkbox"/>	<input type="checkbox"/>
	West Newbury	<input type="checkbox"/>	<input type="checkbox"/>

Beaches

Evacuate

<input type="checkbox"/>	Seabrook Beach
<input type="checkbox"/>	Hampton Beach

Close

<input type="checkbox"/>	Parker River National Wildlife Refuge
<input type="checkbox"/>	Plum Island Beach
<input type="checkbox"/>	Salisbury Beach

Potassium Iodide (General Emergency only)

Implement KI plans for the general public

Block 5: A radiological release  Has not occurred  
 Has occurred and is continuing  
 Occurred but has been terminated

Block 6: Authorized by: \_\_\_\_\_  
 STED / SED / RM Date Time

Block 7: Acknowledge receipt of this message with your name.

New Hampshire: \_\_\_\_\_ Name of Dispatcher  
 Massachusetts: \_\_\_\_\_ Name of Dispatcher



RO ADMIN JOB PERFORMANCE MEASURE- CALCULATE BORON CHANGE  
Rev. 0

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT      UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1. Task Number and Description

Position RO

SBK 0040100601 Perform Boron Concentration Change Calculation

### 2. Conditions:

- A. Plant is in Mode 3.
- B. The RCS is 557°F and 2235 psig.
- C. The crew is making preparations to go critical per OS1000.07.
- D. RCS born sample is 1500 ppm.
- E. The ECP boron concentration is 1120 ppm.
- F. The MPCS Boron/Dilution program is not available.

### 3. Standards:

Calculate total volume required to lower RCS boron concentration ( $\pm$  100 gals) per RS1735, Reactivity Calculations.

### 4. Student Materials:

Calculator  
Copy of Tear Off Sheet.  
Copy of RS1735, Reactivity Calculations Rev 4 Chg.8.  
Copy of Primary TDB, Figure RE-14 Boration/Dilution Tables Rev. 01-00-01  
Copy of Primary TDB, Figure RE-15 Boration/Dilution Temperature Correction, Rev. 01-00-00.

### 5. Limitations On Performance:

Perform all steps. Verbalize all actions to the evaluator.

### 6. References:

Procedures:

- OS1000.07, Approach To Criticality
- RS1735, Reactivity Calculations
- Primary TDB, Figure RE-14 Boration/Dilution Tables
- Primary TDB, Figure RE-15 Boration/Dilution Temperature Correction

## JOB PERFORMANCE WORKSHEET

**7. Setting:**

Simulator or Classroom.

**8. Safety Considerations:**

None.

**9. Approximate Completion Time:**

15 minutes

**10. Directions To The Student:**

A. You are the Primary Operator. You are going to perform a boron change calculation.

B. The following information is provided to you:

1. Plant is in Mode 3.
2. The RCS is 557°F and 2235 psig.
3. The crew is making preparations to go critical per OS1000.07.
4. RCS born sample is 1500 ppm.
5. The ECP boron concentration is 1120 ppm.
6. The MPCS Boron/Dilution program is not available.

C. Perform the task using RS1735, Reactivity Calculations.

**11. Initiating Cue:**

US to Primary Operator, **“Primary Operator (or student’s name), using RS1735, calculate the total volume required to lower RCS boron concentration from the present boron concentration to that required for the ECP.”**

## PERFORMANCE CHECKLIST

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

**NOTE:** When the student demonstrates the ability to obtain controlled copies of RS1735, Reactivity Calculations, Primary TDB, Figure RE-14 Boration/Dilution Tables, and Primary TDB, Figure RE-15 Boration/Dilution Temperature Correction provide the student with the required documents.

- |    |   |                  |                     |  |  |
|----|---|------------------|---------------------|--|--|
| 1. | P | Start time _____ | Initiating cue read |  |  |
|----|---|------------------|---------------------|--|--|

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

- |    |   |  |  |       |       |
|----|---|--|--|-------|-------|
| 2. | P | Obtain Form D, Dilution worksheet for manual calculation of dilution amount. | Obtains Form D, Dilution worksheet for manual calculation of dilution amount from RS1735, Reactivity Calculations. | _____ | _____ |
|----|---|--|--|-------|-------|

**NOTE:** See key for values that student should enter on Form D.

- |    |   |  |   |       |       |
|----|---|--|---|-------|-------|
| 3. | P | Enter expected $T_{avg}$ at the time when concentration change is to be made on Form D item 1. | Enters expected $T_{avg}$ at the time when concentration change is to be made on Form D item 1. | _____ | _____ |
| 4. | P | Enter the present and desired boron concentration on Form D item 2.                            | Enter the present and desired boron concentration on Form D item 2.                             | _____ | _____ |

**NOTE:** Item 3A requires a set of numbers (FROM, TO, and RMW). A value will be entered for each reading set of RE-14. For instance, changing from 1500→1400, 1400→1300, 1300→1200, and 1200→1120 would require four sets of numbers. See key for values that student should enter on Form D for item 3A.

RE-14 has dilution (RMW makeup) values in the upper right and boration values in the lower left (not used for this JPM) for each boron concentration change made of 100 ppm or less.



**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT	
--------------------------------------	---	---------------------------------------	-------------------------	--

**NOTE:** See key for values that student should enter on Form D.

5.	P	Using TBD Figure Re-14 obtain the total required volume of Reactor Makeup Water (RMW) and enter on Form D item 3a.	Using TBD Figure Re-14 obtains the total required volume of Reactor Makeup Water (RMW) and enter on Form D item 3a.	_____	_____
6.	P	Temperature correction for dilutions. Perform one of the following: If $T_{avg}$ is greater than or equal to 557°F then enter 1.0 on Form D item 3b.  OR If $T_{avg}$ is less than 557°F then use TDB Figure RE-15 to obtain the value to enter on Form D item 3b.	Temperature correction for dilutions. Performs one of the following: If $T_{avg}$ is greater than or equal to 557°F then enters 1.0 on Form D item 3b.  OR If $T_{avg}$ is less than 557°F then uses TDB Figure RE-15 to obtain the value to enter on Form D item 3b.	_____	_____

**NOTE:** See key for values that student should enter on Form D.

*7.	P	Calculate the corrected Total Volume of RMW required in units of gallons as the product of items 3a and 3b and enters on Form D item 3c.	*Calculate the corrected Total Volume of RMW required in units of gallons as the product of items 3a and 3b and enters on Form D item 3c.	_____	_____
-----	---	--	---	-------	-------

**CUE:** "The JPM is complete."

8.		Stop time _____  Evaluator calculates time to complete task	Time to complete task $\leq$ 15 minutes		
9.		Obtain from student: Tear Off sheets and any other training materials used in performance of this JPM.		_____	_____



## TEAR OFF SHEET

### Directions To The Student:

- A. You are the Primary Operator. You are going to perform a boron change calculation.
- B. The following information is provided to you:
  - 1. Plant is in Mode 3.
  - 2. The RCS is 557°F and 2235 psig.
  - 3. The crew is making preparations to go critical per OS1000.07.
  - 4. RCS born sample is 1500 ppm.
  - 5. The ECP boron concentration is 1120 ppm.
  - 6. The MPCCS Boron/Dilution program is not available.
- C. Perform the task using RS1735, Reactivity Calculations.

### Initiating Cue:

US to Primary Operator, **“Primary Operator (or student’s name), using RS1735, calculate the total volume required to lower RCS boron concentration from the present boron concentration to that required for the ECP.”**

KEY

**Form D: Dilution Worksheet**

(Sheet 1 of 1)

1. RCS Temp. ( $T_{AVG}$ ) 557 °F  
2. Desired Boron Change: From 1500 ppm To 1120 ppm  
3. Gallons Required

3a. Gallons of RMW at 557°F RCS Temperature.

				RMW			
From	<u>1500</u>	ppm	To	<u>1400</u>	ppm	<u>4294</u>	gals.
From	<u>1400</u>	ppm	To	<u>1300</u>	ppm	<u>4613</u>	gals.
From	<u>1300</u>	ppm	To	<u>1200</u>	ppm	<u>4982</u>	gals.
From	<u>1200</u>	ppm	To	<u>1120</u>	ppm	<u>4294</u>	gals.
From		ppm	To		ppm		gals.
						Total	a <u>18183</u> gals.

**NOTE**

If RCS temperature is greater than or equal to 557 °F, then parameter "b" = 1.0

3b. Temperature Correction for  $T_{AVG}$  less than 557°F  
TDB Figure RE-15 Correction Factor b = 1.0

3c. Corrected Total Gallons Required  
(a 18183 gals.) x (b 1.0) = 18183 gallons of RMW.

Calculated By: \_\_\_\_\_ Date: \_\_\_\_\_

Independently Verified By: \_\_\_\_\_ Date: \_\_\_\_\_



RO ADMIN JOB PERFORMANCE MEASURE- QPTR CALCULATION  
Rev. 0

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### **1.0 Task Number and Description:**

Position: RO

0150200501 Perform A Manual QPTR Calculation

### **2.0 Conditions:**

- A. Plant is now at 100% power after recovering from a dropped rod at EOL.
- B. The main plant computer has been inoperable since yesterday (It was inoperable when the rod dropped).
- C. The seven day QPTR surveillance is scheduled to be done this shift.
- D. Incore/Excore calibration was performed yesterday (before the rod dropped).

### **3.0 Standards:**

Perform the manual QPTR surveillance per RX1703, QPTR Surveillance.

### **4.0 Student Materials:**

Copy of the Directions Tear-Off Sheet  
Calculator  
RX1703, QPTR Surveillance, Rev. 7, Chg. 2.

### **5.0 Limitations on performance:**

Simulate/Perform all steps.

### **6.0 References:**

Procedures

RX1703, QPTR Surveillance.  
OS1000.05, Power Increase.  
ON1251.01, Loss Of Plant Computer.

**JOB PERFORMANCE WORKSHEET**

**7.0 Setting:**

Classroom

1. Examiner must prepare a completed RX1703A in advance. It shall reflect the JPM values for NI cabinet detector currents and the RE-17 100% power, 0% AFD values.
2. Use values listed in RE-17.

**8.0 Safety Considerations:**

None

**9.0 Approximate Completion Time:**

20 minutes

**10.0 Directions to the Student(s):**

Initial Conditions:

1. Plant is now at 100% power following the recovery of a dropped rod at EOL.
2. The main plant computer has been inoperable since yesterday.
3. The QPTR surveillance is scheduled to be done this shift.
4. Incore/Excore calibration was performed yesterday (before the rod dropped).
5. Detector current readings have been taken by the Control Board Monitor.
6. The time is 0800, today's date.

	TOP (A) DETECTORS			
	N41	N42	N43	N44
Detector Current micoamps	184	182	181	179
	BOTTOM (B) DETECTORS			
	N41	N42	N43	N44
Detector Current micoamps	177	197	191	187

## JOB PERFORMANCE WORKSHEET

### **11.0 Initiating Cue:**

**Perform the QPTR Surveillance per RX1703. The QPTR alarm surveillance work order has been generated.**

**All independent verifications of calculations will be performed after you are completed. Provide your results to me.**



## PERFORMANCE CHECKLIST

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical	SAT	UNSAT
S=Simulate	critical step	standard		

1. P Start time \_\_\_\_\_ Initiating cue read.

**CUE:** If the student requests a Peer Check at any time during the JPM, respond: **“No one is available to peer check your actions. Please continue with the task”.**

**NOTE:** For performance of JPM in classroom setting the student is provided with a copy of RX1703, Quadrant Power Tilt Ratio Surveillance. Student should refer to section 4.1 Surveillance With QPTR Alarm Inoperable.

2 P RECORD the Figure RE-17 revision and the date and time the operable power range currents were taken. Records today's date and the revision number of the RE-17 curve used \_\_\_\_\_

**NOTE:** Detector current data for upper & lower detectors are provided. Detector Current value units are microamps. Student should be able to determine that all Power Range Detectors are operable when given the detector current data.

3. P RECORD the current output from the top (A) and bottom (B) detector of each channel on Form A, Quadrant Power Tilt Calculation Sheet Row 1. Records detector outputs.

N41 top (A) detector	_____	_____
N42 top (A) detector	_____	_____
N43 top (A) detector	_____	_____
N44 top (A) detector	_____	_____
N41 bottom (B) detector	_____	_____
N42 bottom (B) detector	_____	_____
N43 bottom (B) detector	_____	_____
N44 bottom (B) detector	_____	_____

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical	SAT	UNSAT
S=Simulate	critical step	standard		

---

**CUE:** If the student asks for independent verification of the values recorded in Row 1 of Form A, cue, evaluator to student, “ **Form A Detector currents have been independently verified.**”

**NOTE:** The student is provided with a copy of RE-17.

4. P Using data from Technical Data Book Figure RE-17, RECORD the 100% power, 0% AFD detector current, for the top (A) and bottom (B) detector of each channel on Form A, Quadrant Power Tilt Calculation Sheet Row 2.

a. From Technical Data Book fig RE-17, Records 100% power, 0% AFD values:

4 Top (A) Detectors

\_\_\_\_\_

b. From Technical Data Book fig RE-17, Records 100% power, 0% AFD values:

4 Bottom (B) Detectors

\_\_\_\_\_

\*5. P CALCULATE the normalized detector current by dividing each detector current by its 100% power, 0% AFD current. RECORD the results on Form A, Quadrant Power Tilt Calculation Sheet Row 3.

**PERFORMANCE CHECKLIST**

D=Discuss  
P=Perform  
S=Simulate

ELEMENT/STEP  
\*denotes a  
critical step

STANDARD  
\*denotes critical  
standard

EVALUATION  
SAT    UNSAT

a. \*Calculates and records Normalized  
Detector Currents:

4 Top (A) Detectors

\_\_\_\_\_

b. \*Calculates and records Normalized  
Detector Currents:

4 Bottom (B) Detectors

\_\_\_\_\_

\*6.    P    CALCULATE the average  
normalized detector current for  
the top detectors and for the  
bottom detectors. RECORD  
the results on Form A,  
Quadrant Power Tilt  
Calculation Sheet Row 4.

a. \*Calculates and records average  
normalized detector currents:

Top (A) Detectors

\_\_\_\_\_

b. \*Calculates and records average  
normalized detector currents:

Bottom (B) Detectors

\_\_\_\_\_

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical	SAT	UNSAT
S=Simulate	critical step	standard		

---

*7.	P	CALCULATE the Quadrant Power Tilt Ratio for each detector by dividing each normalized detector current by its associated average normalized detector current. COMPLETE Form A, Quadrant Power Tilt Calculation Sheet.		
		a. *Calculates and records QPTR for each detector:		
		4 Top (A) Detectors	_____	_____
		b. *Calculates and records QPTR for each detector:		
		4 Bottom (B) Detectors	_____	_____
*8.	P	Indicate the maximum QPTR by circling on Form A Row 5.	*Identifies (circles) the maximum power tilt ratio on Form A Row 5.	_____

**CUE:** If the student asks for independent verification of the Form A calculations, cue, evaluator to student, “**Form A calculations have been independently verified.**”

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform	*denotes a	*denotes critical	SAT	UNSAT
S=Simulate	critical step	standard		

*9.	P	Determine if LCO 3.2.4 is/is not met based on maximum QPTR.		
			*a. Identify in step 6 of Form A that LCO 3.2.4 is/is not met	_____
			*b. In Row 6 Form A circle YES/NO	_____

**NOTE:** See answer key for the correct item to circle in row 6 on Form A

**CUE:** "The JPM is complete."

10.	Stop time_____	Time to complete the task ≤ 20 minutes.
	Evaluator calculates the time to complete the task.	
11.	Obtain from student: Tear Off Sheets and any other training materials used in the performance of the JPM	

**PERFORMANCE SUMMARY**

Provide comments on unsatisfactory performance of an element/step or for deviation from performance as stated. Record interruptions in performance such as retraining, shift change, and processing of procedure changes. Recommend remedial training, if necessary.

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

**TEAR-OFF SHEET FOR JPM**  
**2009 RO-ADMIN#1**

**Initial Conditions:**

1. Plant is now at 100% power following the recovery of a dropped rod at EOL.
2. The main plant computer has been inoperable since yesterday.
3. The QPTR surveillance is scheduled to be done this shift.
4. Incore/Excore calibration was performed yesterday (before the rod dropped).
5. Detector current readings have been taken by the Control Board Monitor.
6. The time is 0800, today's date.

	TOP (A) DETECTORS			
	N41	N42	N43	N44
Detector Current micoamps	184	182	181	179
	BOTTOM (B) DETECTORS			
	N41	N42	N43	N44
Detector Current micoamps	177	197	191	187

**Initiating Cue:**



**Perform the QPTR Surveillance per RX1703. The QPTR alarm surveillance work order has been generated.**

**All independent verifications of calculations will be performed after you are done. Provide your results to me.**

RO KEY

### Form A: Quadrant Power Tilt Calculation Sheet

Detector Current at: TIME \_\_\_\_\_ DATE \_\_\_\_\_ RE-17 Revision 1-14-05

 **CAUTION** 

Record all detector currents in units of microamps.

	TOP (A) DETECTORS				BOTTOM (B) DETECTORS			
	N41	N42	N43	N44	N41	N42	N43	N44
(1) DETECTOR CURRENT 0-500 MICRO	184	182	181	179	177	197	191	187
(2) 100% RTP, 0% AFD DETECTOR CURRENT FROM RE-17	192.76	187.64	204.85	195.84	205.70	230.97	227.05	215.50
(3) NORMALIZED DETECTOR CURRENT = (1)/(2)	.955	.969	.884	.914	.860	.853	.841	.868
(4) AVE. NORMALIZED DETECTOR CURRENT	.931				.856			
(5) QUADRANT POWER TILT RATIO (QPTR) = (3)/(4)	1.026	1.041	.949	.982	1.005	.996	.982	1.014
(6) LCO 3.2.4 Met? YES / <input checked="" type="radio"/> NO								

Detector Current Obtained by: \_\_\_\_\_ Date: \_\_\_\_\_

Detector Current Independently Verified by: \_\_\_\_\_ Date: \_\_\_\_\_

Calculations Performed by: \_\_\_\_\_ Date: \_\_\_\_\_

Calculations Independently Verified by: \_\_\_\_\_ Date: \_\_\_\_\_




## RE-17 NIS CHANNEL and LOOP DELTA-T SCALING

Values Shown Below Indicate 100% Values


Channel	Top ( $\mu$ amps)	Bottom ( $\mu$ amps)	MPCS Constant	Amp. Gain (C*-0231)
N41	192.76	205.70	18.30	2.000
N42	187.64	230.97	18.30	2.000
N43	204.85	227.05	18.30	2.000
N44	195.84	215.50	18.30	2.000

Loop	Full Power $\Delta$ T	$\Delta$ T Gain (C*-0223)	$\Delta$ T Alarm Time Delay	$T_{AVG}$ Dev. Alarm Time Delay
1	61.705	1.2965	60 sec.	60 sec.
2	61.891	1.2926	60 sec.	60 sec.
3	60.314	1.3264	60 sec.	60 sec.
4	61.340	1.3042	60 sec.	60 sec.

Channel	IR Full Power Current ( $\mu$ amps)
N35	337.613
N36	325.517

RE Dept. Supervisor 

6/14/10

Operations Manager  for KTB  
Signature

6/14/10  
Date

Revision  
01-14-05

Revision Summary:

Update 100% Currents and MPCS Constant for Quarterly In/Ex Normalization



RO ADMIN JOB PERFORMANCE MEASURE- SHUTDOWN MARGIN (MODE 1)  
Rev. 0

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT      UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1. Task Number and Description

Position RO

SBK 0010100401 Perform Shutdown Margin Calculation

### 2. Conditions:

- A. The plant is in Mode 1, MOL at 100% RTP and stable.
- B. RCS boron concentration is 1300 ppm.
- C. During performance of OX1410.02, Quarterly Rod Operability Surveillance, rod H-2 dropped to the bottom of the core.
- D. Rod H-2 cannot be moved.
- E. OS1210.05, Dropped Rod actions are being performed.

### 3. Standards:

Determine the shutdown margin within  $\pm 0.035\% \Delta K/K$ .

### 4. Student Materials:

Copy of Tear Off Sheet.

Copy of RX1707, Shutdown Margin Surveillance Rev 7 Chg.7.

Copy of Primary TDB, Figure RE-8 Total Power Defect vs. Power And Boron Concentration Rev. 01-14-00.

Copy of Primary TDB, Figure RE-18 Shutdown Margin Values, Rev. 01-14-00.

Copy of Primary TDB, Figure RE-19 Control Bank Worth At RIL vs. Power Rev. 01-14-00.

Copy of Core Operating Limit Report SSTR Rev. 121.  
Calculator.

### 5. Limitations On Performance:

Perform all steps. Verbalize all actions to the evaluator.

### 6. References:

Procedures:

- OS1210.05, Dropped Rod
- RX1707, Shutdown Margin Surveillance

## JOB PERFORMANCE WORKSHEET

### Curves:

- Primary TDB, Figure RE-8 Total Power Defect vs. Power And Boron Concentration
- Primary TDB, Figure RE-18 Shutdown Margin Values
- Primary TDB, Figure RE-19 Control Bank Worth At RIL vs. Power

### Technical Specifications/TRM:

- 3.1.3.1 Moveable Control assemblies Group Height
- 3.1.3.6 Control Rod Insertion Limits
- 3.1.1.1 Shutdown Margin >200°F
- Core Operating Limit Report

**7. Setting:**

Classroom.

**8. Safety Considerations:**

None.

**9. Approximate Completion Time:**

15 minutes

**10. Directions To The Student:**

A. The following information is provided to you:

1. The plant is in Mode 1, MOL at 100% RTP and stable.
2. RCS boron concentration is 1300 ppm.
3. During performance of OX1410.02, Quarterly Rod Operability Surveillance, rod H-2 dropped to the bottom of the core.
4. Rod H-2 cannot be moved.
5. OS1210.05, Dropped Rod actions are being performed.

B. Perform the task using RX1707, Shutdown Margin Surveillance.

**11. Initiating Cue:**

---

**JOB PERFORMANCE WORKSHEET**

US to student (or student's name), **“Make sure we are in compliance with Tech Spec 3.1.1.1 by calculating shutdown margin using RX1707.”**

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT	
--------------------------------------	---	---------------------------------------	-------------------------	--

**NOTE:** When the student demonstrates the ability to obtain controlled copies of RX1707, Shutdown Margin Surveillance, Primary TDB, Figure RE-8 Total Power Defect vs. Power And Boron Concentration, Primary TDB, Figure RE-18 Shutdown Margin Values, Primary TDB, Figure RE-19 Control Bank Worth At RIL vs. Power, and Core Operating Limit Report, provide the student with the required documents when requested.

1. P Start time \_\_\_\_\_ Initiating cue read

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

2.	P	Refer to section 4.4 of RX1707 Shutdown Margin Surveillance to complete Form C Shutdown Margin Determination Immoveable, Untrippable, Or Dropped Rod(s) Part 1.	Refers to section 4.4 of RX1707 Shutdown Margin Surveillance to complete Form C Shutdown Margin Determination Immoveable, Untrippable, Or Dropped Rod(s) Part 1.	_____	_____
----	---	---	--	-------	-------

**NOTE:** See key for all values that student should enter on Form D.

3.	P	Determine number of immoveable, untrippable or dropped rod(s) and enter on Form C block (a).	Determines number of immoveable, untrippable or dropped rod(s) and enters on Form C block (a).	_____	_____
----	---	--	--	-------	-------

4.	P	Determine maximum worth of individual immoveable, untrippable or dropped rod(s) using Primary TDB figure RE-18 and enter on Form C block (b).	Determines maximum worth of individual immoveable, untrippable or dropped rod(s) using Primary TDB figure RE-18 and enters on Form C block (b).	_____	_____
----	---	---	---	-------	-------

5.	P	Calculate total unavailable rod worth by multiplying (a) by (b) and enter on Form C block (c).	Calculates total unavailable rod worth by multiplying (a) by (b) and enters on Form C block (c).	_____	_____
----	---	--	--	-------	-------

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP  * denotes a critical step	STANDARD  * denotes a critical step	EVALUATION  SAT UNSAT	
--------------------------------------	---	---	-----------------------------	--

**CUE:** If student requests boron concentration, reply, **“RCS boron concentration is 1300 ppm.”**

6.	P	Determine total power defect for current relative power using Primary TDB figure RE-8 and enter on Form C block (d).	Determines total power defect for current relative power using Primary TDB figure RE-8 and enters on Form C block (d).	_____	_____
7.	P	Determine worth of the control banks inserted to the rod insertion limit for current relative power using Primary TDB figure RE-19 and enter on Form C block (e).	Determines worth of the control banks inserted to the rod insertion limit for current relative power using Primary TDB figure RE-19 and enters on Form C block (e).	_____	_____
8.	P	Determine total control and shutdown rod worth minus stuck rod and less 10% uncertainty using Primary TDB figure RE-18 and enter on Form C block (f).	Determines total control and shutdown rod worth minus stuck rod and less 10% uncertainty using Primary TDB figure RE-18 and enters on Form C block (f).	_____	_____
*9.	P	Calculate shutdown margin: [f - (c + d + e)] / 1,000.	Calculates shutdown margin: [f - (c + d + e)] / 1,000.	_____	_____

**CUE:** If student asks for independent verification, provide the following cue, **“Form C Part 1 has been independently verified. Please continue.”**

**CUE:** If student fails to report the shutdown margin adequacy determination, provide the cue, **“Is shutdown margin adequate?”**

10.	P	Notify SM/US if the shutdown margin is less than the limit specified in the Core Operating Limits Report.	Notifies SM/US if the shutdown margin is less than the limit specified in the Core Operating Limits Report.	_____	_____
-----	---	---	---	-------	-------

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

**CUE: "The JPM is complete."**

11. Stop time \_\_\_\_\_ Time to complete task ≤ 15 minutes

Evaluator calculates time to complete task

12. Obtain from student:  
Tear Off sheets and any other training materials used in performance of this JPM.

\_\_\_\_\_





## TEAR OFF SHEET

### Directions To The Student:

- A. You are going to calculate shutdown margin in Mode 1.
- B. The following information is provided to you:
  - 1. The plant is in Mode 1, MOL at 100% RTP and stable.
  - 2. RCS boron concentration is 1300 ppm.
  - 3. During performance of OX1410.02, Quarterly Rod Operability Surveillance, rod H-2 dropped to the bottom of the core.
  - 4. Rod H-2 cannot be moved.
  - 5. OS1210.05, Dropped Rod actions are being performed.
- C. Perform the task using RX1707, Shutdown Margin Surveillance.

### Initiating Cue:

US to student (or student's name), **"Make sure we are in compliance with Tech Spec 3.1.1.1 by calculating shutdown margin using RX1707."**

7

KEY

### Form C: Shutdown Margin Determination Immovable, Untrippable Or Dropped Rod(s)

(Sheet 1 of 2)

#### PART I

<b>Shutdown Margin Determination - MODEs 1 and 2 (Step 4.4.1.1)</b>	
Number of Immovable, Untrippable and Dropped Rod(s)	<u>1</u> (a)
Maximum Worth Individual of Immovable, Untrippable or Dropped Rod (Primary Technical Data Book Figure RE-18)	<u>1037</u> pcm (b)
Total Unavailable Rod Worth = $\frac{1}{(a)} \times \frac{1037}{(b)} \text{ pcm} = \frac{1037}{(c)} \text{ pcm}$	
Total Power Defect - For Current Relative Power (Primary Technical Data Book Figure RE-8)	<u>1980</u> pcm (d)
Worth of the Control Banks Inserted to the Rod Insertion Limit - For Current Relative Power (Primary Technical Data Book Figure RE-19)	<u>340</u> pcm (e)
Total Control and Shutdown Rod Worth Minus Stuck Rod and less 10% uncertainty (Primary Technical Data Book Figure RE-18)	<u>5825</u> pcm (f)
Shutdown Margin $[f - (c + d + e)] / 1,000$	$[5825 - (1037 + 1980 + 340)] / 1000$ %ΔK/K
Notify the SM/US if the Shutdown Margin is less than the limit specified in the Core Operating Limits Report.	
Completed By _____	Date _____
Independently Verified By _____	Date _____
US Review _____	Date _____
SM Review _____	Date _____

2.468 %ΔK/K

Correct answer must be  $\pm 10\%$  of 2.468 %ΔK/K  
 Range 2.22 %ΔK/K to 2.71 %ΔK/K



RO ADMIN JOB PERFORMANCE MEASURE- COP Exhaust RM Setpoints  
Rev. 0

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT      UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1.0 Task Number and Description:

Position: RO/SRO  
Task: 0290100401 Adjust Containment Pressure Using the COP System.  
0290100401 Start-Up the COP System.  
0710101302 Authorize Release of Gaseous Waste.

### 2.0 Conditions:

- A. Plant is in Mode 1.
- B. The previous shift has made preparations to place COP in service per OS1023.69 section 4.2.

### 3.0 Standards:

Verify COP Exhaust Radiation Monitors' Alert and Alarm setpoints prior to gaseous effluent release per OS1023.69 section 4.2.

### 4.0 Student Materials:

Copy of the Tear-Off sheet.  
Copy of CS0917.02C GEW Containment Purge Release Permit  
Copy of OS1023.69, Containment On-Line Purge System Operation

### 5.0 Limitations On Performance:

Perform all steps. Verbalize all actions to the evaluator.

### 6.0 References:

Procedures:

- CS0917.02, Gaseous Effluent Releases, Rev. 10, Chg. 12.
- OS1023.69, Containment On-Line Purge System Operation, Rev. 11.
- CP-4.1 Effluent Surveillance Program
- MA-4.6, RDMS Data Base Item Control

Sys	KA	Description	Value RO/SRO
Generic	A2.3.11	Ability to Control Radiation Releases	2.7/3.2

### 7.0 Setting:

Classroom

### 8.0 Safety Considerations:

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

## JOB PERFORMANCE WORKSHEET

None

### 9.0 Approximate Completion Time:

20 minutes

### 10.0 Directions To The Student(s):

- A. You are the Primary Operator. You are going to verify the alert and alarm setpoints of the COP Exhaust Radiation Monitors prior to placing COP in service.
- B. The following information is provided to you:
  - 1. Plant is in Mode 1.
  - 2. The previous shift has made preparations to place COP in service per OS1023.69, section 4.2.
- C. Perform the task per OS1023.69 Containment On-Line Purge Operation, section 4.2.

### 11.0 Initiating Cue:

US to Primary Operator, "**Primary Operator (or student's name), after reviewing the Gaseous Effluent Waste Containment Purge Release Permit, continue with preparations to place COP in service per OS1023.69 step 4.2.**"

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform			SAT	UNSAT
S=Simulate	* denotes a critical step	* denotes a critical step		

1.	P	Start time	Initiating cue read.		
<b>CUE:</b>		If the student requests a Peer Check at any time during the JPM respond: <b>“No one is available to peer check your actions. Please continue with the task.”</b>			
<b>CUE:</b>		Provide student with a copy of OS1023.69 (steps 4.2.1 and 4.2.2 complete) and CS0917.02C GEW Containment Purge Release Permit. <b>“Prerequisites for performance of OS1023.69 section 4.2 have been verified met by the previous crew.”</b>			
<b>CUE:</b>		If the student asks for US approval for CS0917.02C respond <b>“The release permit has already been approved by a chemistry supervisor – no further approval is required.”</b>			
*2.	P	RECORDS the expected radiation monitor response from the Gaseous Effluent Waste (GEW) Containment Purge Release Permit, CH-L524.	*RECORDS the value 31.2 as Expected Radiation Monitor Response per step 4.2.3.	_____	_____
*3.	P	DETERMINES the New COP Monitor Background Levels (CPM)	Per step 4.2.4, ADDs the Expected Radiation Monitor Response value to the Current COP radiation monitor background levels recorded in step 4.2.2		
			• *RECORDS 4.39E+01 (+/- 4 CPM) for 1-RM-6527A-1	_____	_____
			• *RECORDS 4.30E+01 (+/- 4 CPM) for 1-RM-6527A-2	_____	_____
			• *RECORDS 4.44E+01 (+/- 4 CPM) for 1-RM-6527B-1	_____	_____

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform			SAT	UNSAT
S=Simulate	* denotes a critical step	* denotes a critical step		

---

- \*RECORDS 4.17E+01 (+/- 4 CPM) for 1-RM-6527B-2

\_\_\_\_\_

**CUE:** After student determines that it is necessary to make RDMS data base changes, **“Step 4.2.6.1 will be performed by the BOP operator and is in progress. Continue with step 4.2.6.2”**

**NOTE:** If the student determines that it is not necessary to perform step 4.2.6, then the JPM is complete and the JPM is a failure.

*4.	P	DETERMINES the Need to Make RDMS Data Base Changes.	*DETERMINES that is necessary to perform step 4.2.6	_____	_____
-----	---	---	---	-------	-------

*5.	P	CALCULATES the New ALERT ALARM setpoint for each Channel.	Per step 4.2.6.2, multiplies the New COP Monitor Background Level recorded in step 4.2.4 by 1.5		
-----	---	---	---	--	--

- \*RECORDS 6.59E+01 (+/- 6 CPM) for 1-RM-6527A-1

\_\_\_\_\_

- \*RECORDS 6.45E+01 (+/- 6 CPM) for 1-RM-6527A-2

\_\_\_\_\_

- \*RECORDS 6.66E+01 (+/- 6 CPM) for 1-RM-6527B-1

\_\_\_\_\_

- \*RECORDS 6.26E+01 (+/- 6 CPM) for 1-RM-6527B-2

\_\_\_\_\_

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).



**PERFORMANCE CHECKLIST**

D=Discuss  
P=Perform  
S=Simulate

ELEMENT/STEP  
\* denotes a critical step

STANDARD  
\* denotes a critical step

EVALUATION  
SAT    UNSAT

*6.	P	CALCULATES the New HIGH ALARM setpoint for each Channel.	Per step 4.2.6.3, multiplies the New COP Monitor Background Level recorded in step 4.2.4 by 1.95		
			<ul style="list-style-type: none"> <li>• *RECORDS 8.56E+01 (+/- 8 CPM) for 1-RM-6527A-1</li> <li>• *RECORDS 8.39E+01 (+/- 8 CPM) for 1-RM-6527A-2</li> <li>• *RECORDS 8.66E+01 (+/- 8 CPM) for 1-RM-6527B-1</li> <li>• *RECORDS 8.13E+01 (+/- 8 CPM) for 1-RM-6527B-2</li> </ul>	_____	_____

**CUE: "The JPM is complete."**

7.	Stop time	Evaluator calculates time to complete task.	Time to complete the task ≤ 30 minutes.		
----	-----------	---	---	--	--

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).



## TEAR-OFF SHEET

### **Directions to the Student:**

- A. You are the Primary Operator. You are going to verify the alert and alarm setpoints of the COP Exhaust Radiation Monitors prior to placing COP in service.
- B. The following information is provided to you:
  - 1. The plant is in Mode 1.
  - 2. The previous shift has made preparations to place COP in service per OS1023.69 section 4.2.
- C. Perform the task per per OS1023.69 Containment On-Line Purge Operation, section 4.2.

### **Initiating Cue:**

US to Primary NSO, **“Primary Operator (or student’s name), after reviewing the Gaseous Effluent Waste Containment Purge Release Permit, continue with preparations to place COP in service per OS1023.69 step 4.2.3.”**

---

Note to Evaluator - Obtain Tear Off Sheets from student following JPM completion (Ops only).

**Form C: GEW Containment Purge Release Permit - CH-L524**

RELEASE PERMIT NO. 10-XXXX

SAMPLE DATE/TIME: Today/0000

PURGE RELEASE RATE 1000 CFM

EXPECTED CONTAINMENT PURGE RADIATION MONITOR RESPONSE 31.2 CPM

The Containment Building purge requires Chemistry to sample as follows:

SAMPLE the containment atmosphere prior to the start of the release.

SAMPLE the Plant Vent 30 minutes after the start of the release.

SAMPLE the Plant Vent within four hours after the release is terminated by Operations, or when two containment building volumes have been released (5.43E+06 cubic feet).

Initiation of purge **shall** occur within 24 hours of sample date/time (see above). This permit assumes the purge will be at the Release Rate indicated above provided **no** startup, shutdown, or a thermal power change >15% in one hour has occurred. If a startup, shutdown, or a thermal power change >15% in one hour has occurred during this purge, notify the Duty Chemistry Technician. It is **not** necessary to stop the actual purge, but a new permit will have to be issued after new samples are collected and analyzed.

The purge may be interrupted (stopped and restarted) without obtaining new samples or issuing a new permit, provided one of the following conditions are met:

1. For up to two hours, provided **no** startup, shutdown, or power change greater than 15% in one hour has occurred, with **no** factor of 3 increase in RCS DEI and PV Noble Gas.
2. For up to 24 hours, provided the purge is reinitiated within 24 hours of the sample date and time, with **no** factor of 3 increase in RCS DEI and PV Noble Gas.
3. At any time after 24 hours from the sample date and time for up to 24 hours, provided **no** startup, shutdown, or power change greater than 15% in one hour has occurred, and a two containment volume (5.43 E+06 cubic feet) has been released.

Chemistry Technician John Doe

Chemistry Supervision/SM/US Approval Bob Doe

NOTIFY Chemistry of all purge interruptions.

Operations RECORD the following information:

1. PURGE START DATE & TIME \_\_\_\_\_ / \_\_\_\_\_ INITIALS
2. PURGE FLOW RATE \_\_\_\_\_ CFM
3. CHEMISTRY TECH NOTIFIED OF PURGE STATE \_\_\_\_\_ INITIALS
4. PURGE STOP DATE & TIME \_\_\_\_\_ / \_\_\_\_\_ INITIALS



JOB PERFORMANCE MEASURE Sa Rev. 0

FR-H.1 BLEED AND FEED

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1.0 Task Number and Description:

Position: RO

0060401501 Monitor The Safety Injection System When Activated  
0060501201 Feed And Bleed The RCS During Inadequate Core Cooling

### 2.0 Conditions:

- A. A reactor trip has occurred.
- B. A loss of all feedwater capability has forced a transition to FR-H.1, Response to Loss of Secondary Heat Sink.

### 3.0 Standards:

Initiate bleed and feed per FR-H.1, Response To Loss Of Secondary Heat Sink.

### 4.0 Student Materials:

Copy of the Tear-Off Sheet  
FR-H.1, Response to Loss Of Secondary Heat Sink, Rev. 34.

### 5.0 Limitations on performance:

Perform all steps. Verbalize all actions to the evaluator.  
Even if requested, no Peer Checks will be provided during the JPM.

### 6.0 References:

Procedures:

FR-H.1, Response To Loss Of Secondary Heat Sink.

Sys	KA	Description	Value RO/SRO
EPE 074	EK3.04	Tripping RCPs.	3.9/4.2
EPE 074	EK3.05	Activating HPI system.	4.2/4.5
EPE 074	EK3.11	Guidance contained in EOP for inadequate core cooling	4.0/4.4

## JOB PERFORMANCE WORKSHEET

### 7.0 Setting:

If performed as a pair with JPM Sh, Reset to IC # 81 or IC #382.

For stand alone, reset the simulator to IC #382 or any 100% IC which contains the following:

1. Initialize to the 100% IC and place simulator in RUN.
2. Insert malfunctions mfrPS001 and mfrPS002 failure of automatic reactor trip Train A & B.
3. In panel graphics section PCF07 insert override for RC-PCV-456B control switch to AUTO.
4. Insert remote function rmvMSV129 Value=0
5. Insert malfunctions mffW039 and mffW041 FW-P113 trip (faulty 86 device) Bus 4 & 5.
6. Insert component remote function bkFW37B RF: rack-out, Rack out breaker for FW-P37B and mvFW347 RF: open breaker to deenergize breaker for FW-V347 EFW mini-flow valve. Place FW-P37B control switch in PTL.
7. Insert malfunctions mffW038 and mffW054 Delay 10 seconds to trip both MFPs on low LO pressure.
8. Complete all actions of FR-S.1 and when S/G WR levels <30% trip the reactor.
9. Place the simulator in FREEZE.

Place simulator in RUN (only as long as needed) to ensure all alarms are acknowledged prior to start of JPM.

Ensure 3 S/G WR levels <30%, conditions for immediate Bleed and Feed exist.

Place danger tags on the motor-driven EFW pump and mini-flow valve control switches.

### 8.0 Safety Considerations:

None

### 9.0 Approximate Completion Time:

15 minutes

### 10.0 Directions to the Student(s):

Evaluator gives Tear-Off sheet to the student

- A. You are the Secondary Operator. You are going to evaluate the need for RCS bleed and feed, and perform the appropriate actions.
- B. The following information is provided to you:
  1. An ATWS and loss of both Main Feedwater pumps has occurred.
  2. FR-S.1 has just been successfully completed.
  3. The motor-driven EFW pump is tagged out.
  4. A transition from FR-S.1 to FR-H.1, Response To Loss Of Secondary Heat Sink, has occurred, and steps 1 & 2 are complete.

## JOB PERFORMANCE WORKSHEET

5. You are the only Operator in the control room and you must perform all control board operations.

### **11.0 Initiating Cue:**

US to Secondary Operator: **“Secondary Operator (or student’s name), we will continue performing FR-H.1, beginning with the step 3 Caution.”**



**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP *denotes a critical step	STANDARD *denotes critical standard	EVALUATION	
			SAT	UNSAT

**NOTE:** Ensure that student is ready to begin the JPM before placing simulator in run.

1. Start time \_\_\_\_\_ Initiating cue read.

**CUE:** If the student requests a Peer Check at any time during the JPM, respond: **“No one is available to peer check your actions. Please continue with the task”**.

2.	P	Student identifies need for RCS bleed and feed as described in Step 3, Caution.	Identifies 3 SG wide range levels <30%.	_____	_____
*3.	P	Check RCP status: <ul style="list-style-type: none"> <li>All RCPs - STOPPED.</li> <li>(RNO) Stop all RCPs.</li> </ul>	<ul style="list-style-type: none"> <li>Verifies RCPs all running</li> <li>* Stops all RCPs</li> </ul>	_____	_____
*4.	P	Actuate SI.	*Actuates SI	_____	_____
5.	P	Verifies RCS Feed Path:  a. Check pump status: <ul style="list-style-type: none"> <li>CCPs - AT LEAST ONE RUNNING</li> <li>- OR -</li> <li>SI pumps - AT LEAST ONE RUNNING</li> </ul> b. Check valve alignment for operating pumps - PROPER EMERGENCY ALIGNMENT ON STATUS PANEL  <ul style="list-style-type: none"> <li>TRAIN A – Cold Leg Injection</li> <li>TRAIN B – Cold Leg Injection</li> </ul>	a. Verifies at least one CCP or SI pump running.  b. Verifies proper valve alignment for operating pumps on both status panels:	_____	_____
*6.	P	Establish RCS Bleed Path:  a. Verify power to PZR PORV block valves - AVAILABLE  b. Verify PZR PORV block	Establishes RCS bleed path:  a. Verifies power to PORV block valves available.  b. Verifies PORV block valves both open.	_____	_____

**PERFORMANCE CHECKLIST**

	D=Discuss P=Perform S=Simulate	ELEMENT/STEP *denotes a critical step	STANDARD *denotes critical standard	EVALUATION	
				SAT	UNSAT
		valves - BOTH OPEN			
		c. Open both PZR PORVs	c. Performs the following: * • Opens PORV-455A.  * • Attempts to open PORV-455B.	_____	_____
7.	P	Verify Adequate RCS Bleed Path: • PORVs - BOTH OPEN	• Verifies A PORV is open. • Recognizes B PORV is closed.	_____	_____
		• PZR PORV block valves - BOTH OPEN	• Verifies both block valves open	_____	_____
*8	P	Perform the following: a. Open reactor head vent isolations: • RC-FV-2881  • RC-V323	a. Opens reactor head vents isolations:  * • RC-FV-2881  * • RC-V323	_____	_____
<b>CUE: "The JPM is complete."</b>					
9.		Stop time _____  Evaluator calculates the time to complete the task.	Time to complete the task ≤ 15 minutes.		
10.		Obtain from student: Tear Off Sheets and any other training materials used in the performance of the JPM		_____	



**Directions to the Student:**

- A. You are the Secondary Operator. You are going to evaluate the need for RCS bleed and feed, and perform the appropriate actions.
  
- B. The following information is provided to you:
  - 1. An ATWS and loss of both Main Feedwater pumps has occurred.
  - 2. FR-S.1 has just been successfully completed.
  - 3. The motor driven EFW pump is DTO'd.
  - 4. A transition from FR-S.1 to FR-H.1, Response To Loss Of Secondary Heat Sink, has occurred, and steps 1 & 2 are complete.
  - 5. You are the only operator in the control room, and you must perform all control board operations.

**Initiating Cue:**

US to Secondary Operator: **"Secondary Operator (or student's name), we will continue performing FR-H.1, beginning with the step 3 Caution."**



JOB PERFORMANCE MEASURE JPM Sb Rev. 0

RECOVER FROM A CRFRM ACTUATION

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### **1.0 Task Number and Description:**

Position: RO

1050400301 Remove the control room ventilation system from the filter recirculation mode.

### **2.0 Conditions:**

- A. The plant is at 100% power.
- B. I&C was performing maintenance on control room east air intake rad monitor RM-6506A2. It was in HIGH alarm due to this maintenance procedure. The appropriate paperwork and Tech. Specs. were in place for performance of this maintenance.
- C. A spurious RDMS HIGH radiation alarm was subsequently received on control room east air intake rad monitor RM-6506A1. This resulted in an "A" train CRFRM ESF actuation.
- D. F7009, CTL RM MAKEUP AIR FLTR RECIRC MODE, is in alarm.
- E. While the US was executing OS1252.02, AIRBORNE HIGH RADIATION, based on the HIGH rad signal on RM-6506A1, I&C reported that the HIGH rad signals on RM-6506A1 & RM-6506A2 were due to the maintenance activities. After consultation with HP, the US has determined that the CRFRM Actuation was spurious.
- F. The US is now executing step 11 of OS1223.01, LOSS OF CONTROL ROOM VENTILATION OR AIR CONDITIONING.

### **3.0 Standards:**

- A. Secure from the CRFRM per OS1023.51, CONTROL ROOM VENTILATION AND AIR CONDITIONING SYSTEM OPERATION.
- B. Align control room ventilation to the normal makeup mode per OS1023.51, CR VENTILATION AND AIR CONDITIONING SYSTEM OPERATION.

### **4.0 Student Materials:**

Copy of the Tear-Off Sheet.  
OS1023.51, Control Room Ventilation and Air Conditioning System Operation, Rev 15  
Pages 1-5 and 39-40.

### **5.0 Limitations on performance:**

Simulate/Perform all steps. Verbalize all actions to the evaluator.

## JOB PERFORMANCE WORKSHEET

### 6.0 References:

#### Procedures

OS1223.01, Loss of Control Room Ventilation or Air Conditioning.  
OS1023.51, Control Room Ventilation and Air Conditioning System Operation.

#### Technical Specifications

3.3.3.1, RAD MONITORING FOR PLANT OPS.  
3.7.6, CR AREA VENTILATION.

Sys	KA	Description	Value RO/SRO
013	K1.13	HVAC.	2.8/3.1
013	K1.18	Premature Reset of ESF actuation.	3.7/4.1
013	K4.10	Safeguards equip control reset.	3.3/3.7
013	A3.02	Operation and actuated equipment.	4.1/4.2
2.1	2.1.30	Ability to locate and operate components.	4.3/4.4
2.1	2.1.23	Ability to perform integrated specific plant procedures all modes.	4.4/4.0
072	K1.04	Control Room Ventilation.	3.3/3.5

### 7.0 Setting:

If performed as a pair with JPM Sd, Reset to IC # 81.

For stand alone, reset the simulator to IC #398 or any 100% IC which contains the following:

1. Initialize to the 100% IC
2. Train A of normal CBA running and Train B of normal CBA in standby per OS1023.51, CR VENTILATION AND AIR CONDITIONING SYSTEM Operation.
3. Insert malfunctions mfRM014 RM-6506A-1 Final Value=200 and mfRM015 RM-6506A-2 Final Value=200 to actuate HIHI alarm
4. Place the simulator in RUN.
5. Ensure this 2 of 2 "A" train CRFRM signal resulted in the following CBA line-up:
  - CBA-FN-27A is OFF.
  - CBA-DP-53A remains OPEN (closes on "B" train CRFRM signal).
  - CBA-FN-27B remains OFF.
  - CBA-DP-53B remains CLOSED.
  - CBA-DP-27A OPENS and CBA-FN-16A STARTS.
  - CBA-DP-27B remains CLOSED and CBA-FN-16B remains OFF.
  - CBA-DP-28 shuts.
  - CBA-FN-15 is tripped.
  - CBA-DP-1058 remains OPEN
6. Delete the high rad malfunctions on RM-6506A1 & RM-6506A2. Acknowledge CP-295 to ensure rad monitors are "green".
7. Place the simulator in FREEZE.

Place the simulator in RUN. Acknowledge all alarms.

## JOB PERFORMANCE WORKSHEET

### 8.0 Safety Considerations:

None

### 9.0 Approximate Completion Time:

25 minutes

### 10.0 Directions to the Student(s):

Evaluator gives Tear-Off sheet to the student

Initial Conditions:

1. You are the Primary Operator. You are going shutdown Train A of control room ventilation from filter recirculation mode and place Train A of the control room normal makeup and ventilation supply system in service per. OS1023.51.
2. The following information is provided to you:
  - The plant is at 100% power.
  - I&C was performing maintenance on control room east air intake rad monitor RM-6506A2. It was in HIGH alarm due to this maintenance procedure. The appropriate paperwork and Tech. Specs. were in place for performance of this maintenance.
  - An RDMS HIGH radiation alarm was subsequently received on control room east air intake rad monitor RM-6506A1. This resulted in an "Alpha" train CRFRM ESF actuation.
  - F7009, CTL RM MAKEUP AIR FLTR RECIRC MODE, is in alarm.
  - While the US was executing OS1252.02, AIRBORNE HIGH RADIATION, based on the HIGH rad signal on RM-6506A1, I&C reported that the HIGH rad signals on RM-6506A1 & RM-6506A2 were due to the maintenance activities. After consultation with HP, the US has determined that the CRFRM Actuation was spurious.
  - The US is now executing step 11 of OS1223.01, LOSS OF CONTROL ROOM VENTILATION OR AIR CONDITIONING.

### 11.0 Initiating Cue:

US to Primary Operator, **"Primary Operator (or student's name), Shutdown the "A" train of control room ventilation from filter recirculation mode and place the "A" train of the control room normal makeup and ventilation supply system in service per. OS1023.51. All procedural Prerequisites have been completed.**



## PERFORMANCE CHECKLIST

	D=Discuss P=Perform S=Simulate	ELEMENT/STEP *denotes a critical step	STANDARD *denotes critical standard	EVALUATION	
				SAT	UNSAT

1. Start time \_\_\_\_\_ Initiating cue read.

**NOTE:** Student should use OS1023.51, sections 4.17 and 4.18.

2.	P	CHECK/PLACE the following control switches to AUTO:	Checks the following switches in auto:		
		<ul style="list-style-type: none"> <li>● CR MAKE-UP AIR TRAIN A FILTER RECIRC MODE</li> <li>● CR MAKE-UP AIR TRAIN B FILTER RECIRC MODE</li> </ul>	<ul style="list-style-type: none"> <li>● CR MAKE-UP AIR TRAIN A FILTER RECIRC MODE.</li> <li>● CR MAKE-UP AIR TRAIN B FILTER RECIRC MODE.</li> </ul>	_____	_____

**NOTE:** Both control switches should be in AUTO.

**NOTE:** When CBA-DP-27A goes full closed, CBA-FN-16A stops. When CBA-FN-16A stops, the CRFRM actuation signal resets. If the student does not wait until CBA-DP-27A is closed, which in turn stops CBA-FN-16A, the "A" train CRFRM actuation will reinitiate, causing CBA-DP-27A to re-open.

*3.	P	PLACE the following control switches to STOP, and HOLD until the exhaust damper CLOSES:	Performs the following:		
		<ul style="list-style-type: none"> <li>● CBA-DP-27A EMER MU FLTR DAMPER</li> <li>● CBA-DP-27B EMER MU FLTR DAMPER</li> </ul>	<ul style="list-style-type: none"> <li>*● Positions and holds CBA-DP-27A control switch in STOP until the damper closes</li> <li>● Observes CBA-DP-27B already closed. (Placing switch to close not required)</li> </ul>	_____	_____

**CUE:** US to student: "Use OS1023.51, section 4.18 to place Train A CBA Normal Ventilation In Service."

4.	CHECK CLOSED/CLOSE CBS-DP-53B, CR MU AIR DAMPER.	Verifies CBA-DP-53B closed.		
			_____	_____

**PERFORMANCE CHECKLIST**

	D=Discuss P=Perform S=Simulate	ELEMENT/STEP *denotes a critical step	STANDARD *denotes critical standard	EVALUATION	
				SAT	UNSAT
5.	P	CHECK OPEN/OPEN CBA-DP-53A, CR MU AIR DAMPER	Verifies open CBA-DP-53A	_____	_____
*6.	P	START CBA-FN-27A, Control Room makeup air fan	*Starts CBA-FN-27A.	_____	_____
<b>NOTE:</b> CTL RM STATIC PRESS CONTROLLER is on CP-23. CP-23 is not simulated.					
<b>CUE:</b> When the student identifies actions for the CTL RM STATIC PRESS CONTROLLER on CP-23, Evaluator to student, <b>"CTL RM STATIC PRESS CONTROLLER is in AUTO and set at 0.3 inches."</b>					
7.	S	At CP-23, CHECK or PLACE the CTL RM STATIC PRESS CONTROLLER to AUTO set at 0.3 inches.	Checks the CTL RM STATIC PRESS CONTROLLER in auto set at 0.3 inches.	_____	_____
8.	P	CHECK OPEN/OPEN CBA-DP-1058, Control Room exhaust isolation damper.	Verifies CBA-DP-1058 is open.	_____	_____
9.	P	CHECK/PLACE the control switch for CBA-FN-15, Control Room exhaust fan in AUTO	Verifies CBA-FN-15 switch is in auto.	_____	_____
<b>CUE:</b> When the student identifies actions for the CTL RM STATIC PRESS CONTROLLER on CP-23, Evaluator to student, <b>"CTL RM STATIC PRESS CONTROLLER is in auto with input pressure indication at 0.3 inches WC."</b>					
10.	S	At CP-23, CHECK or PLACE the CTL RM STATIC PRESS CONTROLLER to AUTO set at 0.3 inches.	Checks the CTL RM STATIC PRESS CONTROLLER in auto set at 0.3 inches.	_____	_____
*11.	P	PLACE and MAINTAIN the control switch for CBA-DP-28, Control Room exhaust modulate damper to OPEN until intermediate position of the damper is indicated, then allow the switch to spring return to AUTO	*Places CBA-DP-28 to open until intermediate is indicated, and then releases to auto.	_____	_____

**PERFORMANCE CHECKLIST**

	D=Discuss P=Perform S=Simulate	ELEMENT/STEP *denotes a critical step	STANDARD *denotes critical standard	EVALUATION	
				SAT	UNSAT

12. P VERIFY CBA-FN-15, Control Room exhaust fan STARTS. Verifies CBA-FN-15 starts \_\_\_\_\_

**CUE:** Since the simulator does not model the "Modulate" function, When the student monitors CBA-DP-28 position indication, provide the cue: **"Both the Red and Green position indication lights are lit."**

13. S VERIFY CBA-DP-28, Control Room exhaust modulate damper MODULATES to control pressure. Verifies CBA-DP-28 modulates to control pressure. \_\_\_\_\_

**CUE:** (If required) Evaluator to student, **"CTL RM STATIC PRESS CONTROLLER input pressure indication is 0.3 inches WC and stable."**

**CUE:** **"The JPM is complete."**

14. Stop time \_\_\_\_\_ Time to complete the task ≤ 25 minutes.

Evaluator calculates the time to complete the task.

15. Obtain from student:  
Tear Off Sheets and any other training materials used in the performance of the JPM \_\_\_\_\_



## TEAR-OFF SHEET FOR LOIT JPM Sb

### RECOVER FROM A CRFRM ACTUATION

#### Directions to the Student:

1. You are the Primary Operator. You are going shutdown Train A of control room ventilation from filter recirculation mode and place Train A of the control room normal makeup and ventilation supply system in service per OS1023.51.
2. The following information is provided to you:
  - The plant is at 100% power.
  - I&C was performing maintenance on control room east air intake rad monitor RM-6506A2. It was in HIGH alarm due to this maintenance procedure. The appropriate paperwork and Tech. Specs. were in place for performance of this maintenance.
  - An RDMS HIGH radiation alarm was subsequently received on control room east air intake rad monitor RM-6506A1. This resulted in an "Alpha" train CRFRM ESF actuation.
  - F7009, CTL RM MAKEUP AIR FLTR RECIRC MODE, is in alarm.
  - While the US was executing OS1252.02, AIRBORNE HIGH RADIATION, based on the HIGH rad signal on RM-6506A1, I&C reported that the HIGH rad signals on RM-6506A1 & RM-6506A2 were due to the maintenance activities. After consultation with HP, the US has determined that the CRFRM Actuation was spurious.
  - The US is now executing step 11 of OS1223.01, LOSS OF CONTROL ROOM VENTILATION OR AIR CONDITIONING.

#### Initiating Cue:

US to Primary Operator, **"Primary Operator (or student's name), Shutdown the "A" train of control room ventilation from filter recirculation mode and place the "A" train of the control room normal makeup and ventilation supply system in service per. OS1023.51. All procedural Prerequisites have been completed.**



JOB PERFORMANCE MEASURE JPM New Sc Rev. 0

Loss of Containment Instrument Air

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION
P=Perform			
S=Simulate	* denotes a critical step	* denotes a critical step	SAT UNSAT

---

**1. Task Number and Description:**

NA

**2. Conditions:**

- A. The plant is at about 95% power.
- B. SA-C-4B is tagged out of service for motor replacement.
- C. SA-C-4A has just tripped.
- D. The US has directed performance of OS1242.02, Loss Of Containment Instrument Air.

**3. Standards:**

Restore containment instrument air pressure.

**4. Student Materials:**

Copy of the Tear-Off sheet.  
OS1242.02, Rev 11

**5. Limitations on performance:**

Simulate all steps. Verbalize all actions to the evaluator.  
Even if requested, no Peer Checks will be provided during the JPM.

**6. References:**

Procedures:  
OS1242.02, Loss Of Containment Instrument Air

Sys	KA	Description	Value RO/SRO
078	K1.03	Knowledge of the physical connections and/or cause-effect relationships between the IAS and Containment Air	3.3/3.4
078	K3.01	Knowledge of the effect that a loss or malfunction of the IAS will have on the Containment air system	3.1/3.4
078	A3.012	Ability to monitor automatic operation of the IAS, including Air pressure	3.1/3.2

## PERFORMANCE CHECKLIST

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

**7. Setting:**

If performed as a pair with JPM Sg, Reset the simulator to IC# 82.

For stand alone performance, reset the simulator to IC #30 or any IC which contains the following:

- A. Initialize to any 100% IC and place the simulator in RUN.
- B. Reduce power to 95%
- C. Place SA-C-4B control switch to OFF and Tag
- D. Rack out the breaker for SA-C-4B as Follows:  
SELECT Component Remote Functions  
SELECT SERVICE AIR (Component)  
DOUBLE CLICK cSAC4B, SA Compressor 4b 460V MCC E631 D95  
SELECT RACKOUT  
INSERT
- E. Trip SA-C-4A as Follows:  
SELECT Component Remote Functions  
SELECT SERVICE AIR (Component)  
DOUBLE CLICK cSAC4A, SA Compressor 4A 460V MCC E531 D93  
SELECT RACKOUT  
INSERT
- F. Place the simulator in FREEZE.

**8. Safety Considerations:**

None.

**9. Approximate Completion Time:**

10 mins

**10. Directions to the Student:**

Evaluator gives Tear-Off sheet to the student

Initial Conditions:

- 1. You are the Secondary Operator
- 2. SA-C-4B is tagged out due to a motor replacement.
- 3. SA-C-4A has just tripped.

**11. Initiating Cue:**

US to Secondary Operator, "**Secondary Operator (or student's name), Due to the loss of the only operating Containment Air Compressor, perform the required actions of ON1242.02, Loss Of Containment Instrument Air.**"



**DATA SHEET FOR JPM Sc**

**CUE:** If the student requests a Peer Check at any time during the JPM, respond: **“No one is available to peer check your actions. Please continue with the task”.**

- 1. Start time \_\_\_\_\_ Initiating cue read
- 2. P Check Containment Instrument Air System:

**NOTE:** The performance of either bulleted step below will allow transition to the RNO.

- |   |   |       |       |
|---|---|-------|-------|
| <ul style="list-style-type: none"> <li>• Containment instrument air pressure - GREATER THAN 95 PSIG AND INCREASING</li> </ul> | <ul style="list-style-type: none"> <li>• Checks Containment instrument air pressure - GREATER THAN 95 PSIG AND INCREASING, answer is; No</li> </ul> | _____ | _____ |
| OR  |   |       |       |
| <ul style="list-style-type: none"> <li>• Containment instrument air compressors - BOTH RUNNING</li> </ul>                     | <ul style="list-style-type: none"> <li>• Checks Containment instrument air compressors - BOTH RUNNING, answer is; None running.</li> </ul>          | _____ | _____ |

- |     |   |  |                              |       |       |
|-----|---|--|------------------------------|-------|-------|
| *3. | P | Perform The following:   | Student refers to Step 1 RNO | _____ | _____ |
|     |   | a. Cross connect containment instrument air system with instrument air by opening the following valve: | *a. Opens IA-V530            | _____ | _____ |
|     |   | <ul style="list-style-type: none"> <li>• IA-V530</li> </ul>  |                              |       |       |

**NOTE:** The following step is a long-term action and is met by determining instrumentation/MPCS points that will be used

- |   |  |       |       |
|---|--|-------|-------|
| <ul style="list-style-type: none"> <li>• Monitor containment pressure for instrument air header leakage.</li> </ul> | <ul style="list-style-type: none"> <li>• Monitors containment pressure for instrument air header leakage.</li> </ul> | _____ | _____ |
|---|--|-------|-------|

**CUE:** When directed to cycle breaker, respond: **“Understand, cycle the breaker for SA-C-4A at MCC 531, Node <D93>.” Verify that the control switch for SA-C-4A is in OFF.**

- |     |   |   |  |       |       |
|-----|---|---|--|-------|-------|
| *4. | P | IF a compressor has tripped, reset the compressor by cycling the supply breaker:<br>SAC-4A MCC-531,Node <D93> | <ul style="list-style-type: none"> <li>• *Directs NSO to cycle the supply breaker for SAC-4A at MCC 531, Node &lt;D93&gt;</li> </ul> | _____ | _____ |
|-----|---|---|--|-------|-------|

**DATA SHEET FOR JPM Sc**

**CUE: Simulator Operator: Following verification that the control switch is in off; Delete Component Malfunction; csAC4A SA Compressor 4a 460V MCC E531 D93**

IF a compressor has tripped, reset the compressor by cycling the supply breaker:  
SAC-4B MCC-631,Node <D95>

- Recognizes that SAC-4B is tagged out. Breaker cannot be cycled.

\_\_\_\_\_

**NOTE:** With low IA header pressure indicated, the compressor will start when the control switch is taken to the AUTO position.

- Manually restart compressor.
- \*Places the SA-C-4A control switch to AUTO.

\_\_\_\_\_

**CUE: "The JPM is complete."**

5. Stop time \_\_\_\_\_ Time to complete the task  $\leq$  10 minutes.

Evaluator calculates the time to complete the task.

6. Obtain from student:  
Tear Off Sheets and any other training materials used in the performance of the JPM

\_\_\_\_\_

**PERFORMANCE SUMMARY**

Provide comments on unsatisfactory performance of an element/step or for deviation from performance as stated. Record interruptions in performance such as retraining, shift change, and processing of procedure changes. Recommend remedial training, if necessary.

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

## PERFORMANCE CHECKLIST

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

---

### Directions to the Student:

Initial Conditions:

1. You are the Secondary Operator
2. SA-C-4B is tagged out due to a motor replacement.
3. SA-C-4A has just tripped.

### Initiating Cue:

US to Secondary Operator, "**Secondary Operator (or student's name), Due to the loss of the only operating Containment Air Compressor, perform the required actions of ON1242.02, Loss Of Containment Instrument Air.**



JOB PERFORMANCE MEASURE JPM Sd Rev. 0

TRANSFER SERVICE WATER FROM THE COOLING TOWER TO THE OCEAN

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1. Task Number and Description

Position                      RO

SBK 0760103401      Switch From SW To Cooling Tower Operation

### 2. Conditions:

- A. The plant is operating at 100% power.
- B. On line maintenance/retests are complete on the Service Water system Train A pump house valves.
- C. The SM has directed that Train A Service Water be transferred back to the ocean from the cooling tower.
- D. All pre-starts are complete for the "A" Service Water pump (SW-P-41A).

### 3. Standards:

Return Service Water operation to the ocean per OS1016.05.

### 4. Student Materials:

Copy of Tear Off Sheet.

Copy of OS1016.05 Service Water Cooling Tower Operation, Rev. 10, Section 2 and 3 pages 5-9, Section 4.4 pages 26-28, Figures 1-5 pages 55-61, and Form L.

ODI-05 Pump Pre-start guidelines SW-P-41A page 49, Rev. 00

### 5. Limitations On Performance:

Perform all steps. Verbalize all actions to the evaluator.

Even if requested no Peer Checks will be provided during the JPM.

### 6. References:

Procedures:

- OS1016.05 Service Water Cooling Tower Operation

Sys	KA	Description	Value RO/SRO
076	A2.01	Ability to predict the impacts of loss of SW and use procedures to correct , control, or mitigate the consequences of those malfunctions or operations.	3.5/3.7
076	K3.01	Knowledge of the effect that a loss of SW will have on closed cooling water.	3.4/3.6

## JOB PERFORMANCE WORKSHEET

### 7. **Setting:**

If performed as a pair with JPM Sb, Reset to IC # 8.

For stand alone, Reset the simulator to IC #363 or any 100% IC which contains the following:

- A. Initialize to any 100% IC and place the simulator in RUN.
- B. Place Train A Service Water on the cooling tower per OS1016.05, Service Water Cooling Tower Operation.
- C. Insert component malfunction cSWV22 460V MCC E514 CR7 fail closed.
- D. Place SW-P-41C control switch in PTL.
- E. Insert component remote function cSWP41C 4.16KV Bus E5 AQ4 RF:rackout.
- F. Insert component remote function cSWV22 460V MCC E514 CR7 RF:open breaker.
- G. Insert malfunction mfSW001 SW-P-41A OC trip.

Place the simulator in RUN. Acknowledge all alarms. Place tags on SW-P-41C and SW-V-22 control switches.

### 8. **Safety Considerations:**

None.

### 9. **Approximate Completion Time:**

20 minutes

### 10. **Directions To The Student:**

Evaluator gives Tear Off sheet to the student.

Initial Conditions:

1. You are the Secondary Operator.
2. The following information is provided to you:
  - The plant is operating at 100% power.
  - On line maintenance/retests are complete on the Service Water system Train A pump house valves.
  - The SM has directed that Train A Service Water be transferred back to the ocean from the cooling tower.
  - All pre-starts are complete the "A" Service Water pump (SW-P-41A).

JOB PERFORMANCE WORKSHEET

**11. Initiating Cue:**

US to Secondary Operator, **“Secondary Operator (or student’s name), using OS1016.05, section 4.4, transfer Train A Service Water from the Cooling Tower to the ocean. All prerequisites, limitations, and pre-starts for SW-P-41A are complete.”**



**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

1. Start time \_\_\_\_\_ Initiating cue read

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

**NOTE:** Student may re-verify prerequisites, precautions & limitations and pre-starts.

**CUE:** If student asks, state: **“The fire protection system has not been used to fill the cooling tower, no chemistry sampling is required.”**

**CUE:** Inform student: **“Form L, Cooling Tower Flush NPDES Tracking Sheet has been recorded and tracked by US.”**

**NOTE:** Student may put up color graphic on the MPCS for Service water.

2.	P	Check SW Train B is aligned to the ocean.	Checks SW Train B is aligned to the ocean.	_____	_____
----	---	---	--	-------	-------

*3	P	Record initial Cooling tower level from either SW-LI-6139 or A1537 and record on Form L.	*Records initial Cooling tower level from either SW-LI-6139 or A1537 and record on Form L.	_____	_____
----	---	--	--	-------	-------

**CUE:** When student attempts to determine the position of SW-V-44, provide cue, **“SW-V-44 is open.”**

4.	P	If SW-V-44, SW isolation from the intake structure is closed, perform the following:	Investigates the position of SW-V-44	_____	_____
----	---	--	--------------------------------------	-------	-------

**CUE:** If the student begins to perform pump pre-start checks, provide cue, **“All pre-starts are complete.”**

**CUE:** If the student inquires about the prestart checklist requiring SW-V-20, 34, and 54 in a different position, respond: **“SW-V-20, 34, and 54 are repositioned by the performance of the procedure, continue with the procedure.”**

5.	P	Perform SW ocean pump pre-starts as determined by the US.	Inquires / Determines that the control room pre-start checks are complete.	_____	_____
----	---	---	--	-------	-------

*6.	P	Open SW-V-20, SW Train A to discharge structure.	*Opens SW-V-20, SW Train A to discharge structure.	_____	_____
-----	---	--	--	-------	-------

**PERFORMANCE CHECKLIST**

	ELEMENT/STEP	STANDARD	EVALUATION	
D=Discuss P=Perform S=Simulate	* denotes a critical step	* denotes a critical step	SAT	UNSAT

*7.	P	Close SW-V-34, SW Train A return to cooling tower.	*Closes SW-V-34, SW Train A return to cooling tower.	_____	_____
-----	---	--	--	-------	-------

*8.	P	Simultaneously place and hold control switch for SW-V54, cooling tower pump A discharge to throttle close and control switch for SW-V-56, cooling tower Train A spray header test to open until valves reposition	*Simultaneously manipulate switches until valves reposition as follows: <ul style="list-style-type: none"> <li>• SW-V-54 control switch to throttle close</li> <li>• SW-V-56 control switch to open</li> </ul>	_____	_____
-----	---	---	--	-------	-------

**CUE:** If requested to make a plant announcement, inform the student; **“The announcement for starting Service Water pump 41A has been made.”**

**CUE:** If informed that the cooling tower basin low level alarm has been received, inform student; **“Copy, low cooling tower basin level. I will dispatch a field operator to initiate fill of the cooling tower basin.”**

*9.	P	Start the desired Train A ocean SW pump.	*Starts SW-P-41A.	_____	_____
-----	---	--	-------------------	-------	-------

**CUE:** If student informs US that SW-P41A tripped, respond; **“Continue with the procedure.”**

10.	P	Verify the selected SW pump discharge valve opens.	Recognizes SW-V-2 not open and SW-P-41A tripped	_____	_____
-----	---	--	---	-------	-------

*11.	P	In accordance with caution prior to step 4.4.9: Reopen SW-V-54	*Re-opens SW-V-54	_____	_____
------	---	---	-------------------	-------	-------

**CUE:** **“The JPM is complete.”**

12.	Stop time _____	Time to complete task ≤ 20 minutes
-----	-----------------	------------------------------------

Evaluator calculates time to complete task

13.	Obtain from student: Tear Off sheets and any other training materials used in performance of this JPM.	_____	_____
-----	---	-------	-------



## TEAR OFF SHEET FOR LOIT JPM Sd

### Directions To The Student:

Initial Conditions:

1. You are the Secondary Operator.
2. The following information is provided to you:
  - The plant is operating at 100% power.
  - On line maintenance/retests are complete on the Service Water system Train A pump house valves.
  - The SM has directed that Train A Service Water be transferred back to the ocean from the cooling tower.
  - All pre-starts are complete for the "A" Service Water pump (SW-P-41A).

### Initiating Cue:

US to Secondary Operator, "**Secondary Operator (or student's name), using OS1016.05, section 4.4, transfer Train A Service Water from the Cooling Tower to the ocean. All prerequisites, limitations, and pre-starts for SW-P-41A are complete.**



JOB PERFORMANCE MEASURE JPM Se Rev. 0

LOWER SI ACCUMULATOR LEVEL

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1.0 Task Number and Description

Position RO

SBK 0060100201 Monitor The Safety Injection System

### 2.0 Conditions:

2.1 The "A" Accumulator Level has increased to above the Technical Specification Limit due to containment / system temperature increase.

### 3.0 Standards:

Decrease the "A" Accumulator level to within the limitations of Technical Specifications. (6121 to 6596 gallons at 585 to 664 psig)

### 4.0 Student Materials:

Copy of Tear Off Sheet.

Copy of OS1005.05 Safety Injection System Operation Rev. 12, Pages 32-34.

### 5.0 Limitations On Performance:

Perform all steps. Verbalize all actions to the evaluator.

Even if requested no Peer Checks will be provided during the JPM.

### 6.0 References:

Procedures:

- OS1005.05 Safety Injection System Operation

Technical Specifications:

- 3.5.1.1 ECCS Accumulators – Hot Standby, Startup, and Power Operation

Drawings

- 1-SI-B20455 Safety Injection System

Sys	KA	Description	Value RO/SRO
006	A1.13	Ability to predict and/or monitor (to prevent exceeding design basis limits) accumulator pressure, level, boron concentration.	3.5/3.7

---

JPM Se

## JOB PERFORMANCE WORKSHEET

### 7.0 **Setting:**

If performed as a pair with JPM Sf, Reset to IC # 83.

For stand alone, Reset the simulator to any 100%IC which contains the following:

- A. Initialize to an IC at 100% power.
- B. Raise "A" Accumulator level to > 6473 Gallons. Verify F5498, SI Accumulator Level High alarm is in.
- C. Use "GD ACCUMS" on MPCS to view Accumulator level and pressure "A" points.
- D. Verify "A" Accumulator pressure is 640- 660 psig., or adjust as necessary.
- E. Using Safety Injection Local Panel, OPEN SI-V-67.
- F. Freeze the simulator.

### 8.0 **Safety Considerations:**

None.

### 9.0 **Approximate Completion Time:**

20 minutes

### 10.0 **Directions To The Student:**

Evaluator gives Tear Off sheet to the student.

Initial Conditions:

1. You are the Primary Operator and you are going to lower the "A" Accumulator level to within limits of Tech. Specs. You may use MPCS Group Display "GD ACCUMS" to view Accumulator level and pressure "A" points or SVD A0413 for "A" Accumulator level.
2. The following information is provided to you:
  - The "A" Accumulator level has increased due to normal system heatup.
  - All applicable prerequisites of OS1005.05 Safety Injection System Operation are complete.
  - The Primary NSO is standing by to support local valve manipulations.

### 11.0 **Initiating Cue:**

US to PSO "**Primary Operator (or student's name), lower the 'A' Accumulator level to 6400 gals., +/- 50 gals., using OS1005.05, "Safety Injection System Operation."**

## PERFORMANCE CHECKLIST

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

1. Start time \_\_\_\_\_ Initiating cue read

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

**CUE:** If the student inquires about consideration for initially raising accumulator pressure, respond; **“Pressure appears to be sufficient, continue with lowering level and monitor pressure as appropriate.”**

2.	P	If desired, PRESSURIZE the accumulator to be drained per Section 4.4, Pressurizing an Accumulator.	Determines that Accumulator pressure is sufficient to support the drain-down evolution.	_____	_____
----	---	--	---	-------	-------

**CUE:** If student requests leak testing status, respond, **“Check valve leak testing is not in progress.”**

3.	P	VERIFY that check valve leak testing is not in progress.	VERIFIES that check valve leak testing is not in progress.	_____	_____
----	---	--	--	-------	-------

4.	P	CHECK CLOSED/CLOSE SI-V-157, SI accumulator fill.	CHECKS CLOSED SI-V-157, SI accumulator fill.	_____	_____
----	---	---	--	-------	-------

5.	P	CHECK CLOSED/CLOSE SI-V-62, test line header isolation ORC.	CHECKS CLOSED SI-V-62, test line header isolation ORC.	_____	_____
----	---	---	--	-------	-------

6	P	CHECK CLOSED/CLOSE SI-V-131, test iso for SI cold legs 1,2,3,4 checks.	CHECKS CLOSED SI-V-131, test iso for SI cold legs 1,2,3,4.	_____	_____
---	---	--	--	-------	-------

**CUE:** If the student indicates that they would use an electronic database to determine valve locations for the following step, respond; **“The Primary NSO is standing by to perform local actions for SI-V-67 and 69.”**

\*7. P ALIGN the SI test header to the PDT by performing the following:

**CUE:** When the Primary NSO is directed to check open/open SI-V-67, provide repeat-back and respond: **“SI-V-67 has been opened.”**

		<ul style="list-style-type: none"> <li>• CHECK OPEN/OPEN SI-V-67, isolation for PDT and boron recovery storage tanks 66A and</li> </ul>	<ul style="list-style-type: none"> <li>• *Directs local actions to CHECK OPEN/OPEN SI-V-67, isolation for PDT and boron recovery storage</li> </ul>	_____	_____
--	--	---	---	-------	-------



**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform				
S=Simulate	* denotes a critical step	* denotes a critical step	SAT UNSAT	

---

66B. tanks 66A and 66B.

**CUE:** When the Primary NSO is directed to check closed/close SI-V-69, provide repeat-back and respond: **“SI-V-69 is closed.”**

- |   |  |       |       |
|---|--|-------|-------|
| <ul style="list-style-type: none"> <li>• CHECK CLOSED/CLOSE SI-V-69, test line isolation for RWST.</li> </ul> | <ul style="list-style-type: none"> <li>• Directs local actions to CHECK CLOSED/CLOSE SI-V-69, test line isolation for RWST.</li> </ul> | _____ | _____ |
|---|--|-------|-------|

**CUE:** If student inquires respond, **“SI test header pressure will not be monitored at this time.”**

- |     |   |   |  |       |       |
|-----|---|---|--|-------|-------|
| 8.  | P | If SI test line pressure is to be monitored, then UNLOCK and OPEN SI-V-61, SI-PI-929/PT-2491 isolation.   | Inquires / determines that SI test line pressure will not be monitored.                                      | _____ | _____ |
| *9  | P | OPEN SI-V-70, test line header isolation IRC.   | *OPENS SI-V-70, test line header isolation IRC.  | _____ | _____ |
| *10 | P | OPEN the valve for the accumulator to be drained: <ul style="list-style-type: none"> <li>• SI-V-15, accumulator A drain/fill isolation</li> </ul>   | *OPENS SI-V-15, accumulator A drain / fill isolation.  | _____ | _____ |
| *11 | P | CYCLE OPEN and CLOSED SI-V-62, test line header isolation ORC and MONITOR accumulator level and pressure.   | *CYCLES OPEN and CLOSED SI-V-62, test line header isolation ORC and MONITORS accumulator level and pressure. | _____ | _____ |
| *12 | P | When accumulator has been drained to the desired level, CLOSE the valve opened in step 4.6.9: <ul style="list-style-type: none"> <li>• SI-V-15, accumulator A drain/fill isolation</li> </ul> | *When “A” accumulator level is 6400 gals, +/- 50 gals, CLOSES SI-V-15, accumulator A drain/fill isolation.   | _____ | _____ |

**CUE:** **“The JPM is complete.”**

- |    |  |                                    |
|----|--|------------------------------------|
| 9. | Stop time _____                            | Time to complete task ≤ 20 minutes |
|    | Evaluator calculates time to complete task |                                    |

**PERFORMANCE CHECKLIST**

D=Discuss  
P=Perform  
S=Simulate

ELEMENT/STEP  
\* denotes a critical step

STANDARD  
\* denotes a critical step

EVALUATION  
SAT UNSAT

---

10. Obtain from student:  
Tear Off sheets and any other training  
materials used in performance of this  
JPM.

\_\_\_\_\_



## TEAR OFF SHEET FOR JPM Se

### **Directions To The Student:**

Initial Conditions:

1. You are the Primary Operator and you are going to lower the "A" Accumulator level to within limits of Tech. Specs. You may use MPCS Group Display "GD ACCUMS" to view Accumulator level and pressure "A" points or SVD A0413 for "A" Accumulator level.
2. The following information is provided to you:
  - The "A" Accumulator level has increased due to normal system heatup.
  - All applicable prerequisites of OS1005.05 Safety Injection System Operation are complete.
  - The Primary NSO is standing by to support local valve manipulations.

### **Initiating Cue:**

US to PSO **"Primary Operator (or student's name), lower the 'A' Accumulator level to 6400 gals., +/- 50 gals., using OS1005.05, "Safety Injection System Operation."**



JOB PERFORMANCE MEASURE JPM Sf Rev. 0  
EMERGENCY TRIP OF DIESEL GENERATOR 1B

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1.0 Task Number and Description:

Position: RO

0640402501 Restore off-site power to Bus E5/E6

### 2.0 Conditions:

- A. Bus E6 was being supplied by the RAT (Reserve Auxiliary Transformer) to support a scheduled UAT (Unit Auxiliary Transformer) breaker inspection. The tagging clearance for the UAT breaker had not been started.
- B. A failure on the Bus 6 RAT breaker caused the breaker to trip open.
- C. DG "B" started and restored power to bus E6.
- D. Plant conditions have stabilized. The Shift Manager has directed the Unit Supervisor to transfer bus E6 to the UAT and shutdown DG "B".
- E. The SM and US have decided to use Attachment L of OS1246.01, LOSS OF OFFSITE POWER-PLANT SHUTDOWN, as guidance in restoring off-site power to bus E6.

### 3.0 Standards:

Attempt to restore off-site power to bus E6 and respond to degraded DG "B" condition as necessary.

### 4.0 Student Materials:

Copy of the Tear-Off Sheet.

Attachment L of OS1246.01, LOSS OF OFFSITE POWER-PLANT SHUTDOWN, Rev. 15

### 5.0 Limitations On Performance:

Simulate/Perform all steps. Verbalize all actions to the evaluator. Even if requested, no peer checks will be provided during the JPM.

### 6.0 References:

Procedures: Attachment L of OS1246.01, LOSS OF OFFSITE POWER-PLANT SHUTDOWN

Sys	KA	Description	Value RO/SRO
064	A4.07	Ability to manually operate and/or monitor in the control room: Transfer EDG with load to grid.	3.4/3.4

### 7.0 Setting:

---

## JOB PERFORMANCE WORKSHEET

### Simulator

If performed as a pair with JPM Se, Reset to IC # 83.

For stand alone, Initialize the simulator to any 100% power IC with the following setup:

- A. Place the simulator in RUN.
- B. Transfer Bus E6 to the RAT. Place the UAT breaker in Normal After Stop.
- C. Remove CS-P-2B from service by placing Danger Tags and racking out the breaker. CS-P-2B is removed from service so it does not interfere with the JPM. The CCP's start on a LOP.  
    SELECT: Component Remote Functions  
    SELECT: bkCS1P2B\_52 RACKOUT
- D. Insert component malfunction: bkEDE6RAT, 4160V Bus E6 A72 trip.
- E. Check for the following:
  - EPS sequenced loads start, as applicable with the plant remaining at power.
  - SGBD isolated.
  - SW-V-5 closed.
- F. Clear RAT amber light and PLACE RAT breaker in PTL

### **8.0 Safety Considerations:**

None

### **9.0 Approximate Completion Time:**

20 minutes

### **10.0 Directions To The Student(s):**

---

## JOB PERFORMANCE WORKSHEET

Evaluator gives Tear-Off sheet to the student.

Initial Conditions:

- 1) You are the Secondary Operator.
- 2) The following information is provided to you:
  - A. Bus E6 was being supplied by the RAT (Reserve Auxiliary Transformer) to support a scheduled UAT (Unit Auxiliary Transformer) breaker inspection. The tagging clearance for the UAT breaker had not been started.
  - B. A failure on the Bus 6 RAT breaker caused the breaker to trip open.
  - C. DG "B" started and restored power to bus E6.
  - D. Plant conditions have stabilized. The Shift Manager has directed the Unit Supervisor to transfer bus E6 to the UAT and shutdown DG "B".
  - E. The SM and US have decided to use Attachment L of OS1246.01, LOSS OF OFFSITE POWER-PLANT SHUTDOWN, as guidance in restoring off-site power to bus E6.

### 11.0 Initiating Cue:

Unit Supervisor to Secondary Operator, **"Restore offsite power to bus E6, via the UAT, using Attachment L of OS1246.01, LOSS OF OFFSITE POWER-PLANT SHUTDOWN."**



**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP  * denotes a critical step	STANDARD  * denotes a critical step	EVALUATION	
			SAT	UNSAT

1		Start time	Initiating cue read.		
<b>Evaluator CUE:</b> If the student asks if the grid is stable, respond: <b>“The grid is stable.”</b>					
2	P	IF AC emergency bus is deenergized, THEN restore offsite power as follows:	Recognizes that Bus 6 is energized and continues with step 2.	_____	_____
3	P	Raise DG frequency to 60.2 to 60.4 Hz.	Raises “B” DG frequency to 60.2 to 60.4 Hz.	_____	_____
*3	P	Place the DG synch. Selector switch in the RAT or UAT position.	*Places the Bus 6 synch. Selector switch in the UAT position.	_____	_____
*4	P	Reset RMO (Remote Manual Override).	*Resets “B” Train RMO.	_____	_____
5	P	Adjust EDG voltage to match INCOMING VOLTS with RUNNING VOLTS	Matches “B” EDG voltage $\pm$ 10 Kv	_____	_____
*6	P	Adjust EDG frequency so that the synch meter is going slowly in the fast direction.	* Adjusts “B” EDG speed as required.	_____	_____
*7	P	Close the RAT or UAT Transformer breaker when synchronized.	*Closes the Bus 6 UAT breaker when synchronized.	_____	_____
8	P	Place the synch selector switch in OFF.	Places the Bus 6 synch selector switch in OFF.	_____	_____

**Instructor NOTE:** The DB B Lube Oil Pressure Low and DG B Aux. Lube Oil Pump Running alarms should be initiated before the EDG can be unloaded.

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP  * denotes a critical step	STANDARD  * denotes a critical step	EVALUATION	
			SAT	UNSAT

**Evaluator NOTE:** Wait for the associated low lube oil pressure alarms to go into alarm prior to providing the following CUE.

**Evaluator CUE:** Before the student starts unloading the EDG, the NSO makes an urgent report to the Control Room via the radio, “ **Control Room this is the Rover NSO at the Bravo Emergency Diesel. There is a large amount of lube oil spraying from the Bravo diesel engine.**”

**Instructor CUE:** Run scenario: Len, DG Test  
 -or-  
 Insert malfunction: svo6608DGB f:1  
 Insert malfunction: svo6611DGB f:1

**NOTE:** On a low lube oil condition the emergency diesel engines should automatically trip. This scenario simulates failure of the automatic trip. Based on the VAS (Video Alarm System) alarm and report from the field, it is expected that the candidate will perform a manual emergency shutdown of the diesel generator.

9	P	Acknowledge the report from the field and the MPCS VAS (Video Alarm System) alarm condition.	Acknowledges the report from the field.	_____	_____
			Acknowledges the MPCS VAS alarm condition.	_____	_____

**Evaluator NOTE:** The intention of the JPM is for the student to identify and recommend/perform an emergency shutdown of EDG 1B.

**Evaluator CUE:** If the student recommends stopping the diesel generator, say: “**Perform an emergency shutdown of EDG 1B.**”

*10	P	Perform emergency shutdown of DG-1B by simultaneously pressing BOTH Emergency Stop pushbuttons.	*Performs an emergency shutdown of DG-1B by simultaneously pressing BOTH Emergency Stop pushbuttons.	_____	_____
-----	---	---	--	-------	-------

**Evaluator CUE:** “The JPM is complete.”

11		Stop time _____ Evaluator calculates the time to complete the task.	Start-Stop is <u>&lt;</u> 20 minutes.		
----	--	--	---------------------------------------	--	--

**PERFORMANCE CHECKLIST**

D=Discuss  
P=Perform  
S=Simulate

ELEMENT/STEP

STANDARD

EVALUATION

\* denotes a critical step

\* denotes a critical step

SAT    UNSAT

---

12

Obtain from student:  
Tear Off sheets and any other  
training materials used in  
performance of this JPM.

\_\_\_\_\_

**PERFORMANCE SUMMARY**

Provide comments on unsatisfactory performance of an element/step or for deviation from performance as stated. Record interruptions in performance such as retraining, shift change, and processing of procedure changes. Recommend remedial training, if necessary.

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

## TEAR-OFF SHEET FOR JPM Sf

### Directions to the Student:

Initial Conditions:

- 1) You are the Secondary Operator.
- 2) The following information is provided to you:
  - F. Bus E6 was being supplied by the RAT (Reserve Auxiliary Transformer) to support a scheduled UAT (Unit Auxiliary Transformer) breaker inspection. The tagging clearance for the UAT breaker had not been started.
  - G. A failure on the Bus 6 RAT breaker caused the breaker to trip open.
  - H. DG "B" started and restored power to bus E6.
  - I. Plant conditions have stabilized. The Shift Manager has directed the Unit Supervisor to transfer bus E6 to the UAT and shutdown DG "B".
  - J. The SM and US have decided to use Attachment L of OS1246.01, LOSS OF OFFSITE POWER-PLANT SHUTDOWN, as guidance in restoring off-site power to bus E6.

### Initiating Cue:

Unit Supervisor to Secondary Operator, **"Restore offsite power to bus E6, via the UAT, using Attachment L of OS1246.01, LOSS OF OFFSITE POWER-PLANT SHUTDOWN."**



JOB PERFORMANCE MEASURE JPM Sg Rev. 0

RECOVER A DROPPED ROD

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

**1. Task Number and Description**

Position                      RO

SBK 0010400301      Operate single full length control rod (misalignment)

**2. Conditions:**

- A. The plant is at approximately 95% power following a dropped rod in control bank D (CBD) group 2, identified as H-8.
- B. The plant has been stabilized using turbine load control, with rod control in manual.
- C. I&C has completed replacing a blown fuse on the stationary gripper.

**3. Standards:**

Align the dropped rod with its bank per OS1210.05 Dropped Rod.

**4. Student Materials:**

Copy of Tear Off Sheet.  
Copy of OS1210.05 Dropped Rod Rev 13.

**5. Limitations On Performance:**

Perform all steps. Verbalize all actions to the evaluator.  
Even if requested no Peer Checks will be provided during the JPM.

**6. References:**

Procedures:

- OS1210.05 Dropped Rod

Technical Specifications:

- 3.1.1.1 SDM Tavg Greater Than 200°
- 3.1.3.1 Moveable Control Assemblies Group height
- 3.1.3.2 Moveable Control Assemblies Position Indication Systems
- 3.1.3.5 Shutdown Rod Insertion Limit
- 3.1.3.6 Control Rod Insertion Limit
- 3.2.1 Axial Flux Difference
- 3.2.4 Quadrant power Tilt Ratio

Drawings:

- 1-NHY-509049 Rod Control

## JOB PERFORMANCE WORKSHEET

Sys	KA	Description	Value RO/SRO
001	K4.09	Knowledge of CRDS design features and/or interlocks which provide for recovery of a dropped rod	3.9/4.1

**7. Setting:**

Simulator:

If performed as a pair with JPM Sc, Reset the simulator to IC# 82.  
For stand alone, Reset the simulator to IC# 300 or any 100% IC and reduce power to ~95% power. Complete simulator setup by performing the following:

- A. Insert malfunction mfCP018, Dropped Rod H-8.
- B. Place the simulator in RUN and stabilize the plant per OS1210.05
  1. Place rods in MANUAL.
  2. Match Tave/Tref by reducing turbine load.
  3. Acknowledge alarms.
- C. Verify Bank Demand Counters reflect expected plant conditions.
- D. Delete malfunction mfCP018, Dropped Rod H-8.

Place the simulator in RUN as long as needed to ensure all alarms are acknowledged prior to start of the JPM.

**8. Safety Considerations:**

None

**9. Approximate Completion Time:**

20 minutes

**10. Directions To The Student(s):**

Evaluator gives Tear Off sheet to the student.

Initial Conditions:

1. You are the Primary Operator. You are going to recover a dropped rod.
2. The following information is provided to you:
  - The plant is at approximately 95% power following a dropped rod in control bank D (CBD) group 2, identified as H-8.
  - The plant has been stabilized using turbine load control, with rod control in manual.
  - I&C has completed replacing a blown fuse on the stationary gripper.



JOB PERFORMANCE WORKSHEET

11. **Initiating Cue:**

US to Primary Operator, **“Primary Operator (or student’s name), we are at step 4 of OS1210.05, Dropped Rod. Continue with the procedure and recover the dropped rod.”**

## PERFORMANCE CHECKLIST

	ELEMENT/STEP	STANDARD	EVALUATION	
	D=Discuss P=Perform S=Simulate			
	* denotes a critical step	* denotes a critical step	SAT	UNSAT

1. Start time \_\_\_\_\_ Initiating cue read

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

**CUE:** Note prior to step 4 should be reviewed, if student contacts SM or RE for rod recovery recommendation, respond: **“Recover the dropped rod in an expeditious manner.”**

2.	P	Check rod control urgent failure alarm - RESET	Checks rod control urgent failure alarm - RESET		
		• D7746	• D7746	_____	_____
		• Local power cabinet	• Contacts NSO and Inquires about Local power cabinet alarm.	_____	_____
		• Local logic cabinet	• Contacts NSO and Inquires about Local logic cabinet alarm	_____	_____

**CUE:** When student requests the NSO to locally verify logic and power cabinet alarms, respond, **“There are currently no alarms on the logic or power cabinets.”**

*3.	P	Align rod control system for dropped rod recovery:			
		a. Place the rod bank selector switch to – Affected Bank Position	*a. Place the rod bank selector switch to – CBD	_____	_____
		b. Except for the dropped rod, place all the lift coil disconnect switches for the affected bank to – Rod Disconnected	*b. Places all the lift coil disconnect switches for the Control Bank D to – Rod Disconnected except for rod H-8	_____	_____
		c. Record the affected group step counter position.	c. Records the CBD group 2 step counter position	_____	_____

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

**CUE:** Due to differences between the simulator and the plant if student asks for direction on how to reset counter position, respond, "**Depress step counter reset pushbutton.**"

- |   |   |       |       |
|---|---|-------|-------|
| <p>d. Reset the affected group step counter to zero</p>   | <p>*d. Resets the CBD group 2 step counter position to zero</p>   | _____ | _____ |
| <p>e. Hold and maintain the pulse to analog converter Auto-Man switch in Man until rod withdrawal is complete</p> | <p>*e. Directs NSO to hold and maintain the pulse to analog converter Auto-Man switch in Man until rod withdrawal is complete</p> | _____ | _____ |

**CUE:** When directed NSO to Primary Operator, "**I copy, hold the P/A converter Auto-Man switch to Man until rod withdrawal is complete.**"

**NOTE: Simulator Operator** Place P/A converter switch in Man as follows:  
 Select Local Panels  
 Select Rod Drive System  
 Select Pulse to Analog Converter  
 Select Hold in Manual

**CUE:** NSO to Primary Operator, "**The P/A converter Auto-Man switch is being held in Man.**"

- |  |  |       |       |
|--|--|-------|-------|
| <p>*4. P Withdraw the dropped rod until the step counter reaches the previously recorded position:</p> | <p>a. Verify that the dropped rod is the only rod moving by DRPI</p> | _____ | _____ |
|  | <p>*a. Verifies that only rod H-8 is withdrawing.</p>                |       |       |

**CUE:** When asked for method of maintaining Tav<sub>g</sub> on program, US to Primary Operator, "**The Secondary Operator will maintain Tav<sub>g</sub> with turbine load adjustments while you withdraw the control rod.**"

- |  |  |       |       |
|--|--|-------|-------|
| <p>b. Maintain programmed Tav<sub>g</sub> using boration and/or turbine loading as recommended by Reactor Engineering.</p> | <p>b. Discusses controlling Tav<sub>g</sub> with the US.</p> | _____ | _____ |
|--|--|-------|-------|

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT	
--------------------------------------	---	---------------------------------------	-------------------------	--

	c. Withdraw rod to previously recorded position.	*c. Withdraws rod H-8 to previously recorded position.	_____	_____
*5.	P Align rod control system for normal operation:			
	a. Return the Pulse to Analog Converter Auto-Man switch to Auto.	*a. Directs NSO to return the Pulse to Analog Converter Auto-Man switch to Auto.	_____	_____

**CUE:** NSO to Primary Operator, **“I copy, return The P/A converter Auto-Man switch to Auto.”**

**NOTE: Simulator Operator** Place P/A converter switch in Auto as follows:  
 Select Local Panels  
 Select Rod Drive System  
 Select Pulse to Analog Converter  
 Select Hold in Automatic

**CUE:** NSO to Primary Operator, **“The P/A converter Auto-Man switch is in Auto.”**

	b. Reset the rod control urgent failure alarm by depressing the rod control alarm reset pushbutton.	*b. Depresses the rod control alarm reset pushbutton.	_____	_____
	c. Place all the lift coil disconnect switches to Rod Connect.	*c. Places all the lift coil disconnect switches for Control Bank D to Rod Connect.	_____	_____
	d. Return Rod Bank Selector Switch to Man.	*d. Returns Rod Bank Selector Switch to Man.	_____	_____
	e. If necessary, reset the power range rate trip.	e. If necessary, rotates rate mode reset switch to reset for affected NIs.	_____	_____

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT	
--------------------------------------	---	---------------------------------------	-------------------------	--

6.	P Check the dropped rod is aligned with affected bank	Checks that rod H-8 is realigned to CBD group 2 rod height within allowable tolerances (+/- 12 steps).	_____	_____
----	---	--	-------	-------

**CUE: "The JPM is complete."**

7.	Stop time _____  Evaluator calculates time to complete task	Time to complete task ≤ 20 minutes		
----	---	------------------------------------	--	--

8.	Obtain from student: Tear Off sheets and any other training materials used in performance of this JPM.		_____	
----	---	--	-------	--



## TEAR OFF SHEET FOR JPM Sg

### Directions To The Student:

Initial Conditions:

1. You are the Primary Operator. You are going to recover a dropped rod.
2. The following information is provided to you:
  - The plant is at approximately 95% power following a dropped rod in control bank D (CBD) group 2, identified as H-8.
  - The plant has been stabilized using turbine load control, with rod control in manual.
  - I&C has completed replacing a blown fuse on the stationary gripper.

### Initiating Cue:

US to Primary Operator, **“Primary Operator (or student’s name), we are at step 4 of OS1210.05, Dropped Rod. Continue with the procedure and recover the dropped rod.”**



JOB PERFORMANCE MEASURE JPM Sh Rev. 0

START HYDROGEN RECOMBINERS

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR



## JOB PERFORMANCE WORKSHEET

### 1.0 Task Number and Description:

Position: RO

0280500201 Start 'A' H<sub>2</sub> Recombiner From The Main Control Room.

### 2.0 Conditions:

- A. A reactor trip with SI occurred from 100% power due to a large break LOCA.
- B. The US transitioned through E-0, E-1, ES-1.3, and back to E-1 and is now at step 17.
- C. Hydrogen concentration in containment is 3.4%

### 3.0 Standards:

Place a hydrogen recombiner in service.

### 4.0 Student Materials:

Copy of the Tear-Off Sheet.

Copy of OS1023.40, Hydrogen Recombiner Operation, Rev. 7, Chg. 2.  
Calculator.

### 5.0 Limitations On Performance:

Simulate/Perform all steps. Verbalize all actions to the evaluator.  
Even if requested, no Peer Checks will be provided during the JPM.

### 6.0 References:

Procedures:

- E-1, Loss of Reactor or Secondary Coolant
- OS1023.40, Hydrogen Recombiner Operation.

Sys	KA	Description	Value RO/SRO
028	A2.02	LOCA condition and concern over hydrogen.	3.5/3.9
028	A2.03	The hydrogen/air concentration in excess of limit flame propagation or detonation with resulting equipment damage in containment.	3.4/4.0
2.1	2.1.23	Ability to perform specific system and integrated plant procedures during all modes of operation.	4.3/4.4
2.1	2.1.8	Ability to coordinate personnel activities outside the control room.	3.4/4.1
2.1	2.1.31	Ability to locate control room switches, controls, and indications, and determine that they are correctly reflecting the desired plant lineup.	4.6/4.3

## JOB PERFORMANCE WORKSHEET

### 7.0 Setting:

If performed as a pair with JPM Sd, reset the simulator to IC-82. When run as a pair, simulator conditions will not reflect the conditions identified below.

If running as a stand alone JPM, Reset the simulator to IC #356 or any 100% IC which contains the following:

- A. Initialize to the 100% IC and place simulator in RUN.
- B. Insert malfunction mfRC024A RCS Cold Leg 12 LOCA (double ended shear).
- C. Run the simulator while performing the following per E-0 and E-1:
  1. Trip RCPs.
  2. Reset SI.
  3. Throttle EFW back to approximately 150 gpm per generator.
  4. Shutdown both EDGs. Close SW-V16, and 18. Reset both engines.
  5. Swap to cold leg recirculation when RWST level decreases to 120,478 gallons IAW ES-1.3. Insert component remote function mvCS1LCV112D 460V MCC-512 breaker open and mvCS1LCV-112E 460V MCC-612 breaker open when required in ES-1.3.
  6. Complete the actions of E-1 through step 17.
  7. Using panel graphics display sections PGR06A and PGR06B insert overrides on Hydrogen Analyzer A meter AND Hydrogen Analyzer B meter. Override to 3.4 for both meters.
  8. Insert the following overrides Safety Injection Analog outputs for Containment pressure:
    - IOOZMAOSIPI2576 Final Value=4
    - IOOZMAOSIPI2577 Final Value=4
    - IOOZMAOSIPR934B Final Value=4
    - IOOZMAOSIPR934R Final Value=4
    - IOOZMAOSIPR935B Final Value=4
    - IOOZMAOSIPR935R Final Value=4
    - IOOZMAOSIPI934 Final Value=4
    - IOOZMAOSIPI935 Final Value=4
    - IOOZMAOSIPI936 Final Value=4
    - IOOZMAOSIPI937 Final Value=4
- D. Place the simulator in FREEZE.

The **simulator must be in RUN** to allow the PWR OUT meter to respond to the potentiometer.

**Verify the "PWR OUT" potentiometer is at MINIMUM prior to beginning the JPM.**

### 8.0 Safety Considerations:

None

### 9.0 Approximate Completion Time:

20 minutes

## JOB PERFORMANCE WORKSHEET

### 10.0 Directions To The Student(s):

Evaluator gives Tear-Off sheet to the student.

Initial Conditions:

1. You are the Secondary Operator. You are going to place Hydrogen Recombiner 'A' in service.
2. The following information is provided to you:
  - A reactor trip with SI occurred from 100% power due to a large break LOCA.
  - The US transitioned through E-0, E-1, ES-1.3, and back to E-1.
  - The crew is presently at step 17 of E-1 Loss of Reactor or Secondary Coolant and they have checked containment H<sub>2</sub> concentration, which is 3.4 %.

### 11.0 Initiating Cue:

US to Secondary Operator, **“Secondary Operator (or student’s name), we are in E-1, and containment hydrogen concentration is presently 3.4%. Place Hydrogen Recombiner ‘A’ in service per OS1023.40, Hydrogen Recombiner Operation. Report to me when the recombinaer is in service.”**

## PERFORMANCE CHECKLIST

D=Discuss P=Perform S=Simulate	ELEMENT/STEP	STANDARD	EVALUATION	
	* denotes a critical step	* denotes a critical step	SAT	UNSAT

**NOTE:** When the student is ready to begin place the simulator in run.

1. Start time \_\_\_\_\_ Initiating cue read.

**CUE:** If the student request a Peer Check at any time during the JPM, respond: **“No one is available to peer check your actions. Please continue with the task”.**

**CUE:** If asked by the student, **“The electrical lineup has been completed”.**

2.	P	Verify the white PWR. IN AVAIL. light is energized.	Verifies the PWR. IN AVAIL. light is energized.	_____	_____
3.	P	Set the PWR. ADJ. potentiometer to zero.	Turns PWR ADJ pot to 000.	_____	_____
*4.	P	Place the PWR. OUT SW. switch to the ON position and VERIFY that the red light on the switch plate comes on.	<ul style="list-style-type: none"> <li>* • Moves switch to ON position.</li> </ul>	_____	_____
			<ul style="list-style-type: none"> <li>• Verifies the red light is on.</li> </ul>	_____	_____

**CUE:** At each power level, inform the student; **“The stated time has elapsed.”**

*5.		Energize the Hydrogen Recombiner heater by PERFORMING the following:	Energizes the recombiner:		
	P	a. TURN the PWR. ADJ. Potentiometer clockwise until 5 kW is indicated on the PWR. OUT meter. MAINTAIN the 5 kW value for at least 10 minutes.	*a. Turns the PWR ADJ pot clockwise until 5 kW is indicated.	_____	_____
	P	b. TURN the PWR. ADJ. Potentiometer clockwise until 10 kW is indicated on the PWR. OUT meter. MAINTAIN the 10 kW value for at least 10 minutes.	*b. Turns the PWR ADJ pot clockwise until 10 kW is indicated.	_____	_____

**PERFORMANCE CHECKLIST**

D=Discuss  
P=Perform  
S=Simulate

ELEMENT/STEP  
\* denotes a critical step

STANDARD  
\* denotes a critical step

EVALUATION  
SAT    UNSAT

P	c. TURN the PWR. ADJ. Potentiometer clockwise until 20 kW is indicated on the PWR. OUT meter. MAINTAIN the 20 kW value for at least 5 minutes.	*c. Turns the PWR ADJ pot clockwise until 20 kW is indicated.	_____	_____
---	--	---	-------	-------

P	d. DETERMINE the recombiner power setting per Form A, Power Out Setpoint Calculation.	d. Refers to Form A.	_____	_____
---	---	----------------------	-------	-------

P	e. Calculate the H <sub>2</sub> recombiner power setpoint by performing the following:			
---	--	--	--	--

**CUE:** When the student locates any of the required pressure instruments, cue the student: **“Containment pressure is 4 psig.”**

P	DETERMINE the current containment pressure from SI-PI-934 or SI-PI-935, MCB containment pressure indicators.	• Determines the current cntmnt pressure from SI-PI-934 or 935.	_____	_____
---	--	---	-------	-------

P	Current Containment Pressure + 14.7 psi = psia	* • Converts cntmnt pressure to psia and records on data sheet (= 18.7 psia).	_____	_____
---	--	---	-------	-------

P	• Using containment absolute pressure, pre-accident containment average temperature and Figure 2, Recombiner Power Correction Factor Curve determine the Pressure Factor (C <sub>p</sub> ).	* • Determines C <sub>p</sub> and Records on data sheet - (C <sub>p</sub> = 1.17 - 1.20).  Enter student C <sub>p</sub> value: C <sub>p</sub> = _____	_____	_____
---	---	--	-------	-------

P	• MULTIPLY the Pressure Factor (C <sub>p</sub> ) by Reference Power (45.24 kW).  (C <sub>p</sub> ) x 45.24 = Power Setting kW	* • Multiplies C <sub>p</sub> by the reference power. Records on data sheet - (52.9 – 54.3 kW).  Enter student KW value: KW = _____	_____	_____
---	---	--	-------	-------

**PERFORMANCE CHECKLIST**

D=Discuss	ELEMENT/STEP	STANDARD	EVALUATION	
P=Perform			SAT	UNSAT
S=Simulate	* denotes a critical step	* denotes a critical step		

---

**CUE:** If the student requests a second person verification, respond: **“For the purpose of this evaluation, a second verification will not be performed. Please continue with the procedure.”**

- |   |   |   |       |       |
|---|---|---|-------|-------|
|   | <ul style="list-style-type: none"> <li>• Have a second person VERIFY the power setting calculation.</li> </ul>                            | <ul style="list-style-type: none"> <li>• Requests second person verification.</li> </ul>        | _____ | _____ |
| P | f. Turn the PWR. ADJ. potentiometer clockwise until the power setpoint, as calculated in Step 4.2.4.4, is indicated on the PWR OUT meter. | *f. Turns the PWR ADJ pot clockwise until the power setpoint is indicated on the PWR OUT meter. | _____ | _____ |

**CUE:** When student mentions that conference with the TSC is necessary to determine recombiner effectiveness, inform the student, **“The SM is aware of this and in contact with the TSC on this matter.”**

- |  |  |   |       |       |
|--|--|---|-------|-------|
|  | <ul style="list-style-type: none"> <li>g. CONFER with the TSC to determine recombiner effectiveness and the need to make adjustments to recombiner power.</li> </ul> | <ul style="list-style-type: none"> <li>g. Attempts to confer with the TSC.</li> </ul> | _____ | _____ |
|--|--|---|-------|-------|

**CUE:** **“The JPM is complete.”**

- |    |   |   |       |  |
|----|---|---|-------|--|
| 6. | Stop time _____<br><br>Evaluator calculates the time to complete the task.                                  | Time to complete the task ≤ 20 minutes. |       |  |
| 7. | Obtain from student:<br>Tear Off Sheets and any other training materials used in the performance of the JPM |   | _____ |  |

**PERFORMANCE SUMMARY**

Provide comments on unsatisfactory performance of an element/step or for deviation from performance as stated. Record interruptions in performance such as retraining, shift change, and processing of procedure changes. Recommend remedial training, if necessary.

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

## TEAR-OFF SHEET FOR LOIT JPM Sh

### Directions to the Student:

Initial Conditions:

1. You are the Secondary Operator. You are going to place Hydrogen Recombiner 'A' in service.
2. The following information is provided to you:
  - A reactor trip with SI occurred from 100% power due to a large break LOCA.
  - The US transitioned through E-0, E-1, ES-1.3, and back to E-1.
  - The crew is presently at step 17 of E-1 Loss of Reactor or Secondary Coolant and they have checked containment H<sub>2</sub> concentration, which is 3.4 %.

### Initiating Cue:

US to Secondary Operator, **"Secondary Operator (or student's name), we are in E-1, and containment hydrogen concentration is presently 3.4%. Place Hydrogen Recombiner 'A' in service per OS1023.40, Hydrogen Recombiner Operation. Report to me when the recombinder is in service."**





## JOB PERFORMANCE WORKSHEET

### 1. Task Number and Description

SBK 0010101604      Locally Operate Reactor Trip Breaker  
SBK 0010150204      Trip Rod Drive Motor Generator Sets  
SBK 0120100104      Locally Trip Reactor trip Breaker and Bypass Breaker

### 2. Conditions:

- A. The reactor has a trip demand and should have tripped but both reactor trip breakers are still closed and control rods are withdrawn.
- B. The reactor trip bypass breakers are open and racked out.
- C. The Primary Operator has unsuccessfully tried to manually trip the reactor from both reactor trip switch locations on the MCB.
- D. The control room is executing FR-S.1 and they are using the Operator Action Summary page to have you locally trip the reactor.

### 3. Standards:

Simulate locally tripping the reactor.

### 4. Student Materials:

Copy of Tear Off Sheet.

### 5. Limitations On Performance:

Simulate all steps. Verbalize all actions to the evaluator.  
Even if requested no Peer Checks will be provided during the JPM.

### 6. References:

Procedures:

- FR-S.1 Response To Nuclear Power Generation/ATWS.
- NAP-402 Conduct Of Operations

Sys/Proc	KA	Description	Value RO/SRO
007- Reactor Trip	EA2.04	If the reactor should have tripped but has not, carry out actions in ATWS EOP.	4.4/4.6
2.4- Emergency Proc./Plan	2.4.35	Knowledge of local NSO tasks during emergency operations.	3.8/4.0

## JOB PERFORMANCE WORKSHEET

**7. Setting:**

In-Plant. Train 'A' Essential Switchgear Room.

**8. Safety Considerations:**

Do **NOT** permit opening of reactor trip breaker cubicles or rod drive MG set cubicles.

**9. Approximate Completion Time:**

5 minutes

**10. Directions To The Student:**

Evaluator gives Tear Off sheet to the student.

Initial Conditions:

- A. You are the Secondary NSO. You are going to simulate locally tripping the reactor.
- B. The following information is provided to you:
  - 1. The reactor has a trip demand and should have tripped but both reactor trip breakers are still closed and control rods are withdrawn.
  - 2. The reactor trip bypass breakers are open and racked out.
  - 3. The Primary Operator has unsuccessfully tried to manually trip the reactor from both reactor trip switch locations on the MCB.
  - 4. The control room is executing FR-S.1 and they are using the Operator Action Summary page to have you locally trip the reactor.

**11. Initiating Cue:**

US to Secondary NSO, **"Secondary NSO (or student's name), locally open the reactor trip breakers."**

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

1. P Start time \_\_\_\_\_ Initiating cue read

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

**CUE:** If required upon arrival at the reactor trip breakers, US to Secondary NSO, **“Secondary NSO, locally open the reactor trip breakers.”**

**NOTE:** **CAUTION DO NOT** allow the student to depress the trip plate because this will cause an actual reactor trip.

**CUE:** Evaluator to student, **“The reactor trip breakers indicate closed.”**

2. S Open the reactor trip breakers locally:

a. Depress red trip plate for reactor trip breaker RTA. a. Simulates depressing red trip plate for reactor trip breaker RTA. \_\_\_\_\_

**CUE:** When student simulates depressing red trip plate for reactor trip breaker RTA, evaluator to student, **“The reactor trip breaker does not open.”**

Depress red trip plate for reactor trip breaker RTB. b. Simulates depressing red trip plate for reactor trip breaker RTB. \_\_\_\_\_

**CUE:** When student simulates depressing red trip plate for reactor trip breaker RTB, evaluator to student, **“The reactor trip breaker does not open.”**

3. S Inform the control room that the reactor trip breakers will not open. Inform the control room that the reactor trip breakers will not open. \_\_\_\_\_

**CUE:** US to Secondary NSO, **“I copy, the reactor trip breakers will not open. Open the A & B rod drive MG set motor and generator breakers.”**

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP  * denotes a critical step	STANDARD  * denotes a critical step	EVALUATION  SAT UNSAT
--------------------------------------	---	---	-----------------------------

**NOTE: CAUTION DO NOT** allow the student to actually open or jar the MG set breakers.

**NOTE:** The order in which the breakers are opened is not critical. At least one breaker being opened (motor or generator) for each MG set is critical.

*4.	S Open the input (motor) and/or output (generator) for both MG sets:	*a. Simulates opening "A" MG set motor and/or generator breaker.	_____	_____
	*a. Open "A" MG set motor and/or generator breaker.			

**CUE:** When student simulates rotating each breaker handle switch to TRIP, evaluator to student, "**Red light extinguishes and green light illuminates. The breaker opens.**"

*b. Open "B" MG set motor and/or generator breaker.	*b. Simulates opening "B" MG set motor and/or generator breaker.	_____	_____
---	--	-------	-------

**CUE:** When student simulates rotating each breaker handle switch to TRIP, evaluator to student, "**Red light extinguishes and green light illuminates. The breaker opens.**"

5.	S Inform the control room that the input and output breakers for both rod drive MG sets are open.	Informs the control room that the input and output breakers for both rod drive MG sets are open.	_____	_____
----	---	--	-------	-------

**CUE:** US to Secondary NSO, "**I copy, the input and output breakers for both rod drive MG sets are open. All control rods are inserted.**"

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

**CUE: "The JPM is complete."**

- |    |   |                                    |       |       |
|----|---|------------------------------------|-------|-------|
| 6. | Stop time _____   | Time to complete task ≤ 20 minutes |       |       |
|    | Evaluator calculates time to complete task                            |                                    |       |       |
| 7. | Obtain from student:<br>Tear Off sheets and any other materials used. |                                    | _____ | _____ |



## TEAR OFF SHEET FOR JPM In-Plant 'A'

### Directions To The Student:

- A. You are the Secondary NSO. You are going to simulate locally tripping the reactor.
- B. The following information is provided to you:
  - 1. The reactor has a trip demand and should have tripped but both reactor trip breakers are still closed and control rods are withdrawn.
  - 2. The reactor trip bypass breakers are open and racked out.
  - 3. The Primary Operator has unsuccessfully tried to manually trip the reactor from both reactor trip switch locations on the MCB.
  - 4. The control room is executing FR-S.1 and they are using the Operator Action Summary page to have you locally trip the reactor.

### Initiating Cue:

US to Secondary NSO, **"Secondary NSO (or student's name), locally open the reactor trip breakers."**





IN-PLANT JOB PERFORMANCE MEASURE 'B' Rev. 0

HYDROGEN ANALYZER LOCAL OPERATION

Student Name: \_\_\_\_\_ LMS #: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_

SAT    UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

### 1. Task Number and Description

SBK 0280101104 Align Hydrogen Analyzer to the Analyze Mode

### 2. Conditions:

- A. The reactor tripped from 100% power due to an LOP.
- B. SI has actuated.
- C. The US transitioned from ECA-0.0 to ECA-0.2 after energizing both emergency buses from the EDGs. Step 9 of ECA-0.2 is complete, permitting implementation of FRPs as necessary.
- D. Core exit thermocouples are 1150°F; therefore we have a valid red path on core cooling. The crew transitioned to FR-C.1, Response to Inadequate Core Cooling.
- E. Both hydrogen analyzers have been in standby for > 6 hours.

### 3. Standards:

Simulate placing the hydrogen analyzer in the ANALYZE mode per OS1023.71, Operation of the H<sub>2</sub> Analyzers.

### 4. Student Materials:

Copy of Tear Off Sheet.  
Copy of OS1023.71, Operation of the H<sub>2</sub> Analyzers.

### 5. Limitations On Performance:

Simulate all steps. Verbalize all actions to the evaluator.  
Even if requested no Peer Checks will be provided during the JPM.

### 6. References:

Procedures:

- OS1023.71, Operation of the H<sub>2</sub> Analyzers
- FR-C.1, Response to Inadequate Core Cooling
- ECA-0.2 Loss Of All AC Power Recovery With SI Required

Technical Specifications:

- 3.6.1.1 Containment Integrity

## JOB PERFORMANCE WORKSHEET

Sys	KA	Description	Value RO/SRO
028-HRPS	A4.03	Ability to manually operate/monitor H <sub>2</sub> sampling and analysis of containment atmosphere	3.1/3.3

**7. Setting:**

Plant. H<sub>2</sub> Analyzer Room.

**8. Safety Considerations:**

Hearing protection.

**9. Approximate Completion Time:**

15minutes

**10. Directions To The Student:**

Evaluator gives Tear Off sheet to the student.

Initial Conditions:

A. You are the NSO on a team being dispatched from the OSC. You are going to simulate placing the hydrogen analyzer in the ANALYZE mode using OS1023.71, Operation of the H<sub>2</sub> Analyzers.

B. The following information is provided to you:

1. Core exit thermocouples are 1150°F; therefore we have a valid red path on core cooling. The crew transitioned to FR-C.1, Response to Inadequate Core Cooling.
2. Both hydrogen analyzers have been in standby for > 6 hours.

**11. Initiating Cue:**

OSC Coordinator to NSO, “**NSO (or student’s name), simulate placing Train A H<sub>2</sub> analyzer in the ANALYZE mode per OS1023.71, Operation of the H<sub>2</sub> Analyzers. I am sending the Chemistry tech to verify the sample vessel is installed and an HP tech to monitor radiation levels in the area.**”

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP  * denotes a critical step	STANDARD  * denotes a critical step	EVALUATION  SAT UNSAT
--------------------------------------	---	---	-----------------------------

**NOTE:** When student demonstrates the ability to obtain a controlled copy of OS1023.71, Operation of the H<sub>2</sub> Analyzers provide the student with a copy of OS1023.71, Operation of the H<sub>2</sub> Analyzers

1. P Start time \_\_\_\_\_ Initiating cue read

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

2. S Notify HP and Chemistry Simulates notifying HP and Chemistry \_\_\_\_\_

**CUE:** HP to NSO, **“General dose rates are 10 mr/hr and no indications of radiation streaming are present. It is safe to enter the hydrogen analyzer room and SCBA is not required.”**

**CUE:** Chemist to NSO, **“I understand, you are placing Train A H<sub>2</sub> analyzer in the ANALYZE mode. We have a half inch non-sparking wrench if needed.”**

**NOTE:** The requirements of OS1090.05 shall be waived during the implementation of EOPs. Configuration control will be re-established during recovery operations.

**CUE:** If student requests permission to unlock and open CGC-V3 and V10, provide cue, **“you have permission to unlock and open CGC-V3 and V10 per step 4.3.1.2 of OS1023.71.”**

\*3. S Unlock and open the following valves:  
\*a. Simulates unlocking and opening CGC-V3 \_\_\_\_\_

**CUE:** When student simulates unlocking and opening CGC-V3, evaluator to NSO, **“The valve is unlocked, the handwheel turns and the valve opens.”**

\*b. Simulates unlocking and opening CGC-V10 \_\_\_\_\_

**CUE:** When student simulates unlocking and opening CGC-V10, evaluator to NSO, **“The valve is unlocked , the handwheel turns and the valve opens.”**

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP  * denotes a critical step	STANDARD  * denotes a critical step	EVALUATION	
			SAT	UNSAT

*4.	S	Open CGC-V-12 hydrogen analyzer A train supply ORC isolation.	*Simulates opening CGC-V-12 hydrogen analyzer A train supply ORC isolation.	_____	_____
-----	---	---	---	-------	-------

**CUE:** When student simulates opening CGC-V12, evaluator to NSO, **“The handwheel turns and the valve opens.”**

**NOTE:** DO NOT allow the student to open the cabinet when simulating alignment of the sample vessel.

**CUE:** When asked, the Chemistry Tech reports, **“The sample vessel is installed in the Train A H<sub>2</sub> analyzer.”**

**CUE:** If the student inquires about gloves for operation of potentially hot sample vessel isolation valves, then provide cue, **“Gloves have been obtained.”**

*5	S	Open the following valves:	*a. Simulates opening CGC-V58 hydrogen analyzer A Train sample vessel inlet isolation.	_____	_____
----	---	----------------------------	--	-------	-------

**CUE:** When student simulates opening CGC-V58, evaluator to NSO, **“The handwheel turns and the valve opens.”**

			*b. Simulates opening CGC-V59 hydrogen analyzer A Train sample vessel outlet isolation.	_____	_____
--	--	--	---	-------	-------

**CUE:** When student simulates opening CGC-V59, evaluator to NSO, **“The handwheel turns and the valve opens.”**

*6.	S	Place the main power switch on CP-173A to ANALYZE	Simulates informing control room that main power switch at CP-173A must be placed to ANALYZE	_____	_____
-----	---	---	--	-------	-------

**CUE:** When NSO calls the control room, US to NSO, **“The main power switch has been placed in ANALYZE.”**

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

**CUE: "The JPM is complete."**

7. Stop time \_\_\_\_\_ Time to complete task ≤ 15 minutes

Evaluator calculates time to complete task

8. Obtain from student:  
Tear Off sheets and any other training materials used in performance of this JPM. \_\_\_\_\_



## TEAR OFF SHEET FOR In-Plant 'B'

### Directions To The Student:

- A. You are the NSO on a team being dispatched from the OSC. You are going to simulate placing the hydrogen analyzer in the ANALYZE mode using OS1023.71, Operation of the H<sub>2</sub> Analyzers.
- B. The following information is provided to you:
  1. Core exit thermocouples are 1150°F; therefore we have a valid red path on core cooling. The crew transitioned to FR-C.1, Response to Inadequate Core Cooling.
  2. Both hydrogen analyzers have been in standby for > 6 hours.

### Initiating Cue:

OSC Coordinator to NSO, **“NSO (or student’s name), simulate placing Train A H<sub>2</sub> analyzer in the ANALYZE mode per OS1023.71, Operation of the H<sub>2</sub> Analyzers. I am sending the Chemistry tech to verify the sample vessel is installed and an HP tech to monitor radiation levels in the area.”**





IN-PLANT JOB PERFORMANCE MEASURE 'C' Rev. 0

PERFORM LOCAL OPS TO SWAP CC PUMPS

Student Name: \_\_\_\_\_ DATE: \_\_\_\_\_

Evaluator Name: \_\_\_\_\_ DATE: \_\_\_\_\_

SAT      UNSAT

**OFFICIAL NRC EXAMINATION MATERIAL**  
**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT**  
**FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC**  
**INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TRAINING SUPERVISOR

## JOB PERFORMANCE WORKSHEET

**1. Task Number and Description**

SBK 0080102304 Perform local OPS To Swap CC Pumps

**2. Conditions:**

- A. Plant is at 100% power.
- B. CC-P-11A outboard motor bearing is making a squealing noise and is progressively worsening.
- C. The decision has been made to swap to CC-P-11C.

**3. Standards:**

Simulate valve manipulations and component checks to support start up of CC-P-11C and shutdown of CC-P-11A.

**4. Student Materials:**

Copy of Tear Off Sheet.  
Copy of ODI5 Pump Starts From MCB Or Other Remote Locations  
Page 15 Pre-start Checklist PCCW pump CC-P-11C

**5. Limitations On Performance:**

Simulate all steps. Verbalize all actions to the evaluator.  
Even if requested no Peer Checks will be provided during the JPM.

**6. References:**

Procedures:

- OS1012.03, PCCW Loop A Operation.
- OS1212.01, PCCW System Malfunction.
- ODI5 Pump Starts From MCB Or Other Remote Locations

Sys	KA	Description	Value RO/SRO
008	K4.01	Automatic start of standby pump.	3.1/3.3
191001	K1.08	Operation of valves and verification of position.	3.4/3.4

## JOB PERFORMANCE WORKSHEET

**7. Setting:**

Plant. PAB 25 ft.

**8. Safety Considerations:**

Health Physics postings and ALARA.  
Rotating machinery precautions.

**9. Approximate Completion Time:**

15 minutes

**10. Directions To The Student:**

Evaluator gives Tear Off sheet to the student.

Initial Conditions:

- A. You are the Primary NSO. You are going to simulate the actions required to swap PCCW pumps.
- B. The following information is provided to you:
  - 1. Plant is at 100% power.
  - 2. CC-P-11A outboard motor bearing is making a squealing noise and is progressively worsening.
  - 3. The decision has been made to swap to CC-P-11C.

**11. Initiating Cue:**

US to Primary NSO, **“Primary NSO (or student’s name), we are swapping from the A to the C PCCW pump. Perform the local pre-start checks on CC-P-11C.”**

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

1. P Start time \_\_\_\_\_ Initiating cue read

**CUE:** If the student requests a Peer Check at any time during the JPM respond, **“No one is available to Peer Check your actions. Please continue with the task.”**

**NOTE:** Student may perform the pre-starts in any order. The pre-start checklist is provided to the student by the evaluator.

2. S Verify open CC-V-6 suction isolation. Simulates verifying open CC-V-6 suction isolation. \_\_\_\_\_

**CUE:** When student simulates verifying open CC-V-6 suction isolation, evaluator to student, **“CC-V-6 is open.”**

**CUE:** If student contacts the control room regarding the “procedure determined position” of CC-V-2 discharge isolation, US to NSO, **“CC-V-2 is required to be open.”**

3. S Verify open CC-V-2 discharge isolation. Simulates verifying open CC-V-2 discharge isolation. \_\_\_\_\_

**CUE:** When student simulates verifying open CC-V-2 discharge isolation, US to student, **“CC-V-2 is open.”**

4. S Verify pump is filled and vented. Simulates verifying pump is filled and vented. \_\_\_\_\_

**CUE:** When student simulates verifying pump is filled and vented, evaluator to student, **“Pump is filled and vented.”**

5. S Verify both pump bearing oil cups levels are normal. Simulates verifying both pump bearing oil cups levels are normal. \_\_\_\_\_

**CUE:** When student simulates verifying both pump bearing oil cups levels are normal, evaluator to student, **“Both pump bearing oil cup levels are normal.”**

---

In-Plant ‘C’

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP	STANDARD	EVALUATION	
	* denotes a critical step	* denotes a critical step	SAT	UNSAT

6.	S	Verify both motor bearing bulls eye levels are normal.	Simulates verifying both motor bearing bulls eye levels are normal.	_____	_____
----	---	--	---	-------	-------

**CUE:** When student simulates verifying both motor bearing bulls eye levels are normal, evaluator to student, **“Both motor bearing bulls eye levels are normal.”**

**NOTE:** CC-PI-2165 CC-P-11A/C Train A Return Pressure is located on side of column, 17 ft from North wall and 8 ft from West wall.

7.	S	Verify suction pressure is greater than 15 psig on CC-PI-2165.	Simulates verifying suction pressure is greater than 15 psig on CC-PI-2165.	_____	_____
----	---	--	---	-------	-------

**CUE:** When student simulates verifying suction pressure is greater than 15 psig on CC-PI-2165, evaluator to student, **“Suction pressure is greater than 15 psig.”**

8.	S	Inform US that pre-start checks for CC-P-11C completed.	Simulates informing US that pre-start checks for CC-P-11C completed.	_____	_____
----	---	---	--	-------	-------

**CUE:** When control room is informed that pre-start checks for CC-P-11C completed., US to NSO, **“I copy, pre-start checks for CC-P-11C completed. Stand by for starting of CC-P-11C”**

**CUE:** Provide the following cue, **“The announcement for the starting of CC-P-11C is heard, and moments later CC-P-11C starts. All indications show CC-P-11C is running normally.”**

**CUE:** US to Primary NSO, **“We are preparing to stop CC-P-11A. Unlock and close CC-V-5, CC-P-11A discharge valve.”**

**NOTE:** Primary NSO carries the required key (BEST key) on his key ring.

*9.	S	Unlock and close CC-V-5, CC-P-11A discharge valve.	*Simulates unlocking and closing CC-V-5, CC-P-11A discharge valve.	_____	_____
-----	---	--	--	-------	-------

**CUE:** When student simulates unlocking and closing CC-V-5, CC-P-11A discharge valve, evaluator to student, **“CC-V-5 is unlocked and closed.”**

**PERFORMANCE CHECKLIST**

D=Discuss P=Perform S=Simulate	ELEMENT/STEP * denotes a critical step	STANDARD * denotes a critical step	EVALUATION SAT UNSAT
--------------------------------------	---	---------------------------------------	-------------------------

10. S Inform US that CC-V-5 is unlocked and closed. Simulates informing US that CC-V-5 is unlocked and closed. \_\_\_\_\_

**CUE:** US to Primary NSO, **"I copy, CC-V-5 is unlocked and closed."**

**CUE:** After US is informed that CC-V-5 is closed, the control room stops CC-P-11A. Provide the necessary cues that CC-P-11A is stopped. Us to Primary NSO, **"We have secured CC-P11A. Open and lock open CC-V-5."**

\*11. S Open and lock open CC-V-5, CC-P-11A discharge valve. \*Simulates opening and locking open CC-V-5, CC-P-11A discharge valve. \_\_\_\_\_

**CUE:** When student simulates opening and locking open CC-V-5, CC-P-11A discharge valve, evaluator to student, **"CC-V-5 is open and locked."**

12. S Inform US that CC-V-5 is locked open. Simulates informing US that CC-V-5 is locked open. \_\_\_\_\_

**CUE:** US to Primary NSO, **"I copy, CC-V-5 is locked open."**

**CUE:** **"The JPM is complete."**

13. Stop time \_\_\_\_\_ Time to complete task ≤ 20 minutes

Evaluator calculates time to complete task

14. Obtain from student:  
Tear Off sheets and any other training materials used in performance of this JPM. \_\_\_\_\_



## TEAR OFF SHEET FOR JPM L0052J

### **Directions To The Student:**

- A. You are the Primary NSO. You are going to simulate the NSO actions required to swap PCCW pumps.
- B. The following information is provided to you:
  - 1. Plant is at 100% power.
  - 2. CC-P-11A outboard motor bearing is making a squealing noise and is progressively worsening.
  - 3. The decision has been made to swap to CC-P-11C.

### **Initiating Cue:**

US to Primary NSO, **“Primary NSO (or student’s name), we are swapping from the A to the C PCCW pump. Perform the local pre-start checks on CC-P-11C.”**



**PRIMARY COMPONENT COOLING WATER PUMP CC-P-11C**

	<b>MCB</b>	<b>LOCAL</b>
<b>1) SUCTION PATH</b>		
CC-V-6	----	OPEN
HEAD TANK LEVEL	>45%	----
<b>2) DISCHARGE PATH</b>		
CC-V-2 IN PROCEDURE DETERMINED POSITION	----	YES
CC-TK-2171:		
-W/ CC-P-11A SHUTDOWN	MAN. 0%	----
-W/ CC-P-11A RUNNING	AUTO	----
<b>3) COOLING MEDIUM</b>		
PAB NORMAL VENTILATION	RUNNING	----
PAH-FN-42A OR B	AUTO	----
OR		
PAH-FN-42A OR B	AUTO	----
<b>4) OTHER SUPPORT</b>		
PUMP FILLED AND VENTED	----	YES (Note 1)
PUMP BEARING OIL CUPS (2)	----	NORMAL
MOTOR BEARING BULLS EYES (2)	----	1/2 +/- 1/4
PUMP SUCTION PRESSURE	----	>15#
COLOR GRAPHICS FOR CC-P-11C	DISPLAYED	----
PREVIOUS PUMP STARTS		
-TWO IN LAST HOUR (W. MOTOR STATOR AT AMBIENT TEMP.)	NO	----
-ONE IN LAST 1/2 HOUR (W/ MOTOR STATOR AT OPERATING TEMPERATURE	NO	----
GAITRONICS ANNOUNCEMENT MADE	YES	----

Note 1: If the pump is being started for surveillance testing, it should not be vented unless the pump was drained to support maintenance. This is to prevent preconditioning the pump prior to testing.



2009-2010 LOIT NRC SIMULATOR EXAMINATION # 01

Rev. 0

## OFFICIAL NRC EXAMINATION MATERIAL

ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC INITIAL EXAM SECURITY AGREEMENT.

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
INSTRUCTOR

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
TRAINING SUPERVISOR

REVIEWED BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
SME (OPTIONAL)

|

**SCENARIO**

The Scenario begins with the plant at 55% power. SW-P-41C is danger tagged out for motor replacement. Both Main feed Pumps and one Heater Drain pump are in service.

After the crew begins to increase power, FW-PT-505 fails low, which is addressed in Abnormal Procedure OS1235.05, "Turbine Impulse Pressure PT-505 or PT-506 Instrument Failure."

RC-LT-459 will fail high the crew should take manual control of charging flow. This failure is addressed with Abnormal Procedure OS1201.07, "PZR Level Instrument Failure." Also during this failure, a 20 gpm RCS leak will develop on the instrument sensing line. After initially addressing, or in parallel with the instrument failure, it is expected that the crew will address the RCS leak using Abnormal Procedure OS1201.02, "RCS Leak."

The running EHC pump will trip and the standby EHC pump will start. The standby pump will have a sheared shaft and EHC pressure will continue to decrease. The crew will need to recognize the decreasing EHC pressure and manually trip the reactor or respond to an automatic turbine trip/reactor trip demand. The #2 turbine stop and control valves will stick "as-is" on the trip. Automatic Main Steam Isolation (MSI) will fail to actuate, requiring the crew to manually close the main steam isolation valves to prevent an excessive cooldown.

When the Main Steam Isolation Valves are shut, one safety valve on each of "C" & "D" Steam Generators will open and subsequently stick open, requiring a manual or an automatic Safety Injection. SI-P-6A and SI-P-6B will fail to start on the Safety Injection, requiring a manual start. The crew will enter E-0, "Reactor Trip or Safety Injection" and may enter ES-0.1, "Reactor Trip Response" before transitioning back to E-0 and then to E-2, "Faulted Steam Generator", to address the depressurization of the "C" & "D" Steam Generators.

Anticipated AOP/EOP flow-path: OS1235.05, OS1201.07, OS1201.02, E-0, E-2, ES 1.1

**SIMULATOR SETUP**

1.  Reset the simulator to 50-55 % power with both MFPs in service, Middle of Core Life condition. **This setup has been snapped to a password protected IC with the below conditions. Alternately, any other 55% IC can be used, and conditions established using Scenario Sim test EV1 or individually as described below.**
  
2.  Set Protected Train as "B" on MPCS and MCB.
  
3. Tag out SW-P-41C by inserting the following:
 

<input type="checkbox"/>	Override cSWP41C SW-P-41C breaker racked out
<input type="checkbox"/>	Remote Function cSWV22 SW-V-22 breaker open
<input type="checkbox"/>	Tag the Control Switch for SW-P-41C
  
4.  Verify Pressurizer Level Channel LT-459 is Selected for control.
  
5. Actuate the following scenario to insert malfunctions and activate triggers for the exam setup:
 

<input type="checkbox"/>	SELECT: <b>Scenarios</b>
<input type="checkbox"/>	SELECT: <b>Demo exams</b>
<input type="checkbox"/>	SELECT: <b>Exam #01 setup</b>
<input type="checkbox"/>	SELECT: <b>RUN</b>

Verify the following were inserted and activated:

- |                          |  |
|--------------------------|--|
| <input type="checkbox"/> | <b>mfSI003, SI PUMP 6A FAILS TO AUTO START</b>         |
| <input type="checkbox"/> | <b>mfSI004, SI PUMP 6B FAILS TO AUTO START</b>         |
| <input type="checkbox"/> | <b>avMSVSV2, t:1 d:0, MT STOP VLV #2 FAILS OPEN</b>    |
| <input type="checkbox"/> | <b>mfRPS019, MS ISOLATION FAILS TO ACTUATE (TRN A)</b> |
| <input type="checkbox"/> | <b>mfRPS020, MS ISOLATION FAILS TO ACTUATE (TRN B)</b> |

Verify the following event trigger that will insert malfunctions to fail open SG safety valves on two Steam Generators when Main Steamline Isolation Train "B" switch is turned to ACTUATE has been Activated:

- |                          |   |
|--------------------------|---|
| <input type="checkbox"/> | SELECT: <b>Event Triggers (Top bar)</b> |
| <input type="checkbox"/> | SELECT: <b>Demo Exams/Exam 01 MSI</b>   |
| <input type="checkbox"/> | VERIFY: <b>Activated</b>                |

**SHIFT TURNOVER**

- Plant is at 50-55% power.
- Procedure OS1000.05 is being performed and is completed to step 4.3.10.
- Maintain AFD on target.
- Increase power to 75% at 5%/hour.
- SW-P-41C tagged out for motor replacement.

**SCENARIO OUTLINE****EVENT****INSTRUCTION****COMMENTS**

Shift Turnover

Shift turnover information as stated.

**Event 1**5%/hr. power  
increase**PSO (R), US (N), BOP (N)**

Crew Begins the Power increase IAW MPE Procedure OS1000.05, Power Increase.

The crew should prepare for and initiate a power increase at 5%/hr.

**Unit Supervisor:** A brief reactivity review will take place discussing the temperature limits for Tave to be used in the power increase. The temperature band will normally be  $\pm 1.5^{\circ}\text{F}$  with rods in Auto or  $\pm 3^{\circ}\text{F}$  with rods in manual. Dilution will be used for temperature control during the power increase. Control rods will be used for AFD and temperature control.

**Turbine Operations:** The BOP will increase turbine load using automatic DEHC operations. Using the laminated sheets, Figure 9 of OS1000.05, The basic steps are:

- Check the Load Set is in Hold mode.
- Insert the desired loading Rate.
- Insert the desired Power Level.
- When RCS temperature begins to Increase, Select "Load."
- Monitor turbine loading using "Load Status" is Loading and "Load Actual" increases.

The BOP should verify the change with control valve position change, temperature change and power change.

At any time during the automatic loading, the power increase can be stopped by activating the "Hold" function.

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
		<p><b>Reactor Power change:</b> The crew will use dilution to increase temperature during the turbine load increase. A dilution value will be determined to change the boron concentration and increase power/temperature. If control rods are used in manual to control AFD / temperature, the operator will verify rod speed, place the Rod Motion Selector (In-Hold-Out) switch to the OUT direction and withdraw the rods a maximum of three steps. The PSO will monitor temperature and power as confirmation of actions.</p> <p>Using the laminated sheets OS1008.01, Figure 2, Dilution Check List, the PSO will set up the controllers for the required dilution volume and rate.</p> <p>The high level steps are:</p> <ul style="list-style-type: none"><li>• Verify the pumps in AUTO</li><li>• Verify the makeup valves are in AUTO</li><li>• Place Blender Mode Start Switch to STOP</li><li>• Place the Mode Selector Switch to DILUTE or ALT DILUTE</li><li>• Set the quantity and flow rate on CIS-FIQ-111 controller</li><li>• If not desired, select OFF for the "Stepback Feature"</li><li>• Set the Mode Start Switch to START</li><li>• Verify the pumps and valves respond</li><li>• Verify Plant Response.</li><li>• Restore System to Automatic control</li></ul>

**Allow the crew to demonstrate a power increase or at Chief Examiners discretion, enter the next Event:**

**EVENT****INSTRUCTION****COMMENTS**

**Event 2**  
FW-PT-505  
fails low

Enter the Turbine Impulse Press Channel FW-PT-505  
Failure as follows:

- SELECT: **MF List**
- SELECT: **FEEDWATER (Component)**
- SELECT: **ptFWPT505**
- Double Click**
- SELECT: **Fails Low**
- SELECT: **Insert**

**PSO(I), US(I, TS), BOP(I)**

Turbine Impulse Pressure FW-PT-505 fails low. If Control Rods are selected to auto, automatic rod insertion occurs.

**Alarms:**

B7457 Rod Motion Detected

US may direct termination of the dilution and placing rods in manual.

Crew Enters OS1235.05, Turbine Impulse Pressure PT-505 or PT- 506 Instrument failure.

**Step 1:** Check FW-PT-505 Failed:

- The BOP checks FW-PT-505 Failed using FW-PI-505 or Tref indication.
- PSO places rods in manual.
- PSO/BOP monitor Tavg at program temp., using Tavg indication or RCS cold leg temperature. The Crew will likely withdraw rods in 3-step increments or reduce turbine load to restore temperature.

**Step 2:** BOP Checks Condenser Steam Dumps:

- Checks Steam dump valves closed.
- Transfers Steam dump control to the STM Press Mode.
- Adjust Steam dump controller output, places in AUTO.
- Verifies interlock switches in NA RESET

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
	<p data-bbox="436 435 978 474"><b>Place FW-PT-505 in Bypass as follows:</b></p> <div data-bbox="375 500 1220 662" style="border: 1px solid black; padding: 5px;"> <p data-bbox="375 505 785 544"><input type="checkbox"/> SELECT: <b>Panel Overview</b></p> <p data-bbox="375 553 785 592"><input type="checkbox"/> SELECT: <b>AMSAC CP-519</b></p> <p data-bbox="375 602 726 641"><input type="checkbox"/> SELECT: <b>TB IMP 505</b></p> </div> <p data-bbox="436 699 1188 797"><b>Instructor Cue:</b> If Ops. Management contacted regarding the power increase, respond to continue the power increase.</p>	<p data-bbox="1234 261 1892 326"><b>Step 3:</b> PSO verifies P-13 Status Light for Turbine Power above 10%.</p> <p data-bbox="1234 331 1923 435"><b>Step 4:</b> US verifies TS compliance and determines:</p> <ul data-bbox="1283 370 1923 435" style="list-style-type: none"> <li data-bbox="1283 370 1923 435">• T.S. 3.3.1, Table 3.3-1, Item 18.f, Action 8, is applicable.</li> </ul> <p data-bbox="1234 440 1934 544"><b>Step 5:</b> Crew verifies ATWAS Mitigation Input Status:</p> <ul data-bbox="1283 472 1906 544" style="list-style-type: none"> <li data-bbox="1283 472 1906 544">• US directs I&amp;C to place the failed channel in Operate Bypass.</li> </ul> <p data-bbox="1234 548 1892 581"><b>Alarm:</b> D7899 ATWAS Mitigation Sys Byp/Trouble</p> <ul data-bbox="1283 581 1929 646" style="list-style-type: none"> <li data-bbox="1283 581 1929 646">• BOP verifies UL-28 B-1, Turbine power above 20% - status light energized.</li> </ul> <p data-bbox="1234 651 1892 716">US may contact Ops. Management with regards to continuing with the power increase.</p>

**Allow the crew to complete ON1235.05 or at Chief Examiners discretion prior to entering the next Event:**



<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<b>Event 3</b> RC-LT-459 Failure	Enter the pressurizer Level Channel failure over 5 minutes as follows:	<b>PSO(I), US(I,TS)</b> RC-LI-459, PZR Level, channel 1, fails high, requiring manual control of charging and letdown. No loss of letdown occurs due to the failure of the channel high. Crew may take manual control of charging and/or letdown flow using Skill Of The Operator.
	<div style="border: 1px solid black; padding: 5px;"> <input type="checkbox"/> SELECT: <b>MF List</b>  <input type="checkbox"/> SELECT: <b>REACTOR COOLANT (Component)</b>  <input type="checkbox"/> SELECT: <b>ItRCLT459</b>  <input type="checkbox"/> <b>Double Click</b>  <input type="checkbox"/> SELECT: <b>FAIL TO SPECIFIED VALUE</b>  <input type="checkbox"/> ENTER: <b>100%</b>  <input type="checkbox"/> ENTER: <b>Ramp Rate of 300 secs</b>  <input type="checkbox"/> SELECT: <b>INSERT</b>  <input type="checkbox"/> <b>Input Event 4 as a simultaneous failure.</b> </div>	<b>Alarms:</b> <ul style="list-style-type: none"> <li>• D4436 PZR LVL Deviation High &amp; BU Htrs On</li> <li>• F7861 PZR Level High Channel trip</li> </ul> Crew Enters OS1201.07, PZR Level Instrument Failure. <b>Step 1:</b> PSO checks Pressurizer controlling channel failed. <b>Step 2:</b> PSO Realigns PZR Level Instruments: <ul style="list-style-type: none"> <li>• Manually controls level using Letdown and Charging</li> <li>• Selects an alternate level channel for control</li> <li>• Selects an alternate level channel for recorder</li> </ul> <b>Step 3:</b> PSO will not need to Reset heaters <b>Step 4:</b> PSO checks letdown NOT isolated, US goes to step 7. <b>Step 7:</b> PSO aligns pressurizer level control by verifying controller setpoint and placing RC-LK-459 and CS-FK-121 in Auto. (Time dependent). <b>Step 8:</b> PSO verifies redundant bistables on UL-6, Pressurizer Level High, NOT tripped.

**EVENT****INSTRUCTION****COMMENTS**

**Step 9:** US verifies TS compliance and determines the following are applicable:

- T.S. 3.3.1, Reactor Trip System Instrumentation; Table 3.3-1, Item 11, Action 6 is applicable
- T.S. 3.3.3.6, Accident Monitoring Instrumentation; Table 3.3.10, Item 5, Action A for PAM indication
- T.S. 3.3.3.5, Remote Shutdown Systems; Table 3.3-9, Item 5, Action A for RSSD indication

**To place LB-459A in Bypass perform the following:**

US Coordinates with I&C to place bistables in bypass or tripped.

- |                          |  |
|--------------------------|--|
| <input type="checkbox"/> | SELECT: <b>CP1 Bypass Cabinet</b>          |
| <input type="checkbox"/> | SELECT : <b>Door Open</b>                  |
| <input type="checkbox"/> | SELECT: <b>Enable</b>                      |
| <input type="checkbox"/> | SELECT: <b>Panel Overview</b>              |
| <input type="checkbox"/> | SELECT: <b>BTI CP1</b>                     |
|                          | Position the following switches to bypass: |
| <input type="checkbox"/> | <b>LB- 459, High Reactor Trip BS-1</b>     |
| <input type="checkbox"/> | SELECT: <b>CP1 Bypass Cabinet</b>          |
| <input type="checkbox"/> | SELECT : <b>Door Closed</b>                |
| <input type="checkbox"/> | SELECT: <b>Enable</b>                      |

**Shortly after initiating Event 3, Insert malfunctions for Event 4.**

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<b>Event 4-</b> 20 gpm RCS Leak	Shortly after initiating Event 3, insert the following malfunction for a 20 gpm leak ramped in over 5 minutes, simulating a leak on the pressurizer instrument sensing line:	<p data-bbox="1234 264 1480 300"><b>PSO(C), US(C,TS)</b></p> <p data-bbox="1234 300 1927 397">Supports E-Plan UE call on SU5 (End of Scenario) Crew responds to a 20 gpm RCS leak IAW Abnormal Procedure OS1201.02, RCS Leak</p> <p data-bbox="1234 435 1438 467"><b>RDMS Alarms:</b></p> <ul data-bbox="1281 470 1927 576" style="list-style-type: none"> <li>• Containment Particulate High and High High</li> <li>• Containment Gaseous High and High High</li> <li>• Containment Backup Gas High and High High</li> </ul> <p data-bbox="1234 576 1906 678"><b>Step 1:</b> PSO Checks If Pressurizer Level Can Be Maintained by controlling charging and letdown and checking level stable or increasing.</p> <p data-bbox="1234 678 1822 747"><b>Step 2:</b> US refers to ER1.1, Classification Of Emergencies, SU5.</p> <p data-bbox="1234 747 1927 815"><b>Step 3:</b> US determines step 4 is the appropriate step Transition for a suspected RCS leak.</p> <p data-bbox="1234 815 1953 847"><b>Step 4:</b> PSO Isolates Potential RCS Leakage Sources:</p> <ul data-bbox="1281 852 1974 1404" style="list-style-type: none"> <li>• Checks Safety or PORV leakage using PORV tailpipe temps, and Acoustic monitor alarms</li> <li>• Checks reactor head vents isolated, RC-FV-2881 and RC-V323</li> <li>• Checks Excess Letdown isolated, CS-V175 and CS-V176</li> <li>• Checks Phase A Status lights for RCS sample lines indicate valves are closed</li> <li>• Checks reactor vessel flange leakoff temperature Normal</li> <li>• Checks valve stem leakoff header temperature, D7805 and D7804 not in alarm.</li> <li>• BOP checks SG tubes intact using rad monitors for MS line, SG blowdown, and Condenser air evacuation. Calls Chemistry for sample.</li> <li>• PSO checks SI discharge header pressure &lt; 800</li> </ul>
	<div style="border: 1px solid black; padding: 5px;"> <input type="checkbox"/> Select: <b>MF List</b>  <input type="checkbox"/> Select: <b>Reactor Coolant</b>  <input type="checkbox"/> Select: <b>mfRC049C</b>  <input type="checkbox"/> Select: <b>Final Value = 20</b>  <input type="checkbox"/> Select: <b>Ramp = 300</b>  <input type="checkbox"/> Select: <b>Insert</b> </div>	
	<p>If an NSO is sent to sent to the RSSD panel to check indication, after 2 minutes, <b>Inform the control room that RC-LT-7334 indicates off-scale high.</b> (common instrument sensing line)</p>	

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
		<p>psig</p> <ul style="list-style-type: none"> <li>• US determines RCS leakage is NOT isolated and goes to step 16.</li> </ul> <p><b>Step 16:</b> US continues efforts to determine leak source by considering plant walk-downs or containment entry.</p> <p><b>Step 17:</b> Estimate RCS Leak Rate:</p> <ul style="list-style-type: none"> <li>• Crew stabilizes Tavg</li> <li>• PSO maintains Pzr level stable</li> <li>• Crew estimates leak rate using VCT level, Containment sump levels, and/or PZR/VCT mass balance.</li> </ul> <p><b>Step 18:</b> US verifies TS Compliance and determines the following apply:</p> <ul style="list-style-type: none"> <li>• T.S. 3.4.6.2, Reactor Coolant System Leakage, Action b. Action a will have to be evaluated once the exact leak location is determined.</li> <li>• T.S. 3.4.10, Structural Integrity, will have to be evaluated once the exact leak location is determined.</li> </ul>

**Allow the crew to estimate the leak size and determine Tech. Spec. Compliance or at Chief Examiners discretion, enter the next sequence of Events:**

**EVENT****INSTRUCTION****COMMENTS**

**Event 5**  
EHC Pumps  
Trip

Insert the following to fail Turbine control valve #2 As-Is, partially open, following the impending turbine trip.

- |                          |                                |
|--------------------------|--------------------------------|
| <input type="checkbox"/> | SELECT: <b>Sim Diagram MS4</b> |
| <input type="checkbox"/> | SELECT: <b>CV2</b>             |
| <input type="checkbox"/> | SELECT: <b>Fail As Is</b>      |
| <input type="checkbox"/> | SELECT: <b>INSERT</b>          |

RUN the following scenario to initiate loss of both EHC pumps:

- |                          |                             |
|--------------------------|-----------------------------|
| <input type="checkbox"/> | SELECT: <b>Scenario</b>     |
| <input type="checkbox"/> | SELECT: <b>Demo exams</b>   |
| <input type="checkbox"/> | SELECT: <b>Exam #01 EHC</b> |
| <input type="checkbox"/> | SELECT: <b>RUN</b>          |

Malfunction mfHF001, HF-P-54A, "A" EHC Pump Over Current Trip will actuate.

IF the crew does not start the standby EHC pump, it will start automatically at 1300 psig.

**BOP(C),US(C)**

Crew Responds to sequential loss of EHC pumps with eventual complete loss producing an automatic Turbine/Reactor trip signal.

**Alarms:**

D7185 EHC PUMP A TROUBLE. Crew is expected to monitor HF pressure and dispatch an NSO to the EHC skid.

The crew may choose to have the BOP start the standby pump using "skill of the operator."

**Alarms:**

D7180, EHC HEADER PRESSURE LOW  
D7183, EHC STANDBY PUMP AUTO START

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<b>Event 6</b> EOP entry	<p>Following the loss of the "A" EHC pump, three minutes into Event 5, a combination of I/O overrides and malfunctions will make it appear that there is a "problem" with the "B" EHC pump. The scenario first simulates internal pump mechanical problems (loss of load and low amps) that eventually lead to the pump binding and tripping on over current.</p>	<p>The Crew should refer to D7185 VPRO for additional guidance:</p> <ul style="list-style-type: none"> <li>• Verify started/start EHC Pump B and leave control switch in run.</li> <li>• Stop EHC Pump A.</li> <li>• Verify EHC system operation per ON1031.10, Operation of Electro-Hydraulic control system.</li> <li>• Have an NSO check HF-P-54A or the breaker on MCC-141 &lt;C66&gt;</li> </ul> <p>The BOP should determine that HF pressure is decreasing. It is expected that the crew will trip the plant based on continuously lowering EHC pressure.</p> <p><b>Alarms:</b>            D7186 EHC PUMP B TROUBLE will alarm.</p> <p><b>PSO(M),US(M),BOP(M)</b>            A turbine trip - Reactor trip will occur when EHC pressure decays below 1100 psig or when MANUALLY tripped by the crew. The #2 turbine stop &amp; control valves stick open requiring the crew to manually close the MSIVs to stop the cooldown. When the MSIVs are shut, two SG safeties, one on C and one on D steam lines will fail open.            The steam flow / cooldown will cause a safety injection (automatic or manual).            US will transition to E-2 at step 9 of E-0 after SI has actuated.            The Crew will enter E-0:  <b>Step 1:</b> PSO verifies Reactor Trip</p>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<b>Event 7</b> Turbine trip failure		<p><b>Step 2:</b> BOP verifies Turbine Trip  <b>BOP(C), CCT: #2</b> Stop and #2 Control valves are stuck as-is. The BOP will have to recognize this from valve position and/or excessive cooldown, attempt a manual turbine trip, and then isolate steam by using MSIVs.</p> <p><b>Step 3:</b> BOP verifies power to emergency busses</p> <p><b>Step 4:</b> PSO verifies SI is NOT actuated, and checks if SI is required:</p> <ul style="list-style-type: none"> <li>• RCS pressure &lt;1800</li> <li>• Pressurizer Level &lt; 7%</li> <li>• Containment Pressure &gt; 4 psig</li> <li>• RCS subcooling &lt; 40 degrees</li> <li>• SG pressure &lt; 585</li> </ul> <p>PSO manually actuates SI, if automatic SI has not yet occurred.</p> <p><b>NOTE:</b> Normally the PSO will be assigned actions to complete Attachment "A" of E-0, while the BOP continues processing of E-0. It is possible that these roles could be reversed.</p>
<b>Event 8</b> SI pumps A & B start failure		<p><b>Step 5:</b> PSO completes ESF Attachment A:</p> <ul style="list-style-type: none"> <li>• Verifies Phase A actuation by Status Panel</li> <li>• Verifies Safeguard Equipment alignment by Status Panel. Uses RNO to manually start SI pumps.</li> </ul> <p><b>PSO(C)</b>            SI pumps A &amp; B will fail to auto-start on the SI signal and require manual actions to start.</p> <ul style="list-style-type: none"> <li>• Verifies Feedwater isolation by Status Panel</li> <li>• Verifies both trains of PCCW Pumps running</li> <li>• Verifies ECCS flow (Based upon timing, if RCS pressure has decreased to &lt;1700 psig, this step</li> </ul>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
		<p>provides an additional opportunity to start SI pumps if not previously done, to meet CCT)</p> <ul style="list-style-type: none"> <li>• Verifies MS-V129 open</li> <li>• Verify both trains of Service Water Pumps operating</li> <li>• Verifies Service Water flow to EDGs &gt; 900 GPM</li> <li>• Checks if Main Steam Lines should be isolated. This should have been completed earlier based upon turbine control valve stuck open. Goes to next step.</li> <li>• Checks Containment pressure &lt; 18 psig</li> <li>• Verifies EFW flow total &gt; 500 gpm</li> <li>• Reset of RMO is not required</li> <li>• Notifies US of verification status including manual actions to start SI pumps.</li> </ul> <p><b>Step 6:</b> BOP monitors RCS temperature NOT stable, US refers to RNO:</p> <ul style="list-style-type: none"> <li>• Stops dumping steam</li> <li>• Checks MSR steam isolated</li> <li>• Monitors cooldown and adjust EFW flow to above 500 gpm</li> <li>• Throttles to maintain SG levels &gt; 6% Narrow range in at least 1 SG.</li> <li>• With cooldown continuing, verifies MSIVS and Bypasses closed, and closes Upstream drain valves MSD-V-44 and 45.</li> </ul> <p><b>Step 7:</b> BOP Checks RCS isolated.</p> <p><b>Step 8:</b> BOP Checks if RCPs should be stopped and based upon subcooling &gt; 40 degs. US Goes to step 9.</p> <p><b>Step 9:</b> BOP determines SG pressure boundary is NOT intact, based upon C &amp; D SG pressures decreasing in an uncontrolled manner.</p>



<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
Terminate Exam	Terminate the examination when the crew transitions to ES-1.1, SI Termination, or at Lead Examiner's discretion.	<p>US proceeds to E-2, Faulted Steam Generator Isolation.</p> <p><b>Step 1:</b> BOP checks MSIVS and Bypasses Closed</p> <p><b>Step 2:</b> BOP checks A &amp; B SG pressure boundaries are intact.</p> <p><b>Step 3:</b> BOP identifies C &amp; D SGs are faulted.</p> <p><b>Step 4:</b> BOP checks C &amp; D SGs are isolated.</p> <p><b>Step 5:</b> BOP checks CST level &gt; 250,000 gals.</p> <p><b>Step 6:</b> BOP checks secondary radiation is normal.</p> <p><b>Step 7:</b> PSO checks if ECCS flow can be reduced:</p> <ul style="list-style-type: none"> <li>• Subcooling &gt; 40 deg.</li> <li>• Secondary heat sink &gt; 65 % SG wide range level</li> <li>• RCS pressure stable or increasing</li> <li>• PZR level &gt; 7%</li> <li>• US transitions to ES- 1.1 SI Termination, Step 1</li> </ul> <p>During the post-scenario JPM, the US will evaluate the correct Emergency Response classification based on SU5, RCS Leak</p> <p>Anticipated AOP/EOP flow-path: OS1235.05, OS1201.07, OS1201.02, E-0, E-2, ES 1.1 Possible brief transition may be from E-0 to ES-0.1 and back to E-0, based upon timing.</p>

R-Reactivity, N-Normal, I-Instrument, C-Component, M-Major

**CREW CRITICAL TASKS**

1. MANUALLY actuate main steamline isolation or close MSIVs before a severe (Orange Path) challenge develops to either the subcriticality or the integrity CSF or before transition to ECA-2.1, whichever happens first,(CCT E-0,O)
2. Isolate the faulted Steam Generators before transition out of E-2, Faulted Steam Generator Isolation, or ECA-2.1, Uncontrolled Depressurization of All Steam Generators.(CCT E-2,A)



2009-2010 LOIT NRC SIMULATOR EXAMINATION # 03

Rev. 0

## OFFICIAL NRC EXAMINATION MATERIAL

**ACCESS IS LIMITED TO NRC EXAMINERS AND PERSONNEL THAT FULLY UNDERSTAND AND HAVE SIGNED ON TO THE 2010 NRC INITIAL EXAM SECURITY AGREEMENT.**

PREPARED BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
INSTRUCTOR

REVIEWED BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
SME (Optional)

APPROVED BY: \_\_\_\_\_ DATE: \_\_\_\_\_  
TRAINING SUPERVISOR

## 2007-2009 LOIT NRC Examination Scenario 3

### SCENARIO

The simulator is initialized at 100% power. SW-P-41C is danger tagged out for motor replacement. 'A' ASDV is tagged out of service due to seat leakage.

The A Main Feed Pump has a small control system oil leak that cannot be repaired with the pump operating. The crew will start a 10% per hour downpower to 45% power.

Before starting the power decrease, the Loop 1 Tcold instrument (TE-411) will fail high. The crew responds with OS1201.08, "Tave/Delta T Instrument Failure".

The downpower will be continued.

A leak in the letdown line at the inlet to the Reactor Coolant Filter will be initiated. Letdown flow will be reduced approximately 50%, causing VCT level to decrease. The crew responds using OS1201.02, "RCS Leak".

The "D" ASDV controlling pressure channel will fail high causing "D" ASDV to open. The BOP operator should recognize the "D" ASDV opening is due to a failed pressure channel. The ASDV controller is placed in MANUAL and the valve is closed to prevent an uncontrolled power/reactivity increase.

A Loss of Offsite Power will occur. The 'B' EDG will start and then trip on low lube oil pressure caused by a lube oil leak. The 'A' EDG fails to start. The crew will recover power to Bus E6 via the Supplemental Emergency Power System (SEPS).

The EFW Turbine Trip Throttle valve will close for unknown reasons. Recovery of the EFW turbine will be delayed until later in the scenario.

Upon restoration of power to Bus E6, the "B" train SW pump will not Auto restart and action must be taken to start a pump to restore SW flow. The crew will enter E-0 and ECA-0.0 for these events.

During the recovery of Bus E6, the Motor Driven EFW Pump will trip on Overcurrent requiring the use of the Turbine driven EFW pump to restore EFW flow to the SGs.

Anticipated AOP/EOP flow-path: OS1201.08, OS1201.02, E-0, ECA-0.0, E-0, ES-0.1

2007-2009 LOIT NRC Examination Scenario 3

**SIMULATOR SETUP**

1. Reset the simulator to a 100%, Middle of Core Life condition. **This setup has been snapped to password protected IC92 with the below conditions. Alternately, any other 100% IC (IC-30) can be used, and conditions established using Scenario Sim test EV3 or individually as described below.**

2.  Set Protected Train as "B" on MPCS and MCB

3. If EV3 is to be used, establish the exam setup by running the following scenario:

- Select: Scenario
- Select: Len
- Select: Sim test EV3
- Select Run

4.  **Verify the following conditions were entered:**

5. Insert the following Malfunction and Overrides to fail the Auto Start of "A" EDG; Electrical Distribution:

- IMF mfED031, DG-1A Auto Start Failure
- Override the DG-1A Emergency Start pushbutton to RELEASE.
- On Panel Graphic PHF09, Override the "A" EDG Emergency Stop Pushbuttons to STOP

6. Insert the following Malfunction to Trip the "B" EDG on Low Lube Oil Pressure, Electrical Malfunctions:

- IMF mfED034, DG-1B Low Lube Oil Press Trip

7. Set up the ASDV "A" Closure and Isolation with MS-V5:

- On Sim Diagram MS1, for MS-V5 Select the Remote Function, rFMS009, and Set Final value to 0
- On MS-PK-3001, place the controller to Manual and Minimum Output
- On Sim Diagram MS1, MS-PV-3001, Component Malfunction
- SELECT: FAIL CLOSED
- SELECT: INSERT
- PLACE MCB jog switch to CLOSED for MS-PV-3001 and place a Control Board Tag.

Continued on next page.

**2007-2009 LOIT NRC Examination Scenario 3**

8. Using Malfunctions, Service Water, Insert the following malfunctions to prevent Auto Start of SW-P-41B, 41D and P-110B

- IMF mfSW013, SW-P-41B Fails to Auto Start
- IMF mfSW015, SW-P-41D Fails to Auto Start
- IMF mfSW017, SW-P-110B Fails to Auto Start

9. Activate trigger for FW-P-37A Overspeed.

- LOIT, L3059I, Loss of FW-P-37A on Overspeed

10. Setup the Malfunction for FW-P-37B to Trip on Overcurrent after starting in ECA-0.0.

- Malfunctions, Feedwater
- SELECT: mfFW055, FW-P-37B Overcurrent Trip
- SELECT: INSERT

11. Tag out SW-P-41C by inserting the following:

- Override cSWP41C, SW-P-41C breaker racked out
- Remote Function cSWV22, SW-V-22 breaker open
- Tag the Control Switch for SW-P-41C

## 2007-2009 LOIT NRC Examination Scenario 3

### SHIFT TURNOVER

- The plant is at 100% power.
- Decrease plant power at 10%/hr to 45% power to allow for repairs of FW-P-32A oil leak.
- Main Steam Atmospheric Steam Dump ("A" ASDV), MS-PV-3001 is Danger Tagged closed due to excessive seat leakage. MS-V-5 is closed and tagged. Tech. Spec. 3.7.1.6 and 3.6.3 were entered 4 days ago.
- SW-P-41C tagged out for motor replacement.

**SCENARIO OUTLINE****EVENT****INSTRUCTION****COMMENTS**

Shift Turnover

Shift turnover information as stated.

Operators should review alarms and indications

**At the Chief Examiners discretion initiate the first Event.****Event 1:**RCS Loop 1 Tcold  
fails high

Initiate the instrument failure as follows:

- |                          |  |
|--------------------------|--|
| <input type="checkbox"/> | SELECT Malfunction: <b>Reactor Coolant</b> |
| <input type="checkbox"/> | SELECT Component: <b>ttRCTT411</b>         |
| <input type="checkbox"/> | SELECT: <b>FAIL HIGH</b>                   |
| <input type="checkbox"/> | SELECT: <b>INSERT</b>                      |

**PSO (I) US (I,TS)**

RCS Loop 1 Tcold will fail high causing inward control rod motion.

Control Rods step in based on Tavg/Tref deviation.

The crew should diagnose that rods are stepping in due to an instrument failure. The PSO should recommend and/or the Unit Supervisor should direct the PSO to place rods in manual using "skill of the operator."

**Alarms:**

F5298, OTDT Chan Trip

D4422, Average Tavg High

D4421, Tavg-Tref Deviation

B7457, Rod Motion Detected

UL-6, A3, RC Loop 1, TB-411C OTDT, momentarily lit, transient condition

The crew responds using OS1201.08, Tavg/Delta T Instrument Failure:

**Step 1:** The PSO should identify that Loop 1 Tave instrument has failed.**Step 2:** The US should direct the PSO to place rods in MANUAL. This action may already have taken place prior to the procedure step as a "skill of the operator" task.



<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
		<ul style="list-style-type: none"> <li>• BOP checks condenser steam dumps closed.</li> <li>• PSO adjusts charging and letdown flow as necessary to restore PZR level.</li> </ul> <p><b>Step 3:</b> The PSO defeats the Loop 1 <math>\Delta T</math> input, Loop 1 Tavg input, and selects a non-effected loop for the <math>\Delta T, OT, OP</math> recorder.</p> <p><b>The following Alarms Reset:</b>  F5298, OTDT Chan Trip  D4422, Average Tavg High</p> <p>The following alarms will have occurred and will remain in alarm:  VAS F8115, RC Loop 1 Tavg Deviation  VAS F8119, RC Loop 1 Delta T Deviation</p> <p><b>Step 4:</b> The PSO verifies that Tavg is within 1°F of Tref. If not, the US directs PSO to manually withdrawer rods or the BOP to reduce turbine load to restore temperature.</p> <ul style="list-style-type: none"> <li>• PSO places rods back in automatic.</li> <li>• PSO checks PZR level at program, and restores level control to automatic</li> <li>• BOP checks steam dumps in NA RESET</li> </ul> <p>NOTE; As a power decrease is planned rods may remain in MANUAL.</p> <p><b>Step 5:</b> The RO should verify that there are no redundant bi-stable lights lit for the following:</p> <ul style="list-style-type: none"> <li>• UL-1, T Avg Lo Loop To FW Iso</li> <li>• UL-1, T Avg Lo-Lo Loop Stm Dmp Iso</li> <li>• UL-6, RCS Loop OT<math>\Delta T</math></li> <li>• UL-6, RCS Loop OP<math>\Delta T</math></li> <li>• UL-12, Tavg Lo Loop To FW Iso</li> </ul>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
	<p>If I&amp;C is directed to bypass the failed instrument, RCS Loop 1 Tcold, RC-TI-411, perform the following:</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> SELECT: <b>CP1 Bypass Cabinet</b></li> <li><input type="checkbox"/> SELECT : <b>Door Open</b></li> <li><input type="checkbox"/> SELECT: <b>Enable</b></li> <li><input type="checkbox"/> SELECT: <b>Panel Overview</b></li> <li><input type="checkbox"/> SELECT: <b>BTI CP1</b></li> </ul> <p>Position the following switches to bypass:</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> <b>TB411G</b></li> <li><input type="checkbox"/> <b>TB411C</b></li> <li><input type="checkbox"/> <b>TB412G</b></li> <li><input type="checkbox"/> <b>TB412C</b></li> <li><input type="checkbox"/> SELECT: <b>CP1 Bypass Cabinet</b></li> <li><input type="checkbox"/> SELECT : <b>Door Closed</b></li> <li><input type="checkbox"/> SELECT: <b>Enable</b></li> </ul>	<p><b>Step 6:</b> The Unit Supervisor should identify Tech. Spec. 3.3.1, Reactor Trip System Instrumentation, Item 7, Overtemperature <math>\Delta T</math> is applicable.</p> <ul style="list-style-type: none"> <li>• Requires affected bistables to be placed in the trip condition within 6 hours.</li> </ul> <p>T.R 19, Feedwater Isolation On Low Tavg Coincident With Reactor Trip is not applicable due to 3 other channels available.</p> <p>The Unit Supervisor may coordinate with I&amp;C to place the affected bistables to bypass, using BTI, for up to 6 hours.</p>

Allow the crew to complete the abnormal procedure or at Chief Examiners discretion prior to entering the next Event.

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<p><b>Event 2:</b> Decrease plant power @ 10%/hr.</p>		<p><b>PSO (R) BOP (N) US (N)</b> The crew should prepare for and initiate a plant shutdown at 10%/hr. The US should use OS1000.06, Power Decrease procedure and reference Figure 6, Rapid Power Decrease Guidelines.</p> <p><b>Unit Supervisor:</b> A brief reactivity review will take place discussing the temperature limits for Tave to be used in the power decrease. The temperature band will normally be -3°F to +3°F. Boration will be used for temperature control during the power decrease. Control rods will be used for AFD and temperature control.</p> <p><b>Turbine Operations:</b> The BOP will decrease turbine load using automatic DEHC operations. Using the laminated sheets, Figure 12 of OS1000.06, The basic steps are:</p> <ul style="list-style-type: none"> <li>• Insert the desired loading Rate.</li> <li>• Insert the desired Power Level.</li> <li>• Monitor turbine loading using "Load Status" is Unloading and "Load Actual" decreases.</li> </ul> <p>The BOP should verify the change with control valve position change, temperature change and power change.</p> <ul style="list-style-type: none"> <li>• At any time during the automatic unloading, the power increase can be stopped by activating the "Hold" function.</li> </ul> <p><b>Reactor Power change:</b> The crew will use control rods in automatic to control temperature during the turbine load decrease. Using ODI-56, a boration value will be determined to change the boron concentration and decrease power/temperature. If control rods are used in manual the operator will verify rod speed, place the Rod Motion Selector (in-Hold-Out) switch to the "IN" direction and insert the rods a maximum of three steps. He will monitor temperature and power as confirmation of his actions. Using the laminated sheets for Figure 3 of OS1008.01,</p>

EVENTINSTRUCTIONCOMMENTS

Boration Check List, the RO will set up the controllers for the required boration volume and rate.

The high level steps are:

- Verify the pumps in AUTO
- Verify the makeup valves are in AUTO
- Place Blender Mode Start Switch to STOP
- Place the Mode Selector Switch to Borate
- Set the quantity on CIS-FIQ-111 and CIS-FIQ-110 controllers
- Set the Mode Start Switch to START
- Verify the pumps and valves respond
- Verify Plant Response.

Restore System to Automatic control.

**Allow the crew to commence the downpower or at Chief Examiners discretion prior to entering the next Event.**

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<p><b>Event 3:</b> Initiation of a letdown line leak.</p>	<div style="border: 1px solid black; padding: 5px;"> <input type="checkbox"/> SELECT: <b>Malfunctions</b>  <input type="checkbox"/> SELECT: <b>Chemical and Volume Control:</b>  <input type="checkbox"/> SELECT: <b>mfCS012, Letdown Line Leak At Filter Inlet To Reactor Coolant</b>  <input type="checkbox"/> INPUT Value: <b>0.5</b>  <input type="checkbox"/> SELECT: <b>INSERT</b> </div>	<p><b>PSO (C), US (C,TS)</b>  <b>Alarms:</b>  RDMS High Alarm, RM6541, PAB 7 ft North  B7399, RCS Unidentified Leak Rate High  B8266, RCS Unidentified Leak Rate Warning  RDMS High Alarm, RM6508-2, High Range PAB North EI-7</p> <p>RO should identify decrease in VCT level.</p> <p>The crew responds with OS1201.02, RCS Leak:  The Unit Supervisor should alert the crew to the Caution Statement prior to step 1:  If the plant is in Mode 1,2,or 3 with SI accumulators aligned for injection <u>and</u> pressurizer level can <u>not</u> be maintained greater than 7% using normal charging lineup, <u>then</u> perform the following:</p> <ol style="list-style-type: none"> <li>1) Trip reactor</li> <li>2) <u>When</u> the reactor trip is verified, <u>then</u> actuate SI</li> <li>3) Go to E-0, REACTOR TRIP OR SAFETY INJECTION.</li> </ol> <p><b>Step 1:</b> The PSO will control charging and letdown flow as necessary to maintain pressurizer level, and verify that pressurizer level is stable or increasing.  This is a continuous action step. The RNO response for this step reflects the information contained in the procedure caution as described above.</p> <p><b>Step 2:</b> The US may refer to ER-1.1, Classification of Emergencies for potential E-Plan classification.</p> <p><b>Step 3:</b> The crew should identify that a CVCS leak is suspected. The US should proceed to Step 6.</p> <p><b>Step 6:</b> The Unit Supervisor will direct the PSO to isolate letdown.</p> <ul style="list-style-type: none"> <li>• The PSO will close the following valves: <ul style="list-style-type: none"> <li>○ CS-HCV-189</li> </ul> </li> </ul>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
	<p><b>Instructor CUE:</b> After completion of Step 7, have the NSO report that the leak appears to be from the inlet to the reactor coolant filter, CS-F-1.</p>	<ul style="list-style-type: none"> <li>○ CS-HCV-190</li> <li>○ CS-V-145</li> <li>○ RC-V-81</li> <li>● PSO isolates charging to the loops: <ul style="list-style-type: none"> <li>○ Closes CS-HCV-182</li> <li>○ Maintains seal inj. flow 6-13 gpm utilizing CS-FCV-121 in manual.</li> <li>○ Closes Charging Line isolation valves CS-V-142 and CS-V-143.</li> </ul> </li> </ul> <p><b>Alarms:</b> When letdown flow is isolated the following alarms will occur: VAS B8166, Pzr Stm/Chg Line <math>\Delta</math>T Approach Limit</p> <p>When the charging line isolation valves are closed the following alarms will occur: VAS D7853, Chg Pmp Disch Combined Hdr Flow Low VAS D7872, Chg Header Contm Iso VLV-142 Closed VAS D7873, Chg Header Contm Iso VLV-143 Closed</p> <p>When a VCT auto makeup occurs at 30% level the following alarm will occur” VAS D4660, BA Makeup VLV-110B to Chg Pmp Open</p> <p><b>Step 7:</b> The crew should identify that the leak is isolated by verifying the following parameters:</p> <ul style="list-style-type: none"> <li>● Pressurizer level-Increasing at a rate equal to the difference between seal injection and seal return.</li> <li>● Containment air particulate and gas monitor. Stable or Decreasing. Since the leak was in the PAB, the US may also reference PAB monitors.</li> <li>● Containment temperature and pressure. Stable or Decreasing</li> <li>● Containment sump A and B levels. Normal or</li> </ul>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
		<p>Decreasing</p> <p><b>Step 8:</b> The crew will be checking charging and letdown system integrity based on:</p> <ul style="list-style-type: none"> <li>• VCT level decrease-Equal to the difference between seal injection and seal return.</li> <li>• PAB radiation levels-Stable or decreasing.</li> </ul> <p><b>NOTE: The outcome of these verifications is time dependant. The RNO step directs dispatching HP/NSO's to determine the source of the leak. If the source cannot be identified the step directs entering OS1202.02, Charging System Failure. The crew could also enter procedure OS1252.03, Area High Radiation abnormal.</b></p> <p><b>Step 9:</b> The Unit Supervisor should direct the PSO to establish excess letdown. Excess letdown is necessary to remove the inventory being added to the RCS via seal injection flow.</p> <p>NOTE: Do not exceed Excess Letdown Heat Exchanger outlet temperature of 175<sup>0</sup>F. Do not exceed Excess Letdown Heat Exchanger outlet pressure of 150 psig.</p> <p>The PSO establishes excess letdown as follows:</p> <ul style="list-style-type: none"> <li>• Opens CC-V-434, Excess Letdown Heat Exchanger Cooling Water isolation valve</li> <li>• Checks open CS-V-167 and 168, Excess Letdown Containment Isolation valves</li> <li>• Checks closed CS-HCV-123, Excess Letdown flow control valve.</li> <li>• Opens CS-V-175 and 176, Excess Letdown Containment Isolation valves.</li> <li>• Flushes Excess Letdown to RCDT, Aligns CS-V-170 to RCDT, Slowly opens CS-HCV-123 to flush for greater than 5 minutes, then closes CS-HCV-123.</li> <li>• Aligns CS-V-170 to Seal Return Header.</li> </ul>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
		<ul style="list-style-type: none"> <li>• Establish Excess Letdown flow via CS-HCV-123. The RO should limit flow such that excess letdown heat exchanger outlet temp is &lt;175°F and outlet pressure is &lt;150 psig.</li> <li>• Using the MPCS, the PSO will remove data point A0620, Letdown Outlet Flow, from the plant calorimetric calculation.</li> </ul> <p><b>Step 10:</b> PSO confirms RCS Leakage has stopped by verifying:</p> <ul style="list-style-type: none"> <li>• VCT level stable</li> <li>• Containment radiation particulate &amp; gas stable or decreasing</li> <li>• Containment temperature and pressure stable or decreasing</li> <li>• Containment sump A &amp; B level trends decreasing or normal</li> </ul> <p><b>Step 11:</b> US Minimizes effect of loss of Normal letdown:</p> <ul style="list-style-type: none"> <li>• Contacts Chemistry &amp; HP regarding loss of demin. flow and RCS hydrogen maintenance,</li> <li>• Verify Tech. Spec. Compliance: These T.S. 's are not currently applicable however, follow up will be needed if RCS chemistry samples indicate limits exceeded. <ul style="list-style-type: none"> <li>○ T.S. 3.4.7, Chemistry</li> <li>○ T.S. 3.4.8, Specific Activity</li> </ul> </li> </ul> <p>US goes to step 18</p> <p><b>Step 18:</b> US verifies Tech. Spec. Compliance:</p> <ul style="list-style-type: none"> <li>• T.S. 3.4.6.2, Reactor Coolant System Leakage</li> <li>• T.S. 3.4.10, Structural Integrity</li> </ul> <p>Since the leak was on the letdown System, this is not considered RCS leakage and T.S. does not apply.</p>

Following US review of Tech. Specs. At step 18 or at Chief Examiners discretion continue with the next Event.



<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
Event 4: ASDV Failure	<input type="checkbox"/> SELECT: MALFS <input type="checkbox"/> SELECT: Main Steam (Component) <input type="checkbox"/> SELECT: ptMSPK3004 <input type="checkbox"/> SELECT: Fail to Specified Value <input type="checkbox"/> INSERT FINAL VALUE: 1500 <input type="checkbox"/> INPUT RAMP TIME: 45 <input type="checkbox"/> SELECT: INSERT	<p><b>BOP (C), US (TS)</b></p> <p>“D” ASDV controlling pressure channel will fail high causing “D” ASDV to open.</p> <p><b>Alarms:</b> D5217, ASDV D Not Full Closed</p> <p>BOP operator recognizes “D” ASDV opening due to a failed pressure channel.</p> <p>Using “Skill of the Operator” the US will direct taking manual control of the ASDV and closing the valve. The BOP will place the ASDV controller in MANUAL and close the valve to stop uncontrolled power/reactivity excursion.</p> <p>The BOP/Crew should also refer to the Alarm Response Procedure for D5217 to verify response.</p> <ul style="list-style-type: none"> <li>• Verify S/G pressure and compare to ASDV controllers setpoint. <b>(instrument failure)</b></li> <li>• Adjust ASDV controller setpoint and/or transfer steam load the condenser as required. <b>(Not required)</b></li> <li>• If an ASDV has failed open:             <ul style="list-style-type: none"> <li>○ Places/Verifies ASDV control switch in close</li> <li>○ Locally isolates ASDV as necessary by closing MS-V-49. <b>(Not necessary)</b></li> <li>○ Places/Verifies controller for the ASDV in manual minimum</li> </ul> </li> </ul>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
		<ul style="list-style-type: none"><li>• The US evaluates Tech. Specs:<ul style="list-style-type: none"><li>○ TS 3.7.1.6, Atmospheric Relief Valves. The crew is already in Action A due to the “A” ASDV being tagged out. The US should determine that the “D” ASDV is operable, based upon the availability to control the valve using the “Jog” switch. No additional actions are required.</li><li>○ TS 3.6.3, Containment Isolation Valves. The valve remains operable as a containment isolation valve, no additional actions are required.</li></ul></li></ul>

**Following US review of Tech. Specs. or at Chief Examiners discretion continue with the next series of Events.**

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<p><b>Event 5:</b> The plant has a loss of offsite power.</p>	<p>Initiate the loss of power as follows:</p> <div style="border: 1px solid black; padding: 5px;"> <input type="checkbox"/> SELECT: <b>Malfunctions</b>  <input type="checkbox"/> SELECT: <b>Electrical Distribution</b>  <input type="checkbox"/> SELECT: <b>mfED038, Loss of Offsite Power.</b>  <input type="checkbox"/> SELECT: <b>INSERT</b> </div> <p>Trip the Turbine Driven EFW pump as follows:</p> <div style="border: 1px solid black; padding: 5px;"> <input type="checkbox"/> SELECT: <b>Sim Diagram: FW3</b>  <input type="checkbox"/> LEFT Click on <b>MS-V129</b>  <input type="checkbox"/> SELECT: <b>MANUAL ADJUST</b>  <input type="checkbox"/> SELECT: <b>Final Position = 0</b>  <input type="checkbox"/> SELECT: <b>INSERT</b> </div> <p><b>NOTE: This pump will not be restored until after the power restoration in ECA-0.0. Provide delay statements to control room if asked about status, i.e., can not reset valve, having difficulty with washer and need maintenance assistance.</b></p>	<p><b>PSO (M), BOP (M), US (M)</b></p> <p>The Crew enters E-0 and performs the Immediate Actions steps and exits at step 3 to ECA-0.0.</p> <p><b>ECA-0.0, LOSS OF ALL AC POWER</b></p> <p><b>Step 1:</b> The RO verifies that the reactor is tripped:</p> <ul style="list-style-type: none"> <li>• Checks reactor trip and bypass breakers open.</li> <li>• Checks neutron flux decreasing.</li> </ul> <p><b>Step 2:</b> The BOP verifies that the turbine is tripped:</p> <ul style="list-style-type: none"> <li>• Checks all stop valves closed.</li> <li>• Checks generator breaker open.</li> </ul> <p><b>NOTE:</b> The 'A' DG fails to start and no actions will recover the 'A' DG. The 'B' EDG will trip on Low Lube Oil Pressure.</p> <p><b>Step 3:</b> The PSO checks the RCS Isolated.</p> <ul style="list-style-type: none"> <li>• Pressurizer PORVs closed</li> <li>• Letdown isolation valves closed <ul style="list-style-type: none"> <li>CS-V-145</li> <li>Or</li> <li>RC-LCV-459</li> <li>Or</li> <li>RC-LCV-460</li> </ul> </li> <li>• Excess Letdown valve CS-V-175 and 176 are closed</li> <li>• RCS Sample Valves closed</li> </ul>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<b>Event 6</b> SW pump does not auto-start	<b>Instructor CUE:</b> <b>Delay restoration of EFW flow from the turbine driven pump until Bus E6 is re-energized and B EFW pump trips on Overcurrent. This satisfies a CCT.</b>	<p><b>Step 4:</b> The BOP should identify that there is no EFW flow. MS-V-129 is tripped closed but no indication due to LOP. The crew should utilize Step 4 RNO, and direct an NSO to locally start the steam driven EFW pump per OS1036.03, <b>RESETTING THE STEAM DRIVEN EFW PUMP TRIP VALVE.</b></p> <p><b>Step 5:</b> The crew should continue efforts to restore power. SEP's is available</p> <ul style="list-style-type: none"> <li>• BOP place UAT and RAT breaker switches in Pull-To-Lock.</li> <li>• BOP should attempt an emergency start of EDG 'A'. <b>Instructor Cue; A Slave relay start at K603 test switch S909 is unsuccessful.</b></li> </ul> <p>Neither EDG will be able to function. The RNO for this step is to use the SEP's diesel generator. SEP's is available.</p> <p><b>Upon Bus 6 power restoration from SEPs no Service water pump will start. The Motor Driven EFW Pump Trips on Overcurrent.</b></p> <p><b>CCT 2</b>            US directs <b>Step 5 RNO: B:</b> BOP performs the following:  <u>IF</u> SEPS bus feeder breaker is aligned to Bus 6, <u>THEN</u>:</p> <ol style="list-style-type: none"> <li>1) Places the following equipment control switches in PULL TO LOCK position:               <ul style="list-style-type: none"> <li>• DG 1B output breaker</li> <li>• CBS-P-9B</li> <li>• SI-P-6B</li> </ul> </li> <li>2) Manually closes SEPS Bus 6 breaker.</li> <li>3) US goes to Step 5f.</li> </ol>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
<p>Event 7 EFW pump trip</p>	<p>When the crew dispatches an NSO to the field to reset the EFW pump, perform the following (around step 5g of ECA-0.0):</p> <div style="border: 1px solid black; padding: 5px;"> <p><input type="checkbox"/> Using Panel Graphic FW3: <b>Open FW-V-346</b></p> <p><input type="checkbox"/> <b>SELECT: Component Remote Functions</b></p> <p><b>Summary</b></p> <p><input type="checkbox"/> <b>SELECT: rmvMSV129</b></p> <p><input type="checkbox"/> <b>SELECT: Manual Adjust</b></p> <p><input type="checkbox"/> <b>SELECT: 1.0</b></p> <p><input type="checkbox"/> <b>SELECT: INSERT</b></p> </div>	<p><b>Step 5f:</b> Verifies EPS – ACTUATED <u>AND</u> SEQUENCING</p> <p><b>Step5g:</b> Crew checks equipment loaded:</p> <ul style="list-style-type: none"> <li>• Charging pump</li> <li>• Thermal barrier cooling pump</li> <li>• PCCW pump</li> <li>• EFW pump</li> </ul> <p><b>BOP (C): The EFW Pump will trip on Overcurrent when the Bus is re-energized, requiring the Turbine Driven EFW Pump to be restored to recover feedwater flow and SG level.</b></p> <ul style="list-style-type: none"> <li>• SW or cooling tower pump NOT running, BOP must Reset RMO and manually start SW-P-41D.</li> </ul> <p><b>BOP (C), CCT 1: Sub step g. has the operator verify one ocean SW pump or cooling tower pump running. The crew should identify that Train 'B' has no pumps running. The RNO for the step directs manually starting a SW pump. The RMO relay needs to be reset to restart the SW pump.</b></p> <ul style="list-style-type: none"> <li>• BOP Checks AC emergency busses – AT LEAST ONE ENERGIZED</li> <li>• BOP Checks AC emergency busses – ALL ENERGIZED</li> <li>• BOP Checks emergency bus – NOT POWERED BY EMERGENCY DIESEL . US refers to Step 5j. RNO: If Emergency Bus is powered by SEPS, then maintain SEPS load limit per ATTACHMENT A while performing actions in other procedures in effect.</li> </ul>
<p>Event 6 (Continued) Restoration of SW</p>		

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
	<p data-bbox="447 1295 1087 1360">If SI was actuated, the crew will continue with E-0 step 5.</p>	<ul data-bbox="1171 272 1944 337" style="list-style-type: none"> <li>• US returns to procedure and step in effect. FRPs shall now be implemented as required.</li> </ul> <p data-bbox="1125 342 1944 509"><b>If a RED path exists at this time for Heat Sink, the crew will transition to FR-H.1, Response to Loss of Secondary Heat Sink, and verify actions to recover the turbine driven EFW pump are successful to restore &gt;500 gpm EFW flow.</b></p> <p data-bbox="1125 548 1871 613">Crew Returns to E-0 Step 3 as the procedure and step in effect:</p> <p data-bbox="1125 618 1885 683"><b>Step 3A:</b> BOP verifies AC emergency busses - AT LEAST ONE ENERGIZED</p> <p data-bbox="1125 688 1871 818"><b>Step 3B:</b> BOP responds AC emergency busses – BOTH NOT ENERGIZED. US refers to 3B RNO: Try to restore power to other train from emergency diesel generator or offsite source as time permits. Do <u>NOT</u> use SEPS.</p> <p data-bbox="1125 823 1507 855"><b>SEPS is supplying Bus E6.</b></p> <p data-bbox="1125 860 1625 893"><b>Step 4:</b> PSO Checks If SI Is Actuated:</p> <p data-bbox="1171 898 1808 963">Checks SI annunciators NOT lit for train A and B US Refers to RNO to Check if SI is required:</p> <ul data-bbox="1192 979 1871 1287" style="list-style-type: none"> <li>• RCS pressure - LESS THAN 1800 PSIG</li> <li>• Pressurizer level - LESS THAN 7%</li> <li>• Containment pressure - GREATER THAN 4 PSIG</li> <li>• RCS subcooling - LESS THAN 40°F</li> <li>• Any SG pressure - LESS THAN 585 PSIG</li> </ul> <p data-bbox="1125 1292 1671 1360">SI should NOT be required: <u>IF</u> SI is required, <u>THEN</u> manually actuate.</p>

<u>EVENT</u>	<u>INSTRUCTION</u>	<u>COMMENTS</u>
	<b>SI should not be required and crew transitions to ES-0.1, Reactor Trip Response.</b>	<p><u>IF</u> SI is <u>NOT</u> required, <u>THEN</u> go to ES-0.1, REACTOR TRIP RESPONSE, Step 1</p> <p>Anticipated AOP/EOP flow-path: OS1201.08, OS1201.02, E-0, ECA-0.0, E-0, ES-0.1</p>

Terminate examination when the crew transitions to ES-0.1 and stabilizes RCS temperature with the ASDVs, or processes past step 5 of E-0 or at Chief Examiner direction.

**Instructor NOTE: restore A-Point A0620, Letdown Outlet Flow, to scan at the end of the scenario.**

**Emergency Plan:**

The charging system leak does not qualify as an RCS leak, so no e-plan call is made based on this event.

Post scenario JPM- Alert E-plan classification on:

- Alert based upon EAL SA4, Unplanned Loss of most or all safety system annunciation or indication in Control Room (RDMS) with a significant transient in progress.
- Alert based upon EAL SA5, Power to AC emergency buses reduced to a single power source for >15 minutes such that any additional single failure would result in station blackout. (as validated)
- **IF** 15 minutes had elapsed from the start of Event 5 (LOP Event) until the SEPS breaker was closed at ECA 0.0 step 5.b RNO, then SAE on EAL SS1, Both AC buses E5 and E6 de-energized for > 15 minutes

**CREW CRITICAL TASKS**

1. Manually start an ocean Service Water Pump or a Cooling Tower Pump.
2. Energize at least one AC Emergency bus before transition out of E-0, Reactor trip or Safety Injection, unless the transition is to ECA 0.0, in which case the critical task must be performed before placing safeguards equipment in the pull to lock position as directed by Step 6 of ECA-0.0.