# **ATTACHMENT 2**

Limerick Generating Station Docket Nos. 50-352 and 50-353

License Amendment Request Regarding TS Table 3.3.2-2, Item 4e, HPCI Equipment Room Delta Temperature High Isolation Trip Setpoint and Allowable Value Change

Loop Uncertainty Calculation TE-055-1N028B, dated 11/20/09

1

|--|

LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 1 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

TABLE OF CONTENTS

# SECTION

- 1.0 PURPOSE
- 2.0 DESIGN BASIS
- 3.0 ASSUMPTIONS
- 4.0 REFERENCES
- 5.0 ATTACHMENTS
- 6.0 ANALYSIS
- 7.0 RESULTS

# Support Data Sheet Attachments

Attachment	1:	Loop Uncertainty Session Data
Attachment	2:	Calculation Results
Attachment	3:	Loop Data and Configuration
Attachment	4:	Loop Calibration Data
Attachment	5:	Instrument Data
Attachment	6:	Vendor Data
Attachment	7:	Location Data
Attachment	8:	Process Concerns
Attachment	9:	Device Dependencies





LOOP UNCERTAINTY CALCULATION				
Loop Number: TE-055-1N028B	01	Page 2 of 25		
Originator: COLLIER KB	Date: 11/16/09	Rev: 0		
Reviewer: AJMERA M.	Date: 11/17/09			
Approver: GEORGE RT	Date: 11/20/09			

#### 1.0 PURPOSE

This section includes the Objective, Limitations, Conclusions, and the Applicability Statement of this calculation.

#### 1.1 Objective

The purpose of this calculation is to determine the Allowable Value (AV), Nominal Trip Setpoint (NTSP) and Actual Trip Setpoint (ATSP) for a high differential temperature steam source isolation by the Leak Detection System at the Limerick Generating Station (LGS). The increasing differential temperature signal is sensed by channel "B" of the High Pressure Coolant Injection (HPCI) Compartment Leak Detection Instrument, TE-055-1N028B & TE-055-1N029B.

This calculations is performed utilizing environmental conditions for a High Energy Line Break (HELB) accident scenario.

A summary of the calculation results may be found in Section 7.0 of this calculation.

Other redundant/mirror loops for which the results of this calculation are applicable may be found in Section 1.4, Applicability.

#### 1.2 Limitations

The Max and Min Acceptable Limits calculated in Section 7.8 are not authorized for use in the PECo maintenance program by this revision of the calculation.

This calculation is produced utilizing the harsh environmental conditions for a HELB accident scenario. (See Section 2.2.5).

The appropriate use of this calculation to support design or station activities, other than those specified in Section 1.1 of this calculation, is the responsibility of the user.

#### 1.3 Conclusions

The Upper Allowable Value of 108.5 DEGF was calculated by the software. The Upper Allowable Value is the result displayed in Section 7.7 of this calculation.

A Lower Allowable Value of 99.5 DEGF was determined using the calculation results and engineering judgement. The calculation produces an Upper Allowable Value of 108.5 DEGF. The Upper Allowable Value (108.5 DEGF) is subtracted from the Upper Analytical/Process Limit (113 DEGF) to obtain a value of 4.5 DEGF which represents a two (2) sigma one sided Loop Uncertainty which does not contain any instrument

LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 3 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

drift. This amount (4.5 DEGF) is then added to the Lower Analytical/Process Limit of 95 DEGF to obtain the 99.5 DEGF value (Lower Allowable Value).

An analysis of the proposed changes to the current station process setpoint values in relation to the results of this calculation has been performed and it has been concluded that the results of this calculation support the proposed changes to the current station setpoint values (Ref 4.15).

An Insulation Resistance (IR) Calculation for TE-055-1N028B Configuration 01 determined that the IR error associated with this instrument loop was insignificant (< 0.001% of loop span). It was therefore concluded that no IR effects would be included in this calculation. This IR Calculation resides in the IISCP software and is utilized as further justification for the position taken by PECo previously that IR concerns do not have any adverse effects on system operability at LGS.

The environmental conditions for the locations of the temperature elements for the redundant/mirror loops are the same/equivalent or not as harsh as those specified for the temperature element for this loop. Since the variables in this calculation are the same/equivalent or more restrictive, this calculation is valid for the redundant/mirror loops listed in Section 1.4.

#### 1.4 Applicability

A data evaluation has been performed in order to determine which, if any, redundant/mirror instrument loops are bound by the results of this calculation (the "base" calculation). The data evaluation results validate that this "base" calculation is applicable to the following Loop Affiliation Numbers:

- \* TE-055-1N028D Configuration 01 TE-055-1N029D
- \* TE-055-2N028B Configuration 01 TE-055-2N029B
- \* TE-055-2N028D Configuration 01 TE-055-2N029D

The results of this "base" calculation are bounding values for the instrument loops listed above based on such factors as instrument manufacturer and model number, instrument location environmental parameters, and actual installation and use of the instrument in the measurement of the process variable.

The only difference among the three redundant/mirror loops is the difference in environmental data for each loop due to the physical locations of each thermocouple, which does not introduce any additional uncertainty.







LOOP UNCERTAINTY CALCULATION				
Loop Number: TE-055-1N028B	01	Page 4 of 25		
Originator: COLLIER KB	Date: 11/16/09	Rev: 0		
Reviewer: AJMERA M.	Date: 11/17/09			
Approver: GEORGE RT	Date: 11/20/09			

2.0 DESIGN BASIS

This section includes the Technical Background and Design Input information relevant to this calculation.

2.1 Technical Background

High temperature in the space in which the HPCI steam lines are located outside the primary containment could indicate a breach in a HPCI steam line. The automatic closure of the HPCI isolation valve prevents the excessive loss of reactor coolant and the release of significant amounts of radioactive material from the nuclear system process barrier. When high temperatures occur in the HPCI steam line space, the inboard and outboard steam supply isolation valves are isolated.

Pairs of temperature elements monitor for high ventilation air differential temperature and compartment ambient temperature. One sensor of each pair is associated with one of the logic divisions; the other is associated with the other division.

- 2.2 Design Input
  - 2.2.1 Calculation -1001 specifies 113.0 DEGF as the Upper Analytical/Process Limit (AL) and 95.0 DEGF as the Lower Analytical/Process Limit (AL) (Ref 4.11).
  - 2.2.2 This calculation includes any applicable System Rerate Design/Operating Conditions and Impacts as a result of power rerate analyses per the guidelines contained in Specification NE-177 (Ref 4.6 & 4.8).
  - 2.2.3 Additional margin of 4.5 DEGF was added to this calculation to support the setpoint recommended by Calculation -1001. Of this 4.5 DEGF, 4.5 DEGF is assigned margin to support the IISCP Loop Leave Alone Zone (LAZ)guidelines as discussed in Section 2.2.6 and to account for the calibration practices of the instrument channels.

The calibration practices of the instrument channels are accounted for by providing additional margin for M&TE beyond that in Section 6.2.2. This is done to provide 1% to account for the setting tolerance of the TIS. This also provides additional margin beyond that portion allocated in Section 6.2.1 to cover the 1% required accuracy for the TE. Setting Tolerance is not provided specifically for the TE since it is not calibratable.

- 2.2.4 Based on engineering judgement, S1 has been included as a process consideration. This consideration results in a conservatively rounded Allowable Value that supports the current Tech Spec revision request.
- 2.2.5 The selection of HELB environmental conditions for the performance of this calculation is based on engineering judgement and system knowledge. The environmental conditions for a HELB accident





LOOP UNCERTAINTY CALCULATION				
Loop Number: TE-055-1N028B	01		Page 5 of 25	
Originator: COLLIER KB	Date:	11/16/09	Rev: 0	
Reviewer: AJMERA M.	Date:	11/17/09		
Approver: GEORGE RT	Date:	11/20/09		

scenario are the most severe conditions to which the thermocouple sensors may be exposed and still be expected to perform their safety function.

- 2.2.6 The delta between the Allowable Value and the Actual Trip Set Point within this calculation is 4.5 DEGF which meets or exceeds the IISCP Program Guidance of greater than one times the LAZ (Ref 4.3)
- 2.2.7 The Setting Tolerances for the TIS in this calculation were reallocated from the region between AL and AV to the region between NTSP and ATSP in order to obtain the target Tech Spec setpoint. This reallocation was accomplished by assigning 0.0 to the Setting Tolerance of each instrument and verifying that the assigned margin amount was greater than one LAZ. Since the LAZ is equal to the square root of the sum of the squares of the Setting Tolerances, verification that the assigned margin is greater than one LAZ insures that the effects of the Setting Tolerances, verification that the determination of the ATSP. No specific setting tolerance was provided for the T/C since it is not calibratable.
- 2.2.8 All other design inputs to this calculation are documented on the Supporting Data Sheet Attachments.

#### 3.0 ASSUMPTIONS

3.1 Assumptions Not Requiring Confirmation

3.1.1 None

3.2 Assumptions Requiring Confirmation

3.2.1 None

#### 4.0 REFERENCES

4.1 Limerick Generating Station Updated Final Safety Analysis Report (UFSAR), Revision 14 (dated 9/29/08)

Section 5.2.5.2.2 - Detection of Abnormal Leakage Outside
 the Primary Containment;

4.2 Limerick Generating Station Technical Specifications, Unit 1, Amendment 161, (dated 8/30/02)

Table 3.3.2-2 Item 4.e.

4.3 IISCP-PP-93-001, Revision 1 - Program Plan for the Implementation of Phase I of the PECo Improved Instrument Setpoint Control Program (IISCP) (Setpoint Methodology Reference).

4.4 M-171, Revision 0016, Limerick Generating Station Units 1&2







LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 6 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

Environmental Service Conditions Specification. (Location Data reference).

- 4.5 Master Calibration Sheets generated in accordance with PECo procedure IC-11-50014 for TE-055-1N028B dated 08/30/01, TE-055-1N029B dated 8/30/01, & TIS-025-101B dated 09/03/09.
- 4.6 Philadelphia Electric Letter from G.C. Storey to G.R. Hull General Electric Company, subject "Final OPL-3 for Limerick ARTS/MELLLA Analysis". This document contains Limerick 1 Reload 4(cycle 5) Resolved OPL-3 Forms that include ARTS/MELLLA at rerate conditions Dated 03/09/93. (Power Rerate Information Reference).
- 4.7 General Electric Design Specification Data Sheets (DSDS) A61-4040-L-004, Revision 0005 (Design Basis Reference).
- 4.8 NE-177, Revision 0001, Nuclear Safety Related Specification for Limerick Generating Station Units 1&2 Power Rerate Operating Conditions (Power Rerate Information Reference).
- 4.9 Calculation -1001 Revision 0004 "Compartment Temperature Transients for Steam and Water Leaks" (Analytical/Process Limit Reference)
- 4.10 Calculation -2208 Revision 0003 "RHR Compartment Pressurization due to Steam Line Break to RHR Hx" (Design Basis Reference).
- 4.11 Calculation LM-0400 Revision 0004 "HPCI and RCIC Pump Room Temperature Response Following a Small Break LOCA, Normal & Power Rerate Conditions" (Design Basis Reference).
- 4.12 Calculation LE-0036 Revision 0001 "Equivalency Evaluation between G.E. Numac LDM and Riley Temperature Instrumentation to demonstrate Accuracy and Support the use of existing Setpoints for the Steam Leak Detection System, LGS Units 1 and 2" (Vendor Information Reference)
- 4.13 Modification P-00212 Revision 0000 "HPCI/RCIC EQ Upgrade" (Design Basis Reference).
- 4.14 EQRR P-300 Revision "Pyco Temperature Elements" (Vendor Information Reference)

#### 5.0 ATTACHMENTS

5.1 See Supporting Data Sheet Attachments located within this calculation.

# 6.0 ANALYSIS

6.1 Loop Effects

6.1.1 LOOP ID NO.: TE-055-1N028B

Configuration: 01





LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 7 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

6.1.2 Loop Function: STEAM LEAK DETECTION HPCI PIPEWAY

6.1.3 Configuration Description: HI DIFFERENTIAL TEMP TRIP

6.1.4 Loop Instrument List

<u>Device</u>	ID Number	Function	<u>Number</u>
1	TE-055-1N028B	IO	0
2	TE-055-1N029B	IO	0
3	TIS-025-101B	S	0

6.1.5 Device Dependency

<u>Device</u>	Environment	Power	<u>Calibration</u>	Radiation
1.	A	А	A	A
2	А	А	A	А
3	В	в	В	В

6.1.6 Device Dependency References

Environmental:	N/A
Power:	N/A
Calibration:	N/A
Radiation:	N/A

6.1.7 PMA and PEA Effects

Туре	<u>Magnitude</u>	<u>A/N</u>	<u>Sign</u>
PMA	0.00000	N	
PEA	0.00000	N	
IR	0.00000		

References PMA: PEA: IR: SEE SECTION 1.3

6.1.8 Miscellaneous Random and Bias Effects

		Dependent	Dependent		
Type	<u>Magnitude</u>	Instrument	<u>Uncertainty</u>	A/N	<u>Siqn</u>
S1	0.00992			N	R
S2	0.00000			N	
S3	0.00000			N	
R1	0.00000			N	
R2	0.00000			N	
R3	0.00000			N	
Refer	ences				

...

References S1: SEE SECTION 2.2.4 S2: S3: R1: R2: R3:

6.1.9 Basis



Point of Interest:0Accident:HELBPressure Effects:Independent



LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 8 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

6.2 Device Effects

6.2.1 Device Accuracy (CA) CA = va/S or Setting Tolerance (whichever is greater) Where: va = vendor's stated accuracy = instrument's calibrated span S = instrument's range R 6.2.1.1 TE-055-1N028B va = 0.75% \* S\*0.66S = 300R = 3.500e+002Setting tolerance = 0.00000 CA = 0.004956.2.1.2 TE-055-1N029B va = 0.75%\*S\*0.66 S = 300R = 3.500e+002 Setting tolerance = 0.00000CA = 0.004956.2.1.3 TIS-025-101B va = 1.0% \* S\*0.66S = 300R = 3.500e+002Setting tolerance = 0.00000 CA = 0.006606.2.2 Device M&TE Allowance MTE = CA + marginWhere: CA = device calibration accuracy margin = additional margin supplied by calculation originator 6.2.2.1 TE-055-1N028B CA = 0.00495Margin = 0.00000MTE = 0.004956.2.2.2 TE-055-1N029B CA = 0.00495Margin = 0.00000MTE = 0.004956.2.2.3 TIS-025-101B

CA = 0.00660 Margin = 0.00000



S



Approver: GEORGE RT MTE = 0.00660

Reviewer: AJMERA M.

Loop Number: TE-055-1N028B

Originator: COLLIER KB

6.2.3 Device Drift  $D = vd * (\sqrt{tc * 1.25 / td}) / s$ Where: vđ = vendor's stated drift specification tđ = vendor's drift time specification = instrument's calibration period tc = instrument's calibrated span S = instrument's range R 6.2.3.1 TE-055-1N028B vd = 0.0td = 1.0tc = 731S = 300R = 3.500e+002D = 0.000006.2.3.2 TE-055-1N029B vd = 0.0td = 1.0tc = 732S = 300R = 3.500e+002D = 0.000006.2.3.3 TIS-025-101B vd = 0.233%\*S\*0.66 td = 31.tc = 731S = 300R = 3.500e+002D = 0.008356.2.4 Device Static Pressure  $SPE = \sqrt{(SPz^2 + SPs^2)}$ (for independent pressure effects) SPE = SPz + SPs(for dependent pressure effects) SPz = SPz \* |Po - Pc| / S SPs = SPs \* |Po - Pc| / S / S Where: = vendor's stated zero static pressure effect SPz SPs = vendor's stated span static pressure effect = normal operating pressure Po PC = calibrated pressure = instrument's calibrated span S = instrument's range R Note: Static pressure effects are relevant to sensors only. 6.2.4.1 TE-055-1N028B SPS = 0.0

LOOP UNCERTAINTY CALCULATION

01

Date: 11/16/09

Date: 11/17/09

Date: 11/20/09

Page 9 of 25

Rev: 0





Loop Number: TE-055-1N028B		10 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	
SPZ = 0.0 $Po = 0.00$ $Pc = 0.00000$ $S = 300$ $R = 3.500e+002$ $SPs = 0.00000$ $SPz = 0.00000$ $SPE = 0.00000$		
6.2.4.2 TE-055-1N029B		
SPS = 0.0 SPZ = 0.0 Po = 0.00 Pc = 0.00000 S = 300 R = 3.500e+002 SPs = 0.00000 SPz = 0.00000 SPE = 0.00000		
6.2.4.3 TIS-025-101B		
Sensor is not 'Y' (see attachmen	t 9).	
6.2.5 Device Over Pressure		
<pre>OPE = vope *  Pa - Pm  / S (f OPE = vope / S (f Where: vope = vendor's stated over pre Pa = maximum operating pressu Pm = instrument's design pres S = instrument's calibrated R = instrument's range X =  Pa - Pm </pre>	or linear devices) or non-linear devices) ssure effect re sure span	
Note: Over pressure effects are maximum operating pressure is gr	relevant to sensors only, where eater than instrument's design	e the pressure.
6.2.5.1 TE-055-1N028B		
vope = $0.0$ Pa = $0.00$ Pm = $0.00$ S = $300$ R = $3.500e+002$ OPE = $0.00000$		
6.2.5.2 TE-055-1N029B		

vope = 0.0
Pa = 0.00
Pm = 0.00
S = 300
R = 3.500e+002
OPE = 0.00000

6.2.5.3 TIS-025-101B



.

•



LOOP UNCERTAINTY CALCULATION 01 Page 11 of 25 Loop Number: TE-055-1N028B Date: 11/16/09 Originator: COLLIER KB Rev: 0 Date: 11/17/09 Reviewer: AJMERA M. Date: 11/20/09 Approver: GEORGE RT Sensor is not 'Y' (see attachment 9). 6.2.6 Device Drift Temperature DTE = vte \* dT / S(for linear devices) DTE = vte / S(for non-linear devices) Where: vte = vendor specified temperature effect = (Normal Temp -  $68^{\circ}$  F) dT = instrument's calibrated span S = instrument's range R 6.2.6.1 TE-055-1N028B vte = 0.0S = 300R = 3.500e+002Normal temp = 115.00 DTE = 0.000006.2.6.2 TE-055-1N029B vte = 0.0S = 300R = 3.500e+002Normal temp = 117.00 DTE = 0.000006.2.6.3 TIS-025-101B vte = 0.0S = 300R = 3.500e+002Normal temp = 82.00 DTE = 0.000006.2.7 Device Accuracy Temperature ATE = vte \* dT / S(for linear devices) ATE = vte / S(for non-linear devices) Where: = vendor specified temperature effect vte = |accident temperature - normal temperature| dT= instrument's calibrated span S R = instrument's range 6.2.7.1 TE-055-1N028B

```
vte = 0.0
S = 300
R = 3.500e+002
Normal temp = 115.00
Accident temp = 306.83
ATE = 0.00000
```

6.2.7.2 TE-055-1N029B vte = 0.0





```
LOOP UNCERTAINTY CALCULATION
Loop Number: TE-055-1N028B
                                           01
                                                                 Page 12 of 25
Originator: COLLIER KB
                                           Date: 11/16/09
                                                                        Rev: 0
Reviewer: AJMERA M.
                                           Date: 11/17/09
Approver: GEORGE RT
                                           Date: 11/20/09
     R = 3.500e+002
      Normal temp = 117.00
     Accident temp =
                        307.89
      ATE = 0.00000
      6.2.7.3 TIS-025-101B
     vte = 0.0
     S = 300
R = 3.500e+002
                       82.00
     Normal temp =
      Accident temp =
                         82.00
      ATE = 0.00000
      6.2.8 Device Humidity
     HE = dH * vhe / SHE = vhe / S
                              (for linear devices)
                              (for non-linear devices)
     Where:
      vhe
          = vendor's stated humidity specification
      S
            = instrument's calibrated span
           = instrument's range
     R
           = |accident humidity - normal humidity|
      dH
      6.2.8.1 TE-055-1N028B
     vhe = 0.0
      S = 300
      R = 3.500e+002
      Accident hum =
                       100.00
      Normal hum =
                      90.00
     HE = 0.00000
      6.2.8.2 TE-055-1N029B
      vhe = 0.0
      S = 300
      R = 3.500e+002
      Accident hum =
                      100.00
      Normal hum =
                      90.00
     HE = 0.00000
      6.2.8.3 TIS-025-101B
      vhe = 0.0
      S = 300
      R = 3.500e+002
      Accident hum =
                        90.00
                      90.00
      Normal hum =
      HE = 0.00000
      6.2.9 Device Accuracy Radiation
      ARE = vre * DeltaRad / S
                                    (for linear devices)
      ARE = vre / S
                                    (for non-linear devices)
     Where:
                  = vendor specified radiation effect
      vre
                  = (accident radiation - normal radiation)
      DeltaRad
      S
                  = instrument's calibrated span
```

```
9
```

R

6.2.9.1 TE-055-1N028B

```
LOOP UNCERTAINTY CALCULATIONLoop Number: TE-055-1N028B01Page 13 of 25Originator: COLLIER KBDate: 11/16/09Rev: 0Reviewer: AJMERA M.Date: 11/17/09Approver: GEORGE RTDate: 11/20/09
```

= instrument's range

vre = 0.0S = 300R = 3.500e+002Accident rad = 4.93000Normal rad = 0.90500ARE = 0.000006.2.9.2 TE-055-1N029B vre = 0.0S = 300R = 3.500e+002Accident rad = 1.76000Normal rad = 0.90500ARE = 0.000006.2.9.3 TIS-025-101B Environmental qualifier is not 'Y' (see attachment 5). 6.2.10 Device Seismic VSE = SRS \* vse / S (for linear devices) VSE = vse / S(for non-linear devices) Where: = vendor's stated seismic specification vse = instrument's calibrated span S R = instrument's range = seismic response envelope SRS 6.2.10.1 TE-055-1N028B Seismic class is not '1' in Pims (see attachment 5). 6.2.10.2 TE-055-1N029B Seismic class is not '1' in Pims (see attachment 5). 6.2.10.3 TIS-025-101B Seismic class is not '1' in Pims (see attachment 5). 6.2.11 Device Power PSE = pss \* pse / SWhere: pse = vendor's stated power supply specification = device power supply stability pss = instrument's calibrated span S = instrument's range R 6.2.11.1 TE-055-1N028B pse = 0.0S = 300



LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 14 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

```
R = 3.500e+002
pss = 0.000
PSE = 0.00000
6.2.11.2 TE-055-1N029B
pse = 0.0
S = 300
R = 3.500e+002
pss = 0.000
PSE = 0.0000
6.2.11.3 TIS-025-101B
pse = 0.0
S = 300
R = 3.500e+002
pss = 12.000
PSE = 0.0000
```

# 7.0 RESULTS

7.1 Loop Accuracy Allowance (AL)

AL\_norm = A + OP + SP + PEAL\_accid = AL\_norm + S (for S > TE + RE + AHE)= AL\_norm + TE + RE + AHE AL\_accid (for  $S \ge TE + RE + AHE$ ) Where: Α  $= \Sigma CA^2$ =  $\Sigma ATE^2$ TE=  $\Sigma$  OPE<sup>2</sup> OP =  $\Sigma$  SPE<sup>2</sup> SP  $= \Sigma ARE^{2}$ RE AHE  $= \Sigma HE^2$ =  $\Sigma$  VSE<sup>2</sup> S =  $\Sigma$  PSE<sup>2</sup> PEAL= 0.00009 7.2 Loop Drift Allowance (DL) DL = DE + DTWhere:  $DE = \Sigma D^2$  $= \Sigma DTE^{2}$ DT DL= 0.00007 7.3 Loop Calibration Allowance (CL) CL = V + MWhere: =  $\Sigma$  (setting tolerance)<sup>2</sup> V =  $\Sigma$  MTE<sup>2</sup> М = 0.00014CL



```
LOOP UNCERTAINTY CALCULATION
                                             01
Loop Number: TE-055-1N028B
                                                                    Page 15 of 25
                                             Date: 11/16/09
                                                                           Rev: 0
Originator: COLLIER KB
                                             Date: 11/17/09
Reviewer: AJMERA M.
                                             Date: 11/20/09
Approver: GEORGE RT
      7.4 TLU
      (Positive)TLUp = [IR + PMAp + PEAp + PCp + PMAo + PEAo + Pco +
                        \sqrt{(AL + CL + DL + PMAr + PEAr + PCr)} * Loop span
       (Negative)TLUn = [- PMAn - PEAn - PCn - PMAo - PEAo - PCo + -
                        \sqrt{(AL + CL + DL + PMAr + PEAr + PCr)} * Loop span
      All other variables as previous defined.
      TLUp = 6.01696 DEGF
      TLUn = -6.01696 DEGF
      7.5 NTSP
      (Increasing) NTSP = limit + [- PMAn - PEAn - PCn - PMAo - PEAo - PCo +
      (1.645 / \text{sigma}) * - \sqrt{(\text{AL} + \text{CL} + \text{DL} + \text{PMAr} + \text{PEAr} + \text{PCr})}  * Loop span
      (Decreasing) NTSP = limit + [IR + PMAp + PEAp + PCp + PMAo + PEAo + PCo
      + (1.645 / sigma) * √ (AL + CL + DL + PMAr + PEAr + PCr) ] * Loop span
      Where:
      limit = loop analytical or process limit
                113.00 DEGF
      limit =
      sigma =
                  2
      NTSP = 108.05105 DEGF
      7.6 ATSP
       (Increasing) ATSP = NTSP + margin
       (Decreasing) ATSP = NTSP - margin
      Where:
      margin = additional margin supplied by calculation originator
      margin = -4.05000
      ATSP
             = 104.00105 DEGF
      7.7 Allowable Value
       (Decreasing) AV = limit + [IR + PMAp + PEAp + PCp + PMAo + PEAo + Pco +
       (1.645 / \text{sigma}) * \sqrt{(AL + CL + PMAr + PEAr + PCr)} + Loop span
       (Increasing) AV = limit + [- PMAn - PEAn - PCn - PMAo - PEAo - Pco +
       (1.645 / sigma) * - \sqrt{(AL + CL + PMAr + PEAr + PCr)} * Loop span
      All other variables as previously defined.
      AV = 108.50034 DEGF
```





LOOP UNCERTAINT	Y CALCULATION
Loop Number: TE-055-1N028B	01 Page 16 of 25
Originator: COLLIER KB	Date: 11/16/09 Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09
Approver: GEORGE RT	Date: 11/20/09
ATTACHMENT 1: Session Data	
Station: LG Unit: 1	
Responsible Branch: LEDE	
Safety Related (Y/N): Y	
Description: HPCI EQUIPMENT ROOM DELTA T	'EMPERATURE - HIGH
System Number: 055	
Structure: RX ENCL	
Component: TE-55-1N28/29B TIS-2	
Revision Description: LOWER AV & ATSP TO	0 108.5 & 104.0 PER ECR 09-00438
Vendor Calc Number: N/A	Revision: NA
Other Calculations: N	
Provides info TO: N/A	
Receives info FROM: LE-0036 LM-0400	-1001 -2208
Supercedes: N/A	

1.	Accident type:	HELB
2.	Pressure effects dependent or independent (I/D):	Independent
3.	Process increasing, decreasing or neither (I/D/N):	Increasing
4.	Input point of interest:	0
5.	Include additional margin for actual setpoint calculation:	Yes
6.	Additional margin to be used:	-4.05000



.

LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 17 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

# Attachment 2: Calculation Results

				Tempera	ature			
Device	F	N	Accuracy	<u>Normal</u>	<u>Accident</u>	<u>Humidity</u>	<u>Tol</u>	Pwr Supp
TE-055-1N028B	IO	0	0.00495	0.00000	0.00000	0.00000	0.00000	0.00000
TE-055-1N029B	IO	0	0.00495	0.00000	0.00000	0.00000	0.00000	0.00000
TIS-025-101B	S	0	0.00660	0.00000	0.00000	0.00000	0.00000	0.00000
<u>Device</u> TE-055-1N028B TE-055-1N029B TIS-025-101B	<u>F</u> IO IO S	<u>N</u> 0 0	<u>SPE</u> 0.00000 0.00000 N/A	<u>Rad Acc</u> 0.00000 0.00000 N/A	<u>M&amp;TE</u> 0.00495 0.00495 0.00660	<u>Drift</u> 0.00000 0.00000 0.00835	<u>Ovr Pres</u> 0.00000 0.00000 N/A	<u>Seismic</u> N/A N/A N/A

			Process Co	ncerns		
		Normal			Accident	
	<u>Positive</u>	Negative	<u>Offsetting</u>	<u>Positive</u>	<u>Negative</u>	<u>Offsetting</u>
PMA	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000
PEA IR	0.00000	0.00000	0.00000	0.00000 0.00000	0.00000	0.00000
Other	0.00000	0.00000	0.00000	0.00000	0.00000	0.00000

			Loop	Results		
TLU*	6.01696	<u>Normal</u> -6.01696	-	6.0169	96	<u>Accident</u> -6.01696
AL		0.00009				0.00009

NITCDX	Increasing	Decreasing	Increasing	Decreasing
AV*	108.50034	N/A N/A	108.50034	N/A
ATSP*	104.00105	N/A	104.00105	N/A

Additional Margin: -4.05000 DL: 0.00007 CL: 0.00014

\* These values are in DEGF



LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 18 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

ATTACHMENT 3: Loop Data

Loop Number: TE-055-1N028B

Instruments	Function	Num	1	2	3	4	5	6	7	8	9	10
TE-055-1N028B	IO	0	Х	Х						[		
TE-055-1N029B	IO	0	X	Х								
TIS-025-101B	S	0	Х									
TIS-025-101B	2	0		Х								
		0										
		0							Ι	Γ		
		0			Ţ		1					
		0					[		Γ			
		0					T					
		0				Ι						
· · ·	Configura	tion	Desc	crip	tior	າຣ				and an international states		
1: HI DIFFERENTIAL TEMP T	RIP		6:									
2: DIFFERENTIAL TEMP IND			7:								······································	
3:			8:									
4:			9:									
5:			10:									

Loop Description: STEAM LEAK DETECTION HPCI PIPEWAY

Originator: COLLIER KB Date: 11/12/09 Revision: 00

ATTACHMENT 4: Loop Calibration Data

Loop Number: TE-055-1N028B

Configuration: 01

		P				
	Units		Min	Max	Normal	Trip
Process Temperature		0.00		0.00	0.00	0.00
Process Radiation						
		0.000e+000		0.000e+000	0.000e+000	0.000e+000
Process Humidity		0.00		0.00	0.00	0.00
Process Pressure		0.00		0.00 0.00		0.00
Loop Span	DEGF	-150.00		150.00 Sigma: 2		
	Value	e Units				Value
Setpoint	104.0	00	DEGF	Loop Settin	g Limit	0.000
Reset	3.0	00	DEGF	Loop Leave	Alone Zone	3.000
Allowable 108.5		5 DEGF		Loop Calcul	0.000	
Design/safety Limit	Design/safety Limit 0.00			Calibration Frequency		731
Analytical/Proc Limit	113.0	00	DEGF			

Originator: COLLIER KB Date: 11/13/09 Revision: 00



.

LOOP UNCERTAINTY	CALCULATIO	N	
Loop Number: TE-055-1N028B	01	Pag	e 19 of 25
Originator: COLLIER KB	Date: 11/	/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/	/17/09	
Approver: GEORGE RT	Date: 11/	/20/09	

ATTACHMENT 5: Instrument Data

Component Id: TE-055-1N028B Facility: LG Unit: 1 Syst						
Description: HPCI COMPARTMENT LEAK DE	FECTION			Function: IO 0		
LEAK DET SHOWN ONP&ID 25						
Type: I E Manufacturer Code: P427	Model #:	102-90	)39			
Location: 015177109 Elevation: 177 Area: 015 Serial #: 01116						
QA Class: Q Op Time: 1 Service I	ife: 40	EQ:	Y S	Seismic Class:		
Tech Spec: Y Tech Spec Ref: T3.3.2- 2.4.E	Transier	nt: NA	Re	g Guide 1.97: N		
Power Supply Reg: 0.000	Tolerance:	: 0	.000			
Loop Number: TE-055-1N028B	Loop Diagram	m: N/A	• <u>.</u>			
Computer Address: N/A	P&ID: M-002	5				
Installation Detail: N/A						
Calibration ST: ST-2-025-405-1	Calibration Proc: ST-2-025-405-1					
Functional ST: ST-2-055-611-1	Procedure #: IC-11-00001					
Response ST: N/A	Other:					
Mod Number:	Other:					
Signal From: PROCESS Signa A4-1	1 To: TIS-029	5-101B	СН	Mod Rev:		
Alarms & Actions: N/A						
Instruction Book:						
Input Min: 50.00 Input Max	: 350.00	]	Input U	nit: DEGF		
Output Min: 0.391 Output Ma	<b>x:</b> 8.064		Dutput	Unit: MVDC		
HC: 0.000 Setting Tolerance:	).00000 L	Leave A	Alone Z	one: 0.01000		
HC Corrected: SP Correc	ted:	F	Add. Ma	rgin: 0.00000		
MTE device				Period: 731		
MTE Accuracy						
HC Reference: N/A SP Reference: N/A						

Originator: COLLIER KB Date: 11/12/09 Revision: 1



.

LOOP UNCERTAINTY (	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 20 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	



# ATTACHMENT 5: Instrument Data

Component Id: TE-055-1N029B	Facility: LG Unit: 1 System: 055				
Description: HPCI COMPARTMENT LEAK	DETECTION Function: IO 0				
LEAK DET SHOWN ONP&ID 25					
Type: I E Manufacturer Code: P42	27 Model #: 102-9039				
Location: 015201288 Elevation: 201 Area: 015 Serial #: 00573					
QA Class: Q Op Time: 1 Service	e Life: 40 EQ: Y Seismic Class:				
Tech Spec: Y Tech Spec Ref: T3.3.2	2- Transient: NA Reg Guide 1.97: N				
2.4.E					
Power Supply Reg: 0.000	Tolerance: 0.000				
Loop Number: TE-055-1N028B	Loop Diagram: N/A				
Computer Address: N/A	P&ID: M-0025				
Installation Detail: N/A					
Calibration ST: ST-2-025-405-1	Calibration Proc: ST-2-025-405-1				
Functional ST: ST-2-055-611-1	Procedure #: IC-11-00001				
Response ST: N/A	Other:				
Mod Number:	Other:				
Signal From: PROCESS Sig	1 To: TIS-025-101B CH Mod Rev:				
A4-	-1				
Alarms & Actions: N/A					
Instruction Book:					
Input Min: 50.00 Input Ma	ax: 350.00 Input Unit: DEGF				
Output Min: 0.391 Output Min: 0.391	Max: 8.064 Output Unit: MVDC				
HC: 0.000 Setting Tolerance:	0.00000 Leave Alone Zone: 0.01000				
HC Corrected: SP Corre	ected: Add. Margin: 0.00000				
MTE device	Period: 732				
MTE Accuracy					
HC Reference: N/A	SP Reference: N/A				

Originator: COLLIER KB Date: 11/12/09 Revision: 1



|--|

LOOP UNCERTAINTY (	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 21 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

ATTACHMENT	5:	Instrument	Data
------------	----	------------	------

Component Id: TIS-025-101B Facility: LG Unit: 1 System: 025					
Description: STEAM LEAK DET	ECTION TEMP	MONITOR D	IV. 2/	B1	Function: S 0
Type: I S Manufacturer (	Code: G080	Model #:	304A	3714G00	4
Location: 008289542 Eleva	tion: 289	Area: 008	Ser	ial #:	
QA Class: Q Op Time: N/A	ife: 000	EQ	: N	Seismic Class:	
Tech Spec: Y Tech Spec Ref: T3.3.2-2.4 Transient: NA Reg Guide 1.97: N					leg Guide 1.97: N
Power Supply Reg: 120.000		Toleranc	<u>e: 1</u>	2.000	
Loop Number: SEE REMARKS		Loop Diagr	am: N/	<u>A</u>	
Computer Address: N/A		P&ID: M-00	25		
Installation Detail: N/A					
Calibration ST: ST-2-025-40	Calibration Proc: ST-2-025-405-1				
Functional ST: SEE REMARKS		Procedure #: IC-11-00001			
Response ST: N/A		Other:			
Mod Number:		Other:			
Signal From: SEE REMARKS	Signa	1 TO: SEE REMARKS Mod Rev:			
Alarms & Actions: SEE REMAR	KS				
Instruction Book: N-00E-68-	00024 (GEK-	-97146)			
Input Min: 50.00	Input Max:	350.00		Input	Unit: DEGF
Output Min: 0	Output Max	<b>c:</b> 1		Output	Unit:
HC: 0.000 Setting Tol	.00000	Leave	Alone	Zone: 0.01000	
HC Corrected:	SP Correct	ced:		Add. M	argin: 0.00000
MTE device					Period: 731
MTE Accuracy					
HC Reference: N/A		SP Referen	ce: N/	'A	

Originator: COLLIER KB Date: 11/12/09 Revision: 4

LOOP UNCERTAINTY CALCULATION									
Loop Number: TE-055-1N028B	01	Page 22 of 25							
Originator: COLLIER KB	Date: 11/16/09	Rev: 0							
Reviewer: AJMERA M.	Date: 11/17/09								
Approver: GEORGE RT	Date: 11/20/09								

### ATTACHMENT 6: Vendor Data

Manufacturer Code: P427 Model #: 102-9039

Function: IO 0

Reference: REFLECTS 2 SIGMA VALUE (CALC# LE-0065)										
Min 5.000e+0	01 Max	3.500e+002	Units	DEGF	Pressure	0.00				
Accuracy Information										
Accuracy	0.75%*S*	0.66								
Seismic	0.0									
Temperature	0.0		-							
Radiation	0.0									
Over Pressure	0.0									
Humidity	0.0									
Drift	0.0									
Time	1.0									
Power Supply	0.0									
Pressure Zero	0.0		Press	ure Span	0.0					
			·							

Originator: KINCAID SC Date: 07/06/01 Revision: 00

ATTACHMENT 6: Vendor Data

Manufacturer Code: P427 Model #: 102-9039

Function: IO 0

Reference: REFLECTS 2 SIGMA VALUE (CALC# LE-0065)											
Min 5.000e+	001 Max	3.500e+002	Units	DEGF	Pressure	0.00					
Accuracy Information											
Accuracy	0.75%*S*	0.66									
Seismic	0.0										
Temperature	0.0										
Radiation	0.0										
Over Pressure	0.0										
Humidity	0.0										
Drift	0.0										
Time	1.0										
Power Supply	0.0										
Pressure Zero	0.0		Press	ure Span	0.0						

Originator: KINCAID SC Date: 07/06/01 Revision: 00

LOOP UNCERTAINTY	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 23 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

# ATTACHMENT 6: Vendor Data

Manufacturer Code: G080Model #: 304A3714G004Function: S 0

Reference: GEK-97146, NE-68-24; REFLECTS 2 SIGMA VALUES (CALC# LE-0036)											
Min 5.	000e+001	. Max	3.500e+002	Units	DEGF	Pressure	0.00				
	Accuracy Information										
Accuracy	1	.0**S*0	.66								
Seismic	0	.0	1								
Temperat	ure 0	.0									
Radiatio	n 0	.0	,								
Over Pre	ssure 0	.0									
Humidity	0	.0									
Drift	0	.233%*S	*0.66								
Time	3	1.									
Power Su	pply 0	.0									
Pressure	Zero O	. 0		Press	ure Span	0.0					

Originator: THOMAS RT Date: 04/18/94 Revision: 00

LOOP UNCERTAINTY (	CALCULATION	
Loop Number: TE-055-1N028B	01	Page 24 of 25
Originator: COLLIER KB	Date: 11/16/09	Rev: 0
Reviewer: AJMERA M.	Date: 11/17/09	
Approver: GEORGE RT	Date: 11/20/09	

#### ATTACHMENT 7: Location Data

Location Code: 015177109 Description: UNIT 1 HPCI PUMP COMPT - REVISED BASED ON 94-08691

	Minimum	Normal	Trip LOCA	Trip HELB	Trip MSLB	Maximum
Temp	65.00	115.00	176.00	306.83	306.83	115.00
Radiation	2.580e+00	9.050e+05	4.930e+06	4.930e+06	4.930e+06	9.050e+05
Humidity	50.00	90.00	90.00	100.00	100.00	90.00
Pressure	14.69	14.69	14.70	17.64	17.64	14.69

Seismic Response Envelope:

Originator: GEORGE R T

0.00

Date: 10/29/96

Revision: 02

#### ATTACHMENT 7: Location Data

Location Code: 015201288 Description: UNIT 1 HPCI PIPING AREA

	Minimum	Normal	Trip LOCA	Trip HELB	Trip MSLB	Maximum
Temp	65.00	117.00	120.00	307.89	307.89	117.00
Radiation	2.580e+00	9.050e+05	1.760e+06	1.760e+06	1.760e+06	9.050e+05
Humidity	50.00	90.00	90.00	100.00	100.00	90.00
Pressure	14.69	14.69	14.70	21.34	21.34	14.69

Seismic Response Envelope: 0.00

Originator: THOMAS RT

Revision: 00

# ATTACHMENT 7: Location Data

Date: 05/02/94

Location Code: 008289542 Description: ROOM 542, AUXILIARY EQUIPMENT ROOM

	Minimum	Normal	Trip LOCA	Trip HELB	Trip MSLB	Maximum
Temp	60.00	82.00	82.00	82.00	82.00	82.00
Radiation	5.000e-04	1.760e+02	1.890e+02	1.760e+02	1.760e+02	1.760e+02
Humidity	30.00	90.00	90.00	90.00	90.00	90.00
Pressure	14.70	14.70	14.70	14.70	14.70	14.70

Seismic Response Envelope: 0.00

Originator: CAROLAN JF

Date: 03/31/93

Revision: 00





LOOP UNCERTAINTY CALCULATION								
Loop Number: TE-055-1N028B	01	Page 25 of 25						
Originator: COLLIER KB	Date: 11/16/09	Rev: 0						
Reviewer: AJMERA M.	Date: 11/17/09							
Approver: GEORGE RT	Date: 11/20/09							

#### ATTACHMENT 8: Process Concerns

<u>Co</u> :	nsideration	Contribution <u>Uncertainty</u>	to <u>Sign</u>	<u>A/N</u>			<u>Consideration</u> <u>References</u>
1 2 3	PMA PEA IR	0.00000 0.00000 0.00000		N N	Dependent <u>Device</u>	Dependent <u>Uncertainty</u>	SEE SECTION
4	S1	0.00992	R	N			SEE SECTION
5	S2	0.00000		N			
6	S3	0.00000		N			
7	R1	0.00000		N			
8	R2	0.00000		N			
9	R3	0.00000		N			

# ATTACHMENT 9: Device Dependencies

			I	Depen	dency		Static	Calibration	
Devices	Func	<u>tion</u>	<u>Env</u>	Pwr	<u>Cal</u>	Rad	Pressure	<u>Humid</u>	<u>Sensor</u>
TE-055-1N028B	IO	0	A	А	А	А	0.00000	90.00	Y
TE-055-1N029B	IO	0	А	А	А	А	0.00000	90.00	Y
TIS-025-101B	S	0	В	в	в	в	0.00000	90.00	N



í

Dependency References
-----------------------

Env:	N/A		Cal	: N/	A				Pwr:	N/A
Rad:	N/A		Cal	Con	diti	on:	N/A			
		 		-			_	-		

Just: Maximum Normal Humidity for Location Code

