#### RAI 03.07.02-24, Supplement 2

#### **QUESTION:**

#### Follow-up Question to RAI 03.07.02-15 (STP-NRC-100036)

UHS Basin and RSW Pump House:

10CFR50, Appendix S requires that evaluation for SSE must take into account soil-structure interaction (SSI) effects and the expected duration of vibratory motion. In the response to Item 6 of RAI 03.07.01-15, the applicant has provided a table summarizing the frequencies at which transfer functions are calculated as well as the cut-off frequency used in the SSI analysis for various analysis cases including the lower bound (LB), best estimate (BE) and upper bound (UB) in-situ soil cases; LB, BE and UB backfill soil cases; the cracked concrete and de-bonded soil case. The selected cut-off frequency for the different analysis cases varies from a low of about 16 Hz to a high of 25 Hz. The applicant has stated that the lowest cut-off frequency of 16 Hz meets the ASCE 4-98 Section C3.3.3.4 recommended values.

With respect to the selected frequency cut-off and frequencies of analysis, the staff needs the following information:

- a) Staff has not endorsed ASCE 4-98 Section C3.3.3.4 as acceptable criteria for selecting the cutoff frequency for the SSI analysis for detailed finite element model such as UHS Basin with cooling tower enclosure and RSW Pump House. The applicant is requested to provide comparisons of in-structure response spectra at some selected locations by increasing the frequency cut-off to a minimum of 33 Hz and using a SSI model capable of transmitting a frequency up to 33 Hz (refer to Follow-up Question to RAI 03.07.02-17) for all analysis cases considered demonstrating that cut-off frequencies used in the SSI analysis are acceptable. The staff needs this information to ensure that the selected cut off frequencies less than 33 Hz in SSI analysis will accurately or conservatively account for the expected frequency content of the SSE in the SSI analysis.
- b) In reviewing the tabulated SSI analysis frequencies, it is observed that some frequencies are excluded from the calculation of un-interpolated transfer functions in certain directions. For example, the frequency 14.16 Hz is not included in the z-response analysis for the mean soil case and 9.521 Hz is not included in the z-response analysis for the upper bound soil case. The applicant is requested to provide the basis for selecting the frequencies of analysis for calculating the un-interpolated transfer functions and excluding any frequencies from such calculations. The staff requires this information to ensure that the SSI analysis results are not adversely affected by any numerical instability that may be caused by large numbers of soil layers used in SASSI to model deep non-uniform soil site at the UHS/RSW Pump House.

**RSW Piping Tunnel:** 

10CFR50, Appendix S requires that evaluation for SSE must take into account soil-structure interaction (SSI) effects and the expected duration of vibratory motion. In order to ensure that evaluation of RSW Piping Tunnel for SSE has appropriately taken into account SSI effects, the staff needs the following information:

- 1. In the response to Item 1 of RAI 03.07.02-15, the applicant has stated that a 2D SSI analysis of the RSW tunnel has been performed to quantify the in-structure response of the tunnel. No details of this analysis have been provided. As such, the applicant is requested to describe in sufficient detail in the FSAR how the SSI analysis of the RSW tunnel has been performed. The description shall include the SSI methodology, figures showing the SSI model and boundary conditions, summary of the soil and structure properties, the input motion, etc. so the review can be completed.
- 2. In the response to Item 2 of RAI 03.07.02-15, the applicant has stated that simple manual calculations were used for the analysis and design of individual components of the RSW piping tunnel. For this analysis, the tunnel walls, slabs and base mat are considered as rigid elements, and seismic loads are calculated based on a ZPA of 0.21g. The applicant further states that the analysis did not include any model or soil springs; the seismic loads are applied in terms of dynamic soil pressures on the exterior walls, calculated as per ASCE 4-98 recommendations. Staff has not endorsed ASCE 4-98 recommended dynamic soil pressures for design of tunnel walls. As such, the applicant is requested to provide comparisons of the dynamic soil pressures on the RSW tunnel walls calculated using 2D SSI model versus those of ASCE 4-98 to demonstrate that the design pressures are still bounding when the effects of kinematic interaction between tunnel structures and surrounding soils as well as the effects of structure-soil-structure interaction (SSSI) due to nearby heavy structures are considered.

#### **SUPPLEMENTAL RESPONSE:**

The response to Ultimate Heat Sink (UHS) Basin/Reactor Service Water (RSW) Pump House Part 1b of this RAI was submitted with STPNOC letter U7-C-STP-NRC-100208, dated September 15, 2010. The response to Parts 1 and 2 of the RSW Piping Tunnel was submitted with STPNOC letter U7-C-STP-NRC-100253, dated November 29, 2010. This supplemental response provides the response to Part 1a of the UHS Basin/RSW Pump House.

#### UHS Basin and RSW Pump House (Part 1a):

The original soil-structure interaction (SSI) analysis of the UHS/RSW Pump House was performed considering full UHS basin. The SSI analysis of the UHS/RSW Pump House has been expanded to also consider empty UHS basin as described below.

Following a Loss of Coolant Accident (LOCA), the UHS/RSW Pump House will need to perform its safety-related cooling function for a period of 30 days without any make-up water.

During this period, the UHS basin water inventory will reduce and the water height within the basin may get as low as 3 ft above the top of UHS basin foundation, which is nearly an empty UHS basin.

In order to assess the impact of reduced UHS basin water inventory on the SSI analysis, the original SSI model was modified by removing the hydrodynamic mass and the SSI analysis was repeated. This SSI analysis was performed for six cases (i.e. in-situ lower bound soil, in-situ mean soil, in-situ upper bound soil, backfill upper bound soil, in-situ mean soil with separation in top 20 feet, and cracked case with in-situ mean soil). The results of this analysis show significant impact on the resulting in-structure response spectra as well as seismic forces. Figures 03.07.02-24.3 through 03.07.02-24.16 provide comparison of resulting response spectra for full and empty UHS basin for selected nodes of the UHS/RSW Pump House. Based on the analysis results for the empty UHS basin, modifications in the existing in-structure response spectra of the UHS/RSW Pump House are warranted.

Based on discussions during the August 4, 2010 NRC public meeting in Rockville, MD., two additional UHS/RSW Pump House SSI analyses have been performed for the upper bound soil profile case (UB soil case) considering both full and empty UHS basin, with a refined model which has the following passing frequency capability (passing frequency,  $f = V_s / 5$  h, where  $V_s$  is the shear wave velocity of the soil layer and h is the vertical or horizontal distance between the adjacent interaction nodes).

Vertical direction: 40.4 Hz Horizontal direction: 23.5 Hz

The original SSI model and the refined SSI model are shown in Figures 03.07.02-24.1 and 03.07.02-24.2, respectively. A cut-off frequency of 33 Hz was used in these analyses for transfer function calculation. For soil layers below groundwater level, the Poisson's ratio was capped at 0.495 for determining the compression wave velocity. In the original model the Poisson's ratio was capped at 0.48.

The mesh refinement needed to meet the passing frequency requirement made the model so large that it exceeded the capability of the SASSI2000, Version 3, which has been used in all the SSI analyses. To analyze this larger model, the SASSI2000 Version 3 was modified to allow handling of larger file sizes and to reduce the run time by using a more efficient solver. The modified SASSI2000 program has been verified and validated for analyzing this specific case.

The passing frequency of about 24 Hz was selected since the site has a deep soil profile; the SSI frequencies are below 6 Hz. Also, as noted in Standard Review Plan Section 3.7.1, Revision 3, Appendix A, the energy content of earthquake motions above 24 Hz is inconsequential.

To further assess the adequacy of the passing frequency of 23.5 Hz, the refined SSI model for the full basin case was also analyzed with a cut-off frequency of 23.5 Hz, instead of 33 Hz. The un-widened 5% damped in-structure response spectra from this analysis are compared with the refined SSI analysis where 33 HZ cut-off frequency was used. Figures 03.07.02-24.17 through

03.07.02-24.36 show this comparison for the Y (as representative of the horizontal) and Z (vertical) directions. Also shown on these figures are the corresponding spectra from the original SSI analysis which had a passing frequency capability of 15.6 Hz and a cutoff frequency of 25.4 Hz. The comparison of the spectra shows that:

- Comparison of the spectra from the original SSI analysis which had passing frequency of 15.6 Hz with the refined model SSI analysis with 23.5 Hz passing frequency shows that the responses in the original model were adequately captured for frequencies significantly beyond 15.6 Hz.
- Note that the increase in the spectra from refined SSI analysis at the four locations discussed in the following section is mainly due to the structural mesh refinement rather than the SSI model refinement for passing frequency.

Based on the above, passing frequency of 23.5 Hz is adequate.

#### Impact of Refined SSI analysis on In-Structure Response Spectra:

To assess the effect of refined model on the resulting in-structure response spectra, the resulting un-widened 5% damping response spectra for the UB soil case from the refined SSI model, for both the full and empty UHS basin cases, are compared to the corresponding spectra from the original SSI model at key locations of the structure (i.e. Pump House walls, Pump House Operating Floor, Pump House roof, UHS Basin Walls, and UHS Cooling Tower walls). Note that these locations include locations for comparison of results for structural mesh sensitivity discussed in the response to RAI 03.07.02-25 which is being submitted concurrently with this response. The following summary is based on the examination of these spectra comparison plots shown in Figures 03.07.02-24.37 through 03.07.02-24.87 for the full UHS basin and Figures 03.07.02-24.88 through 03.07.02-24.138 for the empty UHS basin:

There is good agreement between the spectra from the refined and the original SSI models in all three X, Y, and Z directions, with the exception of the following cases where the spectra from the refined model are significantly higher than the respective spectra from the original SSI model:

- Vertical direction spectra at the center of the Pump House Roof (see Figures 03.07.02-24.48 and 03.07.02-24.99)
- Vertical direction spectra at the center of the Pump House Operating Floor (see Figure 03.07.02-24.54)
- Vertical direction spectra of the Cooling Tower Walls (see Figures 03.07.02-24.69 and 03.07.02-24.120)
- Out-of-plane horizontal spectra of the UHS Basin Walls (see Figures 03.07.02-24.65 and 03.07.02-24.116)

There are small differences in some other locations also, but those differences are within an acceptable range of uncertainty in seismic analysis and at locations not critical to design of subsystems.

Based on the above, modifications are warranted for the existing UHS/RSW Pump House response spectra for the above 4 cases.

Additionally, in RAI 03.07.02-25, the NRC requested that a structural mesh sensitivity study be performed. The details of this mesh sensitivity study are provided in the response to RAI 03.07.02-25, which is being submitted concurrently with this response. Based on the results of this structural mesh sensitivity study, the following was concluded:

There was good agreement between the in-structure response spectra and maximum accelerations generated from the original SSI model and refined structural model in all three X, Y, and Z directions with the exception of the following cases:

- Vertical direction spectra at the center of the Pump House Roof
- Vertical direction spectra at the center of the Pump House Operating Floor
- Vertical direction spectra of the Cooling Tower Walls
- Out-of-plane horizontal spectra of the Basin Walls

As can be seen from the conclusions for the refined SSI analysis and the mesh sensitivity study, the cases from the refined SSI analysis requiring modifications in the existing in-structure response spectra match those from the mesh sensitivity study.

#### **Impact of Refined SSI analysis on Maximum Accelerations:**

Tables 03.07.02-24.1 and 03.07.02-24.2 show the comparison between the maximum accelerations from the original and refined SSI analyses for the full and empty UHS basin cases, respectively. These comparisons are also shown in the contour plots provided in Figures 03.07.02-24.140 through 03.07.02-24.145.

Design of UHS/RSW Pump House envelopes the maximum accelerations from the original and refined SSI analyses for both full and empty UHS basin cases. For further details, see Supplement 1 response to RAI 03.08.04-30 currently scheduled to be submitted in January 2011.

#### **Resolution of Items Observed in Various Sensitivity Analyses**

Based on the results presented above, modifications in the existing in-structure response spectra are required to address the 1) local increases in response spectra due to structural mesh refinement and the SSI model refinement, and 2) the impact of the empty basin. The following process is used to conservatively account for these effects:

- Step 1: Based on the envelope of the ratios of the in-structure response spectra comparisons from the structural mesh sensitivity study described in the response to RAI 03.07.02-25, and spectra comparisons from the SSI model refinement described in this response for both empty and full basin, determine the envelope modification factors for the following in-structure response spectra:
  - Vertical response spectra at the center of Pump House Roof
  - Vertical response spectra at the center of Pump House Operating Floor
  - Vertical response spectra for Cooling Tower Walls
  - Out-of-plane response spectra for the Basin Walls

The resulting modification factors for the above response spectra are shown in Table 03.07.02-24.3.

- Step 2: Adjust the applicable spectra in the four locations listed above by multiplying them with the modification factors determined in Step 1 above. This step is performed for results from each of the eight analysis cases for the full basin and each of the six analysis cases for the empty basin using the original SSI mesh.
- Step 3: For all locations and all x, y, and z directions, determine the envelope un-widened response spectra from all the eight cases of the full basin SSI analysis using the original SSI mesh and the upper bound refined SSI mesh full basin analysis.
- Step 4: For all locations and all x, y, and z directions, determine the envelope un-widened response spectra from all the six cases of the empty basin SSI analysis using the original SSI mesh and the upper bound refined SSI mesh empty basin analysis.
- Step 5: For all locations and all x, y, and z directions, determine the envelope of spectra from steps 3 and 4 above.
- Step 6: Increase the results of Step 5 to include interpolation between the results of Step 3 and Step 4 to account for a potential frequency shift observed between the empty or full basin cases. The result is a single envelope data set which envelopes the empty and full basin analysis sets and includes the interpolated values between the empty and full basin envelopes. The results of this step are visible in the "C" regions of Figures 03.07.02-24.139a and 03.07.02-24.139b.
- Step 7: Widen the spectra produced in Step 6 by  $\pm$  15% on frequency scale. The results of this step are seen in the "A" and "D" regions of Figures 03.07.02-24.139a and 03.07.02-24.139b.
- Step 8: To produce the final in-structure response spectra for UHS/RSW Pump House, fill in all valleys of the spectra obtained in Step 7 to remove local minima. The results of step 8 are seen in the "B" regions of Figures 03.07.02-24.139a and 03.07.02-24.139b.

The revised in-structure response spectra per the above criteria are shown in the revised COLA Part 2, Tier 2 Figures 3H.6-16 through 3H.6-39 (see Enclosure 1).

## In-Structure Response Spectra Generation for Site-specific Seismic Category I structures

In-structure response spectra for all site-specific seismic category I structures are determined based on SSI analysis, using the Operating Basis Earthquake level structural damping values as given in Regulatory Guide 1.61, except for cracked concrete cases where SSE level structural damping is used.

Description	SAP	Original	Refined	Peak Nodal Acceleration in			Peak N	odal Accelera	ation in	Percentage Change in Peak			
of Location	Node	Mesh SASSI	Mesh SASSI	Refine	ed Mesh Mo	del (g)	Original N	1odel (g) Upj	per Bound	Acceleratio	on from Origi	inal Model	
		Node	Node					Soil		to	<b>Refined Me</b>	sh	
				X (East-	Y (North-	Z	X (East-	Y.(North-	Z	X (East-	Y (North-	Z	
				West)	South)	(Vertical)	West)	South)	(Vertical)	West)	South)	(Vertical)	
Bottom of PH	walls												
	663	1163	2495	0.115	0.118	0.128	0.113	0.118	0.129	1.6%	0.1%	-0.5%	
	843	1527	3279	0.113	0.117	0.133	0.114	0.117	0.126	-1.3%	0.1%	6.1%	
	860	1561	3328	0.113	0.117	0.135	0.115	0.120	0.137	-1.9%	-2.0%	-1.5%	
	680	1197	2544	0.113	0.118	0.130	0.112	0.123	0.126	1.0%	-4.4%	3.2%	
Mid-level of P	H walls												
	11920	14995	31429	0.139	0.130	0.133	0.137	0.128	0.130	2.0%	1.9%	2.9%	
	11863	15101	31606	0.114	0.161	0.125	0.113	0.151	0.127	1.0%	6.3%	-1.5%	
	11823	15015	31456	0.128	0.135	0.137	0.135	0.141	0.130	-4.9%	-4.1%	5.4%	
	11766	14851	31140	0.116	0.140	0.120	0.114	0.143	0.120	1.8%	-2.3%	0.0%	
PH roof													
	5511	16429	34070	0.118	0.134	0.132	0.119	0.134	0.129	-0.6%	-0.3%	2.1%	
	5690	16608	34537	0.118	0.136	0.133	0.116	0.130	0.135	2.0%	5.0%	-1.1%	
	5707	16625	34562	0.118	0.143	0.136	0.113	0.145	0.136	3.6%	-0.9%	0.0%	
	5528	16446	34095	0.118	0.146	0.132	0.120	0.149	0.131	-1.5%	-1.9%	0.8%	
	5626	16544	34368	0.116	0.137	0.375	0.112	0.137	0.304	3.7%	0.1%	23.5%	
	5621	16539	34360	0.119	0.137	0.318	0.115	0.132	0.280	3.1%	3.7%	13.3%	
	5632	16550	34376	0.117	0.139	0.353	0.115	0.147	0.279	1.6%	-5.9%	26.8%	
Bottom of UH	S basin w	alls											
	3397	8546	18334	0.122	0.133	0.138	0.125	0.130	0.125	-2.7%	2.7%	10.2%	
	3989	9753	20945	0.116	0.129	0.130	0.115	0.128	0.130	1.2%	0.8%	0.4%	
	4023	9821	21044	0.115	0.139	0.132	0.119	0.140	0.133	-2.8%	-0.5%	-0.7%	

6360

17443

35722

0.383

0.343

0.179

0.372

0.334

0.164

#### U7-C-STP-NRC-100268 Attachment 1 Page 9 of 194

2.7%

9.0%

3.0%

#### Description SAP Original Refined **Peak Nodal Acceleration in** Peak Nodal Acceleration in **Percentage Change in Peak** of Location Node Mesh SASSI Mesh SASSI Refined Mesh Model (g) **Original Model (g) Upper Bound** Acceleration from Original Model Node Node Soil to Refined Mesh X (East-Y (North-Ζ Ζ Ζ X (East-X (East-Y (North-Y (North-West) South) (Vertical) West) South) (Vertical) West) (Vertical) South) 3431 8614 18384 0.117 0.139 0.130 0.119 0.142 0.131 -1.8% -1.7% -0.4% Mid-level of UHS basin walls 5778 16815 34846 0.132 0.236 0.135 0.244 0.137 0.129 -3.4% -1.1% 1.7% 5832 34930 16869 0.121 0.164 0.133 0.119 0.153 0.132 1.3% 7.0% 0.4% 5779 16816 34847 0.252 0.144 0.131 0.262 0.144 0.129 -3.8% -0.3% 1.5% 16765 5728 34769 0.118 0.218 0.141 0.123 0.201 0.141 -4.2% 8.3% -0.1% Top of UHS basin walls 6180 17263 35484 0.128 0.144 0.138 0.129 8.1% 0.141 0.128 -0.6% 2.3% 17493 6410 35780 0.143 -3.4% 3.1% 0.124 0.134 0.129 0.139 0.130 2.9% 6444 17527 35830 0.133 0.151 0.134 0.156 0.135 -2.8% -0.9% 0.126 5.1% 6214 17297 35534 -2.3% 0.129 0.150 0.131 0.136 0.155 0.135 -5.5% -3.2% Bottom of cooling tower walls cell 1 6258 17341 35584 0.317 0.143 0.142 0.310 0.140 0.136 2.3% 2.2% 4.3% 3.6% 3.9% 6330 17413 35682 0.320 0.144 0.143 0.310 0.139 0.138 3.2% 6336 17419 35690 0.386 0.226 0.200 0.379 0.231 0.186 1.9% -2.1% 7.9% 6264 17347 35592 0.391 0.255 0.204 0.385 0.252 10.4% 0.185 1.5% 1.3% cell 3 6270 17353 35600 0.406 0.274 0.233 0.406 0.281 0.210 0.2% -2.2% 10.9% 6342 17425 35698 0.394 0.240 0.224 0.383 0.259 0.207 3.0% -7.6% 8.1% 6348 17431 35706 0.401 0.271 0.231 0.391 0.245 0.220 2.6% 10.4% 4.8% 6276 17359 35608 0.413 0.307 0.228 0.413 0.279 0.202 0.1% 10.2% 13.1% cell 6 6288 17371 35624 0.386 0.342 0.183 0.390 0.342 0.172 6.1% -1.0% -0.1%

.

Description	SAP	Original	Refined	Peak Nodal Acceleration in			Peak N	odal Acceler	ation in	Percentage Change in Peak			
of Location	Node	Mesh SASSI	Mesh SASSI	Refined Mesh Model (g)			Original N	/lodel (g) Up	per Bound	Acceleration	on from Orig	inal Model	
		Node	Node					Soil		to	<b>Refined Me</b>	sh	
				X (East-	Y (North-	Z	X (East-	Y (North-	Z	X (East-	Y (North-	Z	
				West)	South)	(Vertical)	West)	South)	(Vertical)	West)	South)	(Vertical)	
	6366	17449	35730	0.323	0.148	0.139	0.303	0.153	0.135	6.7%	-3.3%	2.6%	
:	6294	17377	35632	0.311	0.148	0.141	0.306	0.152	0.139	1.6%	-2.5%	1.4%	
Mid-level of c	ooling tov	wer walls											
cell 1	6823	17956	36372	0.436	0.164	0.142	0.419	0.159	0.136	4.2%	3.4%	4.3%	
	6847	17980	36404	0.389	0.261	0.183	0.385	0.256	0.173	1.2%	2.1%	6.0%	
	6824	17957	36373	0.516	0.252	0.216	0.491	0.267	0.209	5.2%	-5.4%	3.7%	
	6775	17908	36306	0.401	0.257	0.180	0.396	0.258	0.164	1.2%	-0.2%	10.3%	
cell 3	6825	17958	36374	0.533	0.278	0.260	0.609	0.297	0.228	-12.6%	-6.6%	13.9%	
	6859	17992	36420	0.398	0.391	0.261	0.391	0.383	0.241	1.6%	2.3%	8.0%	
	6826	17959	36375	0.512	0.292	0.230	0.496	0.285	0.208	3.4%	2.7%	10.6%	
	6787	17920	36322	0.406	0.385	0.260	0.407	0.369	0.234	-0.2%	4.5%	11.1%	
cell 6	6828	17961	36377	0.507	0.377	0.184	0.498	0.361	0.172	1.7%	4.3%	7.5%	
	6877	18010	36444	0.394	0.358	0.155	0.389	0.357	0.155	1.2%	0.3%	0.0%	
	6829	17962	36378	0.429	0.169	0.138	0.431	0.174	0.139	-0.6%	-2.6%	-0.9%	
	6805	17938	36346	0.393	0.338	0.169	0.396	0.353	0.155	-0.6%	-4.2%	.9.4%	
Top of cooling	tower w	alls											
cell 1	7208	18341	36890	0.444	0.185	0.159	0.440	0.183	0.148	0.8%	1.0%	7.3%	
	7280	18413	36988	0.421	0.183	0.157	0.416	0.182	0.149	1.2%	0.3%	5.4%	
	7286	18419	36996	0.399	0.305	0.226	0.394	0.296	0.208	1.2%	3.2%	8.9%	
	7214	18347	36898	0.419	0.306	0.227	0.416	0.303	0.209	0.7%	1.0%	8.6%	
cell 3	7220	18353	36906	0.406	0.333	0.271	0.404	0.336	0.244	0.6%	-0.8%	11.1%	

## U7-C-STP-NRC-100268 Attachment 1 Page 11 of 194

Description	SAP	Original	Refined	Peak Nodal Acceleration in		Peak N	odal Accelera	ation in	Percentage Change in Peak			
of Location	Node	Mesh SASSI	Mesh SASSI	Refined Mesh Model (g)			Original N	1odel (g) Upp	per Bound	Acceleratio	on from Orig	inal Model
		Node	Node					Soil		to Refined Mesh		
		-		X (East-	Y (North-	Z _	X (East-	Y (North-	Z	X (East-	Y (North-	Z
				West)	South)	(Vertical)	West)	South)	(Vertical)	West)	South)	(Vertical)
	7292	18425	37004	0.396	0.335	0.262	0.397	0.336	0.239	-0.3%	-0.2%	9.8%
	7298	18431	37012	0.398	0.330	0.267	0.389	0.330	0.249	2.3%	0.1%	7.2%
	7226	18359	36914	0.397	0.333	0.259	0.399	0.328	0.236	-0.6%	1.6%	9.9%
cell 6	7238	18371	36930	0.415	0.425	0.204	0.419	0.405	0.196	-1.0%	4.9%	4.3%
	7310	18443	37028	0.414	0.422	0.204	0.406	0.406	0.181	1.8%	3.8%	12.8%
	7316	18449	37036	0.446	0.188	0.147	0.431	0.203	0.142	3.4%	-7.4%	3.9%
	7244	18377	36938	0.447	0.190	0.152	0.433	0.201	0.148	3.3%	-5.7%	2.9%
PH operating	floor	• •										
	3989	9753	20945	0.116	0.129	0.130	0.115	0.128	0.130	1.2%	0.8%	0.4%
	4188	10155	21899	0.115	0.128	0.135	0.112	0.124	0.128	2.6%	3.7%	5.6%
	4205	10189	21948	0.114	0.131	0.134	0.122	0.135	0.135	-6.2%	-3.2%	-0.9%
	4006	9787	20994	0.114	0.135	0.130	0.111	0.138	0.133	2.4%	-2.3%	-2.0%
	4119	10015	21594	0.116	0.130	0.440	0.115	0.129	0.377	0.3%	0.8%	16.6%
· · · · · · · · · · · · · · · · · · ·	4124	10025	21610	0.113	0.133	0.494	0.113	0.133	0.465	-0.5%	0.6%	6.2%
	4130	10037	21626	0.117	0.133	0.488	0.118	0.132	0.443	-1.1%	0.4%	10.1%

Description of Location	SAP Node	Original Mesh SASSI Node	Refined Mesh SASSI Node	Peak Nodal Acceleration in Refined Mesh Model (g)			Peak N Ori	odal Accelera iginal Model	ation in (g)	Percentage Change in Peak Acceleration from Original Model to Refined Mesh			
	1			X (East- West)	Y (North- South)	Z (Vertical)	X (East- West)	Y (North- South)	Z (Vertical)	X (East- West)	Y (North- South)	ي Z (Vertical)	
Bottom of PH	l walls	<u>I</u>										·	
,	663	1163	2495	0.113	0.127	0.124	0.110	0.117	0.131	2.5%	9.0%	-5.2%	
	843	1527	3279	0.113	0.127	0.132	0.109	0.117	0.126	3.7%	8.4%	4.7%	
	860	1561	3328	0.115	0.119	0.136	0.110	0.121	0.129	4.6%	-1.7%	5.6%	
	680	1197	2544	0.111	0.118	0.126	0.108	0.122	0.122	3.2%	-3.6%	3.5%	
Mid-level of F	PH walls												
	1192 0	14995	31429	0.140	0.138	0.130	0.132	0.132	0.131	5.8%	4.5%	-0.6%	
	1186 3	15101	31606	0.113	0.169	0.124	0.115	0.167	0.126	-2.1%	1.3%	-2.1%	
	1182 3	15015	31456	0.151	0.131	0.135	0.142	0.135	0.125	6.2%	-2.6%	8.3%	
	1176 6	14851	31140	0.117	0.138	0.127	0.115	0.135	0.125	2.0%	2.7%	0.9%	
PH roof													
	5511	16429	34070	0.122	0.139	0.145	0.118	0.136	0.143	3.7%	2.4%	1.4%	
·	5690	16608	34537	0.117	0.142	0.139	0.117	0.136	0.137	0.1%	4.5%	1.2%	
	5707	16625	34562	0.124	0.141	0.142	0.122	0.142	0.136	2.0%	-0.9%	4.9%	
	5528	16446	34095	0.122	0.140	0.136	0.117	0.138	0.126	4.0%	1.1%	7.5%	
	5626	16544	34368	0.116	0.141	0.369	0.119	0.137	0.319	-2.5%	3.1%	15.8%	

Description of Location	SAP Node	Original Mesh SASSI Node	Refined Mesh SASSI Node	Peak Nodal Acceleration in Refined Mesh Model (g)			Peak N Or	odal Acceler iginal Model	ation in (g)	Percentage Change in Peak Acceleration from Original Model to Refined Mesh			
	L	 		X (East- West)	Y (North- South)	Z (Vertical)	X (East- West)	Y (North- South)	Z (Vertical)	X (East- West)	Y (North- South)	Z (Vertical)	
	5621	16539	34360	0.115	0.139	0.395	0.116	0.137	0.318	-0.9%	1.3%	24.4%	
	5632	16550	34376	0.118	0.137	0.416	0.120	0.141	0.321	-2.2%	-2.8%	29.6%	
Bottom of UH	IS basin v	valls											
	3397	8546	18334	0.122	0.137	0.131	0.121	0.136	0.131	0.4%	0.9%	-0.3%	
:	3989	9753	20945	0.118	0.132	0.134	0.111	0.131	0.139	6.4%	0.9%	-3.7%	
	4023	9821	21044	0.122	0.141	0.136	0.120	0.140	0.141	1.7%	0.8%	-3.3%	
	3431	8614	18384	0.121	0.138	0.132	0.119	0.139	0.134	1.5%	-1.0%	-1.9%	
Mid-level of L	JHS basir	n walls											
	5778	16815	34846	0.230	0.146	0.144	0.238	0.146	0.141	-3.1%	0.0%	2.2%	
	5832	16869	34930	0.115	0.162	0.136	0.120	0.151	0.128	-4.0%	7.8%	5.9%	
	5779	16816	34847	0.243	0.137	0.140	0.223	0.137	0.138	8.9%	-0.3%	1.2%	
	5728	16765	34769	0.117	0.199	0.144	0.119	0.179	0.134	-2.4%	10.7%	7.6%	
Top of UHS ba	asin walls	5											
	6180	17263	35484	0.134	0.156	0.142	0.132	0.162	0.137	1.1%	-3.5%	3.8%	
	6410	17493	35780	0.128	0.159	0.157	0.130	0.153	0.146	-1.6%	4.0%	7.6%	
	6444	17527	35830	0.135	0.154	0.140	0.132	0.152	0.146	2.7%	1.1%	-4.2%	
•	6214	17297	35534	0.135	0.158	0.142	0.137	0.155	0.139	-0.9%	1.7%	2.1%	
Bottom of co	oling tow	er walls		·									
cell 1	6258	17341	35584	0.313	0.154	0.153	0.319	0.160	0.143	-2.1%	-4.0%	7.4%	
	6330	17413	35682	0.295	0.154	0.162	0.299	0.158	0.157	-1.1%	-2.9%	3.1%	
	6336	17419	35690	0.359	0.202	0.224	0.355	0.208	0.207	1.0%	-3.1%	8.1%	
	6264	17347	35592	0.372	0.227	0.189	0.370	0.218	0.187	0.4%	3.9%	1.0%	

RAI 03.07.02-24, Supplement 2

æ

## U7-C-STP-NRC-100268 Attachment 1 Page 14 of 194

Description of Location	SAP Node	Original Mesh SASSI Node	Refined Mesh SASSI Node	Peak Nodal Acceleration in Refined Mesh Model (g)			Peak N Ori	odal Accelera iginal Model	ation in (g)	Percentage Change in Peak Acceleration from Original Model to Refined Mesh			
				X (East- West)	Y (North- South)	Z (Vertical)	X (East- West)	Y (North- South)	Z (Vertical)	X (East- West)	Y (North- South)	Z (Vertical)	
				-									
cell 3	6270	17353	35600	0.376	0.256	0.249	0.378	0.252	0.217	-0.4%	1.5%	15.1%	
	6342	17425	35698	0.375	0.225	0.248	0.366	0.248	0.214	2.4%	-9.4%	15.7%	
	6348	17431	35706	0.368	0.251	0.278	0.362	0.231	0.240	1.7%	8.8%	15.8%	
	6276	17359	35608	0.377	0.257	0.282	0.373	0.251	0.253	1.1%	2.5%	11.4%	
cell 6	6288	17371	35624	0.359	0.298	0.176	0.364	0.300	0.187	-1.4%	-0.6%	-6.0%	
	6360	17443	35722	0.363	0.305	0.176	0.358	0.300	0.190	1.5%	1.8%	-7.1%	
	6366	17449	35730	0.322	0.151	0.152	0.314	0.151	0.143	2.6%	0.3%	6.4%	
	6294	17377	35632	0.301	0.153	0.149	0.297	0.153	0.139	1.4%	0.3%	7.5%	
Mid-level of c	ooling to	wer walls						-					
cell 1	6823	17956	36372	0.418	0.168	0.166	0.396	0.187	0.160	5.5%	-9.9%	4.0%	
	6847	17980	36404	0.360	0.245	0.204	0.352	0.266	0.197	2.2%	-8.0%	3.3%	
	6824	17957	36373	0.500	0.235	0.225	0.480	0.229	0.211	4.2%	2.5%	6.7%	
	6775	17908	36306	0.375	0.266	0.189	0.374	0.245	0.181	0.2%	8.8%	4.5%	
cell 3	6825	17958	36374	0.486	0.255	0.269	0.528	0.275	0.231	-8.0%	-7.4%	16.4%	
	6859	17992	36420	0.362	0.364	0.284	0.362	0.340	0.253	-0.1%	7.2%	12.0%	
	6826	17959	36375	0.469	0.281	0.292	0.436	0.281	0.253	7.6%	0.1%	15.2%	

RAI 03.07.02-24, Supplement 2

## U7-C-STP-NRC-100268 Attachment 1 Page 15 of 194

Description	SAP	Original	Refined	Peak Nodal Acceleration in			Peak N	odal Accelera	ation in	Percentage Change in Peak			
of Location	Node	Mesh SASSI	Mesh SASSI	Refined Mesh Model (g)			Ori	iginal Model	(g)	Acceleratio	on from Orig	inal Model	
		Node	Node			••				to	Refined Me	sh	
-				X (East-	Y (North-	Z	X (East-	Y (North-	, Z	X (East-	Y (North-	Z	
				West)	South)	(Vertical)	West)	South)	(Vertical)	West)	South)	(Vertical)	
	6787	17920	36322	0.373	0.360	0.301	0.372	0.328	0.254	0.3%	9.8%	18.7%	
cell 6	6828	17961	36377	0.484	0.334	0.186	0.478	0.322	0.198	1.2%	3.9%	-5.8%	
	6877	18010	36444	0.366	0.335	0.175	0.363	0.320	0.177	0.8%	4.9%	-1.4%	
:	6829	17962	36378	0.413	0.174	0.147	0.414	0.173	0.145	-0.3%	1.0%	1.6%	
	6805	17938	36346	0.378	0.336	0.172	0.365	0.318	0.178	3.4%	5.9%	-3.8%	
Top of cooling	; tower w	valls					•						
cell 1	7208	18341	36890	0.415	0.188	0.171	0.409	0.224	0.154	1.6%	-15.9%	10.9%	
	7280	18413	36988	0.395	0.192	0.187	0.389	0.222	0.176	1.7%	-13.4%	6.1%	
	7286	18419	36996	0.372	0.272	0.252	0.368	0.262	0.228	1.2%	4.0%	10.6%	
	7214	18347	36898	0.387	0.276	0.224	0.390	0.256	0.219	-0.7%	7.9%	2.1%	
	•					· · ·							
cell 3	7220	18353	36906	0.375	0.289	0.283	0.376	0.298	0.242	-0.2%	-2.8%	16.7%	
	7292	18425	37004	0.360	0.290	0.280	0.357	0.297	0.245	1.0%	-2.2%	14.2%	
	7298	18431	37012	0.366	0.319	0.287	0.364	0.312	0.262	0.6%	2.2%	9.3%	
	7226	18359	36914	0.370	0.320	0.298	0.371	0.314	0.274	-0.4%	2.1%	8.6%	
cell 6	7238	18371	36930	0.385	0.373	0.206	0.385	0.356	0.210	-0.1%	4.6%	-1.8%	
	7310	18443	37028	0.382	0.369	0.199	0.378	0.357	0.221	1.1%	3.4%	-10.1%	
-	7316	18449	37036	0.402	0.212	0.173	0.413	0.199	0.157	-2.5%	6.3%	10.1%	
	7244	18377	36938	0.417	0.207	0.177	0.412	0.198	0.160	1.1%	4.3%	10.6%	

Description of Location	SAP Node	Original Mesh SASSI Node	Refined Mesh SASSI Node	Peak Nodal Acceleration in Refined Mesh Model (g)			Peak No Ori	odal Accelera iginal Model	ation in (g)	Percentage Change in Peak Acceleration from Original Model to Refined Mesh				
	· ·			X (East- West)	Y (North- South)	Z (Vertical)	X (East- West)	Y (North- South)	Z (Vertical)	X (East- West)	Y (North- South)	Z (Vertical)		
PH operating	floor													
	3989	9753	20945	0.118	0.132	0.134	0.111	0.131	0.139	6.4%	0.9%	-3.7%		
	4188	10155	21899	0.111	0.135	0.136	0.115	0.129	0.138	-3.8%	4.9%	-1.9%		
	4205	10189	21948	0.116	0.125	0.145	0.115	0.131	0.130	0.8%	-4.1%	12.0%		
	4006	9787	20994	0.113	0.130	0.127	0.111	0.132	0.122	2.5%	-1.6%	3.9%		
	4119	10015	21594	0.114	0.130	0.450	0.114	0.130	0.404	0.3%	0.0%	11.4%		
	4124	10025	21610	0.113	0.133	0.537	0.112	0.134	0.524	0.7%	-0.5%	2.4%		
	4130	10037	21626	0.117	0.128	0.537	0.117	0.132	0.500	0.1%	-2.9%	7.6%		

1 able 03.07.02-24.3. Response opectra mounication racion
---

		20% Da	20% Damping		15% Damping		10% Damping		7% Damping		5% Damping	
Location	Direction	1-30 Hz	30-33 Hz	1-30 Hz	30-33 Hz	1-30 Hz	30-33 Hz	1-30 Hz	30-33 Hz	1-30 Hz	30-33 Hz	
Pump House Roof	Vertical	1.444	1.331	1.495	1.346	1.577	1.372	1.629	1.409	1.667	1.463	
Pump House Operating Floor	Vertical	1.223	1.190	1.243	1.194	1.294	1.198	1.362	1.202	1.469	1.204	
Mid-Level of Basin Walls	Horizontal	1.310	1.113	1.338	1.110	1.404	1.112	1.461	1.117	1.458	1.129	
CTSS Walls	Vertical	1.405	1.197	1.441	1.191	1.433	1.205	1.450	1.231	1.478	1.264	

		4% Da	4% Damping		3% Damping		2% Damping		1% Damping		0.5% Damping	
Location	Direction	1-30 Hz	30-33 Hz									
Pump House Roof	Vertical	1.686	1.511	1.793	1.588	2.038	1.718	2.682	1.926	2.769	2.165	
Pump House Operating Floor	Vertical	1.550	1.206	1.678	1.209	1.914	1.217	2.486	1.241	2.826	1.373	
Mid-Level of Basin Walls	Horizontal	1.502	1.153	1.563	1.186	1.835	1.237	2.372	1.326	2.922	1.370	
CTSS Walls	Vertical	1.540	1.289	1.585	1.321	1.749	1.364	1.966	1.418	2.593	1.574	



Figure 03.07.02-24.1 - SSI Original Mesh Model Node Numbers Note that nodes 10025 at center of operating floor and 16765 on south basin wall opposite 16869 are not visible)



Figure 03.07.02-24.2 - SSI Refined Mesh Model Node Numbers Note that node 21610 at center of operating floor and 34769 on south basin wall opposite 34930 not visible)



Figure 03.07.02-24.3: Comparison of Envelope Raw X-Direction Response Spectra at Mid-Level of PH Walls (group2) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 21 of 194



Figure 03.07.02-24.4: Comparison of Envelope Raw X-Direction Response Spectra at PH Roof (group3) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 22 of 194



Figure 03.07.02-24.5: Comparison of Envelope Raw X-Direction Response Spectra at Mid Level of Basin Walls (group6) at 5% Damping.

## U7-C-STP-NRC-100268 Attachment 1 Page 23 of 194



Figure 03.07.02-24.6: Comparison of Envelope Raw X-Direction Response Spectra at Top of Basin Walls (group7) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 24 of 194



Figure 03.07.02-24.7: Comparison of Envelope Raw Y-Direction Response Spectra at Bottom of PH Walls (group1) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 25 of 194



Figure 03.07.02-24.8: Comparison of Envelope Raw Y-Direction Response Spectra at Mid-Level of PH Walls (group2) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 26 of 194



Figure 03.07.02-24.9: Comparison of Envelope Raw Y-Direction Response Spectra at PH Roof (group3) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 27 of 194



Figure 03.07.02-24.10: Comparison of Envelope Raw Y-Direction Response Spectra at Mid Level of Basin Walls (group6) at 5% Damping.

## U7-C-STP-NRC-100268 Attachment 1 Page 28 of 194



Figure 03.07.02-24.11: Comparison of Envelope Raw Y-Direction Response Spectra at Top of Basin Walls (group7) at 5% Damping.

## RAI 03.07.02-24, Supplement 2

#### U7-C-STP-NRC-100268 Attachment 1 Page 29 of 194



Figure 03.07.02-24.12: Comparison of Envelope Raw Y-Direction Response Spectra at Top of Cooling Tower Walls (group10) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 30 of 194



Figure 03.07.02-24.13: Comparison of Envelope Raw Z-Direction Response Spectra at Bottom of PH Walls (group1) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 31 of 194



Figure 03.07.02-24.14: Comparison of Envelope Raw Z-Direction Response Spectra at PH Operating Floor (group4) at 5% Damping.

#### U7-C-STP-NRC-100268 Attachment 1 Page 32 of 194



Figure 03.07.02-24.15: Comparison of Envelope Raw Z-Direction Response Spectra at Mid Level of Basin Walls (group6) at 5% Damping.



Figure 03.07.02-24.16: Comparison of Envelope Raw Z-Direction Response Spectra at Mid-Level of Cooling Tower Walls (group9) at 5% Damping.



Figure 03.07.02-24.17: Comparison of Y - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at Bottom of PH Walls (Node group1), 5% Damping







Figure 03.07.02-24.19: Comparison of Y - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at PH Roof (Node group3), 5% Damping


Figure 03.07.02-24.20: Comparison of Y - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at PH Operating Floor (Node group4), 5% Damping























Figure 03.07.02-24.26: Comparison of Y - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at Top of Cooling Tower Walls (Node group10), 5% Damping

## RAI 03.07.02-24, Supplement 2



Figure 03.07.02-24.27: Comparison of Z - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at Bottom of PH Walls (Node group1), 5% Damping







Figure 03.07.02-24.29: Comparison of Z - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at PH Roof (Node group3), 5% Damping



Figure 03.07.02-24.30: Comparison of Z - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at PH Operating Floor (Node group4), 5% Damping







Figure 03.07.02-24.32: Comparison of Z - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at Mid Level of Basin Walls (Node group6), 5% Damping















Figure 03.07.02-24.36: Comparison of Z - Direction Raw Response Spectra, Full Basin, Upper Bound Soil at Top of Cooling Tower Walls (Node group10), 5% Damping



Figure 03.07.02-24.37: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 18449, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.38: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 18449, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.39: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 18449, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping







Figure 03.07.02-24.41: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 17263, Full Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.42: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 17263, Full Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.43: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16608, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.44: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16608, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.45: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16608, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.46: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16544, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.47: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16544, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.48: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16544, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.49: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 10155, Full Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.50: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 10155, Full Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.51: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 10155, Full Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.52: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 10025, Full Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.53: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 10025, Full Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.54: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 10025, Full Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.55: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 17956, Full Basin Upper Bound Soil - Mid-Level of Cooling Tower Walls - 5% Damping


Figure 03.07.02-24.56: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 17956, Full Basin Upper Bound Soil - Mid-Level of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.57: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 17956, Full Basin Upper Bound Soil - Mid-Level of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.58: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16815, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.59: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16815, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.60: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16815, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.61: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16869, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.62: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16869, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.63: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16869, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.64: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16765, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.65: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16765, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.66: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16765, Full Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.67: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 18431, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.68: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 18431, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.69: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 18431, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.70: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 17431, Full Basin Upper Bound Soil - Bottom of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.71: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 17431, Full Basin Upper Bound Soil - Bottom of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.72: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 17431, Full Basin Upper Bound Soil - Bottom of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.73: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 14995, Full Basin Upper Bound Soil - Mid-Level of PH Walls - 5% Damping



Figure 03.07.02-24.74: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 14995, Full Basin Upper Bound Soil - Mid-Level of PH Walls - 5% Damping



Figure 03.07.02-24.75: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 14995, Full Basin Upper Bound Soil - Mid-Level of PH Walls - 5% Damping



Figure 03.07.02-24.76; Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16625, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.77: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16625, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.78: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16625, Full Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.79: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 17527, Full Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.80: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 17527, Full Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.81: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 17527, Full Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.82: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 17493, Full Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.83: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 17493, Full Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.84: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 17493, Full Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.85: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 18341, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.86: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 18341, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.87: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 18341, Full Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.88: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 18449, Empty Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.89: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 18449, Empty Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.90: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 18449, Empty Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.91: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 17263, Empty Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping


Figure 03.07.02-24.92: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 17263, Empty Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.93: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 17263, Empty Basin Upper Bound Soil - Top of UHS Basin Walls - 5% Damping



Figure 03.07.02-24.94: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16608, Empty Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.95: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16608, Empty Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.96: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16608, Empty Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.97: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16544, Empty Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.98: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16544, Empty Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.99: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16544, Empty Basin Upper Bound Soil - PH Roof - 5% Damping



Figure 03.07.02-24.100: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 10155, Empty Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.101: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 10155, Empty Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.102: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 10155, Empty Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.103: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 10025, Empty Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.104: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 10025, Empty Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.105: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 10025, Empty Basin Upper Bound Soil - PH Operating Floor - 5% Damping



Figure 03.07.02-24.106: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 17956, Empty Basin Upper Bound Soil - Mid-Level of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.107: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 17956, Empty Basin Upper Bound Soil - Mid-Level of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.108: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 17956, Empty Basin Upper Bound Soil - Mid-Level of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.109: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16815, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.110: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16815, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.111: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16815, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.112: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16869, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.113: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16869, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.114: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16869, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.115: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 16765, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.116: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 16765, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.117: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 16765, Empty Basin Upper Bound Soil - Mid-Level of Basin Walls - 5% Damping



Figure 03.07.02-24.118: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 18431, Empty Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.119: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 18431, Empty Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.120: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 18431, Empty Basin Upper Bound Soil - Top of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.121: Comparison of X - Direction Raw Response Spectra for Original Mesh Node 17431, Empty Basin Upper Bound Soil - Bottom of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.122: Comparison of Y - Direction Raw Response Spectra for Original Mesh Node 17431, Empty Basin Upper Bound Soil - Bottom of Cooling Tower Walls - 5% Damping



Figure 03.07.02-24.123: Comparison of Z - Direction Raw Response Spectra for Original Mesh Node 17431, Empty Basin Upper Bound Soil - Bottom of Cooling Tower Walls - 5% Damping