



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 10, 2011

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
DECEMBER 8, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND PACIFIC GAS AND ELECTRIC COMPANY CONCERNING
REQUESTS FOR ADDITIONAL INFORMATION RESPONSE RELATED TO
THE DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2, LICENSE
RENEWAL APPLICATION (TAC NOS. ME2896 AND ME2897)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Pacific Gas and Electric Company (PG&E or the applicant) held a telephone conference call on December 8, 2010, to obtain clarification on PG&E's response to the staff's requests for additional information (RAI) regarding the Diablo Canyon Nuclear Power Plant license renewal application.

By letter dated November 24, 2010, PG&E sent the staff its response to an RAI regarding aging management programs. The staff reviewed the information contained therein, and requested a telephone conference call. The telephone conference call was useful in clarifying PG&E's response. Enclosure 1 provides a listing of the participants. Enclosure 2 provides discussions on the RAI response for which the staff requested clarification.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink, appearing to read "N. Ferrer", with a long horizontal line extending to the right.

Nathaniel Ferrer, Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosures:
As stated

cc w/encls: Distribution via Listserv

**TELEPHONE CONFERENCE CALL
DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
DECEMBER 8, 2010**

PARTICIPANTS

AFFILIATIONS

Nate Ferrer	U.S. Nuclear Regulatory Commission (NRC)
Cliff Douth	NRC
Rui Li	NRC
Terry Grebel	Pacific Gas and Electric Company (PG&E)
Sidney Bowen	PG&E
Miranda Tan	PG&E

Diablo Canyon Nuclear Power Plant, Units 1 and 2
License Renewal Application
Request for Additional Information
Aging Management Programs

B2.1.26-3

In its November 24, 2010, response to RAI B2.1.26-3, the applicant provided additional details on how the Inaccessible Medium Voltage Cables Not Subject to 10 CFR 50.49 Environmental Qualification Requirements Program will manage inaccessible low and medium voltage cables.

Discussion:

The staff was unclear why a 10-year inspection frequency was adequate. The staff was also unclear if the applicant had any cables at a voltage between 400-480V that are within the scope of license renewal. The applicant stated that it would revise its inspection frequency to once every 6 years; it had no in-scope cables at voltages between 400-480 V, and agreed to supplement its response to RAI B2.1.26-3 to address the staff's concerns.

In its response, the applicant stated that event-driven inspections are not performed because significant water ingress and retention in the in-scope pull boxes. The applicant stated that this is because the boxes are designed to drain down-hill toward plant structures/sumps, to automatic pump equipped sumps which pump to structure sumps. However, the staff was not clear on the details of the drainage system, or management of the sump pumps. The applicant agreed to supplement its response to RAI B2.1.26-3 to address the staff's concern.

January 10, 2011

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Nuclear Power Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON DECEMBER 8, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND PACIFIC GAS AND ELECTRIC COMPANY CONCERNING REQUESTS FOR ADDITIONAL INFORMATION RESPONSE RELATED TO THE DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION (TAC NOS. ME2896 AND ME2897)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Pacific Gas and Electric Company (PG&E or the applicant) held a telephone conference call on December 8, 2010, to obtain clarification on PG&E's response to the staff's requests for additional information (RAI) regarding the Diablo Canyon Nuclear Power Plant license renewal application.

By letter dated November 24, 2010, PG&E sent the staff its response to an RAI regarding aging management programs. The staff reviewed the information contained therein, and requested a telephone conference call. The telephone conference call was useful in clarifying PG&E's response. Enclosure 1 provides a listing of the participants. Enclosure 2 provides discussions on the RAI response for which the staff requested clarification.

The applicant had an opportunity to comment on this summary.

/RA/

Nathaniel Ferrer, Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosures:
As stated

cc w/encls: Distribution via Listserv

DISTRIBUTION:
See next page

ADAMS Accession No.:ML103560321

*concurrence via e-mail

OFFICE	LA:DLR*	PM:RPB2:DLR	BC:RPB2:DLR	PM:RPB2:DLR
NAME	SFigueroa	NFerrer	DWrona	NFerrer
DATE	12/27/10	01/05/11	01/07/11	01/10/11

OFFICIAL RECORD COPY

Memorandum to Pacific Gas and Electric Company for N. Ferrer dated January 10, 2011

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON
DECEMBER 8, 2010, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND PACIFIC GAS AND ELECTRIC COMPANY CONCERNING
REQUESTS FOR ADDITIONAL INFORMATION RESPONSE RELATED TO
THE DIABLO CANYON NUCLEAR POWER PLANT, UNITS 1 AND 2, LICENSE
RENEWAL APPLICATION (TAC NOS. ME2896 AND ME2897)

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDir Resource

RidsNrrDirRpb1 Resource

RidsNrrDirRpb2 Resource

RidsNrrDirRarb Resource

RidsNrrDirRapb Resource

RidsNrrDirRasb Resource

RidsNrrDirRerb Resource

RidsNrrDirRpob Resource

RidsOgcMailCenter Resource

NFerrer

KGreen

AStuyvenberg

DWrona

AWang

MPeck, RIV

TBrown, RI

GMiller, RIV

NO'Keefe, RIV

ICouret, OPA

VDricks, OPA

WMaier, RIV

JWeil, OCA

EWilliamson, OGC

SUttal, OGC

RRihm, EDO