



Luminant

Rafael Flores
Senior Executive Vice President
& Chief Nuclear Officer
rafael.flores@Luminant.com

Luminant Power
P O Box 1002
6322 North FM 56
Glen Rose, TX 76043

T 254 897 5550
C 817 559 0403
F 254 897 6652

December 21, 2010

TXX#: 10170

CERTIFIED MAIL
7010 1870 0001 0617 5057

Texas Commission on Environmental Quality
Public Drinking Water Section MC 155
P.O. Box 13087
Austin, Texas 78711-3087

Attn: Public Notice

Luminant Comanche Peak NPP
PWS #2130037
Monitoring Violation – Public Notice

Dear Sir/Madam:

Attached are the Notice of a Routine Monitoring Violation for Disinfectant Residual and the corresponding Certificate of Delivery of Public Notice to Customers by a Public Water System for the above referenced PWS in accordance with 30 TAC 290.110(g)(5) and 290.122(c).

This action is required due to a loss of distribution free chlorine residual records for this system for the month of October 2010 (1/7 day requirement). There is no reason to believe that the residuals were not measured, but the documentation is not available. As indicated in the Public Notice document, the Company has documentation which indicates that appropriate chlorine residual levels were maintained, including: 1. sodium hypochlorite usage logs; 2. Entry Point chlorine residual data; 3. Bacteriological test results and corresponding distribution chlorine residual data. Additionally, involved personnel recall no unusual data and any high or low residual readings would have required immediate response and appropriate documentation.

Residuals recorded with the bacteriological samples will be reported in the Disinfectant Level Quarterly Operating Report (DLQOR) for the 4th Quarter 2010 which will be submitted in January 2011.

If you have any questions concerning this Public Notice or related matters, please contact David Rutledge at 214-875-8296 or by e-mail at david.rutledge@luminant.com.

Sincerely,

Rafael Flores
Raphael Flores

Kim Mireles
By: Kim Mireles

A member of the STARS (Strategic Teaming and Resource Sharing) Alliance

Callaway · Comanche Peak · Diablo Canyon · Palo Verde · San Onofre · South Texas Project · Wolf Creek

IEAS
NRK

Texas Commission on Environmental Quality
TXX-10170
Page 2
12/21/2010

CC: Ms. Marissa Ludwig
TCEQ, Region 4
2309 Gravel Drive
Fort Worth, TX 76118-6951

US Nuclear Regulatory Commission
Document Control Desk
11555 Rockville Pike
Rockville, MD 20852

Notice of a Routine Monitoring Violation for Disinfectant Residual

Comanche Peak Training Center, PWS #2130037, failed to maintain the required documentation of the required daily samples for disinfectant residual monitoring of the water in the distribution system during October 2010. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523. Failure to monitor or monitoring inadequately makes it impossible to know if there is the required minimum disinfectant residual requirement of 0.2 mg/l (ppm) of chlorine. Our water system is required to take a disinfectant residual sample each week. Failure to collect and document all required disinfectant residual samples is a violation of the monitoring requirements and we are required to notify you of this violation.

Circumstances:

This situation arose due to a loss of data from all routine monitoring which was conducted according to Site Environmental activity logs. The following information is provided as further evidence that appropriate chlorine residuals were maintained during the month:

1. Sodium hypochlorite (the chlorine source) usage was normal and in-line with expected use based on previous and subsequent months usage.
2. In-line monitoring of chlorine residuals at the entry points to the system were normal during the month.
3. Required bacteriological testing of the system indicated no contamination and corresponding chlorine residuals on these samples were in the normal range.
4. Personnel involved recall no below minimum samples. Such samples would have required immediate action to elevate the residuals in accordance with procedure.

Appropriate actions are being taken to assure that such a data loss does not occur again (CR2010-010892).

If you have any questions regarding this violation, you may contact Bruce Turner at 254-897-8901 or David Rutledge at 214-875-8296.

PWS/ 2130037 /CO
(Fill in PWS ID NUMBER)

TCEQ-20208 (Revised 6/2005)

Certificate of Delivery of Public Notice to Customers by a Public Water System

After notifying your customers of a violation, complete this form and submit it with a copy of the public notice to the Texas Commission on Environmental Quality at the address given below.

Public Water System (PWS) Name: Comanche Peak Training Center

PWS ID (7-digit number required): 2130037

Constituent (enter name of each chemical): Chlorine Residual

Violation occurred in Quarter (check all that apply)

<input type="checkbox"/> 1 (Jan 1–Mar 31) of year _____
<input type="checkbox"/> 2 (Apr 1–Jun 30) of year _____
<input type="checkbox"/> 3 (Jul 1–Sep 30) of year _____
<input checked="" type="checkbox"/> 4 (Oct 1–Dec 31) of year <u>2010</u>

This notice is for Quarter 4th of year 2010


I certify that the following information is true and accurate:

- The PWS named above has distributed the public notice (PN) for the constituent in violation and for the time period listed above by:
 - Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122 for community water systems
 - Continuous posting or direct delivery as required by 30 TAC §290.122 for nontransient, non-community water systems; and
- The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122; and
- The above system has made an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):
 - Posting the PN on the Internet at www._____
 - Mailing the PN to postal patrons within the service area that do not receive a bill
 - Advertising the PN in news media
 - Publication of PN in local newspaper
 - Posting the PN in public places
 - Delivery of multiple copies to single bill addresses serving several persons
 - Delivery to community organizations
 - E-mail notification

Date Public Notice Delivered to Customers: December 21, 2010

Certified by: Name (print): Kim Mireles Title: Director, Environmental Generation

Phone: 214-875-8382 Date: 12/21/2010

Signature: 

Send one copy of this completed form and one copy of the Public Notification that you delivered to your customers to:

TCEQ
Public Drinking Water Section MC 155
Attn: Public Notice
PO Box 13087
Austin TX 78711-3087