

**Tifft, Doug**

---

**From:** Nancy McNamara  
**Sent:** Thursday, March 12, 2009 3:00 PM  
**To:** Doug Tifft  
**Subject:** FW: Example: for IP NRC Conf. Call

**Importance:** High

---

**From:** Nancy McNamara  
**Sent:** Tuesday, February 17, 2009 3:01 PM  
**To:** 'paul\_eddy@dps.state.ny.us'; 'Alyse L. Peterson'; 'Daniel Greeley'; 'longon@co.rockland.ny.us'; 'Sutton, Anthony'; 'sleary@co.orange.ny.us'; 'Lglander@co.orange.ny.us'; 'astiebeling@pcbcs.org'; 'chrisc@westchesterlegislators.com'; 'vob@bestweb.net'; 'lindap@townofcortlandt.com'; 'galefs@assembly.state.ny.us'; 'levenbergd@assembly.state.ny.us'  
**Cc:** David Decker  
**Subject:** Indian Point Re: CST Pipe Leak and NRC Conf. Call  
**Importance:** High

Good afternoon, everyone. I understand that today, Indian Point notified you of leakage in a buried section of piping associated with a condenser return line to the Indian Point Unit 2 condensate storage tank (CST). The NRC is monitoring the situation, observing and evaluating Entergy's actions to excavate the affected pipe and is assessing Entergy's actions to identify potential safety impacts on surrounding systems and buildings. Also, it is our understanding that Entergy sampled the leakage to determine the tritium concentration and is awaiting the results. Based on previous CST water chemistry results and monitoring of this discharge location, the tritium concentration associated with this leakage is expected to be a fraction of the EPA tritium limit for drinking water.

I have received some questions regarding the licensee's outreach messages. Therefore, the NRC RI staff is going to hold a conference call this afternoon for our offsite stakeholders to address any concerns or answer any questions you may have regarding this issue. The call is scheduled for today, February 17, 4:00 p.m and the teleconference number is: 1-888-917-8044. The Passcode is (b)(2) (sign). If you are trying to access the call and are having difficulties, please call me on my cell at (b)(6) (b)(6). If you are unable to make the call today, but would like to still talk with us, please contact me and we will talk with you at a separate time at your convenience. Thank you.

Nancy McNamara  
State Liaison Officer

EX.6 / EX 2 High

Information in this record was deleted in accordance with the Freedom of Information Act.  
Exemptions 2 High, 6  
FOI/PA 2-011-0021

0/31