


Effective Date 3/13/07

APPROVED: 
Manager - Hope Creek Operations

3-11-07
Date

CATEGORY II

DRYWELL PRESSURE

ALARMS

- | | |
|--------------------------|---------|
| • DRYWELL PRESSURE HI/LO | A7 – E4 |
| • DRYWELL PRESSURE HI/HI | A7 – D4 |
| • DRYWELL PRESSURE HI | C5 – B5 |
| • COMP PT IN ALARM | A4 – F5 |
| • DLD SYSTEM | C6 – B1 |

INDICATIONS

- Rising Drywell Pressure
- Rising Drywell Temperature

TERMINATED Date/Time: _____

RETAINMENT OVERRIDE	
CONDITION	ACTION
I. Drywell Pressure is ≥ 1.5 psig and rising. Date/Time: _____	<input type="checkbox"/> I.a REDUCE Recirc. Pump Speed to MINIMUM. <input type="checkbox"/> I.b LOCK the Mode Switch in Shutdown.

IMMEDIATE OPERATOR ACTIONS

NONE

AUTOMATIC ACTIONS

NONE

RETAINMENT OVERRIDE	
CONDITION	ACTION
I. Drywell Pressure is ≥ 1.5 psig and rising. Date/Time: _____	<input type="checkbox"/> I.a REDUCE Recirc. Pump Speed to MINIMUM. <input type="checkbox"/> I.b LOCK the Mode Switch in Shutdown.

LIST OF CONDITIONS

A. Unexpected rise in Drywell Pressure.	7
B. Turbine Bldg. Chill Water System is lost to the Drywell.....	7
C. Drywell Pressure ≥ 0.75 psig <u>AND</u> No Evidence of Elevated Coolant System Leakage.....	9
D. Indication of Major Fuel Failure. (Post LOCA).....	9
E. High Turbine Bldg. Chill Water Temperature.	11

RETAINMENT OVERRIDE	
CONDITION	ACTION
I. Drywell Pressure is ≥ 1.5 psig and rising. Date/Time: _____	<input type="checkbox"/> I.a REDUCE Recirc. Pump Speed to MINIMUM. <input type="checkbox"/> I.b LOCK the Mode Switch in Shutdown.

CAUTION:

1. If the cause of the loss of Turbine Building Chilled Water is Gas/Air intrusion, there is a potential to displace air into the RACS System, degrading its operation.

NOTES:

1. To minimize TBCW Pump runout and/or aid in the recovery of tripped TBCW Pumps, it may be necessary to align TBCW in a one pump / one evaporator line up until a two pump/three evaporator line up can be established. Monitor affected Drywell Loads (i.e. Recirc Pump Air Coolers, Drywell Temperature, etc.) while in a reduced flow and reduced cooling line up.

ADDITIONAL INFORMATION:

CRIDS Points:

- PAGE DISPLAY 60, DRYWELL UNIT CLR & AREA AIR TEMP
- PAGE DISPLAY 88, DRYWELL CHILLED WTR LOOPS A & B
- PAGE DISPLAY 104, REAC BLDG UNIT COOLERS

Procedures:

- HC.OP-GP.ZZ-0005(Q), Drywell Leakage Source Detection

Valve Descriptions:

- ED-HV-2577 Feed Gas Cooler Condenser 10E306 RACS Supply Valve
- ED-HV-7712A1 Feed Gas Cooler Condenser 00E306 RACS Supply Valve
- GB-HV-9532-1 CHW HDR RB ISLN RET
- GB-HV-9532-2 CHW HDR RB ISLN SPLY
- GB HV-9530A1 CONTAINMENT CLG LOOP A CHW SPLY
- GB HV-9530A3 CONTAINMENT CLG LOOP A CHW RTN
- GB-HV-9530A2 CONTAINMENT CLG LOOP A RACS SPLY
- GB-HV-9530A4 CONTAINMENT CLG LOOP A RACS RTN
- GB-HV-9530B1 CONTAINMENT CLG LOOP B CHW SPLY
- GB-HV-9530B3 CONTAINMENT CLG LOOP B CHW RTN
- GB-HV-9530B2 CONTAINMENT CLG LOOP B RACS SPLY
- GB-HV-9530B4 CONTAINMENT CLG LOOP B RACS RTN

SUBSEQUENT OPERATOR ACTIONS

CONDITION	ACTION
<p>A. Unexpected rise in Drywell Pressure.</p> <p>Date/Time: _____</p>	<p><input type="checkbox"/> A.1 TERMINATE Containment Makeup <u>AND</u> Inerting.</p> <p>A.2 MAXIMIZE Drywell Cooling by ENSURING:</p> <p><input type="checkbox"/> • All Drywell Fan Cooling Coils are Open.</p> <p><input type="checkbox"/> • All Drywell Fans are running in Fast Speed.</p> <p><input type="checkbox"/> **NOTE 1**</p> <p><input type="checkbox"/> • Proper TBCW system operation</p> <p>A.3 PERFORM the following:</p> <p><input type="checkbox"/> • Check Reactor Recirc. Pump Seals.</p> <p><input type="checkbox"/> • Check SRV Tailpipe Temperatures.</p> <p><input type="checkbox"/> • Drywell Leakage Source Detection IAW GP.ZZ-0005.</p>
<p>B. Turbine Bldg. Chill Water System is lost to the Drywell.</p> <p>Date/Time: _____</p>	<p><input type="checkbox"/> ★ CAUTION 1 ★</p> <p>B.1 ALIGN RACS to the Chill Water System for Drywell Cooling as follows:</p> <p>a. ENSURE RACS to the out of service Off-Gas Train is ISOLATED as follows:</p> <p><input type="checkbox"/> • <u>IF</u> the <u>Common</u> Off-Gas Train is in service, <u>THEN CLOSE</u> HV-2577.</p> <p><input type="checkbox"/> • <u>IF</u> Unit 1 Off-Gas Train is in service, <u>THEN CLOSE</u> HV-7712A1.</p> <p><input type="checkbox"/> b. CLOSE HV-9532-1 <u>AND</u> HV-9532-2.</p> <p><input type="checkbox"/> c. PRESS LOOP A SPLY/RTN OPEN RACS PB.</p> <p><input type="checkbox"/> d. PRESS LOOP B SPLY/RTN OPEN RACS PB.</p> <p>e. OBSERVE the following indications:</p> <p><input type="checkbox"/> • HV-9530A1/A3 CLOSED</p> <p><input type="checkbox"/> • HV-9530B1/B3 CLOSED</p> <p><input type="checkbox"/> • HV-9530A2/A4 OPEN</p> <p><input type="checkbox"/> • HV-9530B2/B4 OPEN</p> <p><input type="checkbox"/> f. OPEN HV-9532-1 <u>AND</u> HV-9532-2.</p>

RETAINMENT OVERRIDE	
CONDITION	ACTION
I. Drywell Pressure is ≥ 1.5 psig and rising. Date/Time: _____	<input type="checkbox"/> I.a REDUCE Recirc. Pump Speed to MINIMUM. <input type="checkbox"/> I.b LOCK the Mode Switch in Shutdown.

NOTES:

2. After a DBA-LOCA with immediate and complete Fuel Failure, it is assumed that actions for Condition D will be performed within 1 hour for Feedwater Sealing System.
[CR990623086]

ADDITIONAL INFORMATION:

CRIDS Points:

- D3727, RB PIPE CHASE CH A ISLN DMPR
- D3729, RB PIPE CHASE CH C ISLN DMPR
- PAGE DISPLAY 105, ISOLATION DAMPERS (GU)

Procedures:

- HC.OP-SO.GR-0001(Q), Reactor Building Ventilation System Operation.
- HC.OP-DL.ZZ-0026(Q), Attachment 1A, Surveillance Log - Control Room
- HC.OP-SO.AE-0001(Q), Feedwater System Operation.

Valve Descriptions:

- GS-HV-4951 PRI CNTMT VENT TO CPCS BYPASS
- GS-HV-4952 PRI CNTMT TO CPCS INBD ISLN DMPR
- GT-HD-9372A PURGE EXH DRYWELL VENT
- AB-HV-F071 DRAIN HDR ISLN

TABLE 1

BLOWOUT PANEL	LOCATION	DESCRIPTION
1-GT-PSE-9310A	RM-4319	VIEW FROM STEP-OFF PAD THRU WALL MOUNTED MIRROR
1-GT-PSE-9310B		
1-GT-PSE-9311A	RM-4410	15' UP ABOVE 'A' FRVS RECIRC FAN
1-GT-PSE-9311B		
1-GT-PSE-9324A	TORUS RM	VIEW USING CAMERA INSIDE THE NORTH TORUS DOOR
1-GT-PSE-9324B		
1-GT-PSE-9309	RM 4321	JUST INSIDE PIPECHASE, 20' UP

SUBSEQUENT OPERATOR ACTIONS (continued)

CONDITION	ACTION
<p>C. Drywell Pressure ≥ 0.75psig <u>AND</u> No Evidence of Elevated Coolant System Leakage</p> <p>Date/Time: _____</p>	<div><input type="checkbox"/> C.1 PREPARE a Gaseous Effluent Permit concurrently with Step C.2 and C.3.</div> <div>C.2 VENT the Drywell to maintain Drywell Pressure < 0.75 psig as follows:</div> <div><input type="checkbox"/> a. ENSURE Containment is aligned to vent thru RBVS/FRVS within 4 hours prior to start IAW DL.ZZ-0026.</div> <div>b. OPEN the following:</div> <div><input type="checkbox"/> 1. HD-9372A</div> <div><input type="checkbox"/> 2. HV-4952</div> <div><input type="checkbox"/> 3. HV-4951</div> <div>C.3 SECURE Drywell venting as follows:</div> <div>a. CLOSE the following:</div> <div><input type="checkbox"/> 1. HV-4951</div> <div><input type="checkbox"/> 2. HV-4952</div> <div><input type="checkbox"/> 3. HD-9372A</div> <div><input type="checkbox"/> b. Visually VERIFY the Blowout Panels in TABLE 1 are intact.</div> <div>c. ENSURE the following Back Draft Isolation Dampers are OPEN.(GR)</div> <div><input type="checkbox"/> • Dampers in table on CRIDS Page 105</div> <div><input type="checkbox"/> • RB PIPECHASE CH A ISLN DMPR</div> <div><input type="checkbox"/> • RB PIPECHASE CH C ISLN DMPR</div>
<p>D. Indication of Major Fuel Failure. (Post LOCA) [CD-829X]</p> <p>Date/Time: _____</p>	<div><input type="checkbox"/> **NOTE 2**</div> <div><input type="checkbox"/> D.1 PLACE the Feedwater Sealing System in operation. (AE)</div> <div><input type="checkbox"/> D.2 CLOSE HV-F071.</div>

RETAINMENT OVERRIDE	
CONDITION	ACTION
I. Drywell Pressure is ≥ 1.5 psig and rising. Date/Time: _____	<input type="checkbox"/> I.a REDUCE Recirc. Pump Speed to MINIMUM. <input type="checkbox"/> I.b LOCK the Mode Switch in Shutdown.

ADDITIONAL INFORMATION:

CRIDS Points:

- Page Display 60, Drywell Unit CLR & Area Air Temp
- Page Display 88, Drywell Chilled WTR Loops A&B
- Page Display 104, REAC BLDG Unit Coolers

Procedures:

- HC.OP-SO.GB-0001(Q), Chilled Water System Operation.
- HC.OP-SO.GU-0001(Q), Filtration Recirculation and Ventilation System Operation
- HC.OP-SO.GL-0001(Q), Service Area Ventilation System Operation
- HC.RW-SO.GH-0001(Q), Radwaste Area Ventilation System Operation

Equipment:

- A(B,C)VH300, Reactor Building Supply Fans (RBVS)
- A(B,C)VH301, Reactor Building Exhaust Fans (RBE)
- 0A(B)VH131, Service Area Supply Fans (SAS)
- 0A(B)V308, Service Area Exhaust Fans (SAE)
- 0A(B)VH317, Solid Radwaste Supply Fans
- 0A(B)V318, Solid Radwaste Exhaust
- 0A(B)V316, Radwaste Supply System
- 0A(B,C)V305, Radwaste Exhaust System

SUBSEQUENT OPERATOR ACTIONS (continued)

CONDITION	ACTION
<p>E. High Turbine Bldg. Chill Water Temperature.</p> <p>Date/Time: _____</p>	<p><input type="checkbox"/> E.1 PLACE additional Turbine Bldg. Chillers in service. (GB)</p> <p>E.2 LOWER Chilled Water heat load by performing the following as required:</p> <p><input type="checkbox"/> • PLACE FRVS in service. (GU)</p> <p><input type="checkbox"/> • REMOVE one Service Area Supply <u>AND</u> Exhaust Fan from service. (GL)</p> <p><input type="checkbox"/> • REMOVE one Solid Radwaste Supply <u>AND</u> Exhaust Fan from service. (GH)</p> <p><input type="checkbox"/> • PLACE Radwaste Ventilation in a 1 Supply Fan with two Exhaust Fans alignment. (GH)</p>

This Page Intentionally Blank

COMPLETION AND REVIEW

1.0 COMPLETION AND REVIEW

- 1.1 **EXPLAIN** the entry Condition into the abnormal in the Comments Section. _____
- 1.2 **ANNOTATE** in the comments section all systems affected by the implementation of this procedure AND restoration actions (i.e. restoration line ups) completed/required. _____
- 1.3 **ATTACH** photocopies of any Hard Cards utilized as part of this procedure implementation to Attachment 1. _____
- 1.4 **ENSURE** the Exit time for any applicable conditions and this abnormal are annotated in the comment section AND the Control Room Logs. _____
- 1.5 **FORWARD** completed Portions of this procedure AND Sections 1 and 2 of Attachment 1 to SM/CRS for approval and Record Retention. _____

This Page Intentionally Blank

ATTACHMENT 1

(Page 1 of 2)

COMPLETION AND REVIEW

1.0 COMMENTS:

This image shows a single sheet of white paper with horizontal blue or grey ruling lines. The lines are evenly spaced and run across the width of the page. There are no margins, text, or other markings on the paper.

**ATTACHMENT 1
(Page 2 of 2)
COMPLETION AND REVIEW**

2.0 SIGNATURES:

<u>PRINT NAME</u>	<u>SIGNATURE</u>	<u>INITIALS</u>	<u>DATE/TIME</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Completion of this attachment is annotated in the Control Room Logs:

_____	_____	_____
Printed Name	Signature	Date/Time

3.0 SM/CRS FINAL REVIEW AND APPROVAL:

This procedure and Attachment 1 have been reviewed for completeness and accuracy.
Entry/Exit conditions and all deficiencies, including corrective actions, are clearly recorded in the
COMMENTS Section above.

_____	_____	_____
Printed Name	SM/CRS	Date/Time

4.0 RECORDS

4.1 **RETAIN** the following in accordance with RM-AA-101, Records Management Program:

- Procedure cover page
- Affected Conditions and Hard Cards performed
- Completion and Review section
- Attachment 1

REVISION SUMMARY

- Adds a TERMINATED Date/Time block to the front page of this procedure. This is an editorial change. (80076308-0010)
- Incorporates approved OTSC 0A into Condition B (formerly Condition C) to add direction to secure RACS flow to Off-Gas train prior to aligning RACS to Drywell Cooling. This is an editorial change. (80070707-0020)
- Incorporates approved OTSC 0B to give additional guidance to lower Chill Water heat load. Moved Condition B to Condition E for space considerations in support changes. This is an editorial change. (80071123-0020)
- Moved Step C.2.b to C.3.c. These dampers are not part of the ventilation line up for venting the drywell. As requested by the order the dampers are checked on a post evolution step to ensure none have tripped during drywell venting. (80069904-0010)
- Added Caution 1 to Condition B stating: "If the cause of the loss of Turbine Building Chilled Water is Gas/Air intrusion, there is a potential to displace air into the RACS System, degrading its operation." This change alerts the operators of potential adverse effects on the RACS System should this be the problem with Turbine Building Chilled Water. (80073815-0010)
- Added Note 1 to Condition A "To minimize TBCW Pump runout and/or aid in the recovery of tripped TBCW Pumps, it may be necessary to align TBCW in a one pump / one evaporator line up until a two pump/three evaporator line up can be established. Monitor affected Drywell Loads (i.e. Recirc Pump Air Coolers, Drywell Temperature, etc.) while in a reduced flow and reduced cooling line up." (80074155-0010)
- Added "Completion and Review" section to the procedure with associated Attachment 1. This is an editorial change. Revision bars were not used for this change.
- Changes ACTION A.1 to terminate containment makeup and inerting. Makeup is another source of rising pressure. (70065906-0010)
- Corrects the system designator for HD-9372A to system GT. This is an editorial change. (70064474-0050)

IMPLEMENTATION REQUIREMENTS

None