

From: HOO Hoc
Sent: Monday, January 17, 2011 3:54 PM
To: HOO Hoc
Subject: Logbook Entry: 1/17/2011

Ops Officer : VINCE KLCO
Entry Date : 1/17/2011 - 15:40
Entry Type : 50.72 LOGGED ONLY
Notify Date - Time : 1/17/2011 - 15:14
Event Date - Time : 1/17/2011 - 12:36 ()
Site : CRYSTAL RIVER
Emergency Class : NON EMERGENCY

"As a result of a Crystal River Unit 1 transformer fire, both Crystal River Units 1 & 2 tripped offline and will remain shutdown for greater than 24 hours. Crystal River Units 1 & 2 are fossil generating units outside the Crystal River Unit 3 Protected Area and the discharge canal is common to all three units. Therefore, with the status of Crystal River Unit 3 Nuclear Plant being Shutdown/Mode 5, there is no significant thermal discharge to the Crystal River discharge canal for manatee artificial thermal refuge. In accordance with the Crystal River Power Plant Manatee Protection Plan, notification to the Florida Fish and Wildlife Conservation Commission will be made for an unplanned shutdown that is expected to result in no thermal discharge for 24 hours or longer. This is a 4-hour reportable event per 10CFR50.72(b) (2) (xi) as a notification to a government agency has been made.

The licensee notified the NRC Resident Inspector.

Notified the Endangered Species group by email and the R2D0(Bonser).

E-mail Properties
Mail Envelope Properties (CC56DD79EC73A545B9890C3C629E307D6F53441B03)

Subject: Logbook Entry: 1/17/2011
Sent Date: 01/17/2011 3:54:51 PM
Received Date: 01/17/2011 3:54:51 PM
From: HOO Hoc

Created By: HOO.Hoc@nrc.gov

Recipients:
HOO.Hoc@nrc.gov (HOO Hoc)
Tracking Status: None

Post Office:
HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	8650	01/17/2011

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: