

CCNPP3eRAIPEm Resource

From: Arora, Surinder
Sent: Friday, January 21, 2011 7:10 AM
To: 'Poche, Robert'
Cc: CCNPP3eRAIPEm Resource; Strnisha, James; Terao, David; Colaccino, Joseph; Miernicki, Michael; Wilson, Anthony; Vrahoretis, Susan
Subject: Draft RAI 293 CIB1 5378
Attachments: Draft RAI 293 CIB1 5378.doc

Rob,

Attached is Draft RAI No. 293 (eRAI No. 5378). You have until February 4, 2011 to review it and decide whether you need a clarification phone call to discuss any questions in the RAI before the final issuance. After the phone call or on February 4, 2011, the RAI will be finalized and sent to you for response. You will then have 30 days to provide a technically complete response or an expected response date for the RAI.

Thanks

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CalvertCliffs_Unit3Col_RAI
Email Number: 82

Mail Envelope Properties (B46615B367D1144982B324704E3BCEED4512603EC7)

Subject: Draft RAI 293 CIB1 5378
Sent Date: 1/21/2011 7:09:52 AM
Received Date: 1/21/2011 7:09:55 AM
From: Arora, Surinder

Created By: Surinder.Arora@nrc.gov

Recipients:

"CCNPP3eRAIPEm Resource" <CCNPP3eRAIPEm.Resource@nrc.gov>
Tracking Status: None
"Strnisha, James" <James.Strnisha@nrc.gov>
Tracking Status: None
"Terao, David" <David.Terao@nrc.gov>
Tracking Status: None
"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Miernicki, Michael" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"Wilson, Anthony" <Anthony.Wilson@nrc.gov>
Tracking Status: None
"Vrahoretis, Susan" <Susan.Vrahoretis@nrc.gov>
Tracking Status: None
"Poche, Robert" <Robert.Poche@constellation.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	645	1/21/2011 7:09:55 AM
Draft RAI 293 CIB1 5378.doc		30202

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 293 (eRAI 5378)
DRAFT
1/19/2011

Calvert Cliffs Unit 3
UniStar

Docket No. 52-016

SRP Section: 03.11 - Environmental Qualification of Mechanical and Electrical Equipment
Application Section: 3.11

QUESTIONS for Component Integrity, Performance, and Testing Branch 1 (AP1000/EPR Projects)
(CIB1)

03.11-5

Revision 7 to the Calvert Cliffs Unit 3 FSAR includes numerous changes to the description of the site-specific Environmental Qualification (EQ) Program in Table 3.11-1, "Site-Specific Environmentally Qualified Electrical/I&C Equipment." The Calvert Cliffs Unit 3 COL applicant is requested to describe these EQ table changes and their justification.