



# BWROG Actions to Address Containment Accident Pressure Issues

Alan Wojchowski  
BWROG CAP Committee  
Chairman

NRC-BWROG Meeting  
January 19, 2011



# BWROG Purpose

---

Define path forward for obtaining final SE for BWROG CAP LTR

Define path forward to reengage BWR EPU CAP reviews

# Current Situation

---

## BWROG LTR (NEDC-33347P)

- LTR developed at NRC request to provide consistent methodology for requesting CAP credit
- Draft SE issued on September 29, 2009 and revised draft SE on March 22, 2010
- Expect to address NRC guidance document elements in order to obtain final SE

# Current Situation

---

## EPU Submittals

- BWR EPU review has been delayed > 1 year by CAP resolution
  - Long-standing ACRS concerns on CAP overreliance
  - Finalization of NRC staff CAP guidelines
- EPU CAP reviews put on hold by NRC
  - Browns Ferry
  - Monticello
- Peach Bottom EPU submittal is pending

# Topics

---

Brief background

NRC CAP guidance document and information request

BWROG response to provide information request

Path forward on NPSH evaluations

BWROG Action Items

Summary of BWROG recommendations

BWROG Response to NRC Information Request

# Brief Background

---

NRC asked BWROG to develop a method for utilities to use in requesting CAP credit

- BWROG developed LTR NEDC-33347P
- Draft SE issued September 29, 2009

March 1, 2010, NRC published draft CAP guidelines

March 19, 2010, ACRS letter to staff outlining ACRS recommendations on CAP use

June 25, 2010, Commission issued Staff Requirements Memorandum for NRC staff to address similarities and differences between staff and ACRS positions

# NRC CAP Guidance Document

---

NRC CAP Guidelines introduce

- Uncertainty terms for NPSHr
- Maximum erosion zone
- Testing requirements for  $NPSH_a < NPSH_r$
- Defines events for which NPSHr uncertainties are applied

# NRC CAP Guidance Document

---

For LOCA - use pump vendor 3% NPSHr plus an uncertainty adder

For special events - use pump vendor 3% NPSHr

- Appendix R
- ATWS
- SBO



# NRC CAP Guidance Document Information Request

---

NRC requested industry and vendor input on CAP guidelines including LOCA uncertainty adders

- Pump field speed variation
- Suction piping configuration
- Dissolved gas

## Other Issues

- Water temperature
- Instrument uncertainties
- Wear ring wear
- Effect of dissolved gas on pump seals



# BWROG Response to NRC Information Request

---

Perform CFD analysis to address NPSHr uncertainty factors for 2 different size ECCS pumps

- Browns Ferry/Peach Bottom RHR pump
- Monticello RHR pump

Provide BWROG recommendations on other issues and alternative approaches to:

- Guideline 4.6 (operation with  $NPSH_a < NPSH_r$ )
- Guideline 4.9 (operation in maximum erosion zone)



# Pump Field Speed Variation

Accounts for possibility that pump speed may be higher than factory test

Using pump scaling laws to define uncertainty;

$$\text{NPSH}_2 = \text{NPSH}_1 (n_2 / n_1)^2$$

Small effect – no more than 0.35 feet at maximum



# Suction Piping Configuration

---

Field configuration of pump suction piping may contribute to increase in NPSHr compared to factory testing

Use CFD to determine to determine delta between 3% vendor NPSHr and field suction piping configuration at throttled and run out flow rate

# Dissolved Gas

---

Centrifugal pump performance sensitive to gas voids when voids  $> 2\%$

BWR containments are inerted with nitrogen

- Nitrogen less soluble in water than oxygen

At 95 °F, if all gas came out of solution void fraction  $\sim 1.2\%$

At 140 °F, if all gas came out of solution void fraction  $\sim 0.7\%$

# Dissolved Gas

---

Dissolved gas fraction will continue to decrease as pool temperature increases

Small amount of gas content reduces cavitation damage

Use CFD to determine to determine dissolved air delta in NPSHr at 95 °F and 155 °F at run out flow, and 155 °F and 210 °F at throttled flow

# Other Issues: Water Fluid Temperature

---

Improvement in NPSHr with increasing water temperature is scientifically well-established

- Hydraulic Institute tables
- Stepanoff correlation

NRC CAP guidelines do not allow use of water temperature NPSHr improvement

BWROG position is that credit for water temperature NPSHr factor should be included in the LOCA uncertainty adder

# Other Issues: Instrument Uncertainties

---

BWROG recommends using vendor pump curves for 3% NPSHr without additional instrument uncertainties

- NPSHr is based on original pump test results from factory
- Methods and instrumentation based on industry standards of accuracy
- All pumps are tested so test uncertainties tend to cancel out
- Pumps are tested at low water temperature so NPSHr test results are conservative



# Other Issues: Wear Ring Wear

---

Not discussed in NRC draft guidance document

BWROG position: Not expected to be a significant uncertainty factor:

- Core Spray pumps are operated only for surveillance tests
- RHR pumps are low use pumps
  - shutdown cooling during outages
  - multiple RHR pumps so operating duty is shared
  - infrequent suppression pool cooling
  - periodic TS or ASME surveillance testing
- Due to low operational use, wear ring wear is not a significant factor
- Unexpected wear would show as a decline in TS and ASME pump testing

# Other Issues: Effects of Dissolved Gas on Pump Seals

---

Concern is dissolved gas will migrate into pump seals which could cause excessive seal wear

ECSS pumps have water seal injection

BWROG will request pump vendor engineering evaluation to address

# Summary of LOCA Uncertainty Terms

Uncertainty factor	BWROG Recommendation
Pump Field Speed	Use pump scaling laws to quantify
Suction Piping Configuration	Use CFD to quantify
Dissolved Gas	Use CFD to quantify
Water Temperature	Allow use in uncertainty factor determination
Instrument Uncertainties	Use vendor supplied 3% pump curves
Wear Ring Wear	Not an issue due to low pump duty

# NRC Guideline 4.6

---

NRC Guideline: Operation with NPSHa less than NPSHeff (LOCA) or 3% NPSHr (non-design basis events) is acceptable if < 100 hours and like testing is performed

With CAP credit, NPSHa will be less than NPSHeff only during short-term LOCA response (< 10 minutes) for some plants

Maintenance of adequate core cooling is paramount concern for short-term LOCA response, therefore:

- Viable alternative to testing is demonstrated by analysis that core cooling is maintained for short-term LOCA response

# NRC Guideline 4.9

---

NRC Guideline: The zone of maximum erosion rate should be considered to lie between NPSH margin ratios of 1.1 to 1.6. The permissible time in this range for very high suction energy pumps should be limited ( $< 100$  hours).

BWROG recommends a pump impeller operational lifetime analysis as an alternative approach

# Path Forward on EPU NPSH Evaluations

To address NRC draft guideline pending completion of CFD analyses:

- For LOCA: licensees should use 5 feet of uncertainty for NPSHeff
  - Consistent with NRC contractor recommendation to use larger of  $1.15 \times 3\% \text{NPSHr}$  or 5 feet
  - 5 foot value represents a  $\sim 30\%$  uncertainty imposed on a typical  $3\% \text{NPSHr}$  at BEP
- For special events: licensees should use pump vendor  $3\% \text{NPSHr}$  in accordance with NRC guideline
  - Appendix R
  - ATWS
  - SBO

# BWROG Action Items

---

BWROG will provide plan and schedule for response

BWROG will perform CFD analyses to quantify LOCA uncertainty adders

Engineering evaluation will address effects of gas on pump seals

Report will be provided to NRC in a format to be determined

# Summary of BWROG Recommendations

---

For LOCA; licensees should use 5 feet of uncertainty for NPSHeff or a lower value as justified by CFD analysis

For special events – licensees should use pump vendor 3% NPSHr in accordance with NRC guidelines

BWROG recommended alternatives for guidelines 4.6 and 4.9:

- 4.6 Perform analysis that core cooling is maintained for short-term LOCA response (<10 minutes)
- 4.9: Perform pump impeller operational lifetime analysis



# BWROG Response to NRC Information Request

---


**The BWROG requests feedback from NRC on the general approach and specific elements of the proposed CFD analysis**

**The BWROG will propose for NRC concurrence a plan and schedule for completing its response**


---

# Backup slides

# NPSHa/NPSHr Ratio v. With/Without Adder



# CAP need with/without LOCA adder



# Short-Term LOCA Design


In the event of a LOCA, ECCS logic will auto-start all 4 RHR and 4 Core Spray pumps and inject to the reactor

Design ensures adequate core cooling (fuel peak clad temperature) when reactor decay heat is highest (assuming worst case single failure)

High system flow in this short-term mode results in temporary pump operation in regions of high NPSHr and low NPSHa

At 10 minutes operator throttle Core Spray and RHR pumps

# Suppression Pool Flooding (cont.)



# Typical NPSHr Curves (Browns Ferry RHR)

