

2010 MNGP ILT EXAMINATION
OPERATING TEST COMMENTS

Admin JPM e (SRO)	Update performance step 3 to be critical and be more specific on the standard.	Changed step to critical and specified the standard to include using the correct side of the EAL Board for the plant Mode.
CR JPM a	For performance step 3 on page 5 - update the evaluator cue for the correct suction pressure.	Updated to 5 psig.
CR JPM d	For Performance Step 5 add a range of gains that is expected for the candidates to enter.	Added range of 2.44-2.56
CR JPM e	For initial conditions state that maintenance was performed on channel A1 for performance plausibility.	Added
	For performance step 15 add an evaluator cue to state SPDS reads 20 mr/hr.	Added
CR JPM h	Update candidate turnover sheet with instructor turnover sheet.	Updated
In-Plant JPMs	No comments on the In-Plant JPMs	
Simulator Comments	The comments for the dynamic simulator scenarios were only minor in nature, such as typographical errors and were not individually tracked. No significant changes were made.	