



Serial: HNP-11-012
10 CFR 50.55a

JAN 27 2011

U.S. Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
COMPLETION OF REGULATORY COMMITMENT
REGARDING RELIEF REQUEST I3R-06

- References:
1. Letter from D. H. Corlett to the Nuclear Regulatory Commission (SERIAL: HNP-10-004), "Relief Request From ASME Boiler and Pressure Vessel Code, Section XI Requirements for the Service Water System," dated April 15, 2010 (ML101170058)
 2. Letter from M. Vaaler, Nuclear Regulatory Commission, to C. L. Burton, "Shearon Harris Nuclear Power Plant, Unit No. 1 - Request for Additional Information Regarding a Relief Request to Defer an American Society of Mechanical Engineers Code-Required Repair of a Service Water System Weld until the Next Refueling Outage (TAC NO. ME3765)," dated September 22, 2010
 3. Letter from J. R. Caves to the Nuclear Regulatory Commission (SERIAL: HNP-10-098), "Response to Request for Additional Information Regarding Relief Request I3R-06," dated October 4, 2010 (ML102861818)

Ladies and Gentlemen:

By letter dated April 15, 2010, the Harris Nuclear Plant (HNP) submitted a request to the NRC (Reference 1) for relief from ASME Boiler and Pressure Vessel Code, Section XI Requirements for the Service Water System. Additionally, HNP submitted its response to the NRC's Request for Additional Information on October 4, 2010 (Reference 3).

During a January 26, 2011, telephone discussion with NRC Staff, HNP agreed to provide the completion date for the Regulatory Commitment that required a code repair be completed during Refueling Outage 16.

The Attachment to this submittal contains the requested information.

This document contains no new Regulatory Commitment.

Progress Energy Carolinas, Inc.
Harris Nuclear Plant
P. O. Box 165
New Hill, NC 27562

A047
NRR

Please refer any questions regarding this submittal to me at (919) 362-3137.

Sincerely,



J.R. Caves
Supervisor – Licensing/Regulatory Programs
Harris Nuclear Plant

JRC/kab

Attachment: Completion Date of Regulatory Commitment for Relief Request I3R-06

cc: Mr. J. D. Austin, NRC Sr. Resident Inspector, HNP
Mrs. B. L. Mozafari, NRC Project Manager, HNP
Mr. V. M. McCree, NRC Regional Administrator, Region II

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
10 CFR 50.55a RELIEF REQUEST: I3R-06
REGULATORY COMMITMENT COMPLETION

The action identified in the table below was committed to by Harris Nuclear Plant (HNP) regarding 10 CFR 50.55a Request I3R-06, "Request for Relief for Temporary Non-Code Repair of Service Water Supply Piping Line in Accordance with 10 CFR 50.55a(g)(5)(iii). Please direct any questions regarding this document or any associated regulatory commitments to the Supervisor, Licensing/Regulatory Affairs.

Item	Commitment	Actual Completion Date
1	Replace temporary non-code repair of defect in weld on line 3SW3/4-1630SA-1 with a permanent repair. Temporary non-code repair consists of deferral of code repair until the next scheduled outage exceeding 30 days but no later than the next scheduled refueling outage, provided the condition continues to meet the acceptance criteria of Generic Letter 90-05.	October 12, 2010