

There should be a discussion of the data availability  
and the communication capability in the EOF trailer(s).

MAR 10

8104160415

H. G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street Tower II  
Chattanooga, Tennessee 37401

Dear Mr. Parris: OFFICIAL RECORD COPY

The Commission has reviewed the TVA centralized emergency management organization concept and has approved the concept with certain provisions. The NRC and TVA have not yet addressed the details for implementing the centralized emergency management organization concept at each site.

The Commission also instructed the staff to proceed with the issuance of Action Plan III.A.1.2., "Upgraded Emergency Support Facilities," contained in NUREG-0737. That requirement was issued by my letter dated February 18, 1981.

This letter is to inform you of the need to provide certain details of your plan to implement the centralized emergency management concept, approved by the Commission, in a formal request for an exemption from the requirements of Section 50.47(b) and paragraph D. of Appendix E of 10 CFR Part 50, regarding the near site EOF for each site. This letter is also to advise you of some specific elements regarding the EOF trailer(s) that you should address in your submittal, according to Action Plan III.A.1.2.

1. The EOF trailer(s) should be able to be positioned and operational within two hours of being notified that the NRC Regional Director and site team are departing for a site.
2. There should be a discussion of the location(s) where the trailer(s) will be stored and where the trailer(s) will be positioned and operational. In the latter case, discuss the relationship of the location to projected release dispersion patterns.
3. There should be a description of the data availability and the communication capability in the EOF trailer(s).

8104160415

OFFICE						
SURNAME						
DATE						

4. There should be adequate space available (on the order of 1500 square feet) to accommodate the NRC site team and a FEMA liaison individual with an appropriate TVA complement. The space should be configured to provide for:

- o a work area for EOF personnel;
- o EOF data system equipment needed to receive and transmit data from/to other locations;
- o performing repair, maintenance, and service equipment, displays and instrumentation;
- o ready access to communications equipment by all EOF personnel who need communications capabilities to perform their functions;
- o ready access to functional displays of EOF data and to displays of plant records and historical data.

As the TVA personnel prepare the site specific submittals regarding the upgrading of emergency support facilities, I encourage them to work closely with the respective NRC project managers.

Sincerely,

Darrell G. Eisenhut

Darrell G. Eisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosure:  
As Stated

OFFICE	EPDBL&E	EPDBL&E	EPDBL&E	EPDBL&E	EPDBL&E
SURNAME	JROLE:mj	SRAMOS	BARTMES	RPURPLE	DGEISENHUT
DATE	3/16/81	3/16/81	3/16/81	3/16/81	3/18/81