

Facility: 2010 -302 Sequoyah Written Date of Examination: 09/29/20210
 Examinations Developed by: Facility NRC
Written / Operating Test Written / Operating Test

Target Date*	Task Description (Reference)	Chief Examiner's Initials
-180	1. Examination administration date confirmed (C.1.a; C.2.a and b)	RSB
-120	2. NRC examiners and facility contact assigned (C.1.d; C.2.e)	RSB
-120	3. Facility contact briefed on security and other requirements (C.2.c)	RSB
-120	4. Corporate notification letter sent (C.2.d)	RSB
[-90]	[5. Reference material due (C.1.e; C.3.c; Attachment 2)]	RSB
{-75}	6. Integrated examination outline(s) due, including Forms ES-201-2, ES-201-3, ES-301-1, ES-301-2, ES-301-5, ES-D-1's, ES-401-1/2, ES-401-3, and ES-401-4, as applicable (C.1.e and f; C.3.d)	RSB
{-70}	{7. Examination outline(s) reviewed by NRC and feedback provided to facility licensee (C.2.h; C.3.e)}	RSB
{-45}	8. Proposed examinations (including written, walk-through JPMs, and scenarios, as applicable), supporting documentation (including Forms ES-301-3, ES-301-4, ES-301-5, ES-301-6, and ES-401-6), and reference materials due (C.1.e, f, g and h; C.3.d)	RSB
-30	9. Preliminary license applications (NRC Form 398's) due (C.1.i; C.2.g; ES-202)	RSB
-14	10. Final license applications due and Form ES-201-4 prepared (C.1.i; C.2.i; ES-202)	RSB
-14	11. Examination approved by NRC supervisor for facility licensee review (C.2.h; C.3.f)	RSB
-14	12. Examinations reviewed with facility licensee (C.1.j; C.2.f and h; C.3.g)	RSB
-7	13. Written examinations and operating tests approved by NRC supervisor (C.2.i; C.3.h)	RSB
-7	14. Final applications reviewed; 1 or 2 (if >10) applications audited to confirm qualifications / eligibility; and examination approval and waiver letters sent (C.2.i; Attachment 4; ES-202, C.2.e; ES-204)	RSB
-7	15. Proctoring/written exam administration guidelines reviewed with facility licensee (C.3.k)	RSB
-7	16. Approved scenarios, job performance measures, and questions distributed to NRC examiners (C.3.i)	RSB

* Target dates are generally based on facility-prepared examinations and are keyed to the examination date identified in the corporate notification letter. They are for planning purposes and may be adjusted on a case-by-case basis in coordination with the facility licensee.
 [Applies only] {Does not apply} to examinations prepared by the NRC.

FINAL

ES-201

Examination Outline Quality Checklist

Form ES-201-2

Facility: **Sequoyah Nuclear Plants 1 & 2** Date of Examination: **9/13/2010**

Item	Task Description	Initials		
		a	b*	c#
1. W R I T T E N	a. Verify that the outline(s) fit(s) the appropriate model, in accordance with ES-401.	N/A	→	N/A
	b. Assess whether the outline was systematically and randomly prepared in accordance with Section D.1 of ES-401 and whether all K/A categories are appropriately sampled.	N/A	→	N/A
	c. Assess whether the outline over-emphasizes any systems, evolutions, or generic topics.	N/A	→	N/A
	d. Assess whether the justifications for deselected or rejected K/A statements are appropriate.	N/A	→	N/A
2. S I M U L A T O R	a. Using Form ES-301-5, verify that the proposed scenario sets cover the required number of normal evolutions, instrument and component failures, technical specifications, and major transients.	JMS	NY	JMS
	b. Assess whether there are enough scenario sets (and spares) to test the projected number and mix of applicants in accordance with the expected crew composition and rotation schedule without compromising exam integrity, and ensure that each applicant can be tested using at least one new or significantly modified scenario, that no scenarios are duplicated from the applicants' audit test(s), and that scenarios will not be repeated on subsequent days.	JMS	NY	JMS
	c. To the extent possible, assess whether the outline(s) conform(s) with the qualitative and quantitative criteria specified on Form ES-301-4 and described in Appendix D.	JMS	NY	JMS
3. W / T	a. Verify that the systems walk-through outline meets the criteria specified on Form ES-301-2: (1) the outline(s) contain(s) the required number of control room and in-plant tasks distributed among the safety functions as specified on the form (2) task repetition from the last two NRC examinations is within the limits specified on the form (3) no tasks are duplicated from the applicants' audit test(s) (4) the number of new or modified tasks meets or exceeds the minimums specified on the form (5) the number of alternate path, low-power, emergency, and RCA tasks meet the criteria on the form.	JMS	NY	JMS
	b. Verify that the administrative outline meets the criteria specified on Form ES-301-1: (1) the tasks are distributed among the topics as specified on the form (2) at least one task is new or significantly modified (3) no more than one task is repeated from the last two NRC licensing examinations	JMS	NY	JMS
	c. Determine if there are enough different outlines to test the projected number and mix of applicants and ensure that no items are duplicated on subsequent days.	JMS	NY	JMS
4. G E N E R A L	a. Assess whether plant-specific priorities (including PRA and IPE insights) are covered in the appropriate exam sections.	JMS	NY	JMS
	b. Assess whether the 10 CFR 55.41/43 and 55.45 sampling is appropriate.	JMS	NY	JMS
	c. Ensure that K/A importance ratings (except for plant-specific priorities) are at least 2.5.	JMS	NY	JMS
	d. Check for duplication and overlap among exam sections.	JMS	NY	JMS
	e. Check the entire exam for balance of coverage.	JMS	NY	JMS
	f. Assess whether the exam fits the appropriate job level (RO or SRO).	JMS	NY	JMS

a. Author	Michael Buckner / <i>Michael Buckner</i>	Date 8/19/2010
b. Facility Reviewer (*)	Van Ford / <i>Van Ford</i>	8/20/10
c. NRC Chief Examiner (#)	Richard S. Bawwin / <i>Richard S. Bawwin</i>	9/2/10
d. NRC Supervisor	Malcolm T. Wisniewski / <i>Malcolm T. Wisniewski</i>	09/02/10

Note: # Independent NRC reviewer initial items in Column "c"; chief examiner concurrence required.
* Not applicable for NRC-prepared examination outlines

Facility: Sequoyah Nuclear Plants 1 & 2		Date of Examination: 9/29/2010																						
Item	Task Description	Initials																						
		a	b*	c#																				
1. W R I T T E N	a. Verify that the outline(s) fit(s) the appropriate model, in accordance with ES-401.	①	N/A	Kob																				
	b. Assess whether the outline was systematically and randomly prepared in accordance with Section D.1 of ES-401 and whether all K/A categories are appropriately sampled.	①	↓	Kob																				
	c. Assess whether the outline over-emphasizes any systems, evolutions, or generic topics.	Kob	↓	Kob																				
	d. Assess whether the justifications for deselected or rejected K/A statements are appropriate.	Kob	↓	Kob																				
2. S I M U L A T O R	a. Using Form ES-301-5, verify that the proposed scenario sets cover the required number of normal evolutions, instrument and component failures, technical specifications, and major transients.																							
	b. Assess whether there are enough scenario sets (and spares) to test the projected number and mix of applicants in accordance with the expected crew composition and rotation schedule without compromising exam integrity, and ensure that each applicant can be tested using at least one new or significantly modified scenario, that no scenarios are duplicated from the applicants' audit test(s), and that scenarios will not be repeated on subsequent days.																							
	c. To the extent possible, assess whether the outline(s) conform(s) with the qualitative and quantitative criteria specified on Form ES-301-4 and described in Appendix D.																							
3. W / T	a. Verify that the systems walk-through outline meets the criteria specified on Form ES-301-2: (1) the outline(s) contain(s) the required number of control room and in-plant tasks distributed among the safety functions as specified on the form (2) task repetition from the last two NRC examinations is within the limits specified on the form (3) no tasks are duplicated from the applicants' audit test(s) (4) the number of new or modified tasks meets or exceeds the minimums specified on the form (5) the number of alternate path, low-power, emergency, and RCA tasks meet the criteria on the form.																							
	b. Verify that the administrative outline meets the criteria specified on Form ES-301-1: (1) the tasks are distributed among the topics as specified on the form (2) at least one task is new or significantly modified (3) no more than one task is repeated from the last two NRC licensing examinations																							
	c. Determine if there are enough different outlines to test the projected number and mix of applicants and ensure that no items are duplicated on subsequent days.																							
4. G E N E R A L	a. Assess whether plant-specific priorities (including PRA and IPE insights) are covered in the appropriate exam sections.	Kob	NY	Kob																				
	b. Assess whether the 10 CFR 55.41/43 and 55.45 sampling is appropriate.	Kob	NY	Kob																				
	c. Ensure that K/A importance ratings (except for plant-specific priorities) are at least 2.5.	Kob	NY	Kob																				
	d. Check for duplication and overlap among exam sections.	Kob	NY	Kob																				
	e. Check the entire exam for balance of coverage.	Kob	NY	Kob																				
	f. Assess whether the exam fits the appropriate job level (RO or SRO).	Kob	NY	Kob																				
<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%; padding: 5px;">a. Author</td> <td style="padding: 5px;">Michael Buckner / <u>Michael Buckner</u></td> <td style="width: 15%; padding: 5px;">Printed Name/Signature</td> <td style="width: 15%; padding: 5px;">Date</td> <td style="padding: 5px;">9/23/2010</td> </tr> <tr> <td style="padding: 5px;">b. Facility Reviewer (*)</td> <td style="padding: 5px;">Van Ford / <u>Van Ford</u></td> <td></td> <td style="padding: 5px;"></td> <td style="padding: 5px;">9/23/10</td> </tr> <tr> <td style="padding: 5px;">c. NRC Chief Examiner (#)</td> <td style="padding: 5px;">Richard S. Baldwin / <u>Richard S. Baldwin</u></td> <td></td> <td style="padding: 5px;"></td> <td style="padding: 5px;">9/23/10</td> </tr> <tr> <td style="padding: 5px;">d. NRC Supervisor</td> <td style="padding: 5px;">Malcolm T. Widmann / <u>Malcolm T. Widmann</u></td> <td></td> <td style="padding: 5px;"></td> <td style="padding: 5px;">9/23/10</td> </tr> </table>		a. Author	Michael Buckner / <u>Michael Buckner</u>	Printed Name/Signature	Date	9/23/2010	b. Facility Reviewer (*)	Van Ford / <u>Van Ford</u>			9/23/10	c. NRC Chief Examiner (#)	Richard S. Baldwin / <u>Richard S. Baldwin</u>			9/23/10	d. NRC Supervisor	Malcolm T. Widmann / <u>Malcolm T. Widmann</u>			9/23/10			
a. Author	Michael Buckner / <u>Michael Buckner</u>	Printed Name/Signature	Date	9/23/2010																				
b. Facility Reviewer (*)	Van Ford / <u>Van Ford</u>			9/23/10																				
c. NRC Chief Examiner (#)	Richard S. Baldwin / <u>Richard S. Baldwin</u>			9/23/10																				
d. NRC Supervisor	Malcolm T. Widmann / <u>Malcolm T. Widmann</u>			9/23/10																				
<p>Note: # Independent NRC reviewer initial items in Column "c"; chief examiner concurrence required. * Not applicable for NRC-prepared examination outlines</p>																								

① Outline developed by NRC Region II

pg 1 of 4

1. Pre-Examination

I acknowledge that I have acquired specialized knowledge about the NRC licensing examinations scheduled for the week(s) of ~~09/06 - 09/13/2010~~ ^{9/13 - 9/20/10} ~~09/13/2010~~ ^{9/27/10} as of the date of my signature. I agree that I will not knowingly divulge any information about these examinations to any persons who have not been authorized by the NRC chief examiner. I understand that I am not to instruct, evaluate, or provide performance feedback to those applicants scheduled to be administered these licensing examinations from this date until completion of examination administration, except as specifically noted below and authorized by the NRC (e.g., acting as a simulator booth operator or communicator is acceptable if the individual does not select the training content or provide direct or indirect feedback). Furthermore, I am aware of the physical security measures and requirements (as documented in the facility licensee's procedures) and understand that violation of the conditions of this agreement may result in cancellation of the examinations and/or an enforcement action against me or the facility licensee. I will immediately report to facility management or the NRC chief examiner any indications or suggestions that examination security may have been compromised.

2. Post-Examination

To the best of my knowledge, I did not divulge to any unauthorized persons any information concerning the NRC licensing examinations administered during the week(s) of ~~9/13-9/20/10~~ ^{9/13-9/20/10} From the date that I entered into this security agreement until the completion of examination administration, I did not instruct, evaluate, or provide performance feedback to those applicants who were administered these licensing examinations, except as specifically noted below and authorized by the NRC.

PRINTED NAME	JOB TITLE / RESPONSIBILITY	SIGNATURE (1)	DATE	SIGNATURE (2)	DATE NOTE
1. Michael Buckner	Exam Author	<i>Michael Buckner</i>	01/08/2010	<i>Michael Buckner</i>	09/05/2010
2. Larry W. Pruett	Exam developer	<i>Larry Pruett</i>	02-16-10	<i>Larry Pruett</i>	per telecon 9/30/2010
3. JOHN B. RODEN	Exam Developer	<i>John B. Roden</i>	02/25/10	<i>John B. Roden</i>	per telecon 9/30/2010
4. Michael Wilson REESE	Exam Development	<i>Michael Wilson Reese</i>	3/16/2010	<i>Michael Wilson Reese</i>	9/30/2010
5. James D. Knight	SIM Software Engr	<i>James D. Knight</i>	4/19/2010	<i>James D. Knight</i>	10/5/2010
6. Mike B. Bercher	SIM Foreman	<i>Mike B. Bercher</i>	4/19/10	<i>Mike B. Bercher</i>	9-29-10
7. Gary R. Sanders	EXAM Development	<i>Gary R. Sanders</i>	5/3/10	<i>Gary Sanders</i>	9-30-10
8. BROOKS MATTHEW	SIM Testing Engr.	<i>Brooks Matthew</i>	5/5/10	<i>Brooks Matthew</i>	9/30/2010
9. Mark Hammond	Infrastructure admin	<i>Mark D. Hammond</i>	5/19/10	<i>Mark D. Hammond</i>	10-5-10
10. Chris Brooks	RO	<i>Chris Brooks</i>	5/25/10	<i>Chris Brooks</i>	10-1-10
11. Van Ford	SM	<i>Van Ford</i>	5/26/10	<i>Van Ford</i>	9-30-10
12. Kyle Bell	RO	<i>Kyle Bell</i>	5/26/10	<i>Kyle Bell</i>	10/1/10
13. Martin Puarberg	SRO	<i>Martin Puarberg</i>	7/26/10	<i>Martin Puarberg</i>	10/1/10
14. David Williams	RO	<i>David Williams</i>	4/1/10	<i>David Williams</i>	9/30/10
15. Jeremy Layman	RO	<i>Jeremy Layman</i>	6/1/10	<i>Jeremy Layman</i>	10/3/10

NOTES:

1. Pre-Examination

I acknowledge that I have acquired specialized knowledge about the NRC licensing examinations scheduled for the week(s) of ~~8/16/2010 & 8/23/2010~~ ^{9/13/2010} ~~9/13/2010~~ ^{9/27/10} as of the date of my signature. I agree that I will not knowingly divulge any information about these examinations to any persons who have not been authorized by the NRC chief examiner. I understand that I am not to instruct, evaluate, or provide performance feedback to those applicants scheduled to be administered these licensing examinations from this date until completion of examination administration, except as specifically noted below and authorized by the NRC (e.g., acting as a simulator booth operator or communicator is acceptable if the individual does not select the training content or provide direct or indirect feedback). Furthermore, I am aware of the physical security measures and requirements (as documented in the facility licensee's procedures) and understand that violation of the conditions of this agreement may result in cancellation of the examinations and/or an enforcement action against me or the facility licensee. I will immediately report to facility management or the NRC chief examiner any indications or suggestions that examination security may have been compromised.

2. Post-Examination

To the best of my knowledge, I did not divulge to any unauthorized persons any information concerning the NRC licensing examinations administered during the week(s) of ~~9/13-9/23/10~~ ^{9/13/10}. From the date that I entered into this security agreement until the completion of examination administration, I did not instruct, evaluate, or provide performance feedback to those applicants who were administered these licensing examinations, except as specifically noted below and authorized by the NRC.

PRINTED NAME	JOB TITLE / RESPONSIBILITY	SIGNATURE (1)	DATE	SIGNATURE (2)	DATE NOTE
1. DIERYEL WIDE	SRO / SIM. VALIDATION	[Signature]	6/1/10	[Signature]	7/29/10
2. Bruce Buch	US / Written Validation	[Signature]	6/2/10	[Signature]	10-7-10
3. Russell JOPLIN	CORP EXAM SIM MGR	[Signature]	6/2/10	Russell Joplin per telecon	10/04/10 10/05/10
4. FRANK SOENS	SRO / SIM	[Signature]	6/3/10	[Signature]	10/31/10
5. Norman Thomas	Licensing Engineer	[Signature]	6/10/10	[Signature]	9/30/2010
6. Johnnie Edwards	US / SRO	[Signature]	6/24/10	[Signature]	9/29/10
7. Steve Tutwill	US / SRO	[Signature]	6/24/10	[Signature]	10/1/10
8. MARIE HANKINS	LEAD INSTRUCTOR	[Signature]	6/24/10	Marie Hankins	9/30/10
9. WILLIAM FARNSWORTH	RO	[Signature]	6/24/10	[Signature]	10/3/10
10. Tony LANGFORD	RO	[Signature]	7/7/10	[Signature]	7/29/10
11. Gary CASEY	US	[Signature]	7/13/10	[Signature]	10/3/10
12. David A. Porter	US/SRO	[Signature]	7/13/10	[Signature]	9/30/10
13. Roger H. Brown	RO	[Signature]	8-2-10	[Signature]	10-6-10
14. OWEN B TRIOLA	OPS TRNG	[Signature]	8/2/2010	Owen B Triola	9/29/2010
15. Michael Chambers	Instructor	[Signature]	8/2/2010	MW Chambers	9/29/10

NOTES:

1. Pre-Examination

I acknowledge that I have acquired specialized knowledge about the NRC licensing examinations scheduled for the week(s) of ^{9/13/10} ~~09/13 - 09/20/2010~~ ^{9/10/10} as of the date of my signature. I agree that I will not knowingly divulge any information about these examinations to any persons who have not been authorized by the NRC chief examiner. I understand that I am not to instruct, evaluate, or provide performance feedback to those applicants scheduled to be administered these licensing examinations from this date until completion of examination administration, except as specifically noted below and authorized by the NRC (e.g., acting as a simulator booth operator or communicator is acceptable if the individual does not select the training content or provide direct or indirect feedback). Furthermore, I am aware of the physical security measures and requirements (as documented in the facility licensee's procedures) and understand that violation of the conditions of this agreement may result in cancellation of the examinations and/or an enforcement action against me or the facility licensee. I will immediately report to facility management or the NRC chief examiner any indications or suggestions that examination security may have been compromised.

2. Post-Examination

To the best of my knowledge, I did not divulge to any unauthorized persons any information concerning the NRC licensing examinations administered during the week(s) of ^{9/13-12/10} ~~9/13 - 9/20/10~~ ^{9/13/10} from the date that I entered into this security agreement until the completion of examination administration, I did not instruct, evaluate, or provide performance feedback to those applicants who were administered these licensing examinations, except as specifically noted below and authorized by the NRC.

PRINTED NAME	JOB TITLE / RESPONSIBILITY	SIGNATURE (1)	DATE	SIGNATURE (2)	DATE NOTE
1. HAROLD BIRCH	ILT INSTRUCTOR	<i>H Birch</i>	8-3-10	<i>H Birch</i>	9/30/10
2. STEVEN SMITH	LOR SUPERVISOR	<i>SV SA</i>	8-27-10	<i>SV SA</i>	9/30/2010
3. DENNIS DIMOPOULOS	Unit Supervisor	<i>Dennis Dimopoulos</i>	9/3/10	<i>Dennis Dimopoulos</i>	10/1/2010
4. Teri McConner	Unit Supervisor	<i>Teri McConner</i>	9/7/10	MICHELE CONNER ^{PBT}	10/4/10
5. Michael P. McDaniel	FLO/RO	<i>Michael P. McDaniel</i>	9-7-10	<i>Michael P. McDaniel</i>	10-3-10
6. Brian K. Coarner	Provisional Support	<i>Brian K. Coarner</i>	9-7-10	<i>Brian K. Coarner</i>	10-25-10
7. D. Reed Jones	Outage SW	<i>D. Reed Jones</i>	9/6/10	<i>D. Reed Jones</i>	10/3/10
8. JEFFREY S. MOSER	OUTAGE SUPPORT	<i>Jeffrey S. Moser</i>	9/9/10	<i>Jeffrey S. Moser</i>	9/30/10
9. GARY GARNER	SHIFT MANAGER	<i>Gary Garner</i>	9/9/10	<i>Gary Garner</i>	9/30/10
10. THOMAS JONES	OPS INSTRUCTOR	<i>Thomas Jones</i>	9/2/10	<i>Thomas Jones</i>	9/30/2010
11. DG Selph	OPS INSTRUCTOR	<i>DG Selph</i>	9/2/10	<i>DG Selph</i>	9/29/2010
12. AF RODDY	OPS INST	<i>AF Roddy</i>	9/16/10	<i>AF Roddy</i>	9/29/2010
13. MATTHEW McMULLIN	OPS	<i>Matthew McMullin</i>	9/12/10	<i>Matthew McMullin</i>	9/30/2010
14. DEREK HAWES	ILT SUPERVISOR	<i>Derek Hawes</i>	9/13/10	<i>Derek Hawes</i>	9/30/10
15. AARON BERGERON	OPS TRAINING MANAGER	<i>Aaron Bergeron</i>	9/13/10	<i>Aaron Bergeron</i>	9/30/2010

NOTES:

1. Pre-Examination

I acknowledge that I have acquired specialized knowledge about the NRC licensing examinations scheduled for the week(s) of 09/13 - 09/20/2010 ^{9/27/10 10/5/10} as of the date of my signature. I agree that I will not knowingly divulge any information about these examinations to any persons who have not been authorized by the NRC chief examiner. I understand that I am not to instruct, evaluate, or provide performance feedback to those applicants scheduled to be administered these licensing examinations from this date until completion of examination administration, except as specifically noted below and authorized by the NRC (e.g., acting as a simulator booth operator or communicator is acceptable if the individual does not select the training content or provide direct or indirect feedback). Furthermore, I am aware of the physical security measures and requirements (as documented in the facility licensee's procedures) and understand that violation of the conditions of this agreement may result in cancellation of the examinations and/or an enforcement action against me or the facility licensee. I will immediately report to facility management or the NRC chief examiner any indications or suggestions that examination security may have been compromised.

2. Post-Examination

To the best of my knowledge, I did not divulge to any unauthorized persons any information concerning the NRC licensing examinations administered during the week(s) of 9/13 - 9/27/10. From the date that I entered into this security agreement until the completion of examination administration, I did not instruct, evaluate, or provide performance feedback to those applicants who were administered these licensing examinations, except as specifically noted below and authorized by the NRC.

PRINTED NAME	JOB TITLE / RESPONSIBILITY	SIGNATURE (1)	DATE	SIGNATURE (2)	DATE NOTE
1. Michael L. Stephens	ILT1009 Lead		9/13/10		9/30/10
2. DYNE K. Cassidy	ILT OPS INSTRUCTOR		9/13/10		9/30/10
3. J.K. Wilkes	OPS SUPPORT SUPT.		9/15/10		10/2/10
4. Paul Simmons	OPS MANAGER		9-27-10		10/2/10
5. Melissa S. Mullan	Dev. Rep.		9-29-10		9/30/10
6.					
7.					
8.					
9.					
10.					
11.					
12.					
13.					
14.					
15.					

NOTES:

FINAL

ES-301

Administrative Topics Outline

Form ES-301-1

Facility: <u>Sequoyah Nuclear Station 1 & 2</u>		Date of Examination: <u>09/13/2010</u>
Examination Level: RO <input checked="" type="checkbox"/> SRO <input type="checkbox"/>		Operating Test Number: <u>2010302</u>
Administrative Topic (see Note)	Type Code*	Describe activity to be performed
Conduct of Operations	M, R, P	2.1.5 Ability to use procedures related to shift staffing, such as minimum crew compliment, overtime limitations, etc (2.9/3.9) A.1.a Evaluate Overtime Restrictions (Both RO & SRO)
Conduct of Operations	D, R	2.1.25 Ability to interpret reference materials, such as graphs, curves, tables, etc. (3.9/4.2) A.1.b Calculate Manual Makeup to VCT
Equipment Control	M, R	2.2.12 Knowledge of surveillance procedures (3.9/4.2) A.2 Boric Acid Storage Tank Level Operability Determination
Radiation Control	N, R	2.3.4 Knowledge of radiation exposure limits under normal and emergency conditions. (3.2/3.7) A.3 Determine Potential Total Dose for Valve Alignment
Emergency Procedures/Plan		
NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.		
* Type Codes & Criteria: (C)ontrol room, (S)imulator, or Class(R)oom (D)irect from bank (≤ 3 for ROs; ≤ 4 for SROs & RO retakes) (N)ew or (M)odified from bank (≥ 1) (P)revious 2 exams (≤ 1 ; randomly selected)		

FINAL

Admin 1.a – This JPM requires the candidate to evaluate different schedules and determine if any of the required work-hour rules were violated. This is a Bank JPM that was used on the 2009 NRC exam which has been Modified.

Admin 1.b – This JPM requires the candidate to calculate the amount of boric and demin water necessary to make a manual makeup to the VCT that is equal to existing RCS boron concentration. This is a Bank JPM.

Admin 2 – This JPM requires the candidate to evaluate the conditions of a Boric Acid Storage Tank to determine if it meets the Tech Spec requirements. This is a Modified Bank JPM.

Admin 3 – This JPM requires the candidate to determine the potential dose they would receive while performing a surveillance that verifies the timed operation of a valve in the RCA. This is a New JPM.

FINAL

ES-301

Administrative Topics Outline

Form ES-301-1

Facility: <u>Sequoyah Nuclear Station 1 & 2</u>		Date of Examination: <u>09/13/2010</u>
Examination Level: RO <input type="checkbox"/> SRO <input checked="" type="checkbox"/>		Operating Test Number: <u>2010302</u>
Administrative Topic (see Note)	Type Code*	Describe activity to be performed
Conduct of Operations	M, R, P	2.1.5 Ability to use procedures related to shift staffing, such as minimum crew compliment, overtime limitations, etc. (2.9/3.9) A.1.a Evaluate Overtime Restrictions (Both RO & SRO)
Conduct of Operations	N, R	2.1.25 Ability to interpret reference materials, such as graphs, curves, tables, etc. (3.9/4.2) A.1.b Review of Estimated Critical Position Calculation
Equipment Control	M, R	2.2.43 Knowledge of the process used to track inoperable alarms. (3.0/3.3) A.2 Review and Approve a Disabled Alarm Checklist
Radiation Control	D, R	2.3.4 Knowledge of radiation exposure limits under normal and emergency conditions. (3.2/3.7) A.3 Evaluate Worker Exposure
Emergency Procedures/Plan	D, R	2.4.38 Ability to take actions called for in the facility emergency plan, including supporting or acting as emergency coordinator if required. (2.4/4.4) A.4 Classify the Event per the REP (SGTR with Failed S/G Safety)
<p>NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.</p>		
<p>* Type Codes & Criteria:</p> <ul style="list-style-type: none"> (C)ontrol room, (S)imulator, or Class(R)oom (D)irect from bank (≤ 3 for ROs; ≤ 4 for SROs & RO retakes) (N)ew or (M)odified from bank (≥ 1) (P)revious 2 exams (≤ 1; randomly selected) 		

FINAL

Admin 1.a – This JPM has the candidate review several different work schedules and determine if any of the required work-hour rules were violated. This is a Bank JPM that was on the 2009 NRC exam but has been Modified.

Admin 1.b – This JPM has the candidate review a completed ECP calculation and identify any and all errors that were committed during the development of the ECP. This is a New JPM.

Admin 2 – This JPM has the candidate review a Disabled Annunciator request and identify any and all errors that may have been committed during the development of the request. This is a Modified Bank JPM.

Admin 3 – This JPM has the candidate review projected worker's dose for performing a job in the RCA and determine if any Federal or Administrative dose limits may be exceeded by any of the workers and any additional approvals that would need to be made if the actual doses were to reach the estimated values. This is a Bank JPM.

Admin 4 – This JPM has the candidate review the data presented during a proposed accident and determine the Emergency Event Classification, also identify and report any Protective Action Recommendations (PARs) which would be appropriate for the accident. This is a Bank JPM.

FINAL

ES-301

Control Room/In-Plant Systems Outline

Form ES-301-2

Facility: <u>Sequoyah Nuclear Station 1 & 2</u>		Date of Examination: <u>09/13/2010</u>
Exam Level: RO <input checked="" type="checkbox"/> SRO-I <input checked="" type="checkbox"/> SRO-U <input type="checkbox"/>		Operating Test No.: <u>2010302</u>
Control Room Systems [®] (8 for RO); (7 for SRO-I); (2 or 3 for SRO-U, including 1 ESF)		
System / JPM Title	Type Code*	Safety Function
a. 001 Control Rod Drive System; A2.17 (3.3/3.8) SIM A – Shutdown Bank Withdrawal	M, A, S, L	1
b. 006 Emergency Core Cooling System; A1.13 (3.5/3.7) SIM B – Refill #3 CLA to within Normal Range	D, S	2
c. 007 Pressurizer Relief Tank System; A2.02 (2.6/3.2) SIM C – Return PRT to Normal	D, S	5
d. 003 Reactor Coolant Pump System; A1.02 (2.9/2.9) SIM D – Respond to Loss of Flow to RCP Oil Cooler	N, S	4P
e. W/E14 High Containment Pressure; EA1.1 (3.7/3.7) SIM E – Respond to HI CNMT Pressure, Place RHR Spray In Service	D, A, S	3
f. 015 Nuclear Instrumentation System; A4.02 (3.9/3.9) SIM F – Calibrate Power Range NIs	D, S	7
g. 036 Fuel Handling Incidents AA2.02 (3.4/4.1) SIM G – Initiate Makeup to the Refueling Cavity	M, A, S, L	8
h. 064 Emergency Diesel Generation; A4.06 (3.9/3.9) SIM H – Shutdown the Diesel Generators Following Auto Start	D, S	6
In-Plant Systems [®] (3 for RO); (3 for SRO-I); (3 or 2 for SRO-U)		
i. 063 D.C. Electrical Distribution; A4.01 (2.7/3.0) In Plant I – Spare out a Vital Batt Charger	D	6
j. 061 Auxiliary/Emergency Feedwater System; A2.07 (3.4/3.5) In Plant J – Local control of MD AFW Pump Flow	D, A, R	4S
k. 002 Reactor Coolant System; A3.01 (3.7/3.8) In Plant K – Local Alignment of 2-RM-90-112 to Lower CNMT	D, R	8

FINAL

<p>@ All RO and SRO-I control room (and in-plant) systems must be different and serve different safety functions; all 5 SRO-U systems must serve different safety functions; in-plant systems and functions may overlap those tested in the control room.</p>	
* Type Codes	Criteria for RO / SRO-I / SRO-U
(A)lternate path	4-6 / 4-6 / 2-3
(C)ontrol room	
(D)irect from bank	$\leq 9 / \leq 8 / \leq 4$
(E)mergency or abnormal in-plant	$\geq 1 / \geq 1 / \geq 1$
(E)ngineered safety feature	- / - / ≥ 1 (control room system)
(L)ow-Power / Shutdown	$\geq 1 / \geq 1 / \geq 1$
(N)ew or (M)odified from bank including 1(A)	$\geq 2 / \geq 2 / \geq 1$
(P)revious 2 exams	$\leq 3 / \leq 3 / \leq 2$ (randomly selected)
(R)CA	$\geq 1 / \geq 1 / \geq 1$
(S)imulator	

SIM A – This JPM has the candidate identify misaligned control rods while attempting to withdraw the Shutdown banks in preparation for a reactor start-up. This is a Modified Bank, Low Power, Alternate Path JPM.

SIM B – This JPM has the candidate refill a cold leg accumulator to its normal level using a safety injection pump and place the SI pump back in standby status after fill complete. This is a Bank JPM.

SIM C – This JPM has the candidate return the PRT to normal temperature and pressure following a leaking PZR PORV. This is Bank JPM.

SIM D – This JPM has the candidate determine that a loss of cooling has occurred to the RCP oil coolers which will require the candidate to stop the affected RCP. This is a New JPM.

SIM E – This JPM directs the candidate to respond to continued High CNMT pressure following a LOCA by aligning RHR to provide CNMT spray. The Alternate path develops when the normal spray supply valve will not open. This is an Alternate Path, Bank JPM.

SIM F – This JPM has the candidate review the NIS readings against a calorimetric power calculation. The Alternate path is that a calibration adjustment is required to be made to a power range NI. This is a Bank JPM.

SIM G – This JPM has the candidate respond to lowering level in the Refueling Cavity. The Alternate path is that the normal supply of fill from the charging pumps will be unavailable and will require re-alignment of the suction of RHR pumps to provide the fill. This is a Modified Bank, Low Power, Alternate path JPM.

SIM H – This JPM has the candidate shutdown an EDG that has been running unloaded for an extended period of time following an auto start. This will require the diesel to be paralleled and loaded prior to shutdown. This is a bank JPM. (proposed RO only)

In-plant I – This JPM has the candidate walk through process of placing the spare battery charger in service and removing the normal charger. This is Bank JPM.

In-plant J – This JPM has the candidate take local control of AFW supply to #3 SG due to valve not responding from the control room. Alternate path is that the valve will not respond to local control switch manipulations either and will require manual operation for control. This is an Alternate Path, Bank JPM performed in the RCA.





In-plant K – This JPM directs the candidate to locally realign 2-RM-90-112 to monitor Lower Containment vs Upper Containment as part of the Unit 2 RCS leak detection system. This is a Bank JPM performed in the RCA.

FINAL

ES-301

Operating Test Quality Checklist

Form ES-301-3

Facility: Sequoyah Nuclear Station 1 & 2		Date of Examination: 09/13/2010		Operating Test Number: 2010302	
1. General Criteria			Initials		
			a	b*	c#
a.	The operating test conforms with the previously approved outline; changes are consistent with sampling requirements (e.g., 10 CFR 55.45, operational importance, safety function distribution).	JTB	nr	JTB	
b.	There is no day-to-day repetition between this and other operating tests to be administered during this examination.	JTB	nr	JTB	
c.	The operating test shall not duplicate items from the applicants' audit test(s). (see Section D.1.a.)	JTB	nr	JTB	
d.	Overlap with the written examination and between different parts of the operating test is within acceptable limits.	JTB	nr	JTB	
e.	It appears that the operating test will differentiate between competent and less-than-competent applicants at the designated license level.	JTB	nr	JTB	
2. Walk-Through Criteria			--	--	--
a.	Each JPM includes the following, as applicable: <ul style="list-style-type: none"> • initial conditions • initiating cues • references and tools, including associated procedures • reasonable and validated time limits (average time allowed for completion) and specific designation if deemed to be time-critical by the facility licensee • operationally important specific performance criteria that include: <ul style="list-style-type: none"> – detailed expected actions with exact criteria and nomenclature – system response and other examiner cues – statements describing important observations to be made by the applicant – criteria for successful completion of the task – identification of critical steps and their associated performance standards – restrictions on the sequence of steps, if applicable 	JTB	nr	JTB	
b.	Ensure that any changes from the previously approved systems and administrative walk-through outlines (Forms ES-301-1 and 2) have not caused the test to deviate from any of the acceptance criteria (e.g., item distribution, bank use, repetition from the last 2 NRC examinations) specified on those forms and Form ES-201-2.	JTB	nr	JTB	
3. Simulator Criteria			--	--	--
The associated simulator operating tests (scenario sets) have been reviewed in accordance with Form ES-301-4 and a copy is attached.		JTB	nr	JTB	
		Printed Name / Signature	Date		
a.	Author	Michael Buckner 	8/19/2010		
b.	Facility Reviewer(*)	Van Ford 	8/20/10		
c.	NRC Chief Examiner (#)	RICHARD S. BALOWIN 	9/2/10		
d.	NRC Supervisor	MALCOLM T. WIDMANN 	09/02/10		
<p>NOTE: * The facility signature is not applicable for NRC-developed tests. # Independent NRC reviewer initial items in Column "c"; chief examiner concurrence required.</p>					

FINAL

ES-301

Simulator Scenario Quality Checklist

Form ES-301-4

Facility: Sequoyah Nuclear Station 1 & 2 Date of Exam: 09/13/2010 Scenario Numbers: 1 / 2 / 3 Operating Test No.: 2010302					
QUALITATIVE ATTRIBUTES		Initials			
		a	b*	c#	
1.	The initial conditions are realistic, in that some equipment and/or instrumentation may be out of service, but it does not cue the operators into expected events.	JMS	NT	JSB	
2.	The scenarios consist mostly of related events.	JMS	NT	JSB	
3.	Each event description consists of <ul style="list-style-type: none"> the point in the scenario when it is to be initiated the malfunction(s) that are entered to initiate the event the symptoms/cues that will be visible to the crew the expected operator actions (by shift position) the event termination point (if applicable) 	JMS	NT	JSB	
4.	No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario without a credible preceding incident such as a seismic event.	JMS	NT	JSB	
5.	The events are valid with regard to physics and thermodynamics.	JMS	NT	JSB	
6.	Sequencing and timing of events is reasonable, and allows the examination team to obtain complete evaluation results commensurate with the scenario objectives.	JMS	NT	JSB	
7.	If time compression techniques are used, the scenario summary clearly so indicates. Operators have sufficient time to carry out expected activities without undue time constraints. Cues are given.	JMS	NT	JSB	
8.	The simulator modeling is not altered.	JMS	NT	JSB	
9.	The scenarios have been validated. Pursuant to 10 CFR 55.46(d), any open simulator performance deficiencies or deviations from the referenced plant have been evaluated to ensure that functional fidelity is maintained while running the planned scenarios.	JMS	NT	JSB	
10.	Every operator will be evaluated using at least one new or significantly modified scenario. All other scenarios have been altered in accordance with Section D.5 of ES-301.	JMS	NT	JSB	
11.	All individual operator competencies can be evaluated, as verified using Form ES-301-6 (submit the form along with the simulator scenarios).	JMS	NT	JSB	
12.	Each applicant will be significantly involved in the minimum number of transients and events specified on Form ES-301-5 (submit the form with the simulator scenarios).	JMS	NT	JSB	
13.	The level of difficulty is appropriate to support licensing decisions for each crew position.	JMS	NT	JSB	
Target Quantitative Attributes (Per Scenario; See Section D.5.d)		Actual Attributes	--	--	--
1.	Total malfunctions (5-8)	5 / 8 / 8	JMS	NT	JSB
2.	Malfunctions after EOP entry (1-2)	1 / 1 / 3	JMS	NT	JSB
3.	Abnormal events (2-4)	3 / 4 / 4	JMS	NT	JSB
4.	Major transients (1-2)	1 / 1 / 2	JMS	NT	JSB
5.	EOPs entered/requiring substantive actions (1-2)	3 / 2 / 4	JMS	NT	JSB
6.	EOP contingencies requiring substantive actions (0-2)	1 / 2 / 2	JMS	NT	JSB
7.	Critical tasks (2-3)	1 / 2 / 3	JMS	NT	JSB

FINAL

ES-301

Simulator Scenario Quality Checklist

Form ES-301-4

Facility: Sequoyah Nuclear Station 1 & 2 Date of Exam: 09/13/2010 Scenario Numbers: 4 / 6 / 7 Operating Test No.: 2010302				
QUALITATIVE ATTRIBUTES		Initials		
		a	b*	c#
1.	The initial conditions are realistic, in that some equipment and/or instrumentation may be out of service, but it does not cue the operators into expected events.	JMS	nr	PAB
2.	The scenarios consist mostly of related events.	JMS	nr	PAB
3.	Each event description consists of <ul style="list-style-type: none"> • the point in the scenario when it is to be initiated • the malfunction(s) that are entered to initiate the event • the symptoms/cues that will be visible to the crew • the expected operator actions (by shift position) • the event termination point (if applicable) 	JMS	nr	PAB
4.	No more than one non-mechanistic failure (e.g., pipe break) is incorporated into the scenario without a credible preceding incident such as a seismic event.	JMS	nr	PAB
5.	The events are valid with regard to physics and thermodynamics.	JMS	nr	PAB
6.	Sequencing and timing of events is reasonable, and allows the examination team to obtain complete evaluation results commensurate with the scenario objectives.	JMS	nr	PAB
7.	If time compression techniques are used, the scenario summary clearly so indicates. Operators have sufficient time to carry out expected activities without undue time constraints. Cues are given.	JMS	nr	PAB
8.	The simulator modeling is not altered.	JMS	nr	PAB
9.	The scenarios have been validated. Pursuant to 10 CFR 55.46(d), any open simulator performance deficiencies or deviations from the referenced plant have been evaluated to ensure that functional fidelity is maintained while running the planned scenarios.	JMS	nr	PAB
10.	Every operator will be evaluated using at least one new or significantly modified scenario. All other scenarios have been altered in accordance with Section D.5 of ES-301.	JMS	nr	PAB
11.	All individual operator competencies can be evaluated, as verified using Form ES-301-6 (submit the form along with the simulator scenarios).	JMS	nr	PAB
12.	Each applicant will be significantly involved in the minimum number of transients and events specified on Form ES-301-5 (submit the form with the simulator scenarios).	JMS	nr	PAB
13.	The level of difficulty is appropriate to support licensing decisions for each crew position.	JMS	nr	PAB
Target Quantitative Attributes (Per Scenario; See Section D.5.d)		Actual Attributes	--	--
1.	Total malfunctions (5-8)	8 / 6 / 8	JMS	nr
2.	Malfunctions after EOP entry (1-2)	2 / 1 / 1	JMS	nr
3.	Abnormal events (2-4)	5 / 4 / 5	JMS	nr
4.	Major transients (1-2)	1 / 2 / 1	JMS	nr
5.	EOPs entered/requiring substantive actions (1-2)	2 / 3 / 3	JMS	nr
6.	EOP contingencies requiring substantive actions (0-2)	1 / 1 / 2	JMS	nr
7.	Critical tasks (2-3)	4 / 2 / 2	JMS	nr

FINAL

ES-301

Transient and Event Checklist

Form ES-301-5

Facility: Sequoyah Nuclear Plant 1 & 2		Date of Exam: 09/13/2010			Operating Test No.: 2010302												
A P P L I C A N T	E V E N T T Y P E	Scenarios												T O T A L	M I N I M U M (*)		
		1			2			3			4						
		CREW POSITION			CREW POSITION			CREW POSITION			CREW POSITION						
		S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P				
RO <input type="checkbox"/> SRO-I <input checked="" type="checkbox"/> SRO-U <input type="checkbox"/>	RX							1						1	1	1	0
	NOR	1												1	1	1	1
	I/C	2,3,4,5						2,5,9						7	4	4	2
	MAJ	6						6,7						3	2	2	1
	TS	2,3												2	0	2	2
RO <input checked="" type="checkbox"/> SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>	RX		1,5a											2	1	1	0
	NOR		2a					1						2	1	1	1
	I/C		2,4					3,4,8,10						6	4	4	2
	MAJ		6					6,7						3	2	2	1
	TS													0	0	2	2
RO <input checked="" type="checkbox"/> SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>	RX							1						1	1	1	0
	NOR			1										1	1	1	1
	I/C			3,5				2,5,9						5	4	4	2
	MAJ			6				6,7						3	2	2	1
	TS													0	0	2	2
RO <input type="checkbox"/> SRO-I <input checked="" type="checkbox"/> SRO-U <input type="checkbox"/>	RX		1,5a											2	1	1	0
	NOR		2a					1						2	1	1	1
	I/C		2,4					2,3,4,5,7,8,9,10						10	4	4	2
	MAJ		6					6,7						3	2	2	1
	TS							2,3,5						3	0	2	2

- Instructions:**
- Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must serve in both the SRO and the ATC positions, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position. If an Instant SRO *additionally* serves in the BOP position, one I/C malfunction can be credited toward the two I/C malfunctions required for the ATC position.
 - Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
 - Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

FINAL

ES-301

Transient and Event Checklist

Form ES-301-5

Facility: Sequoyah Nuclear Plant 1 & 2														Date of Exam: 09/13/2010			Operating Test No.: 2010302		
A P P L I C A N T	E V E N T T Y P E	Scenarios												T O T A L	M I N I M U M (*)				
		1			2			3			4								
		C R E W P O S I T I O N			C R E W P O S I T I O N			C R E W P O S I T I O N			C R E W P O S I T I O N								
		S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P					S R O	A T C
														R	I	U			
RO <input type="checkbox"/>	RX												5		1	1	1	0	
SRO-I <input checked="" type="checkbox"/>	NOR	1													1	1	1	1	
SRO-U <input type="checkbox"/>	I/C	2,3,4,5											2,4,6,9		8	4	4	2	
	MAJ	6													2	2	2	1	
	TS	2,3													2	0	2	2	
RO <input checked="" type="checkbox"/>	RX		1,5a												2	1	1	0	
SRO-I <input type="checkbox"/>	NOR		2a												2	1	1	1	
SRO-U <input type="checkbox"/>	I/C		2,4												6	4	4	2	
	MAJ		6												2	2	2	1	
	TS														0	0	2	2	
RO <input checked="" type="checkbox"/>	RX														1	1	1	0	
SRO-I <input type="checkbox"/>	NOR			1											1	1	1	1	
SRO-U <input type="checkbox"/>	I/C			3,5											6	4	4	2	
	MAJ			6											2	2	2	1	
	TS														0	0	2	2	
RO <input type="checkbox"/>	RX		1,5a												2	1	1	0	
SRO-I <input checked="" type="checkbox"/>	NOR		2a												2	1	1	1	
SRO-U <input type="checkbox"/>	I/C		2,4												9	4	4	2	
	MAJ		6												2	2	2	1	
	TS														3	0	2	2	

- Instructions:**
1. Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must serve in both the SRO and the ATC positions, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position. If an Instant SRO *additionally* serves in the BOP position, one I/C malfunction can be credited toward the two I/C malfunctions required for the ATC position.
 2. Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
 3. Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

FINAL

ES-301

Transient and Event Checklist

Form ES-301-5

Facility: Sequoyah Nuclear Plant 1 & 2														Date of Exam: 09/13/2010			Operating Test No.: 2010302		
A P P L I C A N T	E V E N T T Y P E	Scenarios												T O T A L	M I N I M U M (*)				
		1			2			3			4								
		C R E W P O S I T I O N			C R E W P O S I T I O N			C R E W P O S I T I O N			C R E W P O S I T I O N								
		S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P		R	I	U		
RO <input type="checkbox"/> SRO-I <input checked="" type="checkbox"/> SRO-U <input type="checkbox"/>	RX								1					1	1	1	0		
	NOR				4									1	1	1	1		
	I/C				1,2,3,6,8				2,5,9					8	4	4	2		
	MAJ				7				6,7					3	2	2	1		
	TS				3,5									2	0	2	2		
RO <input checked="" type="checkbox"/> SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>	RX					4								1	1	1	0		
	NOR									1				1	1	1	1		
	I/C					2,6,8				3,4,8,10				7	4	4	2		
	MAJ					7				6,7				3	2	2	1		
	TS													0	0	2	2		
RO <input checked="" type="checkbox"/> SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>	RX								1					1	1	1	0		
	NOR						4							1	1	1	1		
	I/C						1,3		2,5,9					5	4	4	2		
	MAJ						7		6,7					3	2	2	1		
	TS													0	0	2	2		
RO <input type="checkbox"/> SRO-I <input checked="" type="checkbox"/> SRO-U <input type="checkbox"/>	RX					4								1	1	1	0		
	NOR								1					1	1	1	1		
	I/C					2,6,8		2,3,4,5,8,9,10						10	4	4	2		
	MAJ					7		6,7						3	2	2	1		
	TS							2,3,5						3	0	2	2		

Instructions:

1. Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must serve in both the SRO and the ATC positions, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position. If an Instant SRO *additionally* serves in the BOP position, one I/C malfunction can be credited toward the two I/C malfunctions required for the ATC position.
2. Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
3. Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

FINAL

ES-301

Transient and Event Checklist

Form ES-301-5

Facility: Sequoyah Nuclear Plant 1 & 2														Date of Exam: 09/13/2010			Operating Test No.: 2010302		
A P P L I C A N T	E V E N T T Y P E	Scenarios												T O T A L	M I N I M U M (*)				
		1			2			3			4								
		C R E W P O S I T I O N			C R E W P O S I T I O N			C R E W P O S I T I O N			C R E W P O S I T I O N								
		S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P		S R O	A T C	B O P		
														R	I	U			
RO <input type="checkbox"/>	RX												5		1	1	1	0	
SRO-I <input checked="" type="checkbox"/>	NOR				4										1	1	1	1	
SRO-U <input type="checkbox"/>	I/C				1,2,3, 6,8								2,4,6,9		9	4	4	2	
	MAJ				7								7		2	2	2	1	
	TS				3,5										2	0	2	2	
RO <input checked="" type="checkbox"/>	RX					4									1	1	1	0	
SRO-I <input type="checkbox"/>	NOR													5	1	1	1	1	
SRO-U <input type="checkbox"/>	I/C				2,6,8									1,3,4, 8	7	4	4	2	
	MAJ				7									7	2	2	2	1	
	TS														0	0	2	2	
RO <input checked="" type="checkbox"/>	RX													5	1	1	1	0	
SRO-I <input type="checkbox"/>	NOR							4							1	1	1	1	
SRO-U <input type="checkbox"/>	I/C							1,3						2,4,6,9	6	4	4	2	
	MAJ							7						7	2	2	2	1	
	TS														0	0	2	2	
RO <input type="checkbox"/>	RX					4									1	1	1	0	
SRO-I <input checked="" type="checkbox"/>	NOR													5	1	1	1	1	
SRO-U <input type="checkbox"/>	I/C				2,6,8								1,2,3,4, 6,8,9		10	4	4	2	
	MAJ				7								7		2	2	2	1	
	TS												1,2,4		3	0	2	2	

- Instructions:**
1. Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must serve in both the SRO and the ATC positions, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position. If an Instant SRO *additionally* serves in the BOP position, one I/C malfunction can be credited toward the two I/C malfunctions required for the ATC position.
 2. Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
 3. Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

FINAL

ES-301

Transient and Event Checklist

Form ES-301-5

Facility: Sequoyah Nuclear Plant 1 & 2														Date of Exam: 09/13/2010			Operating Test No.: 2010302			
A P P L I C A N T	E V E N T T Y P E	Scenarios												T O T A L	M I N I M U M (*)					
		1			2			3			*6*									
		CREW POSITION			CREW POSITION			CREW POSITION			CREW POSITION									
		S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P							
RO <input type="checkbox"/>	RX																			
SRO-I <input checked="" type="checkbox"/>	NOR	1												5			1	1	1	0
SRO-U <input type="checkbox"/>	I/C	2,3,4,5												1,2			6	4	4	2
	MAJ	6												6,7			3	2	2	1
	TS	2,3															2	0	2	2
RO <input checked="" type="checkbox"/>	RX		1,5a														2	1	1	0
SRO-I <input type="checkbox"/>	NOR		2a													5	2	1	1	1
SRO-U <input type="checkbox"/>	I/C		2,4													3,4	4	4	4	2
	MAJ		6													6,7	3	2	2	1
	TS																0	0	2	2
RO <input checked="" type="checkbox"/>	RX														5		1	1	1	0
SRO-I <input type="checkbox"/>	NOR			1													1	1	1	1
SRO-U <input type="checkbox"/>	I/C			3,5											1,2		4	4	4	2
	MAJ			6											6,7		3	2	2	1
	TS																0	0	2	2
RO <input type="checkbox"/>	RX		1,5a														2	1	1	0
SRO-I <input checked="" type="checkbox"/>	NOR		2a												5		2	1	1	1
SRO-U <input type="checkbox"/>	I/C		2,4											1,2,3,4			6	4	4	2
	MAJ		6											6,7			3	2	2	1
	TS													1,2			2	0	2	2

- Instructions:
- Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must serve in both the SRO and the ATC positions, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position. If an Instant SRO *additionally* serves in the BOP position, one I/C malfunction can be credited toward the two I/C malfunctions required for the ATC position.
 - Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
 - Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

FINAL

ES-301

Transient and Event Checklist

Form ES-301-5

Facility: Sequoyah Nuclear Plant 1 & 2		Date of Exam: 09/13/2010		Operating Test No.: 2010302															
A P P L I C A N T	E V E N T T Y P E	Scenarios												T O T A L	M I N I M U M (*)				
		1			2			3			*7*								
		CREW POSITION			CREW POSITION			CREW POSITION			CREW POSITION								
		S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P						
RO <input type="checkbox"/> SRO-I <input checked="" type="checkbox"/> SRO-U <input type="checkbox"/>	RX												1			1	1	1	0
	NOR	1														1	1	1	1
	I/C	2,3,4,5											3,6,7,8			8	4	4	2
	MAJ	6											9			2	2	2	1
	TS	2,3														2	0	2	2
RO <input checked="" type="checkbox"/> SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>	RX		1,5a													2	1	1	0
	NOR		2a										1,3a,6			4	1	1	1
	I/C		2,4										2,5,10			5	4	4	2
	MAJ		6										9			2	2	2	1
	TS															0	0	2	2
RO <input checked="" type="checkbox"/> SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>	RX												1,6			2	1	1	0
	NOR			1												1	1	1	1
	I/C			3,5									3,6,7,8			6	4	4	2
	MAJ			6									9			2	2	2	1
	TS															0	0	2	2
RO <input type="checkbox"/> SRO-I <input checked="" type="checkbox"/> SRO-U <input type="checkbox"/>	RX		1,5a													2	1	1	0
	NOR		2a										1,6			3	1	1	1
	I/C		2,4										2,3,5,6,7,8,10			9	4	4	2
	MAJ		6										9			2	2	2	1
	TS												3,4			2	0	2	2

Instructions:

- Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must serve in both the SRO and the ATC positions, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position. If an Instant SRO *additionally* serves in the BOP position, one I/C malfunction can be credited toward the two I/C malfunctions required for the ATC position.
- Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
- Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

FINAL

ES-301

Competencies Checklist

Form ES-301-6

Facility: Sequoyah Nuclear Plant 1 & 2 Date of Examination: 09/13/2010 Operating Test No.: 2010302														
Competencies	APPLICANTS													
	RO <input checked="" type="checkbox"/> X SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>				RO <input type="checkbox"/> SRO-I <input checked="" type="checkbox"/> X SRO-U <input type="checkbox"/>				RO <input checked="" type="checkbox"/> X SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>			RO <input type="checkbox"/> SRO-I <input checked="" type="checkbox"/> X SRO-U <input type="checkbox"/>		
	SCENARIO				SCENARIO				SCENARIO			SCENARIO		
	1	2	3	4	1	2	3	4	6	7		6	7	
Interpret/Diagnose Events and Conditions	2,3, 4,5, 6	1,2, 3,5, 6,7, 8	2,3,4, 5,6,7, 8,9, 10	1,2,3, 4,6,7, 8,9	2,3, 4, 5,6	1,2, 3,5, 6,7, 8	2,3,4, 5,6,7, 8,9, 10	1,2, 3,4, 6,7, 8,9	1,2,3, 4,6,7	2,3,5,6, 7,9,10		1,2, 3,4, 6,7	2,3,5, 6,7,8, 9,10	
Comply With and Use Procedures (1)	1,2, 3,4, 5,6	1,2, 3,4, 5,6, 7,8	1,2,3, 4,5,6, 7,8,9, 10	1,2,3, 4,5,6, 7,8,9	1,2, 3, 4,5, 6	1,2, 3,4, 5,6, 7,8	1,2,3, 4,5,6, 7,8,9, 10	1,2, 3,4, 5,6, 7,8, 9	1,2,3, 4,5,6, 7	1,2,3,5, 6,7,8, 9,10		1,2, 3,4, 5,6, 7	1,2,3, 5,6,7, 8,9, 10	
Operate Control Boards (2)	1,2, 3,4, 5,6	1,2, 3,4, 5,6, 7,8	1,2,3, 4,5,6, 7,8, 10	1,2,3, 4,5,6, 7,8,9	1,2, 3, 4,5, 6	1,2, 3,4, 5,6, 7,8	1,2,3, 4,5,6, 7,8,9, 10	1,2, 3,4, 5,6, 7,8, 9	1,2,3, 4,5,6, 7	1,2,3,5, 6,7,8, 9,10		1,2, 3,4, 5,6, 7	1,2,3, 5,6,7, 8,9, 10	
Communicate and Interact	1,2, 3,4, 5,6	1,2, 3,4, 5,6, 7,8	1,2,3, 4,5,6, 7,8,9, 10	1,2,3, 4,5,6, 7,8,9	1,2, 3, 4,5, 6	1,2, 3,4, 5,6, 7,8	1,2,3, 4,5,6, 7,8,9, 10	1,2, 3,4, 5,6, 7,8, 9	1,2,3, 4,5,6, 7	1,2,3,5, 6,7,8, 9,10		1,2, 3,4, 5,6, 7	1,2,3, 5,6,7, 8,9, 10	
Demonstrate Supervisory Ability (3)					1,2, 3, 4,5, 6	1,2, 3,4, 5,6, 7,8	1,2,3, 4,5,6, 7,8,9, 10	1,2, 3,4, 5,6, 7,8, 9				1,2, 3,4, 5,6, 7	1,2,3, 5,6,7, 8,9, 10	
Comply With and Use Tech. Specs. (3)					2,3	3,5	2,3,5	2,3, 4				1,2	3,4	

Notes:

(1) Includes Technical Specification compliance for an RO.

(2) Optional for an SRO-U.

(3) Only applicable to SROs.

Instructions:

Check the applicants' license type and enter one or more event numbers that will allow the examiners to evaluate every applicable competency for every applicant.

Facility: SEQUOIA Date of Exam: 2010-302 EXAM

Tier	Group	RO K/A Category Points											SRO-Only Points				
		K 1	K 2	K 3	K 4	K 5	K 6	A 1	A 2	A 3	A 4	G *	Total	A2	G*	Total	
1. Emergency & Abnormal Plant Evolutions	1	3	3	3	N/A			3	3	N/A			3	18	3	3	6
	2	2	1	2	N/A			2	1	N/A			1	9	2	2	4
	Tier Totals	5	4	5	N/A			5	4	N/A			4	27	5	5	10
2. Plant Systems	1	3	2	3	3	3	2	2	3	2	3	2	28	3	2	5	
	2	1	1	1	1	1	0	1	1	1	1	1	10	2	1	3	
	Tier Totals	4	3	4	4	4	2	3	4	3	4	3	38	5	3	8	
3. Generic Knowledge and Abilities Categories		1	2	3	4	10			1	2	3	4	7				
		2	2	3	3				1	2	2	2					

1. Ensure that at least two topics from every applicable K/A category are sampled within each tier of the RO and SRO-only outlines (i.e., except for one category in Tier 3 of the SRO-only outline, the "Tier Totals" in each K/A category shall not be less than two).
2. The point total for each group and tier in the proposed outline must match that specified in the table. The final point total for each group and tier may deviate by ± 1 from that specified in the table based on NRC revisions. The final RO exam must total 75 points and the SRO-only exam must total 25 points.
3. Systems/evolutions within each group are identified on the associated outline; systems or evolutions that do not apply at the facility should be deleted and justified; operationally important, site-specific systems that are not included on the outline should be added. Refer to section D.1.b of ES-401 for guidance regarding the elimination of inappropriate K/A statements.
4. Select topics from as many systems and evolutions as possible; sample every system or evolution in the group before selecting a second topic for any system or evolution.
5. Absent a plant-specific priority, only those K/As having an importance rating (IR) of 2.5 or higher shall be selected. Use the RO and SRO ratings for the RO and SRO-only portions, respectively.
6. Select SRO topics for Tiers 1 and 2 from the shaded systems and K/A categories.
7. *The generic (G) K/As in Tiers 1 and 2 shall be selected from Section 2 of the K/A Catalog, but the topics must be relevant to the applicable evolution or system. Refer to section D.1.b of ES-401 for the applicable KAs.
8. On the following pages, enter the K/A numbers, a brief description of each topic, the topics' importance ratings (IRs) for the applicable license level, and the point totals (#) for each system and category. Enter the group and tier totals for each category in the table above; if fuel handling equipment is sampled in other than Category A2 or G* on the SRO-only exam, enter it on the left side of Column A2 for Tier 2, Group 2 (Note # 1 does not apply). Use duplicate pages for RO and SRO-only exams.
9. For Tier 3, select topics from Section 2 of the K/A catalog, and enter the K/A numbers, descriptions, IRs, and point totals (#) on Form ES-401-3. Limit SRO selections to K/As that are linked to 10 CFR 55.43..

KA	NAME / SAFETY FUNCTION:	IR	RO	SRO	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G												TOPIC:
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
008AK2.02	Pressurizer Vapor Space Accident / 3	2.7	2.7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sensors and detectors	
011EK2.02	Large Break LOCA / 3	2.6	2.7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pumps	
022AA2.01	Loss of Rx Coolant Makeup / 2	3.2	3.8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Whether charging line leak exists	
025AG2.1.7	Loss of RHR System / 4	4.4	4.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Ability to evaluate plant performance and make operational judgments based on operating characteristics, reactor behavior and instrument interpretation.	
026AK3.01	Loss of Component Cooling Water / 8	3.2	3.5	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	The conditions that will initiate the automatic opening and closing of the SWS isolation valves to the CCWS coolers	
027AA1.05	Pressurizer Pressure Control System Malfunction / 3	3.3	3.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Transfer of heaters to backup power supply	
029EG2.4.31	ATWS / 1	4.2	4.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Knowledge of annunciators alarms, indications or response procedures	
038EA1.17	Steam Gen. Tube Rupture / 3	3.2	3.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	S/G sample isolation valve indicators	
054AA2.07	Loss of Main Feedwater / 4	3.4	3.9	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Reactor trip first-out panel indicator	
056AA2.56	Loss of Off-site Power / 6	3.6	3.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	RCS T-ave	
057AK3.01	Loss of Vital AC Inst. Bus / 6	4.1	4.4	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Actions contained in EOP for loss of vital ac electrical instrument bus	

KA	NAME / SAFETY FUNCTION:	IR	RO	SRO	K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G													TOPIC:
					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
058AK1.01	Loss of DC Power / 6	2.8	3.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Battery charger equipment and instrumentation		
062AA1.07	Loss of Nuclear Svc Water / 4	2.9	3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Flow rates to the components and systems that are serviced by the SWS; interactions among the components		
077AK1.03	Generator Voltage and Electric Grid Disturbances / 6	3.3	3.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Under-excitation		
WE04EK1.1	LOCA Outside Containment / 3	3.5	3.9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Components, capacity, and function of emergency systems.		
WE05EK3.2	Inadequate Heat Transfer - Loss of Secondary Heat Sink / 4	3.7	4.1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Normal, abnormal and emergency operating procedures associated with (Loss of Secondary Heat Sink).		
WE11EK2.1	Loss of Emergency Coolant Recirc. / 4	3.6	3.9	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Components and functions of control and safety systems, including instrumentation, signals, interlocks, failure modes and automatic and manual features.		
we12EG2.4.3	Steam Line Rupture - Excessive Heat Transfer / 4	3.7	3.9	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Ability to identify post-accident instrumentation.		

KA	NAME / SAFETY FUNCTION:	IR	K1	K2	K3	K4	K5	K6	A1	A2	A3	A4	G	TOPIC:
		RO	SRO											
028AK2.02	Pressurizer Level Malfunction / 2	2.6	2.7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sensors and detectors
032AK3.02	Loss of Source Range NI / 7	3.7	4.1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Guidance contained in EOP for loss of source-range nuclear instrumentation
033AG2.4.30	Loss of Intermediate Range NI / 7	2.7	4.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Knowledge of events related to system operations/status that must be reported to internal organizations or outside agencies.
036AK1.01	Fuel Handling Accident / 8	3.5	4.1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Radiation exposure hazards
068AA1.06	Control Room Evac. / 8	4.1	4.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Charging pump
074EA1.23	Inad. Core Cooling / 4	3.9	4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PORV block valve indicators, switches, controls (for both RCS and S/G).
076AK3.06	High Reactor Coolant Activity / 9	3.2	3.8	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Actions contained in EOP for high reactor coolant activity
WE14EA2.1	Loss of CTMT Integrity / 5	3.3	3.8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Facility conditions and selection of appropriate procedures during abnormal and emergency operations.
WE15EK1.2	Containment Flooding / 5	2.7	2.9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Normal, abnormal and emergency operating procedures associated with (Containment Flooding).

KA	NAME / SAFETY FUNCTION:	IR		K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G												TOPIC:						
		RO	SRO																			
003A4.03	Reactor Coolant Pump	2.8	2.5	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>					RCP lube oil and lift pump motor controls
004K4.08	Chemical and Volume Control	2.8	3.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					Hydrogen control in RCS
004K5.29	Chemical and Volume Control	2.6	3.3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					Reason for sampling for chloride, fluoride, sodium and solids in RCS
005G2.4.46	Residual Heat Removal	4.2	4.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>					Ability to verify that the alarms are consistent with the plant conditions.
006K2.04	Emergency Core Cooling	3.6	3.8	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					ESFAS-operated valves
007K1.03	Pressurizer Relief/Quench Tank	3.0	3.2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					RCS
008A2.08	Component Cooling Water	2.5	2.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					Effects of shutting (automatically or otherwise) the isolation valves of the letdown cooler
008K1.04	Component Cooling Water	3.3	3.3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					RCS, in order to determine source(s) of RCS leakage into the CCWS
010K4.02	Pressurizer Pressure Control	3.0	3.4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					Prevention of uncovering PZR heaters
012A1.01	Reactor Protection	2.9	3.4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					Trip setpoint adjustment
013K5.02	Engineered Safety Features Actuation	2.9	3.3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>					Safety system logic and reliability

KA	NAME / SAFETY FUNCTION:	IR		K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G												TOPIC:		
		RO	SRO															
013K6.01	Engineered Safety Features Actuation	2.7	3.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Sensors and detectors
022K3.01	Containment Cooling	2.9	3.2	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Containment equipment subject to damage by high or low temperature, humidity and pressure
025K5.02	Ice Condenser	2.6	2.8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Heat transfer
026A3.01	Containment Spray	4.3	4.5	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pump starts and correct MOV positioning
026A4.01	Containment Spray	4.5	4.3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	CSS controls	
039A3.02	Main and Reheat Steam	3.1	3.5	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Isolation of the MRSS	
059K3.02	Main Feedwater	3.6	3.7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	AFW system
059K3.03	Main Feedwater	3.5	3.7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	S/GS
061K6.02	Auxiliary/Emergency Feedwater	2.6	2.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pumps
062G2.4.35	AC Electrical Distribution	3.8	4.0	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Knowledge of local auxiliary operator tasks during emergency and the resultant operational effects
063A4.01	DC Electrical Distribution	2.8	3.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Major breakers and control power fuses

KA	NAME / SAFETY FUNCTION:	IR		K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G											TOPIC:	
		RO	SRO	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
064A2.05	Emergency Diesel Generator	3.1	3.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Loading the ED/G
073A1.01	Process Radiation Monitoring	3.2	3.5	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Radiation levels
073K1.01	Process Radiation Monitoring	3.6	3.9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Those systems served by PRMs
076K2.04	Service Water	2.5	2.6	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Reactor building closed cooling water
078K4.02	Instrument Air	3.2	3.5	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Cross-over to other air systems
103A2.04	Containment	3.5	3.6	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Containment evacuation (including recognition of the alarm)

KA	NAME / SAFETY FUNCTION:	IR		K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G													TOPIC:				
		RO	SRO																		
001K2.03	Control Rod Drive	2.7	3.1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	One-line diagram of power supplies to logic circuits
002A4.02	Reactor Coolant	4.3	4.5	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Indications necessary to verify natural circulation from appropriate level, flow and temperature indications and valve positions upon loss of forced circulation
017K3.01	In-core Temperature Monitor	3.5	3.7	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Natural circulation indications
027K5.01	Containment Iodine Removal	3.1	3.4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Purpose of charcoal filters
028A1.02	Hydrogen Recombiner and Purge Control	3.4	3.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Containment pressure
034K4.03	Fuel Handling Equipment	2.6	3.3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Overload protection
035G2.2.40	Steam Generator	3.4	4.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Ability to apply technical specifications for a system.
055K1.06	Condenser Air Removal	2.6	2.6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	PRM system
071A3.02	Waste Gas Disposal	2.8	2.8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Pressure-regulating system for waste gas vent header
075A2.03	Circulating Water	2.5	2.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Safety features and relationship between condenser vacuum, turbine trip and steam dump

KA	NAME / SAFETY FUNCTION:	IR		K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G											TOPIC:			
		RO	SRO															
001AA2.02	Continuous Rod Withdrawal / 1	4.2	4.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Position of emergency boration valve		
060AG2.4.1	Accidental Gaseous Radwaste Rel. / 9	4.6	4.8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Knowledge of EOP entry conditions and immediate action steps.		
061AA2.01	ARM System Alarms / 7	3.5	3.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	ARM panel displays		
069AG2.4.21	Loss of CTMT Integrity / 5	4.0	4.6	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Knowledge of the parameters and logic used to assess the status of safety functions		

KA	NAME / SAFETY FUNCTION:	IR		K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G												TOPIC:		
		RO	SRO															
012A2.01	Reactor Protection	3.1	3.6	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Faulty bistable operation	
039A2.03	Main and Reheat Steam	3.4	3.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Indications and alarms for main steam and area radiation monitors (during SGTR)		
076G2.4.3	Service Water	3.7	3.9	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Ability to identify post-accident instrumentation.		
078A2.01	Instrument Air	2.4	2.9	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Air dryer and filter malfunctions		
103G2.4.3	Containment	3.7	3.9	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Ability to identify post-accident instrumentation.		

KA	NAME / SAFETY FUNCTION:	IR		K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G											TOPIC:	
		RO	SRO	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
028A2.01	Hydrogen Recombiner and Purge Control	3.4	3.6	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hydrogen recombiner power setting, determined by using plant data book
068A2.04	Liquid Radwaste	3.3	3.3	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Failure of automatic isolation
071G2.2.36	Waste Gas Disposal	3.1	4.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Ability to analyze the effect of maintenance activities, such as degraded power sources, on the status of limiting conditions of operations





KA	NAME / SAFETY FUNCTION:	IR		K1 K2 K3 K4 K5 K6 A1 A2 A3 A4 G												TOPIC:			
		RO	SRO	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G2.1.27	Conduct of operations	3.9	4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Knowledge of system purpose and or function.
G2.2.18	Equipment Control	2.6	3.8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Knowledge of the process for managing maintenance activities during shutdown operations.
G2.2.40	Equipment Control	3.4	4.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Ability to apply technical specifications for a system.
G2.3.12	Radiation Control	3.2	3.7	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Knowledge of radiological safety principles pertaining to licensed operator duties
G2.3.14	Radiation Control	3.4	3.8	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Knowledge of radiation or contamination hazards that may arise during normal, abnormal, or emergency conditions or activities
G2.4.30	Emergency Procedures/Plans	2.7	4.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Knowledge of events related to system operations/status that must be reported to internal organizations or outside agencies.
G2.4.46	Emergency Procedures/Plans	4.2	4.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Ability to verify that the alarms are consistent with the plant conditions.

FINAL

ES-401

Written Examination Quality Checklist

Form ES-401-6

Facility: Sequoyah Nuclear Plant 1 & 2		Date of Exam: 09/13/2010		Exam Level: RO X	SRO X	
Item Description	Initial					
	a	b*	c#			
1. Questions and answers are technically accurate and applicable to the facility.	JTB	NY	JTB			
2. a. NRC K/As are referenced for all questions. b. Facility learning objectives are referenced as available.	JTB	NY	JTB			
3. SRO questions are appropriate in accordance with Section D.2.d of ES-401	JTB	NY	JTB			
4. The sampling process was random and systematic (If more than 4 RO or 2 SRO questions were repeated from the last 2 NRC licensing exams, consult the NRR OL program office).			JTB			
5. Question duplication from the license screening/audit exam was controlled as indicated below (check the item that applies) and appears appropriate: <input type="checkbox"/> the audit exam was systematically and randomly developed; or <input type="checkbox"/> the audit exam was completed before the license exam was started; or <input type="checkbox"/> the examinations were developed independently; or <input checked="" type="checkbox"/> the licensee certifies that there is no duplication; or <input type="checkbox"/> other (explain)	JTB	NY	JTB			
6. Bank use meets limits (no more than 75 percent from the bank, at least 10 percent new, and the rest new or modified); enter the actual RO / SRO-only question distribution(s) at right.	Bank	Modified	New	JTB	NY	JTB
	47 / 11 (%) 63/44	5 / 2 7 / 8	23 / 12 30/48			
7. Between 50 and 60 percent of the questions on the RO exam are written at the comprehension/ analysis level; the SRO exam may exceed 60 percent if the randomly selected K/As support the higher cognitive levels; enter the actual RO / SRO question distribution(s) at right.	Memory	C/A		JTB	NY	JTB
	32 / 5 (%) 43/20	43 / 20 57 / 80				
8. References/handouts provided do not give away answers or aid in the elimination of distractors.	JTB	NY	JTB			
9. Question content conforms with specific K/A statements in the previously approved examination outline and is appropriate for the tier to which they are assigned; deviations are justified.	JTB	NY	JTB			
10. Question psychometric quality and format meet the guidelines in ES Appendix B.	JTB	NY	JTB			
11. The exam contains the required number of one-point, multiple choice items; the total is correct and agrees with the value on the cover sheet.	JTB	NY	JTB			
Printed Name / Signature				Date		
a. Author	Michael Buckner			9/24/2010		
b. Facility Reviewer (*)	Van Ford			9/23/10		
c. NRC Chief Examiner (#)	Richard S. Baldwin			9/23/10		
d. NRC Regional Supervisor	Malcolm T. Widmann			09/29/10		
<p>Note: * The facility reviewer's initials/signature are not applicable for NRC-developed examinations. # Independent NRC reviewer initial items in Column "c"; chief examiner concurrence required.</p>						

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Back-ward	Q=K/A	SRO Only			
4	H	2												B	E	<p>025AG2.107, Bank, higher</p> <p>Add to the stem the reference to what procedure these actions are being taken. Is the AOP the appropriate procedure, what Annunciators would be in for this situation? added as requested.</p> <p>This question identifies that C is the answer, however, the analysis states that D is the answer. Select D as the answer on the question.changed as requested.</p> <p>Distractors are not consistent again, need to use additional words to make sentences. Add "valves" before the listed valves in distractor D. This has changed as requested.</p> <p>KA appears to match</p> <p>Address above concerns. Question is ok as changed.</p>
5	H	2-3												N	E	<p>026AK3.01, New, Higher</p> <p>For the valves in the stem, add commas where necessary to separate the valve numbers from the valve nomenclature. Additionally, is "open position" different from OPEN? Yes there is a difference with the nomenclature.</p> <p>Place commas in the appropriate positions for the first time the valve and valve numbers in the stem. After the valve number and then again after the noun name and inside the quotes. Done as requested, ok as it appears..</p> <p>KA appears to match</p> <p>Otherwise, question appears to be ok</p> <p>Question is ok as changed.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Back-ward	Q=K/A	SRO Only			
6	H	2												N	E	<p>027AA1.05, New, Higher</p> <p>Distractor B is not plausible. The system design would never allow no heaters to be on at this time. If you want this to be plausible, change the time provided to a time before the heaters are re-energized. This is ok the way it is.</p> <p>Change the initial premise of the question to have just one of the shutdown boards be energized and then you can use various answers and none of them being no heaters available.</p> <p>When the question is changed remove "if any" from the question. N/A</p> <p>Disagree with level of knowledge. If you don't have this memorized, you cannot answer the question. Discuss with the licensee. Na ok as is</p> <p>KA appears to match.</p> <p>Ok as is, no changes necessary to the question.</p>
7	F Changed to a higher H	2-3												B	S	<p>029EG2.4.31, Bank, Lower</p> <p>Be consistent with the placement of the quotes. The punctuation following a phrase that is always included in the quotes. It is done differently with this question and throughout the examination. Just be consistent.</p> <p>KA appears to match</p> <p>Question appears to be ok.</p> <p>RO reviewer states that B is not plausible because they are not required to memorize step 6. SO added the verbage from step six of the procedure.</p> <p>Also added to stem capitalizes VERIFY and TRIPPED. As is in the procedure. Ok as changed. See exam to see what was modified.</p> <p>Changed from Fundamental to Higher.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Back-ward	Q=K/A	SRO Only			
8	H	2-3												N	E	<p>038EA1.17, New, Higher</p> <p>Place in the stem the procedure the operator is expected to do this in accordance with. Changed.</p> <p>The references provided do not identify the panel or what is necessary to ensure it is open. Had to use Reference material to obtain this information. Understand where these are now.</p> <p>What is the significance of the M-6 panel, where is it and what valves are you describing when it is used? This is where the operator looks at the valves for blow down.</p> <p>S</p> <p>Need to add words to make complete sentences. Add "the" prior to S/G. Verify the red sample valve status light is lit for THE S/G to be sampled on 2-M-6. What panel is this? Have licensee help out to describe what valves they are speaking about.</p> <p>The Phase A isolated both inside and outside isolation valves and sample valves. While AFW either outside containment isolation valves and sample valves.</p> <p>What is the significance of the Mode? When you are in mode 3 vs one and two.</p> <p>Disagree with level of difficulty, its memorization and answering if all you do is apply this. Discuss with licensee.</p> <p>KA appears to match.</p> <p>The distractor analysis for C was D and visa versa, chanted.</p>

Instructions

[Refer to Section D of ES-401 and Appendix B for additional information regarding each of the following concepts.]

1. Enter the level of knowledge (LOK) of each question as either (F)undamental or (H)igher cognitive level.
2. Enter the level of difficulty (LOD) of each question using a 1 – 5 (easy – difficult) rating scale (questions in the 2 – 4 range are acceptable).
3. Check the appropriate box if a psychometric flaw is identified:
 - The stem lacks sufficient focus to elicit the correct answer (e.g., unclear intent, more information is needed, or too much needless information).
 - The stem or distractors contain cues (i.e., clues, specific determiners, phrasing, length, etc).
 - The answer choices are a collection of unrelated true/false statements.
 - The distractors are not credible; single implausible distractors should be repaired, more than one is unacceptable.
 - One or more distractors is (are) partially correct (e.g., if the applicant can make unstated assumptions that are not contradicted by stem).
4. Check the appropriate box if a job content error is identified:
 - The question is not linked to the job requirements (i.e., the question has a valid K/A but, as written, is not operational in content).
 - The question requires the recall of knowledge that is too specific for the closed reference test mode (i.e., it is not required to be known from memory).
 - The question contains data with an unrealistic level of accuracy or inconsistent units (e.g., panel meter in percent with question in gallons).
 - The question requires reverse logic or application compared to the job requirements.
5. Check questions that are sampled for conformance with the approved K/A and those that are *designated SRO-only* (K/A and license level mismatches are unacceptable).
6. Enter question source: (B)ank, (M)odified, or (N)ew. Check that (M)odified questions meet criteria of ES-401 Section D.2.f.
7. Based on the reviewer's judgment, is the question as written (U)nsatisfactory (requiring repair or replacement), in need of (E)ditorial enhancement, or (S)atisfactory?
8. At a minimum, explain any "U" ratings (e.g., how the Appendix B psychometric attributes are not being met).

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
9	H	2-3												N	S	054AA2.07, New, Higher KA appears to be ok Question appears to be ok.
10	H													B	S	056AA2.56, Bank, Higher KA appears to match Question appears to be ok.
11	H													B	S	057AK3.01, Higher, Bank KA appears to match Question appears to be ok.
12	H													B	E S	058AK1.01, Bank, Higher The second bullet is teaching, is this necessary to answer the question? Can it be said that the 125 VDC power supply is in its normal alignment? <i>I read this incorrectly, this is ok the way it was.</i> KA appears to be ok. Otherwise, question appears to be ok. <i>Needed to add assuming no operator action. Wording consistent. Changed the stem from greater than 4 hours. To 5 hours. Don't use the set point. VF identified that requirements do not need to be in each distractor where it was used. OK as changed.</i>
13	H	2-3												B	E	062AA1.07, Bank, Higher Be consistent with how the information that no operator action is taken is standard. This question is different than question #6. Either way is ok, I sort of prefer the way # 6 is done, whatever is easier to accomplish. <i>Changed the stem to Assuming NO operator action. Used in 6, ok as changed.</i> KA appears to be ok. Otherwise, question appears to be ok.

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
14	H	2-3												M	E	<p>077AA1.03, Modified Bank, Higher.</p> <p>Are there two answers to this question? Why would the manual operation of the Voltage Base Adjuster not be also used to adjust MVARs incoming? As licensee. OK as is, the voltage adjuster is in AUTO and would ONLY be operated in AUTO.</p> <p>KA appears to match</p> <p>S Is this information concerning the 500 KV line required RO/SRO knowledge? Ask licensee if this is something they expect the operators to know. OK as is.</p> <p>Otherwise, question appears to be ok.</p>
15	F	2												N	E	<p>W/E04EK1.1, New, Lower</p> <p>Add to the stem after WOOTF "pumps" is contributing...NA this is not necessary.</p> <p>KA appears to be ok.</p> <p>Otherwise, question appears to be ok.</p> <p>S RO commented that the 1400 confuses the process and will be hard to determine with the information. SO changes the pressure to 1495 to ensure the answer will be what we expected.</p> <p>NEED TO STILL RUN THIS ON THE SIMULATOR.</p>
16	F	2-3												B	E	<p>W/E05EK3.2, Bank, Lower</p> <p>KA appears to be ok.</p> <p>S Change answer to what is said in the analysis. Propose answer to be, "To extend the effectiveness of the remaining water inventory in the Steam Generator." Changed as requested.</p> <p>Otherwise, question appears to be ok with suggested change.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
17	H	3				X									B	U E S	<p>WE11EK2.1, Bank, Higher.</p> <p>Put the noun name of valves 72 and 73, in quotes. Also add appropriate words where needed. (i.e. both "valves" prior to the 1FCV-63-72...)</p> <p>The reference to the step in the last bullet is not necessary, only refer to what they are doing. The way it is written implies that the applicant should, from memory, know what that step is.</p> <p>The question asks wooff will result in the proper alignment of the CSPs under plant conditions. Each distractor puts the applicant at a different part of the procedure. Distractor A puts you in Step 8 to stop pumps if level is below 8%, but then the PTL does not come happen to step 9 b. Made a bad assumption and would not do this, would have to go to step 10. And not do step 9 entirely.</p> <p>Distractor C is not totally correct, in that, it states to stop one pump (should be in PTL) and cannot allow to swap this is a manual action and only if the sump level is greater than 18% (22%). Ask licensee if this is correct. Added containment sump level of 52% good.</p> <p>Distractor A does not appear to be plausible.</p> <p>Add to the stem a value of containment sump level that would be available at that time. Propose that 19%.</p> <p>Change answer B to read Continue to run both CSPs until RWST level is less than 8%, then swap both CSPs to the RWST.. This suggestion is incorrect, should not have done this and did not.</p> <p>The changed analysis of this question from U to E. Should not have had this. As changed this question's changes were ok.</p>
18																S	<p>WE12 EG2.4.3 New, Higher, This question was NOT in the hard copy.</p> <p>Question appears to be ok. Capitalize Category and provide a color copy of this to the applicants, if possible.</p>
19	H	3													B	S	<p>028AK2.02, Bank, Higher</p> <p>KA appears to match</p> <p>Question appears to be ok.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
20	H	2-3											X		M	U	<p>032AK3.02, Modified Bank, Higher</p> <p>Unmodified question was not provided, could not determine if the question was modified in accordance with the NUREG.</p> <p>Add to the stem the procedure, it should then read, WOOTF action(s) is required to be taken in accordance with ECA - 0.0.</p> <p>The Answer is the only distractor that has a caveat to it, which provides a clue but not a reason for doing it. KA does not appear to match. In that, there are NO reasons being evaluated.</p> <p>This question needs to be modified to have two ideas the first being stop dumping steam. Add to that, one reason why that is correct and another that is not correct. Then select distractor C and have two reasons for those. Thus creating a 2x2 question.</p> <p>Could not make a 2X2, but added reasons to the distractors.</p> <p>The sentence concerning the failure of BOTH Source Range NI's does not appear plausible. Need to change this to make it plausible. Added to the stem to have unit 2 at 100% with N31 out of service. Now the question will have a loss of SR NI's.</p>
21	H	2-3													N	S	<p>033AG2/4/30, New, Higher</p> <p>Question Appears to be ok</p> <p>KA appears to match.</p>
22	F	2-3													B	S	<p>036AK1.01, Bank, lower</p> <p>KA appears to match</p> <p>Question appears to be ok.</p>
23	F	2													N	S	<p>068AA1.06, New, Lower,</p> <p>KA appears to match</p> <p>Question appears to be ok.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
24	H	3											X		N	U E S	<p>074EA123, New, Higher</p> <p>Change first bullet to read, "Unit-2 has experienced a small break LOCA that resulted into entry into FR-C.1, "Inadequate Core Cooling." While performing FR-C.1, the position of pressurizer PORV block valve"</p> <p>KA does not match the question. Are these actions ONLY done in C-1? If not, then it is a generic and has nothing with C.1. If it's the only place they occur then it may be ok. Licensee to discuss.</p> <p>Question appears to be ok. The examiner initially diagnosed this as a U and was incorrect. This question should not have been evaluated as a U but an E. The changes were made as requested. The KA did match. Not sure why it was initially identified as a U and not matching the KA.</p> <p>Question is OK now.</p>
25	L	3													B	E S	<p>076AK3.06, Bank, Lower</p> <p>KA appears to match</p> <p>Change the numbers each distractor, change from 0.16 and 0.36. and then change the second part to reflect that the number is now not the first. Just the activity level that would require entry into the TS.</p> <p>Don't like to use set points as the value, this triggers the applicants memory just because of the memory of a familiar number. If the ROs received a chem. Report stating that the value was something greater than 0.35 then the operator is required to know that entry condition.</p> <p>Changed this as requested.</p>
26	H	3													N	S	<p>W/E14EA2.1, New, higher.</p> <p>KA appears to match</p> <p>Question appears to be ok.</p> <p>Should the stem have reference to 2-FR-0? Added this enhancement to the question.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Back-ward	Q=K/A	SRO Only			
27	F	2-3												B	E S	<p>WE15EK1.2, Bank, Lower,</p> <p>In the stem, the last bullet, does not seem like it should be included. This short of answers the question incorrectly, remove this from the stem, it's not necessary.</p> <p>KA appears to match,</p> <p>Otherwise, question appears to be ok. Question was changed, and added FRZ 2 in the first stem of the question.</p>
28	F	3												N	E S	<p>003A4.03, New, Lower</p> <p>In stem, first bullet, add the RCP that is being started. The Lift Pump is the pump for #2 RCP. Make this as clear as possible.</p> <p>Add to each distractor's second part, the 1 min minimum required by the procedure.</p> <p>Changed the question as requested. OK</p>
29	F					X								B	U E S	<p>004K4.08, Bank, Lower,</p> <p>In the stem, it is not necessary to have the nominal pressure of hydrogen in the VCT. Remove this from the stem.</p> <p>Distractor A, is not plausible, since when does the plant simultaneously start pumps, does not make it plausible just because the NPSH is addressed. Need another distractor.</p> <p>Suggestion,</p> <p>Use pressures 15 and 17 and oxygen scavenging and back pressure to the RCP #2 seal and ensure flow to the # 3 seal</p> <p>a. 15 #s, nominal Hydrogen pressure, and oxygen scavenging b. 17#s , nominal Hydrogen pressure, and provides RCP #2 seal to ensure adequate flow to # 3 Seal. Etc.</p> <p>Needs work to fix.</p> <p>OK as changed. Misclassified as a U, should have been an E.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
30	F	2-3												N	E/U	<p>004K5.29, New, Lower,</p> <p>Distractor C does not seem plausible, it ONLY discusses the oxygen concentration and does not address the other limits for chlorides and fluorides because of singling out only oxygen from the stem, why would anyone pick this distractor. Added the other chemicals to the question.</p> <p>Is distractor B totally incorrect? From the basis of the TS, there is a statement on page B3/4 4-2, that states something similar, in that, it states this for the Reactor Coolant System. Is not the RCP seals part of the RCS? Discuss with licensee to ensure this is entirely incorrect. VF states this is the basis for sampling not the limits of the chlorides fluorides and oxygen.</p> <p>The initial analysis should be an E not a U. OK as changed.</p>
31	H	3												B	E	<p>005G2.4.46, Bank, Higher</p> <p>When this phenomenon occurs, where is the temperature indicator? Cannot find on the procedures/lesson plans. Based on the analysis, it appears that the temperature indicator is some place on the output line on the RHR heat exchanger. Cannot find on simplified drawing.</p> <p>Have licensee explain how, the isolation of letdown does not stop or reduce leakage. Cannot determine how this would not help or prevent the high temperature alarm.</p> <p>Have licensee explain how this works and what the applicant has to do to answer this question.</p> <p>What constitutes the removal of RHR Letdown from service as used in distractors A and B?</p> <p>KA appears to match.</p> <p>Question appears to be ok.</p> <p>CCW side of the alarm, not the RHR side. 1-TI-70-157 is the detector for the temperature of this alarm. OK as is.</p>
32	F	2-3												N	S	<p>006K2.04, New, Lower</p> <p>Is this something an operator is expected to know from memory? VF and RO stated it is an expected knowledge for applicants. OK.</p> <p>KA appears to match</p> <p>Question appears to be ok.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
33	H	2-3												B	E/S	<p>007K1.03, Bank, Higher</p> <p>Distractors used in this question appear to have different properties in them, in that, the answer, distractor C states RCP seal leakoff flow is returning to the PRT. While this is true, it should be written as just RCP seal leakoff flow. The part "returning to the PRT" is not necessary. Or is it? Ask licensee. This part is NOT necessary to provide. Removed as requested.</p> <p>The same analysis can be applied to distractor D. This distractor is the only distractor that has a reason for the valve opening. Remove this part of the question. D should now read, Valve FCV-68-303, PRT fill valve, fails OPEN. The valve actually fails closed. So VF does not want to put the direction on the distractor.</p> <p>C should read RCP seal leakoff flow.</p> <p>S</p> <p>Changed D to Loss of air to the PRT fill valve FCV-68-303.</p>
34	H	2-3												N	U	<p>008A2.08. New, Higher.</p> <p>Place a comma between TS-62-78 and LTDN.</p> <p>.In the initial conditions of the question, it states that the ALL other CCS indications are NORMAL. If they are normal, how then in distractors A and B, could there be a leak on the CCS header? It appears to me that distractors A and B are not plausible because of this. Discuss with licensee to understand what may be occurring.</p> <p>S</p> <p>Added operator prior to action.</p> <p>Removed the last bullet, this made this satisfactory question. Does the name of the procedure need to be added? VF leave as it is. Agree with licensee. .</p>
35	H	3												B	E	<p>008K1.04, Bank, Higher.</p> <p>The way this question is worded in the stem is very confusing. Rewrite this to be less confusing.</p> <p>KA appears to match.</p> <p>Question appears to be ok, however, confusing.</p> <p>S</p> <p>Reworded the stem, WOOTF identifies the location of the CCS leak and the resulting plant condition the leak would cause?</p> <p>OK as changed</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
36	H	2-3												M	S	010K4.02, Modified bank, Not rated for Level of Knowledge. Chief Examiner rated as a higher LOK question. Original question was not submitted to verify it met the modification requirements. Will not use as a modified question, need to move it back to a bank. This modification does not constitute a modified question. KA appears to match. Question appears to be ok.
37	H	3												B	S	012A1.01, Bank, Higher KA appears to match Question appears to be ok.
38	H	2-3				X								B	U	013K5.02, Bank, Higher, Distractors A and B are not plausible. When the instrument fails LOW, the instrument opening does not make sense. These need to be fixed. KA appears to match.
						ok									S	Changed the question to allow for the A and B implausible being fixed. Added additional words to all distractors see the actual changed question.

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
39	L	2				X									B	U	<p>013K6.01, Bank, Lower,</p> <p>The question as presented has multiple flaws, most of which are plausibility of the distractors. The evaluation of the system is the 2/4 and this is not really being tested.</p> <p>Distractor C is NOT plausible, why would a failure of ONE instrument cause BOTH trains to be inoperable, are there any other systems that this type of failure occurs in the entire plant? I would say no.</p> <p>Suggest to tag out the same instrument then fail another instrument and ask the same questions. This may work then. But have to make sure it does. As it sits now it is not satisfactory.</p> <p>Low level channel swap over, need 2 of 4 and tagged out the 52. This made this better, additionally, a failure of an additional instrument made this more relevant.</p> <p>S Removed the time frame from the test. It really does not matter.</p> <p>VF states that OPERABLE in the stems are not actually correct. This really mean available. Need to change the words in each distractor.</p> <p>Changed lots, see changes on the test.</p>
40	H					X						X			B	U	<p>022K3.01, Bank, Higher</p> <p>Used on the 2006 Exam WBN</p> <p>The question is NOT specific to the KA, in that, the KA speak about damage, however, this could be stated that the seat leakage or something else that is changing is affected detrimentally.</p> <p>IN ALL distractors the described conditions have an effect. While they may or may not be significant, they all will have something that is affected. This is the reason why the question as it stands is poor.</p> <p>There is a fundamental difference on what the statement in the containment means. Examiner believes it is containment equipment, however, the licensee believes it is equipment inside the containment. Discuss with another examiner and the supervisor to see if this is or is not correct.</p> <p>DISTRACTORS INITALLY WERE NON PLAUSIBLE. A B C AND WAS NOT IMPLAUSIBLE DUE TO THE KA MATCH,</p> <p>S CHANGED THE QUESTION. SEE TEST GOOD AS IS.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
41	L	2											X			<p>U 025K5.02, Bank, Lower, KA does not match, The question as written does not address the licensee's discussion of the KA match, it does not cover any of the items the licensee identifies in this area. This question only address's a precaution and Limitation of what is the optimal temperature range.</p> <p>E THE KA covers the ice condenser and its ability to for heat transfer. This question tests how this is accomplished, ie for a LOCA and how the system works. Question is ok, however, it does not match KA Replace question.</p> <p>S Was the examiners Initial characterization incorrect? This question may be ok, ask other examiners. 18 and 27 (TS limit) and then the heat transfer part. Use, second part, maintain with in ts limits, and or use sublimation. ?? Review to see what to do. Changed the question to make it 18 or 27 and excessive concrete expansion or outside tech spec limit. MB stated the questions does meet KA. Mischaracterized initially.</p>
42	H	2-3												B		<p>E 026A3.01, Bank, Higher. In the analysis of this question, the time used is 184 seconds, however, in all the reference material this time is 180 seconds or 3 minutes. It is 180! Changed in this.</p> <p>In the question the applicant has to assume that the EDGs loaded on their respective buses at time 1205, and about 30 seconds. 10 seconds for the DG to start, and the first 4 steps being completed. Is this something we want the applicant to assume? Discuss with licensee if this needs to be identified more clearly. Also is it important for us to make sure that the position of the CS switches are in standby readiness and in A-Auto, etc. Discuss! MB states that this is not necessary. Examiner agrees. Nothing needs to be done.</p> <p>KA appears to match.</p> <p>S Question appears to be ok. Waiting final outcome of discussions above. Question is sat as it was submitted.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
43	L	2				X									B	U	<p>026A4.01., Bank, Lower, KA appears to match CSS is actuated via the phase B controls.</p> <p>Question's distractors A and B are NOT plausible!. Everyone knows that there has to be two switches manipulated and this will not do. The licensee took offense to that that, everyone would not know this from memory. Change to have one switch in each of the opposite pairs has to be manipulated to operate.</p> <p>E This will make this question a little higher level of knowledge.</p> <p>What was the spread of answers for this question, if any spread at all? From validation. This was validated as 100% correct. Done by requal operators.</p> <p>S Examiner mischaracterized this question as a U. This should have been evaluated as an E not a U.</p> <p>The question was rewritten to make distractor A to read, Operation of any one of the 4 handswitches will actuate both trains.</p> <p>Rewrote distractor to read Operation of either 1 HS 30-64A or 1 HS 30-68A (M-5) will actuate train A ONLY.</p> <p>Added handswitches to switches in both C and D, also, stated that distractor D was taken the two switches and to pair.</p>
44	H	3													B	E/S	<p>039A3.02, Bank, Higher KA appears to be ok</p> <p>Distractor A, add BOTH to the front of the distractor.</p> <p>For all the distractors, start with SI and end with MSLI, or visa versa. It does not matter, just make sure they are in the same order. It makes it harder to read the question when they are different. Did as suggested.</p> <p>Otherwise, question appears to be ok. IS ok. As changed.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
45	H	2-3				X									B	E/S	<p>059K3.02, Bank, higher. KA appears to match.</p> <p>Since the answers are concerning the Unit 1 AFW pumps, how about customizing this question to be unit 1 specific, by changing the information in the stem to Unit 1. Changed as requested, made it a unit 1 question.</p> <p>Or, just change the answers to be more generic if that can be done.</p> <p>In other distractors, the word ONLY has been capitalized. So be consistent with whatever convention is used followed this suggestion also .</p> <p>Otherwise, question appears to be ok.!</p>
46	H	2	X			X									B	U	<p>059K3.03, Bank, higher.</p> <p>The stem needs to be made tighter. In that, the word used "APPARENT" to the operators. This is NOT concise enough, because it means where the operator happens to be looking at the time. Tighten up to insure we are asking the correct question.</p> <p>Question has many non plausible distractors. Distractor B would take a long time to be seen by the operator. Replace with something more plausible and not requiring the system feedback from secondary to primary.</p> <p>Change distractor C, to decreases, now the applicant has to determine which comes in first.</p> <p>Distractor A is the only annunciator, the licensee KA match determine states that the applicants were to determine which indications (alarms) would be generated first. This is incorrect! There is only one annunciator that is provided. Also this distractor is the only one that is ALL Capitalized. Gives it a clue it may be the answer.</p> <p>Will come up with 4 alarms, and will go over this again, Changed this question to use the alarms.</p> <p>Looks good, need to run on simulator to determine if there is an issue with how the applicants have to answer this.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
50	H												X		N	U	064A2.05, New, Higher, Question doesn't appear to match K/A. Don't see how the question addresses the use of procedures to correct, control or mitigate the consequences ...
																S	REPLACED THIS QUESTION TO MATCH KA. NEW question appears to be ok. KA matches.
51															B	S	073.A1.01
52	F	1	X			X									B	E	073K1.01, Bank, Fundamental. (LOD) Should avoid using "best." It appears that two of the distractors can be immediately dismissed based on the alarms received – what occurs when a high rad alarm is received and why Information for RICK....
																S	Appears that the first two answers/distractors could be discounted because they do not run ever. The answer or control building emergency air pressurization fans start on this signal. Change A and B to Main Control room Air handling unit. This will make it better.
53	F	2													N	S	076K2.08, New Lower,
54	F	1	X			X									M	U	LOD as written. The stem appears to ask what must/should have occurred to maintain Air Header Pressure for the given conditions. I would think that based on what is asked, distractors A, B & C are not plausible. Please answer what pressures would be/or could be maintained if actions taken in distractors A, B & D are taken.
																E	In this question, the distractor s that each of the distractors provide different components compressor is 77 pounds, isolation valve is 69 pounds, service air receiver,
																S	Should have been characterized as an E. Changed the stem to have should have vice would have

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
55	H					X								B	E	Distractor A is not plausible. Not sure of any mechanical equipment malfunction which would require an evacuation of containment. Provided information if there is.
															S	Changed A second part, to Place Rx Vessel Head on stand. . Reworded the stem to reflect the way the table is. See question.
56	F	2												B	S	
57	H	3												B	S	
58	H	2				X								B	S?/U	017K3.01, Bank, higher. The question appears to be OK, however the use of the words several and slightly could be challenged. Several could mean 2 or more and slightly could mean 1-2????? This could result in several correct answers. ES-0.1 for both running and stopped RCP says stable or trending between 547 and 552. Please explain.....
															S	The question appears to be ok as is. Question matches the KA.
59	F	2												B	S	
60	F	2												N	S	
61	F	2												M	S	
62	F	2												B	S	
63	F	2												B	S	
64	F	2				X								N	E	071A3.02, New, Lower, Not sure why one would think that closing the pressure control valve would be plausible as in Distractor A
															S	The suction control valve is not credible, when do you throttle the suction of any pump? This will be changed in distractors A and C to the discharge throttle valve. This makes more sense and does not accomplish the task as discussed in the question.

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Back-ward	Q=K/A	SRO Only			
65	H	3												N	S	075A2.03
66	F	1												B	S/U	<p>G2.138 LOD. Addressed K/A. This area is tested through simulator scenarios. Would suggest replacing the K/A if it is not too late</p> <p>The new KA is G2.1.32, was used to prevent the overlap of competencies in the question and the simulator scenarios. This new question covers operation of pumps with successive motor starts.</p> <p>OK meets ka and question is ok.</p>
67	H	2	X			X								B	U	<p>G.2.1.7 bank, higher.</p> <p>Should stem state according to plant procedure? Distractor B & D do not appear to be plausible. Do not see why starting the AFW pumps would be acceptable. Even if starting the pumps were acceptable and we make the assumption that parameters are restored, why would one trip the turbine.</p> <p>AOP S.1, Main feed water malfunctions. Added this. Changed this question significantly. See exam for changes.</p>
68	F	1 2-3												B	S	<p>LOD</p> <p>Changed the question that added information to make the level of difficulty higher, KA matches a Question is ok.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
69	F	1				X									M	U E S	<p>LOD Not able to identify information in the procedure to support answer. Distractor D is not plausible. Why would one think that a procedure that need a minor editorial change would be placed on hold?</p> <p>G.2.2.6, Modified , Higher. Change distractor D to read Process a Minor Editorial Change. Did not have the appropriate references but were available during combined review.</p> <p>Question was mischaracterized as a U. This should have been characterized as an E. Question change is ok.</p>
70	H	2 2-3				X									B	U E S	<p>Distractor A is not plausible. Do not know of any reasons to dispatch radcon to control room. It appears that distractor C may also be correct based on information provided. RM-103 is increasing. Distractor D, which is the correct answer appears to lead the applicant do the fact that the stem talks about SFP and the answer reads High Radiation in the SFP area.....</p> <p>G2.3.13, Bank, Higher Changed bullet to have fuel shuffle in progress. Changed both distractors C and D, Verify the Auxilliary Building General Supply and Exhaust fans are shutdown, manually actuate BOTH A and B train Auxilliary Building Isolation. And D reads now, similar to the c but only the A train to start manually.</p> <p>Mischaracterized the evaluation of the question it should have been an E and not a U. Changed from U to E and changes to S.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
71	F	2												B	S?	Provide information on each of the monitors identified in distractors A, C & D. Unable to identify them in any procedure G 2.3.15, Bank, Lower, Are expected to know, above the line on TSs. OK for RO knowledge. Need to change the noun names of what is actually listed on the radiation monitor, this needs to be done to ensure that an applicant does not have an excuse that an incorrect noun name threw them off of the answer because of incorrect nomenclature. .
72	H	1												B	S	LOD
73	F	2												N	S	
74	H	3												B	S	
75	F	2				X								B	U E S	As the question is written it appears there could be two correct answers. A & C. Distractor D is not plausible -- don't see why applicant consider D. Distractor D was not totally incorrect, made so that the distractor encompassed the whole procedure by adding anytime making it incorrect. Distractors C (the answer) and D could almost be considered correct. Removed from the stem the statement ECCS flow injecting. This made B almost the same as C. Implausible. C was not correct. This should have been an E not a U. KA ok and question now as it appears is ok.
SRO Only																
76	F	2-3												N	S	029EA2.06, NEW, KA matches While this question is a lower level question, it appears to be ok.

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws					5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
77	H	2-3													B	E	038EG2.2.40, Bank KA matches Distractor D, is not plausible! The target temperature usually is determined by the associated SG. Since there is NO steam generator pressure to figure out what the target temperature, this could not be credible as a distractor. Select another Distractor for D.
																S	Spell out Tech Spec, changed distractor D to add the 100 deg F for cool down in TS. OK as changed.
78	H	3													N	E	054AG2.4.30, New, The second bullet in the initial conditions is too long to read. It also does not explicitly allow the reader to determine that the TDAFW pump is out of service and provides an element of teaching. Shorten this and that the TDAFW pump is OOC. Added TDAFW tagged out. KA appears to match
																S	Remove from stem the yellow path reference.
79	H	3													N	S	055EA2.03, New, KA appears to match Appears to be ok.
80	H	2-3													N	E	058AG2.4.18, New KA appears to match Teaching in the third bullet. Remove the word "three" from the sentence. They should know that there are three other SD boards. And add to the 2A shutdown board as being the ONLY SDB being powered. Remove the reference to "three" other SDBs being without power. Did this, appears to be ok. In the initial conditions should the word "complete" be "completed?" Why didn't the writer use EA-250-1 in either distractors a or b? This also would be untrue. Will change A to have 250-1, for the 250-2.
																S	Question appears to be ok.

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Back-ward	Q=K/A	SRO Only			
83	H	2-3												N	U	<p>060AG2.4.21, New, higher</p> <p>Not sure if it is clear that the high Radiation levels are on Unit 1. Make sure it is clear. Appears to the licensee.</p> <p>Since the LCO is not a short period LCO, meaning hour or less is it reasonable for the SROs to be required to know this TS? As licensee if this is ok to make sure we test the appropriate items. VF expects the SROs to know this 3.0.3 from memory. ROs do not have to know this.</p> <p>Is it a true statement that the EGTS system will automatically start on the conditions listed in the initial conditions of the question? If this is true, the operator merely has to identify that the system auto-starts and aligns automatically. If this is the case, there is no analysis of the safety functions listed in the KA. I do not believe the KA is being met because of this. Discuss with licensee to understand system requirements.</p> <p>KA does not match.</p> <p>Does it meet the KA. And is it an SRO ONLY</p> <p>S This is SRO only, and the KA does meet, met with another examiner and found this does meet the requirements of both the SRO and KA match.</p> <p>Question is ok.</p>




Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
84	H	3-4												M	S	<p>061AA2.01, Modified Bank, Higher</p> <p>Trivial, on third bullet, there are two periods in a row.</p> <p>In bullet 4, there is a reference to a radiation monitor, 0-RM-90-102, in the third bullet, the same name is used for the rad monitors, however, the rad monitor number is 103. Are they the same or, is this a mistake? Licensee to review. The same name but different trains.</p> <p>Question is modified bank, in order to determine if it was modified as required by 1021, the bank question needs to be provided which it was not. Provide bank question for review. Or identify what was changed from the original bank question.</p> <p>This question appears to be complicated and would need references, however, the questions references are not required to answer the question. Is this expected of the SROs to know this detail of the TS without TSs? Yes its complicated the TS 3.9.12, the answer to determine if this is entered is located in the 18 month surveillance requirements. Because this is buried in this it would seem unfair and unreasonable to NOT allow this TS to be used. Will allow this TS to be provided for the exam.</p> <p>Discuss with licensee to show me how the switch manipulations in the IC effects or does not affect the answers. Understand what this means.</p> <p>KA appears to match.</p>
85	H	2-3												N	E	<p>069AG2.4.21, New, Higher</p> <p>The question itself states that References are provided, however, on the page that provides the references that developed this question, there is a place that identifies references provided, this states NONE as the references provided. This conflicts each other. Ask licensee which is correct. Clarify what references are being provided. Just the 3.6.1.3 TS will be added and not the basis. This is ok.</p> <p>If the basis is provided then the question's second part will become a direct look up.</p>
															S	<p>KA appears to match.</p> <p>Question is ok as is.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
89	H	3											X	M	U	<p>078A2.01, Modified Bank, Higher.</p> <p>Question meets modification requirements.</p> <p>This question appears to be answerable with ONLY RO knowledge. RO knowledge is system knowledge for the system bypass. Based on the information provided in the stem the applicant can use system knowledge to answer the first part.</p> <p>The answer to the question mislead that answer B was marked as the answer this was not the answer but B, this provided impetus for calling this unsat initially.</p> <p>The second part can also be answered by system knowledge. If the applicant knows from system knowledge, what will happen with the AFW system on a loss of auxiliary air, then they can determine what TS action to enter. Disagree with SRO only designation.</p> <p>S A misunderstanding of the Basis of the effect of loss of one train of instrument air, was the basis for making this a Unsat question. The licensee presented information the examiner did not know/understand and this question should have been identified as a S.</p>
90	H	3												B	S	<p>103G.2,4,21, Bank, Higher</p> <p>KA appears to be ok</p> <p>Question appears to be ok.</p>
91	H	3												N	S	<p>028A2.01, New, Higher</p> <p>KA appears to be ok</p> <p>Question appears to be ok</p>
92	H	3												N	S	<p>068A2.04, New, Higher</p> <p>KA appears to be ok.</p> <p>Question appears to be ok.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
93	H	3											X	M	U	<p>071G2.2.36, Modified Bank, Higher</p> <p>Add commas to the stem before and after the procedure number and name. Added as suggested.</p> <p>This question is not SRO only. To answer the first part of the question this requires RO system knowledge. To answer the second part, for distractors basically would be RO knowledge that you need both radiation monitors for the release to be allowed.</p> <p>If the release was terminated by the system, and both are required for the release one could surmise that only one rad monitor is NOT sufficient to allow the release without doing something. I don't believe that the second part of distractors B and D are plausible. Discuss with licensee.</p> <p>This is a chemistry procedure that is administrative and controlled by the SRO. This then is based on the release permission and is expected to be SRO only in nature in accordance with Clarification for SRO only.</p> <p>This question should have been designated as an S and not an Unsatisfactory.</p>
94	F	2-3												N	S	<p>G2.1.27, New, Lower</p> <p>KA appears to match</p> <p>Question appears to be ok.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only			
95	H	3												N	E	<p>G 2.2.18, New Higher,</p> <p>This question is a series of true or false statements that are to be evaluated against the requirements of the procedure appendix that is being used as a reference.</p> <p>Diving while being High risk, is not listed in the procedure provided. While this may be the case, the applicant could evaluate this as not the answer because of it not being there. This is considered non-plausible. This distractor needs to be changed.</p> <p>KA appears to be ok.</p> <p>After discussion with licensee, this distractor will be allowed. It could be misunderstood that this will affect the other unit.</p>
															S	<p>Question as is is ok.</p>
96	H	3												N	E	<p>G2.2.40, New, Higher</p> <p>The question proposes a scenario then asks what to do prior to Mode 4 entry. The question uses the statement "if any," as if there is NO answer. This should be removed from the question stem. This makes no sense here. Accepted.</p> <p>Distractor C is non-plausible, in that, the TS 3.4.1.2, requires 2 SGs and 2 RCPs, however this is for MODE 3. Change this to 2 and it will be more plausible. Accepted.</p> <p>KA appears to be ok</p>
															S	<p>Question appears</p>
97	F	2-3												B	E/S	<p>G 2.3.12, Bank, Lower Level, Question used on 1/2009 SRO Audit examination.</p> <p>In the stem, underline the word maximum or capitalize it, whatever is better to get the applicants attention. Accepted.</p> <p>KA appears to be ok.</p> <p>Question appears to be ok.</p>

Q#	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. B/M/N	7. U/E/S	8. Explanation	
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/units	Backward	Q=K/A	SRO Only				
98	F	2-3											X	X	B	U S	<p>G2.3.14, Bank, Lower</p> <p>The procedures operator actions states Stage I at 10 hours and Stage II at 17 hours. This makes the answer trivial. .</p> <p>Do not believe that the question matches the KA. The KA is Radiation control, Knowledge of radiation contamination hazards that may arise during normal, abnormal or emergency. This question ONLY asks the time for Stage I to start and what actions .</p> <p>Asked other examiners and they said this could be used, the KA can be linked that way. Should have been an S to begin with.</p> <p>Ok as is.</p>
99	H	2-3												X	B	U S	<p>G2.4.30, Bank, Higher</p> <p>While this question appears to be SRO only, it basically is RO knowledge that the first declaration made has to be done in 15 minutes. Since ROs are normally the communicators of this information to the State this is knowledge they have and can be answered with only that knowledge.</p> <p>KA appears to match</p> <p>Shift Manager only at SQN. Not communications (RSs). They do not support the emergency plan. At Sequoyah. Since the ROs at SQN do not do this, and there is a complication of an ODS. Operations Duty Specialist. In Chattanooga, the RO has nothing to do with this.</p> <p>Initially mischaracterized this as a U, should be an S.</p> <p>Question as is, is an S.</p>

Facility: Sequoyah Nuclear Plant		Date of Exam: 09/29/2010		Exam Level: <u>RO/SRO</u>		
Item Description				Initials		
				a	b	c
1.	Clean answer sheets copied before grading			RSB	NA	RSB
2.	Answer key changes and question deletions justified and documented			RSB	NA	N/A
3.	Applicants' scores checked for addition errors (reviewers spot check > 25% of examinations)			RSB	NA	RSB
4.	Grading for all borderline cases (80 ±2% overall and 70 or 80, as applicable, ±4% on the SRO-only) reviewed in detail			RSB	NA	RSB
5.	All other failing examinations checked to ensure that grades are justified			RSB	NA	RSB
6.	Performance on missed questions checked for training deficiencies and wording problems; evaluate validity of questions missed by half or more of the applicants			RSB	NA	RSB
Printed Name/Signature					Date	
a. Grader	Richard S. Baldwin / 			12/03/2010		
b. Facility Reviewer(*)	NA					
c. NRC Chief Examiner (*)	Bruno Caballero / 			12-3-10		
d. NRC Supervisor (*)	Malcolm T. Widmann / 			12/06/10		
(*) The facility reviewer's signature is not applicable for examinations graded by the NRC; two independent NRC reviews are required.						