



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
WASHINGTON, D.C. 20555-0001

February 28, 2011

Mr. Michael J. Pacilio  
President and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: CLINTON POWER STATION, UNIT NO. 1 - WITHDRAWAL OF AN  
AMENDMENT REQUEST (TAC NO. ME3476)

Dear Mr. Pacilio:

By letter dated March 3, 2010, you applied for an amendment to the Clinton Power Station, Facility Operating License No. NFP-62. The proposed change would have modified the facility technical specifications pertaining to standby liquid control system to extend the completion time from 8 hours to 72 hours. Subsequently, by letter dated February 22, 2011, you withdrew the amendment request.

The Nuclear Regulatory Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in black ink, reading "Nicholas DiFrancesco", is written over a horizontal line.

Nicholas DiFrancesco, Project Manager  
Plant Licensing Branch LPL3-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No.: 50-461

Enclosure:  
Notice of Withdrawal

cc w/encl: Distribution via Listserv

UNITED STATES NUCLEAR REGULATORY COMMISSION

CLINTON POWER STATION

DOCKET NO. 50-461

NOTICE OF WITHDRAWAL OF APPLICATION FOR  
AMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (NRC, the Commission) has granted the request of Exelon Generation Company, LLC, to withdraw its March 3, 2010 application for proposed amendment to Facility Operating License No. NPF-62 for the Clinton Power Station, Unit No. 1, located in DeWitt County, Illinois.

The proposed amendment would have revised the Technical Specifications 3.1.7, to extend the completion time for Condition B (i.e., two standby liquid control subsystems inoperable) from 8 hours to 72 hours.

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on May 4, 2010, 75 FR 23814. However, by letter dated February 22, 2011, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated March 3, 2010, and the licensee's letter dated February 22, 2011, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Room, P1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who

encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov).

Dated at Rockville, Maryland, this 28th day of February 28, 2011.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "Nicholas J. DiFrancesco", with a long horizontal flourish extending to the right.

Nicholas J. DiFrancesco, Project Manager  
Plant Licensing Branch 3-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

February 28, 2011

Mr. Michael J. Pacilio  
President and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: CLINTON POWER STATION, UNIT NO. 1 - WITHDRAWAL OF AN  
AMENDMENT REQUEST (TAC NO. ME3476)

Dear Mr. Pacilio:

By letter dated March 3, 2010, you applied for an amendment to the Clinton Power Station, Facility Operating License No. No. NFP-62. The proposed change would have modified the facility technical specifications pertaining to standby liquid control system to extend the completion time from 8 hours to 72 hours. Subsequently, by letter dated February 22, 2011, you withdrew the amendment request.

The Nuclear Regulatory Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,  
**/RA/**

Nicholas DiFrancesco, Project Manager  
Plant Licensing Branch LPL3-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No.: 50-461

Enclosure:  
Notice of Withdrawal

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC

Branch Reading `LPL3-2R/F

RidsAcrsAcnw\_MailCTR Resource

RidsNrrDoriDpr Resource

RidsRgn3MailCenter Resource

RidsNrrLASRohrer Resource

RidsNrrPMDiFrancesco Resource

RidsOgcRp Resource

RidsRgnXMailCenter Resource

**ADAMS Accession Nos.:** PKG ML LTR (NRR-106) ML110590197 FRN (ADM-012) ML110590158

OFFICE	DORL/LPL3-2/	DORL/LPL3-2/PM	DORL/LPL3-2/LA	DORL/LPL3-2/BC
NAME	CNorton	NDFrancesco	SRohrer	RCarlson
DATE	2/28 /11	2/28 /11	2/28/11	2./28/11

OFFICIAL AGENCY RECORD